



FRAMATOME ANP

An AREVA and Siemens company

FRAMATOME ANP, Inc.

January 28, 2003
NRC:03:010

Document Control Desk
ATTN: Chief, Planning, Program and Management Support Branch
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Topical Report EMF-92-153(P)(A) and Supplement 1, "HTP: Departure from Nucleate Boiling Correlation for High Thermal Performance Fuel"

Framatome ANP recently discovered a number of minor errors in the analyses reported in topical report EMF-92-153(P)(A). The purpose of this letter is to inform the NRC of these errors and their impact. The errors affect the detailed comparisons of the calculated CHF to the measured CHF and the statistical representation of those results. The correlation itself is unaffected by the errors, and the 95/95 DNB limit for the correlation is unchanged. The errors do not impact any plant analyses.

Since the correlation and the 95/95 DNB limit are unaffected by the errors, Framatome ANP does not plan to revise the topical report and will continue to use the NRC approved 95/95 DNB limit. The attachment provides additional details of the errors and their impact.

A proprietary and a non-proprietary version of the attachment are provided. As required by 10 CFR 2.790(b), an affidavit is enclosed to support the withholding of this information from public disclosure.

This letter is provided for information only and no NRC action is requested.

Very truly yours,

James F. Mallay, Director
Regulatory Affairs

Enclosures

cc: R. Caruso (w/attachment)
D. G. Holland (w/attachment)
Project 728

4601
TOD 7
Add: Drew Holland