



SIGNIFICANCE DETERMINATION PROCESS

TASK GROUP REPORT

December 13, 2002

SIGNIFICANCE DETERMINATION PROCESS TASK GROUP REPORT
TABLE OF CONTENTS

EXECUTIVE SUMMARY		
Objective and Scope	v	
Background	v	
Observations and Conclusions	vii	
Recommendations	xi	
1.0	INTRODUCTION	1
1.1	Objective	1
1.2	Scope and Method	1
2.0	ISSUE SUMMARY AND BACKGROUND	2
2.1	Issue Summary	2
2.2	Background	4
3.0	EVALUATION RESULTS AND RECOMMENDATIONS	6
3.1	Evaluation of Reactor Oversight Process and Significance Determination	
	Process Objectives	10
3.1.1	Observations	10
	3.1.1.1 Phase 2 SDP Contribution to ROP and SDP Objectives	10
	3.1.1.2 Insights Regarding the Viability of the Phase 2 Process	12
	3.1.1.3 Alternatives to the Current Phase 2 Process	13
3.1.2	Conclusions	23
3.1.3	Recommendations	24
3.2	Performance Expectation for the Significance Determination Process	24
3.2.1	Observations	25
3.2.2	Conclusions	27
3.2.3	Recommendations	27
3.3	Expectations for Use of Significance Determination Process Phase 2	27
3.3.1	Observations	28
3.3.2	Conclusions	29
3.3.3	Recommendations	29
3.4	Applicability of the Current Significance Determination Process to the Range of Inspection Findings	29
3.4.1	Observations	30
3.4.2	Conclusions	31
3.4.3	Recommendations	31
3.5	Significance Determination Process Training and Guidance	32
3.5.1	Observations	32
3.5.2	Conclusions	33
3.5.3	Recommendations	34

3.6	Significance Determination Process Benchmarking and the Need for Peer Review Criteria	34
3.6.1	Observations	34
3.6.2	Conclusions	36
3.6.3	Recommendations	37
3.7	Use of Uncertainty in the Significance Determination Process	37
3.7.1	Observations	37
3.7.2	Conclusions	39
3.7.3	Recommendations	40
3.8	Evaluation of How Other Inputs are Factored Into the Significance Determination Process	41
3.8.1	Observations	41
3.8.2	Conclusions	42
3.8.3	Recommendations	43
3.9	Significance Determination Process Timeliness	43
3.9.1	Observations	44
3.9.2	Conclusions	45
3.9.3	Recommendations	46
3.10	Reactor Oversight Process Web Site Improvements	47
3.10.1	Observations	47
3.10.2	Conclusions	48
3.10.3	Recommendations	49
3.11	Evaluation of Other Reactor Oversight Process and Significance Determination Process Issues	49
3.11.1	Accident Sequence Precursor Program and Significance Determination Process	49
3.11.1.1	Observations	49
3.11.1.2	Conclusions	51
3.11.1.3	Recommendations	51
3.11.2	Objectivity of Probabilistic Risk Assessments	51
3.11.2.1	Observations	51
3.11.2.2	Conclusions	52
3.11.2.3	Recommendations	52
3.11.3	Insights on Performance of ROP Action Matrix	52
3.11.3.1	Observations	53
3.11.3.2	Conclusions	53
3.11.3.3	Recommendations	53

FIGURES

Figure 1	14
Figure 2	15

APPENDICES:

APPENDIX A - Consolidated List of Recommendations	54
APPENDIX B - List of Acronyms	58
APPENDIX C - List of Documents Reviewed	59
APPENDIX D - List of Persons Contacted	60

EXECUTIVE SUMMARY

Objective and Scope

The Executive Director for Operations (EDO) directed the formation of an NRC task group to perform an independent and objective review of the Significance Determination Process (SDP). This review was prompted, in part, by issues described in a Differing Professional Opinion (DPO) Panel Response dated June 28, 2002, and an Office of Inspector General (OIG) Audit Report dated August 21, 2002. The Charter for the Significance Determination Process Task Group was established in a memorandum dated September 18, 2002, from Samuel J. Collins, Director, Office of Nuclear Reactor Regulation (NRR) to Victor M. McCree, the Task Group Chairperson. The overall objective of the Task Group was to review the issues raised in both the DPO Panel Response and the OIG Audit Report and provide observations, conclusions, and recommendations to address the underlying concerns, including whether the current reactor safety Phase 2 SDP approach should be continued, modified, or replaced.

The scope of the review, as indicated in the Charter, consisted of the key SDP issues outlined in the EDO's tasking memorandum dated August 6, 2002, including: (1) achievement of SDP and Reactor Oversight Process (ROP) objectives; (2) performance expectation for the SDP; (3) applicability of the SDP to inspection findings; (4) consideration of uncertainty in the SDP; (5) consideration of "other inputs" in the ROP/SDP; (6) expectations for inspector use of the reactor safety SDP; (7) the need to continue, modify, or replace the current Phase 2 SDP tool; (8) implementation of the SDP by appropriate agency personnel; (9) improvements in SDP training and guidance; and (10) other ROP process changes. The Task Group's review also included: as described in the DPO Panel Report, (11) development and peer review of criteria for SDP benchmarking; and, as indicated in the OIG Audit Report, (12) SDP timeliness and (13) ROP web site improvements.

Consistent with the Charter, the Task Group's review focused on the SDP for the Reactor Safety Strategic Performance Area and, in particular, issues pertaining to the SDP for the Initiating Events (IE), Mitigating Systems (MS) and Barrier Integrity (BI) Cornerstones. As a result, the Task Group did not perform a detailed review of the SDP for the Radiation Safety Performance Area or Safeguards Performance Area. In addition, because the Emergency Preparedness (EP) Cornerstone SDP was not the focus of the DPO Panel Response or OIG Audit Report, and because the relevant EP SDP issues are the focus of other NRC review activities, the Task Group did not emphasize this area in its review.

The Task Group met with a broad spectrum of persons involved with the SDP to obtain their views and recommendations regarding the SDP. Task Group members met with NRC staff and managers in Headquarters and in each Regional office, and interviewed resident inspectors, licensee managers, and licensee risk analysts at two sites in each Region. Altogether, the Task Group obtained input from 160 stakeholders, including 118 NRC staff, 36 licensee representatives and 6 external stakeholders.

Background

In SECY-99-007, "Recommendations for Reactor Oversight Process Improvements," dated January 8, 1999, the staff provided its recommendations to the Commission for improving the

reactor regulatory oversight processes, including proposed changes to the NRC's inspection, assessment, and enforcement processes. The staff's efforts to develop the proposed changes was guided by three objectives: (1) improve the objectivity of the [reactor] oversight process so that subjective decisions were not central process features; (2) improve the scrutability of these processes so that NRC actions have a clear tie to licensee performance; and (3) risk-inform the process so that NRC and licensee resources are focused on those aspects of performance having the greatest impact on safe plant operations.

With respect to the assessment process, the staff sought to develop a process that would allow the integration of various information sources relevant to licensee safety performance. In SECY-99-007, the staff concluded that adequate assurance of licensee performance would be achieved through the use of risk-informed performance indicators (PIs) and inspection findings. The staff also highlighted the need to develop a method for characterizing the risk of inspection findings and indicated that a "level of risk significance, based on a risk scale, will be determined and documented for the findings."

In SECY-99-007A, "Recommendations For Reactor Oversight Process Improvements" (follow-up to SECY-99-007), Attachment 2, dated March 22, 1999, the staff introduced the Significance Determination Process (SDP) as the method for characterizing the risk of inspection findings. The SDP was designed to assess only those inspection findings associated with at-power operations in the Reactor Safety Strategic Performance Area cornerstones of IE, MS and BI; however, concepts for characterizing the risk significance of inspection findings in the emergency preparedness, radiation safety, and safeguards areas were under development. The SDP provided a means to screen out inspection findings that have minimal or no risk significance and trigger a more detailed analysis of potentially risk-significant findings.

To support the start of the initial implementation the revised Reactor Oversight Process (ROP) in April 2000, the staff issued Inspection Manual Chapter (IMC) 0609, "Significance Determination Process." Appendix A to IMC 0609 provided guidance for the staff to estimate the unintended increase in risk during at-power plant conditions caused by deficient licensee performance. The guidance was intended to provide a simplified probabilistic framework for use by the staff in identifying potentially risk significant findings in the reactor safety area--either the IE, MS, or BI cornerstones.

When the ROP was initially implemented in April 2000, the staff's efforts to develop the Phase 2 notebooks for each nuclear plant were still in progress. As a result, the draft notebooks that were made available for staff use at initial ROP implementation were considered to be incomplete. By late 2000, the staff had made sufficient progress in the site visits associated with the development of Phase 2 SDP notebooks, that it began to issue the "Revision 0" notebooks to the sites. After issuance of the first Rev 0 notebooks, the staff identified problems with the accuracy of the notebooks and concluded that benchmarking was needed to confirm the adequacy of the notebooks. Using NRC risk analysts and contractor resources, the staff began its efforts to benchmark the notebooks in April 2001. As of November 12, 2002, the staff had issued 24 Revision 1, Phase 2 notebooks.

In a memorandum dated November 8, 2001, Troy Pruett, Senior Reactor Analyst, Region IV, submitted a differing professional view (DPV) to the Director of the Division of Reactor Safety in

Region IV. The DPV expressed concerns about the performance of the SDP Phase 2 analyses. An Ad Hoc Panel, appointed by the Regional Administrator by memorandum dated November 16, 2001, was formed to review the DPV and make appropriate recommendations. The DPV Panel documented its findings in a report to the Region IV Administrator dated January 10, 2002. This report was forwarded to the Director, NRR, for program office consideration and appropriate action. In a memorandum dated February 18, 2002, the Director, NRR informed Mr. Pruett of the results of the review of his DPV. Mr. Pruett expressed several concerns with the results of the DPV review and, in a memorandum to the EDO dated March 15, 2002, recommended an independent review of the concerns in his DPV. Through a memorandum dated April 9, 2002, the EDO convened an Ad Hoc panel to review Mr. Pruett's DPO.

The DPO Panel completed its review and issued conclusions and recommendations in a report dated June 28, 2002. The DPO Panel generally agreed with the overall analysis performed by the DPV panel and its response to Mr. Pruett's recommendations. The DPO Panel found that "NRC management and staff are in the process of addressing many of the Ad Hoc DPV Panel's observations and recommendations in the SDP Improvement Initiative." However, the DPO Panel also recommended that the NRC conduct an independent review of the SDP assessment tools.

Between May and October 2001, the OIG conducted an audit of the SDP. The objectives of the audit, as indicated in the OIG's report (OIG-02-A-15) dated August 21, 2002, were to determine whether (1) the SDP is achieving desired results, (2) NRC staff clearly understand the process, and (3) NRC staff are using [the] SDP in accordance with agency guidance. In its report, OIG concluded that "while the SDP is meeting its objectives and agency staff are using SDP in accordance with guidance, additional refinements are needed." The report provided a number of recommendations, including that the NRC develop an action plan to correct Phase 2 analysis weaknesses or eliminate this portion of the SDP.

In a memorandum to the Director, NRR dated August 6, 2002, the EDO directed that a plan be developed to address both the DPO Ad Hoc Panel and OIG recommendations. The EDO's memorandum indicated that this "plan shall address the DPO Panel recommendation for an overall objective review of the SDP." The plan developed by the Director, NRR included the formation of the SDP Task Group to conduct an independent review of the SDP.

Observations and Conclusions

The SDP, including the Phase 2 process, has generally succeeded in meeting the ROP objectives of providing a more objective, scrutable, and risk-informed process. In addition, the four SDP objectives have generally been met by the current SDP process. Although the contribution of the Phase 2 process to the SDP objectives was limited because of its relatively infrequent use, feedback from stakeholders indicated that the Phase 2 process has contributed to the staff's efforts to characterize the significance of inspection findings, facilitate stakeholder communication, provide a basis for assessment and enforcement actions, and risk-inform the inspection program.

The Task Group concluded that the SDP should retain the Phase 2 process to facilitate (resident and region-based) inspector involvement in the screening of Green findings and the

characterization of potentially greater-than-green inspection findings. However, the SDP should be enhanced to address the current problems with the Phase 2 notebooks, including the technical inadequacies and the cumbersome, complex and time-consuming characteristics of the worksheets. In this regard, the Task Group evaluated six options to enhance the SDP and recommended the development of enhanced pre-solved Phase 2 SDP tables (Option 3) to replace the Phase 2 SDP notebooks as the primary tool for inspectors to perform Phase 2 evaluations. However, the notebooks should be retained for optional use by the NRC staff to gain additional risk insights.

The performance expectations for Phase 1 of the SDP were clearly documented in IMC 0609, well understood by the staff. The Phase 1 process has been used to appropriately screen out inspection findings of very low safety significance. However, the original performance expectations regarding the use and accuracy of the Phase 2 process have not been fully realized due, in large part, to the untimely development and issuance of the Phase 2 notebooks and the errors associated with the Revision 0 notebooks. The current SDP performance expectations, as well as the expectations for inspectors to use the SDP, are described in an August 9, 2002, memorandum from the Director, NRR. The Task Group concluded that the expectations were understandable and capable of being implemented by the Regions; however, based on the interviews in the Regions, some staff were unfamiliar with the guidance and others were unsure of whether and how it had been implemented.

The Task Group determined that resident and region-based inspectors rarely used the Phase 2 notebooks to characterize an inspection finding because the majority of the findings screened (out) as minor or Green prior to meeting a condition that required use of the Phase 2. Also, most of the inspector interviewees expressed difficulty in using the Phase 2 notebooks because the guidance was complex and the worksheets were time consuming and not user-friendly. Notwithstanding these concerns, most of the NRC interviewees supported the continued use of the Phase 2 process, provided that the current problems are addressed, and felt that it was essential for inspectors to participate in determining the significance of inspection findings beyond the initial screening, Phase 1.

IMC 0609 and IMC 0612, "Power Reactor Inspection Reports," provide some guidance on the types of inspection findings that can be evaluated using the SDP. The reactor safety Phase 2 SDP notebooks do not currently allow for treatment of inspection findings that are related to external events, shutdown modes and Large Early Release Frequency (LERF). However, the staff has initiated action to refine the SDP guidance documents for evaluation of findings related to shutdown modes, containment, and fire protection. The degraded condition of a Structure, System or Component (SSC) can also be treated using the SDP if agreement can be reached on characterizing the impact of the finding on equipment unavailability or initiating event frequency. The Task Group also concluded that external events can have a significant effect on risk analyses and, therefore, should be included in the SDP. In this regard, the Task Group concurred in the ongoing NRR initiatives to develop better tools and guidance for external events so that the risk insights can be applied in a consistent manner.

A variety of NRC training courses and seminars were administered over a relatively short time frame and a number of training courses were established to enhance the knowledge of NRC staff and managers in the area of risk. Although the general consensus from the Task Group's interviews of internal and external stakeholders was that the staff's knowledge and ability to

communicate risk insights has improved due, in part, to staff training, many commented on areas for improvement. In particular, many inspectors felt that the training could have been better and that it did not make them proficient in use of the Phase 2 tool. Although training was a factor in inspector proficiency, the Task Group concluded that the complexity of the Phase 2 notebooks, the unavailability of benchmarked notebooks, and the infrequent use of the Phase 2 process were the main hindrances to inspectors' proficiency in use of the Phase 2 SDP. The Task Group concluded that simplifying the Phase 2 SDP by using enhanced pre-solved tables will alleviate the need for inspectors' current reliance on the SRAs to conduct the Phase 2 evaluation. The Task Group also recommended that a systematic assessment of agency training in the area of risk be conducted.

Although the current Phase 2 SDP guidance is complex, it was deemed adequate to implement the current Phase 2 worksheets. In addition, the Task Group concluded that the enhanced pre-solved Phase 2 SDP tables will prompt the development of more user-friendly implementation guidance. The actions and schedule in the SDP Task Action Plan to enhance the current Phase 3 guidance are appropriate. Although no examples were cited where the limited Phase 3 SDP guidance has resulted in an unsatisfactory outcome (i.e., inadequate or poor quality Phase 3 analysis), the Task Group concurred in the ongoing NRR initiative to enhance the Phase 3 guidance.

The Task Group concluded that the ongoing benchmarking contributes significantly to improving the quality of the Phase 2 SDP notebooks and Standardized Plant Analysis Risk (SPAR) models. Many of the recommendations contained in the DPO Ad Hoc Panel report regarding the benchmarking process, including staff qualification and peer review recommendations, have already been included in the current process. However, the Task Group noted several areas for further improvement, including documentation of the "construction rules" for developing the Phase 2 SDP notebooks and comparison between the results of the benchmarked SPAR models and the benchmarked notebooks. In addition, because future licensee probabilistic risk assessment (PRA) changes and/or plant modifications can affect the adequacy of the notebooks, the Task Group concluded that a plan to update the Phase 2 tool was warranted.

The Task Group reviewed the use of uncertainty in SDP evaluations in light of the three types of uncertainty highlighted in Regulatory Guide (RG) 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis:" parameter uncertainty; model uncertainty; and completeness uncertainty. The Task Group concluded that parameter uncertainty was a relatively minor contributor for the purpose of the SDP, and that model uncertainties, particularly those associated with the characterization of the impact of the inspection finding on the function of an SSC, represented the greatest source of uncertainty. The Task Group also noted that the staff should consider the contribution from external events, and low power and shutdown events when making a final assessment of risk significance of a finding (for completeness). The Task Group concurred in the ongoing initiatives to develop better tools and guidance in the area of low power and shutdown. The Task Group also noted that the SDP does not provide for explicit consideration of traditional engineering analysis (deterministic) inputs in the risk significance estimation process. This is in contrast to RG 1.174 which uses considerations of defense-in-depth and safety margins to assess whether license amendments should be granted. In that context, defense-in-depth and safety margins are seen as mechanisms to account for incompleteness.

The Task Group concluded that the SDP should not be modified to include consideration of “other inputs.” There were no examples where the current provisions for treating other inputs in the ROP had limited the staff’s ability to focus resources in appropriate areas. In addition, the existing guidance in IMC 0305, “Operating Reactor Assessment Program,” regarding deviations from the Action Matrix can be employed, where appropriate, to consider “other inputs” in determining agency response. However, the Task Group also concluded that the current guidance in IMC 0305 does not promote consistency in the identification of substantive cross-cutting issues by the Regions and the guidance is vague on the expected NRC and licensee response to a substantive cross-cutting issue.

The Task Group concluded that the ROP timeliness goal of completing the SDP within 120 days of the first inspection exit meeting and within 90 days of the issuance of the inspection report is reasonable. However, the goals were not well understood by all members of the staff. The Task Group recognized that some findings involve complex engineering issues and may require additional time to adequately assess the safety significance. The Task Group determined that significant progress has been made in tracking the timeliness of findings that are greater than Green and establishing accountability within the responsible offices. However, the Task Group concluded that improved management decisiveness in determining the engineering assumptions used in risk evaluations would also contribute to the timeliness of the SDP. The Task Group concluded that a recent revision to the Office of Public Affairs (OPA) policy regarding issuance of a press release for a White findings was an improvement and noted that further revision to link press releases to a finding(s) that results in a Degraded Cornerstone was warranted.

The OIG Audit Report, (OIG-02-A-15) provided several recommendations to enhance the ROP web site. The Task Group concluded that the recommendation to improve the web site links for all relevant documents for greater-than-green findings was appropriate and should be adopted by NRR. The recommendation to link the summary of findings to the inspection report had already been implemented. The recommendation to revise IMC 0612 to include a brief summary of corrective actions in the inspection report summary of findings was reasonable. The Task Group concluded that the recommendation to display all significant findings colors in a cornerstone should not be adopted. Web site users are provided ready access to all findings in a cornerstone by hyper-linking to the next web page, and the difficulty and costs of implementing this change would likely exceed the benefit.

The Task Group determined that the issuance of different NRC risk characterizations from the Accident Sequence Precursor (ASP) Program and SDP can have a potentially negative impact on public confidence. Consequently, program requirements and/or an Office of Nuclear Regulatory Research (RES)/NRR office protocol should ensure reasonable consistency in the output of the programs to promote public confidence. The Task Group concluded that efficiencies could be gained through a better coordination and/or integration of these two programs.

The Task Group evaluated concerns about the perceived overemphasis on the objectivity of PRA results and the quality of the PRA models used to determine the final risk significance of inspection findings. The Task Group concluded that the staff routinely uses engineering judgement in the SDP and that this practice is consistent with the NRC's PRA Policy Statement. With respect to the quality and scope of licensee PRAs, the Task Group concluded that

guidance should be developed to allow the staff to determine whether the results of a licensee's risk analysis of a finding is of sufficient quality to use as input to the staff's final significance determination.

The Task Group concluded that overall, the Action Matrix has fulfilled its purpose in providing an objective, scrutable and predictable framework for NRC actions in response to licensee performance problems. The oversight process also provides sufficient flexibility in use of the Action Matrix for NRC managers to use discretion in decisions concerning the scope and timing of the agency's response to licensee performance problems. In addition, the Task Group concluded that the staff used reasoned judgement in its decision to use two White inputs in the same cornerstone as part of the criteria for defining a "Degraded Cornerstone." Although a detailed analysis or evaluation was not developed to support this decision, the Task Group did not identify data or obtain information from its interviews to suggest that the criteria were inappropriate.

Recommendations

The Task Group determined that the NRC should take specific actions to address the issues described in Section 3 of this report. A consolidated list of recommendations is provided in Appendix A.



**SIGNIFICANCE DETERMINATION PROCESS
TASK GROUP**

DECEMBER 13, 2002

Prepared by SDP Task Group:

V. McCree, SDP Task Group Chairperson
L. Dudes, NRR
H. Hamzehee, RES
I. Jung, NRR
G. Parry, NRR
D. Roberts, NRR
J. Trapp, RI

_____/RA/_____
_____/RA/_____
_____/RA/_____
_____/RA/_____
_____/RA/_____
_____/RA/_____
_____/RA/_____

Task Group Administrative Support provided by:
C. Raynor

1.0 INTRODUCTION

1.1 Objective

The Executive Director for Operations (EDO) directed the formation of an NRC task group to perform an independent and objective review of the Significance Determination Process (SDP). This review was prompted, in part, by issues described in a Differing Professional Opinion (DPO) Panel Response dated June 28, 2002, and an Office of Inspector General (OIG) Audit Report dated August 21, 2002. The Charter for the Significance Determination Process Task Group was established in a memorandum dated September 18, 2002, from Samuel J. Collins, Director, Office of Nuclear Reactor Regulation (NRR) to Victor M. McCree, the Task Group Chairperson. The objective, scope and management interface of the Task Group are defined in the memorandum and its attachment. The overall objective of the Task Group was to review the issues raised in both the DPO Panel Response and the OIG Audit Report and provide observations, conclusions, and recommendations to address the underlying concerns, including whether the current reactor safety Phase 2 SDP approach should be continued, modified, or replaced.

1.2 Scope and Method

The scope of the review, as indicated in the Charter, consisted of the key SDP issues outlined in the EDO's tasking memorandum dated August 6, 2002, including: (1) achievement of SDP and Reactor Oversight Process (ROP) objectives; (2) performance expectation for the SDP; (3) applicability of the SDP to inspection findings; (4) consideration of uncertainty in the SDP; (5) consideration of "other inputs" in the ROP/SDP; (6) expectations for inspector use of the reactor safety SDP; (7) the need to continue, modify, or replace the current Phase 2 SDP tool; (8) implementation of the SDP by appropriate agency personnel; (9) improvements in SDP training and guidance; and (10) other ROP process changes. The Task Group's review also included: as described in the DPO Panel Report, (11) development and peer review of criteria for SDP benchmarking; and, as indicated in the OIG Audit Report, (12) SDP timeliness and (13) ROP web site improvements.

Consistent with the Charter, the Task Group's review focused on the SDP for the Reactor Safety Strategic Performance Area and, in particular, issues pertaining to the SDP for the Initiating Events (IE), Mitigating Systems (MS) and Barrier Integrity (BI) Cornerstones. As a result, the Task Group did not perform a detailed review of the SDP for the Radiation Safety Performance Area or Safeguards Performance Area. In addition, because the Emergency Preparedness (EP) Cornerstone SDP was not the focus of the DPO Panel Response or OIG Audit Report, and because the relevant EP SDP issues are the focus of other NRC review activities, the Task Group did not emphasize this area in its review.

A Steering Committee, consisting of four senior managers, was formed to guide the Task Group and to provide counsel in areas of concern. The Task Group kept the Steering Committee informed of its activities and periodically briefed the members during its review. In addition, on October, 16, 2002, the Task Group met with the OIG to discuss the Task Group Charter. On October 25, 2002, the Task Group held a public meeting at NRC Headquarters to solicit input from public stakeholders on the SDP.

The Task Group met in September 2002, and developed a method for data gathering and information management that included techniques used in NRC Incident Investigation Team

reviews and other methods used in the past to successfully evaluate agency programs. The Task Group's review was accomplished in three phases: a Preparatory Phase, an Evaluation Phase and a Report Phase. The six members of the Task Group were split into three, two-member groups to promote synergy and to distribute the workload.

During the Preparatory Phase, the Task Group conducted a range of activities to prepare for the Evaluation and Report Phases, including an extensive review of background documents associated with the SDP (see Appendix C). Several orientation briefings were conducted to familiarize the Task Group members with various aspects of the review. The Task Group developed an extensive list of interview questions during this phase to facilitate the interviews and provide a basis for comparing the opinions and recommendations of the various stakeholders. This phase of the review was also used to identify and arrange interviews with NRC staff, licensee representatives and other external stakeholders.

During the Evaluation Phase, the Task Group met with a broad spectrum of persons involved with the SDP to obtain their views and recommendations regarding the SDP. Task Group members met with NRC staff and managers in Headquarters and in each Regional office, and interviewed resident inspectors, licensee managers, and licensee risk analysts at two sites in each Region. Altogether, the Task Group obtained input from 160 stakeholders, including 118 NRC staff, 36 licensee representatives and 6 external stakeholders.

The 118 NRC interviewees consisted of: the Regional Administrators and most of the reactor-program senior managers in each Region (18); at least four reactor-program Branch Chiefs in each Region (19); Regional inspectors, project engineers and resident inspectors (34); most of the Regional Senior Reactor Analysts (SRAs) (6); most of the NRR senior managers responsible for the development and/or implementation of the ROP/SDP (13); NRR Section Chiefs responsible for the development and/or implementation of the ROP/SDP (3); some NRR Senior Risk Analysts and other NRR staff, including seven recently reassigned resident inspectors (14); Senior Managers, Section Chiefs and/or Risk Analysts from the Office of Nuclear Regulatory Research (RES) (7); Office of Enforcement (OE) (3); Office of General Counsel (OGC) (1) and Office of Nuclear Security Incident and Response (NSIR) (1).

The 35 licensee interviewees included Plant Managers and Regulatory Affairs Managers (22) and Licensee PRA Managers and Risk Analysts (13). External Stakeholders who participated in the October 25, 2002, SDP Task Group public meeting included a representative from the State of Illinois, the State of Pennsylvania, the Union Concerned Scientists, the New England Coalition on Nuclear Pollution, and the Nuclear Energy Institute. A representative from the State of New Jersey also submitted a letter to the Task Group providing views on the SDP. The Task Group considered all the comments received during its review.

2.0 ISSUE SUMMARY AND BACKGROUND

2.1 Issue Summary

In a memorandum dated November 8, 2001, Troy Pruett, SRA, Region IV, submitted a differing professional view (DPV) to the Director of the Division of Reactor Safety in Region IV. The DPV expressed concerns about the performance of the SDP Phase 2 analyses. An Ad Hoc

panel, appointed by the Regional Administrator by memorandum dated November 16, 2001, was formed to review the DPV and make appropriate recommendations. The DPV Panel documented its findings in a report to the Region IV Administrator dated January 10, 2002. This report was forwarded to the Director, NRR, for program office consideration and appropriate action. In a memorandum dated February 18, 2002, the Director of NRR informed Mr. Pruett of the results of the review of his DPV. Mr. Pruett expressed several concerns with the results of the DPV review and, in a memorandum to the EDO dated March 15, 2002, recommended an independent review of the concerns in his DPV. Through a memorandum dated April 9, 2002, the EDO convened an Ad Hoc panel to review Mr. Pruett's DPO.

The DPO Panel completed its review and issued its conclusions and recommendations in a report dated June 28, 2002. The DPO panel generally agreed with the overall analysis performed by the DPV panel and its response to Mr. Pruett's recommendations. Included in the DPO Panel's report were the following conclusions:

- (1) The SDP, in its entirety, appropriately addresses the safety significance of inspection findings.
- (2) The extensive dependency on the SRAs has contributed to inefficiencies and ineffectiveness of the Phase 2 reviews.
- (3) The current implementation of SDP does not result in an unnecessary burden to the licensee.
- (4) The use of the Phase 2 notebooks currently provides marginal benefit within the ROP since not all of the notebooks have been benchmarked.
- (5) There is no basis to limit the number of risk assessment tools currently utilized by the NRC staff. The development and expenditure of resources for both the Phase 2 notebooks and the Standardized Plant Analysis Risk (SPAR) model should not be suspended.
- (6) It is conceivable that different tools could be applicable to varying categories of inspection findings. SPAR models have the potential to provide safety significance insights beyond the plant specific notebooks, while the notebooks, with planned improvements, could be an effective screening tool.

The DPO Panel found that "NRC management and staff are in the process of addressing many of the Ad Hoc DPV Panel's observations and recommendations in the SDP Improvement Initiative." However, the DPO Panel also made the following specific recommendations:

- (1) The NRC should conduct an independent review of the SDP assessment tools.
- (2) The SDP should incorporate uncertainty analysis in the inspection finding assessments.
- (3) Criteria for benchmarking the SDP should be subjected to peer review.
- (4) Guidance for performing SDP (Phase 3) reviews should be developed and applied consistently across the regions.

Between May and October 2001, the OIG conducted an audit of the SDP. The objectives of the audit, as indicated in the OIG's report (OIG-02-A-15) dated August 21, 2002, were to determine whether: (1) the SDP is achieving desired results; (2) NRC staff clearly understand the process; and (3) NRC staff are using [the] SDP in accordance with agency guidance. In its report, the OIG concluded that "while the SDP is meeting its objectives, and agency staff are using SDP in accordance with guidance, additional refinements are needed." The report provided the following recommendations for the NRC:

- (1) Develop an action plan to correct Phase 2 analysis weaknesses or eliminate this portion of the SDP;
- (2) Discontinue the expenditure of about \$650,000 remaining to develop Phase 2 until the action plan is completed;
- (3) Provide guidance for using information from licensee risk assessments in SDP evaluations;
- (4) Improve SDP timeliness;
- (5) Improve the NRC's [ROP] web site to more fully inform the public; and
- (6) Improve SDP training and guidance.

In a memorandum dated May 14, 2002, the Deputy Executive Director for Reactor Programs informed the OIG that, in general, the staff agreed with many of the observations and recommendations in the OIG's draft report. The memorandum indicated that the staff had already initiated various SDP improvement initiatives and forwarded specific comments on the OIG draft report. In a memorandum to the Director of NRR, dated August 6, 2002, the EDO directed that a plan be developed to address both the DPO Ad Hoc panel and the OIG recommendations. The EDO's memorandum indicated that this plan shall address the DPO Panel recommendation for an "overall objective review of the SDP." The plan developed by the Director of NRR included the formation of the SDP Task Group to conduct an independent review of the SDP.

2.2 Background

In SECY-99-007, "Recommendations for Reactor Oversight Process Improvements," dated January 8, 1999, the staff provided its recommendations to the Commission for improving the reactor regulatory oversight processes, including proposed changes to the NRC's inspection, assessment, and enforcement processes. The staff's efforts to develop the proposed changes were guided by three objectives: (1) improve the objectivity of the [reactor] oversight process so that subjective decisions were not central process features; (2) improve the scrutability of these processes so that NRC actions have a clear tie to licensee performance; and (3) risk-inform the process so that NRC and licensee resources are focused on those aspects of performance having the greatest impact on safe plant operations.

With respect to the assessment process, the staff sought to develop a process that would allow the integration of various information sources relevant to licensee safety performance. In

SECY-99-007, the staff concluded that adequate assurance of licensee performance would be achieved through the use of risk-informed performance indicators (PIs) and inspection findings. The staff also highlighted the need to develop a method for characterizing the risk of inspection findings, indicating that a "level of risk significance, based on a risk scale, will be determined and documented for the findings" and that both the PIs and inspection findings would be evaluated against risk-informed thresholds.

In SECY-99-007A, "Recommendations For Reactor Oversight Process Improvements" (Follow-up to SECY-99-007), Attachment 2, dated March 22, 1999, the staff introduced the SDP as the method for characterizing the risk of inspection findings. The SDP was designed to assess only those inspection findings associated with at-power operations in the Reactor Safety Strategic Performance Area cornerstones of initiating events, mitigation systems, and barrier integrity; however, concepts for characterizing the risk significance of inspection findings in the emergency preparedness, radiation safety, and safeguards areas were under development. The SDP provided a means to screen out inspection findings that have minimal or no risk significance and trigger a more detailed analysis of potentially risk-significant findings. As indicated in Appendix 1 to SECY 99-007A, the following objectives were used to guide the staff's development of the SDP: (1) characterize the risk significance of an inspection finding consistent with the regulatory response thresholds used for PIs and (2) provide a risk-informed framework for discussing and communicating the potential significance of inspection findings.

To support the start of the initial implementation the revised ROP in April 2000, the staff issued Inspection Manual Chapter (IMC) 0609, "Significance Determination Process." Appendix A to IMC 0609 provided guidance for the staff to estimate the unintended increase in risk during at-power plant conditions caused by deficient licensee performance. The guidance was intended to provide a simplified probabilistic framework for use by the staff in identifying potentially risk significant findings in the reactor safety area--either the initiating events, mitigation systems, or barrier integrity cornerstones.

The reactor safety SDP uses a graduated, three-phase process to differentiate inspection findings on the basis of their risk significance. Phase 1 of the SDP provides a characterization of the finding and an initial screening of very low safety-significance findings for disposition by the licensee's corrective action program. Phase 2 of the SDP provides an initial approximation of the risk significance of the finding and develops the basis for the significance determination. The Phase 2 SDP is performed using risk-informed inspection notebooks, which the staff develops for each nuclear plant. The Phase 2 notebooks contain plant-specific worksheets used by the inspectors to determine the safety-significance (color) of the inspection finding. Phases 1 and 2 of the SDP are intended to be accomplished primarily by inspectors and their supervisors or managers. Phase 3 of the SDP, which is performed by an NRC risk analyst, involves a review and, as needed, refinement of the risk significance estimate from Phase 2. A Phase 3 evaluation is also performed for inspection findings which cannot be evaluated using the plant-specific risk-informed Phase 2 notebooks.

When the ROP was initially implemented in April 2000, the staff's efforts to develop the Phase 2 notebooks for each nuclear plant were still in progress. As a result, the draft notebooks that were made available for staff use at initial ROP implementation were considered to be incomplete. By late 2000, the staff had made sufficient progress in the site visits associated with the development of Phase 2 SDP notebooks, that it began to issue the "Revision 0" notebooks to the sites. After issuance of the first Rev 0 notebooks, the staff identified problems

with the accuracy of the notebooks and concluded that benchmarking was needed to confirm the adequacy of the notebooks. Using NRC risk analysts and contractor resources, the staff began its efforts to benchmark the Phase 2 SDP the notebooks in April 2001. As of November 12, 2002, the staff had issued 24 Revision 1, Phase 2 notebooks.

In March 2002, the staff revised IMC 0609, Appendix A, to provide guidance for evaluating concurrent inspection findings and clarified the process of accounting for external event core damage initiators in the risk significance characterization of inspection findings. Attachment 1 to the revision incorporated rules for using the Phase 2 SDP notebooks, including a "counting rule" convention for estimating the risk significance of inspection findings based on the internal initiating events that lead to core damage. Also, in a memorandum dated March 18, 2002, the Director NRR issued an integrated plan to coordinate and complete initiatives aimed at improving process, tools and knowledge issues associated with the SDP.

In a memorandum to the Regional Administrators dated August 9, 2002, the Director, NRR, issued guidance to clarify and emphasize the program office's expectations for inspector use of the SDP. The memo provided guidance in six areas; however, particular emphasis was placed on two areas: (1) the importance of inspectors using their initial SDP evaluation of a finding as a basis for discussing the finding with the licensee at the earliest opportunity following the initial characterization of the finding; and (2) guidance to inspectors and SRAs on the use of the Phase 2 risk-informed inspection notebooks, including when it is necessary for the SRAs to perform additional analysis of an inspection finding beyond the Phase 2 process.

3.0 EVALUATION RESULTS AND RECOMMENDATIONS

The SDP, including the Phase 2 process, has generally succeeded in meeting the ROP objectives of providing a more objective, scrutable, and risk-informed process. In addition, the four SDP objectives have generally been met by the current SDP process. Although the contribution of the Phase 2 process to the SDP objectives was limited because of its relatively infrequent use, feedback from stakeholders indicated that the Phase 2 process has contributed to the staff's efforts to characterize the significance of inspection findings, facilitate stakeholder communication, provide a basis for assessment and enforcement actions, and risk inform the inspection program.

The Task Group concluded that the SDP should retain the Phase 2 process to facilitate (resident and region-based) inspector involvement in the characterization of potentially greater-than-green inspection findings. However, the unbenchmarked SDP notebook should be enhanced to address the current problems with the Phase 2 Worksheets, including the technical inadequacies and the cumbersome, complex and time-consuming characteristics of the worksheets. In this regard, the Task Group evaluated six options to enhance the SDP and recommended the development of enhanced pre-solved Phase 2 SDP tables (Option 3) to replace the Phase 2 SDP notebooks as the primary tool for inspectors to perform Phase 2 evaluations. However, the notebooks should be retained for optional use by the NRC staff to gain additional risk insights.

The performance expectations for Phase 1 of the SDP were clearly documented in IMC 0609, well understood by the staff, and have been used to appropriately screen out inspection

findings of very low safety significance. However, the original performance expectations regarding the use and accuracy of the Phase 2 process have not been fully realized due, in large part, to the untimely development and issuance of the Phase 2 notebooks and the errors associated with the Revision 0 notebooks. The current SDP performance expectations, as well as the expectations for inspectors to use the SDP, are described in an August 9, 2002, memorandum from the Director, NRR. The Task Group concluded that the expectations were understandable and capable of being implemented by the Regions, however, based on the interviews in the Regions, some staff were unfamiliar with the guidance and others were unsure of whether and how it had been implemented.

The Task Group determined that resident and region-based inspectors rarely used the Phase 2 notebooks to characterize an inspection finding because the majority of the findings screened (out) as minor or Green prior to meeting a condition that required use of the Phase 2. Also, most of the inspector interviewees expressed difficulty in using the Phase 2 notebooks because the guidance was poorly organized and the worksheets were time consuming and not user-friendly. Notwithstanding these concerns, most of the NRC interviewees supported the continued use of the Phase 2 process, provided that the current problems are addressed, and felt that it was essential for inspectors to participate in determining the significance of inspection findings beyond the initial screening, Phase 1.

IMC 0609 and IMC 0612, "Power Reactor Inspection Reports," provide some guidance on the types of inspection findings that can be evaluated using the SDP. The reactor safety Phase 2 SDP notebooks do not currently allow for treatment of inspection findings that are related to external events, shutdown modes and Large Early Release Frequency (LERF). However, the staff has initiated action to refine the SDP guidance documents for evaluation of findings related to shutdown modes, containment, and fire protection. The degraded condition of a Structure, System or Component (SSC) can also be treated using the SDP if agreement can be reached on characterizing the impact of the finding on equipment unavailability or initiating event frequency. The Task Group also concluded that external events can have a significant effect on risk analyses and, therefore, should be included in the SDP. In this regard, the Task Group concurred in the ongoing NRR initiatives to develop better tools and guidance for external events so that the risk insights can be applied in a consistent manner.

A variety of NRC training courses and seminars were administered over a relatively short time frame and a number of training courses were established to enhance the knowledge of NRC staff and managers in the area of risk. Although the general consensus from the Task Group's interviews of internal and external stakeholders was that the staff's knowledge and ability to communicate risk insights has improved due, in part, to staff training, many commented on areas for improvement. In particular, many inspectors felt that the training could have been better and that it did not make them proficient in use of the Phase 2 tool. Although training was a factor in inspector proficiency, the Task Group concluded that the complexity of the Phase 2 notebooks, the unavailability of benchmarked notebooks, and the infrequent use of the Phase 2 process were the main hindrances to inspectors' ability to use the Phase 2 SDP. The Task Group concluded that simplifying the Phase 2 SDP by using enhanced pre-solved tables will alleviate the need for inspectors' current reliance on the SRAs to conduct the Phase 2 evaluation. The Task Group also recommended that a systematic assessment of agency training in the area of risk be conducted.

Although the current Phase 2 SDP guidance is complex, it was deemed adequate to implement the current Phase 2 worksheets. In addition, the Task Group concluded that the enhanced pre-solved Phase 2 SDP tables will prompt the development of more user-friendly implementation guidance. The actions and schedule in the SDP Task Action Plan to enhance the current Phase 3 guidance are appropriate. Although no examples were cited where the limited Phase 3 SDP guidance has resulted in an unsatisfactory outcome (i.e., inadequate or poor quality Phase 3 analysis), the Task Group concurred in the ongoing NRR initiative to enhance the Phase 3 guidance.

The Task Group concluded that the ongoing benchmarking contributes significantly to improving the quality of the Phase 2 SDP notebooks and SPAR models. Many of the recommendations contained in the DPO Ad Hoc Panel report regarding the benchmarking process, including staff qualification and peer review recommendations, have already been included in the current process. However, the Task Group noted several areas for further improvement, including documentation of the “construction rules” for developing the Phase 2 SDP and comparison between the results of the benchmarked SPAR models and the benchmarked notebooks. In addition, because future licensee probabilistic risk assessment (PRA) changes and/or plant modifications can affect the adequacy of the notebooks, the Task Group concluded that a plan to update the Phase 2 tool was warranted.

The Task Group reviewed the use of uncertainty in SDP evaluations in light of the three types of uncertainty highlighted in Regulatory Guide (RG) 1.174, “An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant Specific Changes to the Licensing Basis:” parameter uncertainty; model uncertainty; and completeness uncertainty. The Task Group concluded that parameter uncertainty was a relatively minor contributor for the purpose of the SDP, and that model uncertainties associated with the characterization of the impact of the inspection finding on the function of an SSC represented the greatest source of uncertainty. The Task Group also noted that the staff should consider the contribution from external events, and low power and shutdown events when making a final assessment of risk significance of a finding (for completeness). The Task Group concurred in the ongoing initiatives to develop better tools and guidance in the area of low power and shutdown.

The Task Group concluded that the SDP should not be modified to include consideration of “other inputs.” There were no examples where the current provisions for treating other inputs in the ROP had limited the staff’s ability to focus resources in appropriate areas. In addition, the existing guidance in IMC 0305, “Operating Reactor Assessment Program,” regarding deviations from the Action Matrix can be employed, where appropriate, to consider “other inputs” in determining agency response. The Task Group also concluded that the current guidance in IMC 0305 does not promote consistency in the identification of substantive cross-cutting issues by the Regions and the guidance is vague on the expected NRC and licensee response to a substantive cross-cutting issue.

The Task Group concluded that the ROP timeliness goal of completing the SDP within 120 days of the first inspection exit meeting and within 90 days of the issuance of the inspection report is reasonable, however, the goals were not well understood by all members of the staff. The Task Group recognized that some findings involve complex engineering issues and may require additional time to adequately assess the safety significance. The Task Group determined that significant progress has been made in tracking the timeliness of the issues that are greater than Green and establishing accountability within the responsible offices. However,

the Task Group concluded that improved management decisiveness in determining the engineering assumptions used in risk evaluations would contribute to the timeliness of the SDP. The Task Group concluded that a recent revision to the Office of Public Affairs (OPA) policy regarding issuance of a press release for a White findings was an improvement and noted that further revision to link press releases to a finding(s) that results in a Degraded Cornerstone was warranted.

The OIG audit report, (OIG-02-A-15) provided several recommendations to enhance the ROP web site. The Task Group concluded that the recommendation to improve the web site links for all relevant documents for greater-than-green findings was appropriate and should be adopted by NRR. The recommendation to link the summary of findings to the inspection report had already been implemented. The recommendation to revise IMC 0612 to include a brief summary of corrective actions in the inspection report summary of findings was reasonable. The Task Group concluded that the recommendation to display all significant findings colors in a cornerstone should not be adopted. Web site users are provided ready access to all findings in a cornerstone by hyper-linking to the next web page, and the difficulty and costs of implementing this change would exceed the benefit.

The Task Group determined that the issuance of different NRC risk characterizations from the Accident Sequence Precursor (ASP) Program and SDP can have a potentially negative impact on public confidence. Consequently, program requirements and/or an RES/NRR office protocol should ensure reasonable consistency in the output of the programs to promote public confidence. The Task Group concluded that efficiencies could be gained through a better coordination and/or integration of these two programs.

The Task Group evaluated concerns about the perceived overemphasis on the objectivity of PRA results and the quality of the PRA models used to determine the final risk significance inspection findings. The Task Group concluded that the staff routinely uses engineering judgement in the SDP and that this practice is consistent with the NRC's PRA Policy Statement ("Use of Probabilistic Risk Assessment Methods in Nuclear Activities: Final Policy Statement," dated August 16, 1995). With respect to the quality and scope of licensee PRAs, the Task Group concluded that guidance should be developed to allow the staff to determine whether the results of a licensee's risk analysis of a finding is of sufficient quality to use as input to the staff's final significance determination.

The Task Group concluded that overall, the Action Matrix has fulfilled its purpose in providing an objective, scrutable and predictable framework for NRC actions in response to licensee performance problems. The oversight process also provides sufficient flexibility in use of the Action Matrix for NRC managers to use discretion in decisions concerning the scope and timing of the agency's response to licensee performance problems. In addition, the Task Group concluded that the staff used reasoned judgement to support its decision to use two White inputs in the same cornerstone as part of the criteria for defining a "Degraded Cornerstone." Although a detailed analysis or evaluation was not developed to support this decision, the Task Group did not identify data or obtain information from its interviews that suggested that the criteria were inappropriate.

Sections 3.1 through 3.11 describe the Task Group's recommendations to address the identified issues.

3.1 Evaluation of Reactor Oversight Process and Significance Determination Process Objectives

As directed by the Charter, the Task Group evaluated whether the SDP, particularly the Phase 2 portion of the process, had succeeded in meeting the objectives of the ROP and SDP, and whether the Phase 2 SDP should be continued, modified or replaced. In its evaluation, the Task Group reviewed various background documents, including SECY-99-007, SECY-99-007A, and IMC 0609. The Task Group also considered in its evaluation, insights obtained from interviews with internal stakeholders, licensee representatives and other external stakeholders.

3.1.1 Observations

The three objectives of the ROP, which were established in SECY-99-007, are to improve the objectivity, improve the scrutability, and to risk-inform the inspection and oversight process. The first two SDP objectives were established in SECY-99-007A: (1) to characterize the significance of an inspection finding for the NRC licensee performance assessment process, using risk insights as appropriate; and (2) to provide all stakeholders an objective and common framework for communicating the potential safety significance of inspection findings. Subsequently, two additional SDP objectives were identified in IMC 0609: (3) provide a basis for assessment and/or enforcement actions associated with an inspection finding; and (4) provide inspectors with plant-specific risk information for use in risk-informing the inspection program.

3.1.1.1 Phase 2 SDP Contribution to ROP and SDP Objectives

Many of the NRC staff interviewed by the Task Group indicated that the ROP objectives, particularly Objectivity and Scrutability, have been met. A common point of comparison among the interviewees was their reference to the previous inspection and enforcement process. Many stated that the ROP and SDP have reduced the subjectivity that characterized NRC inspection, enforcement, and assessment decision-making prior to ROP, and provide for a more understandable and predictable process.

Although many NRC staff interviewees agreed that the SDP had contributed to risk-informing the ROP, almost all of the NRC staff interviewees stated that they believe the process had become too *risk-based*. Many stated that significant staff resources are often expended for potentially greater-than-green findings in an effort to refine the quantitative output of the SDP (Phase 3). Some indicated that this refinement, and the associated staff effort, results from the staff's desire to develop a precise measurement of risk associated with findings, while others attributed the perceived need for a precise determination to the fact that any greater-than-green finding is strongly challenged by the licensee. Some noted that potential differences between final SDP determinations and the Accident Sequence Precursor (ASP) program evaluations had prompted a greater sensitivity, on the part of staff conducting SDP evaluations, towards developing the "best" possible SDP determination. Still others indicated that the SDP is predisposed to being viewed as a *risk-based* process because the process requires a comparison of point estimates to discrete response thresholds (i.e., 10^{-6} per reactor year, Green/White; 10^{-5} per reactor year, White/Yellow; and 10^{-4} per reactor year, Yellow/Red) to determine the required regulatory actions. Another indication to some NRC staff that the SDP is risk-based, is the fact that IMC 0609 does not explicitly include provisions for considering

traditional engineering considerations (i.e., defense-in-depth and safety margins) during the SDP deliberation process.

With respect to the four SDP objectives, most NRC staff interviewees also indicated that the current SDP process had successfully met the first, third, and fourth objectives. There was a general belief that the SDP had risk-informed what was previously a more subjective, design-basis-oriented approach to regulation. By providing a common frame of reference from which to evaluate performance issues associated with the initiating event and mitigating system cornerstones, most interviewees credited the Phase 2 process with providing a consistent repeatable basis for assessment and/or enforcement actions, particularly where the Phase 2 process screened the finding as one of having very low safety significance (Green). Yet, a number of NRC staff interviewees shared the view that the contribution of the Phase 2 worksheets to the SDP objectives was unclear because the worksheets have been used infrequently as the sole input to the final significance determination.

Although it was not identified as the primary tool for inspectors to gain risk insights for inspection planning (the fourth SDP objective), the Phase 2 SDP was credited as one of many tools from which inspectors gained risk insights. Other tools used to acquire risk insights included licensee online risk monitor programs, maintenance rule scoping summaries, plant-specific PRA summaries, simplified lists of Risk Achievement Worth values for plant equipment, etc.

The Task Group's interviews revealed mixed views on whether the Phase 2 SDP notebooks have provided an objective and common framework for communicating the potential safety significance of inspection findings. Some of the NRC staff interviewees indicated that the Phase 2 process had met this SDP objective because the dialogue between inspectors who have used the Phase 2 SDP and licensees indicates greater awareness of risk significant plant issues. Several of the licensee interviewees indicated that they do not use the current Phase 2 notebooks to evaluate the significance of issues and they consider the notebooks to be a tool for use by NRC inspectors. They also indicated that because the worksheets were designed to be conservative in their initial assessments of significance, licensees rely more on their own plant-specific probabilistic risk assessments to analyze findings and plant conditions. However, despite the fact that they do not routinely use the Phase 2 SDP notebooks, most of the licensee interviewees indicated that communications with NRC on the risk significance of findings was good. This was attributed, in part, to the framework of the Phase 2 SDP which allowed the NRC and the licensee to focus on the influential assumptions.

During a public meeting that the Task Group held on October 25, 2002, external stakeholders were asked their views on whether the Phase 2 SDP had met the ROP and SDP objectives. Their response indicated that timeliness and clarity in the NRC communication of significance determinations were of greater importance (than the stated objectives) when evaluating the efficacy of the SDP. One stakeholder indicated that because some findings have not been processed in a timely manner, the resultant risk characterization was out of phase with the performance indicators. Another indicated that the NRC's release of final significance determinations as much as a year after the fact serves no purpose. The external stakeholders acknowledged that the use of the Phase 2 worksheets by inspectors does not significantly influence the timeliness of SDP determinations and that other factors in the SDP process have a greater impact, such as NRC decisions on basic assumptions (see Section 3.9 , SDP Timeliness).

Several external stakeholders also expressed concern about the amount of information available to the public concerning the significance determinations of findings, including the fact that the site-specific SDP notebooks are not currently publicly available documents. While acknowledging that the SDP notebooks have not been released publicly for security purposes, they indicated that this underscored the importance of the NRC clearly articulating in its reports the basis for final significance determinations, particularly when the final determination differs from the preliminary determination. In general, the external stakeholders indicated that the SDP (as a whole) had not succeeded in providing timely and clear communications to the public regarding the significance of findings; thus, the objective of providing a common framework for NRC staff and stakeholders to communicate the safety significance of findings had not been fully achieved. When asked about their specific views on the use of Phase 2 worksheets, most of the external stakeholders were not inclined to support NRC's use of any particular risk assessment tool, as long as the results are communicated in a clear and timely manner.

3.1.1.2 Insights Regarding the Viability of the Phase 2 Process

The interviews with stakeholders revealed mixed views on whether the Phase 2 process should be continued, modified or replaced. When asked about their specific views on the use of Phase 2 worksheets, most of the external stakeholders did not recommend that NRC use any particular risk assessment tool, but reiterated their concern that the results of the NRC's risk assessments be clear and timely. Although most licensee interviewees indicated that they do not routinely use the current Phase 2 notebooks to evaluate the significance of issues, several of the licensee risk analysts indicated that the Phase 2 SDP worksheets represent a useful tool to screen Green findings and to identify potentially greater-than-green findings for follow-on review by NRC SRAs. Most of the licensee risk analysts also commented that the Phase 2 worksheets were overly complex and not user-friendly, and suggested that they be made more simple (as they were initially intended) for use by inspectors to screen Green findings.

Some NRC staff interviewees indicated that the current Phase 2 SDP had provided questionable results and that the Phase 2 worksheets are cumbersome and complicated. Experience with inadequacies in the Revision 0 notebooks and frustration with the perceived complexity of the Phase 2 worksheets were the primary reasons for this view. Some interviewees also indicated that the Phase 2 process was unnecessary, particularly in light of the staff's success in using the Phase 1 to initially screen and Phase 3 to estimate the risk significance of inspection findings. It was noted that the Phase 2 worksheets have been used infrequently as the sole input to the final significance determination for green or greater-than-green findings affecting the mitigating systems and initiating events cornerstones. Since the initial implementation of the ROP in April 2000, most findings were either screened as green in Phase 1 or, if potentially greater-than-green, the final significance determinations involved a Phase 3 analysis (due to the complexity of the finding or the lack of confidence in the non-benchmarked Phase 2 notebooks). Based on data provided by the Regional offices, 54 Green inspection findings were processed through Phase 2 of the SDP during the 12-month period, October 1, 2001 to September 30, 2002: eight in Region I; 24 in Region II; nine in Region III; and 13 in Region IV. An even smaller number was determined to be greater than green after passing through Phase 2. As a result, some interviewees believed that the time and effort expended to conduct Phase 2 evaluations with the current notebooks is unwarranted.

Notwithstanding the problems encountered to date with use of the Phase 2 SDP, most of the NRC interviewees support the continued use of the process to screen out Green findings and identify potentially greater-than-green findings. Most NRC interviewees indicated that the benchmarking of the Phase 2 SDP workbooks would address many of the problems and that it was essential for the SDP to continue to facilitate inspector involvement in significance determinations beyond the initial screening, Phase 1. Many indicated that the Phase 2 process benefits from the site specific knowledge of resident inspectors in determining the significance of inspection findings and that placing this responsibility on the Regional SRAs would be less effective and inefficient. Most NRC interviewees also suggested that the Phase 2 SDP should be made more simple and user friendly, which would allow the Phase 2 process to be more easily implemented by inspectors and reduce the burden of screening Green findings by the SRAs.

3.1.1.3 Alternatives to the Current Phase 2 Process

In light of the insights obtained from interviews with stakeholders, the Task Group evaluated seven different options for determining the significance of inspection findings, as summarized in Figure 1. One of the options was to continue with the current process and complete the benchmarking of the remaining notebooks (i.e., the “Base Case”). The other six options were as follows:

- Option 1: Retain the Phase 2 SDP, but terminate benchmarking of the remaining Phase 2 SDP notebooks;
- Option 2: Develop Corel Quattro-Pro Spreadsheet Presentation of the Phase 2 SDP Worksheets; complete benchmarking of the remaining Phase 2 SDP notebooks to support development of spreadsheets. This option represents a computerized version of the existing worksheets that requires the user to (i) select affected equipment , (ii) enter exposure time, and (iii) enter recovery credit, and then the spreadsheet automatically presents the significance determination (color);
- Option 3: Develop Enhanced Pre-Solved Phase 2 SDP Tables using the Phase 2 Worksheets; complete benchmarking of the remaining Phase 2 SDP notebooks to support development of the tables. The tables are pre-solved worksheets, with the accident sequences already solved for each mitigating strategy and for each of the three exposure time ranges (<3 days, 3 - 30 days, and > 30 days) that are used in the current Phase 2 worksheets. In addition, the table includes easy-to-understand narrative discussion on the risk insights associated with each of the mitigating functions or initiating events for which consideration was given in the original worksheets. A sample table is provided in Figure 2;

FIGURE 1 - EVALUATION OF SIGNIFICANCE DETERMINATION PROCESS OPTIONS

EVALUATION CRITERIA-->	Produces Objective Results	Produces Scrutable Results	Produces Risk-Informed Results	Facilitates Stakeholder Communication	Provides for Assessment and Enforcement	*Promotes Maintaining Safety	*Promotes Efficiency, Effectiveness & Realism	*Reduces Unnecessary Regulatory Burden	*Enhances Public Confidence	Provides Reasonably Accurate Results	Provides Independence from Licensee PRA	*User Friendly	*Facilitates Inspector Involvement in SDP	*Developmental Costs/Time to Develop	Evaluation Total
Base Case(statusquo)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Option 1	0	0	0	-1	0	0	-2	0	0	-1	0	-2	0	+2	-4
Option 2	0	0	0	0	0	0	+2	0	0	0	0	+2	0	-2	+2
Option 3	0	0	0	+1	0	0	+2	0	0	0	0	+2	0	-2	+3
Option 4	0	0	0	0	0	0	+2	0	0	+1	-1	+2	0	-4 [†]	0
Option 5	0	0	0	0	0	0	-2	0	0	+1	n/a	0	-2	+2	-1
Option 6	0	0	0	0	0	0	+2	0	0	+1	+1	+2	0	-4 [†]	+2

Note: Base Case: Retain Phase 2 SDP; complete benchmarking of remaining notebooks
 Option 1: Retain Phase 2 SDP; terminate benchmarking of remaining notebooks
 Option 2: Develop Quattro-Pro Spread Sheet Presentation; complete benchmarking of remaining notebooks
 Option 3: Develop Enhanced Pre-Solved Table; complete benchmarking of remaining notebooks
 Option 4: Develop Enhanced Pre-Solved Table using Licensee’s PRA; terminate benchmarking of remaining notebooks
 Option 5: Use SDP Phase 1 and SDP Phase 3; terminate benchmarking of remaining notebooks
 Option 6: Develop SPAR-driven User-friendly Input/Output Device; terminate benchmarking of remaining notebooks

Key: Meets the Base Case = 0 Does Not Meet the Base Case = -1 Exceeds the Base Case = +1
 Double Weighted - * Development Cost/ Time to Develop significantly more than the Base Case- †

FIGURE 2

**ENHANCED PRE-SOLVED PHASE 2 SIGNIFICANCE DETERMINATION PROCESS TABLE
BWR PLANT X**

UNAVAILABLE EQUIPMENT	DURATION			RISK INSIGHTS
	<3 DAYS	3-30 DAYS	>30 DAYS	
HPCI	G	W	Y	The HPCI System is important because it provides 1 of 3 high pressure injection sources to maintain reactor vessel inventory. The following sequences are the primary contributors to the risk if HPCI is unavailable: (1) In the event of a failure of the feedwater system, either HPCI or RCIC is required for vessel inventory makeup. If HPCI and RCIC were unavailable, the operators would need to manually depressurize the vessel and use low pressure injection pumps to maintain core cooling. (2) An inadvertent failure of a SORV open would require HPCI to maintain core cooling. In this case, high containment pressure causes feedwater to isolate so feedwater would not be available for vessel injection. Additionally, RCIC does not have adequate capacity to provide vessel makeup with a SORV open. Therefore, if HPCI fails, operators would be required to manually depressurize and use low pressure injection to maintain vessel inventory. [Sequences: TPCS-2, SORV-2]
RCIC	G	W	Y	The RCIC system is important because it provides 1 of 3 high pressure injection sources to maintain reactor vessel inventory. The sequence of events that contributes to RCIC's importance is a loss of feedwater followed by the loss of both HPCI and RCIC. In this case, operators would need to manually depressurize the reactor vessel and use low pressure injection pumps to maintain core cooling. [Sequence: TPCS-2]
RHR TRAIN A	G	W	Y	The RHR Train A is important because Train A can be used for containment heat removal (suppressions pool cooling). If the normal heat removal path to the condenser is lost, suppression pool cooling is required to maintain containment integrity. It is assumed if containment heat removal is lost, containment will fail, resulting in failure of all reactor vessel injection sources, located in the reactor building. The dominating sequence is a loss of turbine building closed cooling water (TBCCW) followed by a loss of containment heat removal. The failure of TBCCW results in a loss of the condenser and normal heat removal. Loss of TBCCW also results in the loss of all potential injector sources outside of the reactor building such as CRD pump suppression pool cooling (SPC) is important because it is necessary to mitigate a loss of TBCCW. [Sequence: TBCCW-17]
RHR TRAIN B	G	G	G	The loss of Train B is not risk significant because it can't be used for suppression pool cooling and any one train of four LPCI trains or one of two trains of LPCS trains can be used for low pressure injection. [No Risk Significance Sequence: TPCS-3, SORV-3, MLCCA-3]
EDG TRAIN A	G	G	W	The EDGs are important because they provide an alternate means to power vital electrical if normal offsite power is lost. If offsite power is lost and not recovered for a long period of time, the station batteries will deplete and all reactor vessel injection sources will be lost. However, Plant X also has a portable diesel which can be used to recharge the station batteries. Therefore, operators can also mitigate core damage by maintaining the station batteries charge with this portable diesel generator. [LOOP Sequence: LOOP-3]

- Option 4: Develop Enhanced Pre-Solved Phase 2 SDP Tables using the licensee's PRA as a basis; terminate benchmarking of the remaining Phase 2 SDP notebooks. This option provides similar information for the user as Option 3, however, it would require "benchmarking" and/or quality review of a licensee PRAs;
- Option 5: Use SDP Phase 1 and SDP Phase 3 only; terminate the benchmarking of the remaining Phase 2 SDP notebooks. This option would require inspectors to complete the initial screening of inspection findings using Phase 1 and the SRAs to evaluate all potentially greater-than-green findings using Phase 3 tools (SPAR models and/or insights from licensee PRAs);
- Option 6: Develop SPAR-driven Input/Output Device for inspectors to conduct Phase 2 SDP reviews; terminate benchmarking of the remaining Phase 2 SDP notebooks. This option would use the SPAR engine and an interface device to convert the output of the SPAR to intellectually manageable information for inspectors.

The Task Group identified 14 criteria to evaluate the merits of the different options. The criteria, which included the ROP objectives, the SDP objectives, the four NRC Performance Goals, and other considerations that reflect the predominant views of most stakeholders, were as follows: Produces Objective Results; Produces Scrutable Results; Produces Risk-Informed Results; Facilitates Stakeholder Communication; Provides for Assessment and Enforcement; Promotes Maintaining Safety; Promotes Efficiency and Effectiveness; Reduces Unnecessary Regulatory Burden; Enhances Public Confidence; Provides Reasonably Accurate Results; User Friendly; Facilitates Inspector Involvement in SDP; Development Costs/Time to Develop. Each of the criteria was used to evaluate the six options relative to the Base Case. A grading scale was also employed to aid the evaluation: -1 = does not meet the Base Case; 0 = meets the Base Case; and +1 = exceeds the Base Case. For ease of comparison, the Base Case was assigned a zero in all 14 criteria; however, the Task Group recognized that the current Phase 2 worksheets did not meet the Base Case for several criteria, as noted in the discussion of each criterion. The six options were compared to the Base Case in determining their scores.

A (double) weighting scheme was developed and applied to seven of the criteria to recognize their relative importance to enhancing the SDP. These criteria included the four Agency Performance Goals, User Friendly, Facilitates Inspector Involvement in SDP and Development Costs/Time to Develop. To recognize the importance of evaluating existing programs and new initiatives against the achievement of the agency performance goals, as outlined in the Strategic Plan, the Task Group determined that additional weight should be given to the agency performance goal criteria. The Task Group also recognized that the basis for much of the criticism of the Phase 2 SDP was the cumbersome, complex and time-consuming characteristics of the worksheets. As a result, the Task Group determined that the User Friendly criteria should be weighted to emphasize its importance. The vast majority of the NRC interviewees also cited the importance of continued inspector involvement in the SDP beyond the initial screening (SDP Phase 1) to exploit their knowledge of the design and condition of the plant and to enhance the knowledge of inspectors through the practical application of risk concepts. As a result, the Task Group gave added weight to its importance. Finally, the Task Group thought it prudent to weight both the Developmental Costs/Time to Develop criteria to

distinguish the business and practical implications of the various options. For each option, the range of possible scores was -23 to +21.

The following paragraphs provide a description of the 14 evaluation criteria and insights into the basis for the Task Group's assessment (and scoring) for the Base Case and the six options. A summary of the Task Group's evaluation is shown in Figure 1:

- (1) Produces Objective Results. The primary factor used to assess the options against this criterion was whether or not the option would facilitate an objective determinations of risk when compared to the Base Case. The Task Group concluded that none of the six options would inherently provide more or less objective result than the current notebooks. The Task Group considered the fact that each of the options, including the Base Case, has risk as a key factor in determining the safety significance of inspection findings. Consequently, each option reduces the subjectivity involved in significance determinations and were considered to "meet the Base Case."
- (2) Produces Scrutable Results. The primary factor used to assess the options against this criterion was whether or not the option would promote understandable, predictable, repeatable, and traceable results when compared to the Base Case. Also, key to the Task Group's assessment of this criterion was whether knowledgeable stakeholders could review the product and understand the method by which the agency arrived at its significance determination. The Task Group concluded that each option would "meet the Base Case" because the results of each option (a significance determination) would provide similar input to the agency's inspection report process—no option provided a result that was more or less scrutable than the Base Case.
- (3) Produces Risk-Informed Results. The primary factor used to assess the options against this criterion was the extent to which the option would use PRA concepts (e.g., initiating event frequencies, equipment failure rates, minimum cut-set accident sequences, etc.) when compared to the Base Case. The Task Group found the benchmarked notebooks to be reasonably risk-informed due to their use of such concepts and because of continued staff efforts to benchmark the notebooks against the licensee's PRA. The Task Group concluded that, because all of the options were rooted in PRA concepts, none was more or less risk-informed than the other, thus, they all "meet the Base Case."
- (4) Facilitates Stakeholder Communication. The primary factor used to assess the options against this criterion was the extent to which the option would provide a more common framework for communicating risk insights between NRC and its stakeholders when compared to the Base Case. Although the Task Group received mixed views from interviewees regarding the contribution of the current Phase 2 notebooks to quality communications between NRC and all of its stakeholders, the Base Case was assigned a zero to facilitate a comparison of the options.

Of the six options, the Task Group felt that four (Options 2, 4, 5 and 6) would not provide more or less of a common frame of reference from which to enter into

discussions with stakeholders on plant risk significance. Option 1 (retain notebooks; terminate benchmarking) was considered to “not meet the Base Case” because the inspectors’ use of non-benchmarked notebooks would not contribute to a common frame of reference for communicating plant risk significance. Option 3, however, was viewed as exceeding the Base Case because the proposed tables would require completion of the benchmarking and include risk insights using plain-English narrative text for each of the affected systems. The Task Group believed that these risk insights will promote a more common understanding of the risk insights among NRC staff (particularly inspectors) and stakeholders.

- (5) Provides for Assessment and Enforcement. The primary factor used to assess the options against this criterion was the extent to which the option would provide a more discernible advantage or disadvantage in how it contributed to the assessment and enforcement processes when compared to the Base Case. In evaluating each option against this criterion, the Task Group recognized that the each option would provide comparable input to the enforcement and assessment processes in the form of safety significance determination (color). Consequently, all seven options were considered to “meet the Base Case.”
- (6) Promotes Maintaining Safety. The primary factor used to assess the options against this criterion was the extent to which the option contributed more or less to the agency’s ability to focus on maintaining safety at power reactors when compared to the Base Case. The Task Group determined that the significance determinations provided by each of the options would provide an adequate contribution to the assessment process and that the ROP affords sufficient defense-in-depth to assure that risk-significant findings would be identified. Therefore, each option was considered to “meet the Base Case.”
- (7) Promotes Efficiency, Effectiveness and Realism. The primary factors used to assess this criterion by comparing the options against the Base Case were the extent to which the option would promote balancing of the risk evaluation workload, capitalize on information technology, and provide a basis for consistent quality decision-making. The Task Group noted that the aforementioned problems with the Phase 2 notebooks (e.g., cumbersome, complex and time-consuming) detract from its ability to support consistent quality decision-making; however, the Base Case was assigned a score of zero to facilitate a comparison of the options.

The Task Group acknowledged that either of the options would generally support improvement in consistency and predictability because each option provides a risk-informed approach to determining the significance of findings. However, the Task Group determined that Option 1 did “not meet the Base Case” because terminating the benchmarking of the Phase 2 notebooks would not further the accuracy of the worksheets and, as a result, there would be a diminished basis for consistent quality decision-making.

For Options 2, 3, 4 and 6, the Task Group determined that the improved accuracy of the tools would provide a basis for more consistent quality decision-

making. In addition, the Phase 2 SDP worksheets and licensee PRAs, which have been used to evaluate the safety significance of inspection findings, would form the basis for the Quattro Pro spreadsheet presentation (Option 2) and the enhanced pre-solved tables (Options 3 and 4), respectively. For Option 6, a SPAR-driven, user-friendly input/output device would be used by inspectors to complete the Phase 2 evaluation. Because these options involve inspectors to complete the Phase 2 process, there is a sharing of the risk evaluation burden between inspectors and SRAs. Options 2, 3, 4 and 6 were considered to "exceed the Base Case."

Option 5 did "not meet the Base Case" because it would require the SRAs rather than inspectors to assume the burden of evaluating all findings that screen out of Phase 1 (as potentially greater-than-green). Although inspectors would still be required to gather information to support the Phase 3 evaluations, the Task Group determined that omitting inspectors from the (Phase 2) evaluation of potentially greater-than-green findings would not exploit their site specific knowledge and, thereby, result in a less efficient distribution of the risk assessment workload within a Region.

- (8) Reduces Unnecessary Regulatory Burden. The primary factor used to assess the options against this criterion was the extent to which the option would contribute to action that is necessary and sufficient to assure safety when compared to the Base Case. The Task Group assumed that for each option the output (color) would continue to be used in the Action Matrix to guide the staff's response to inspection findings. As a result, the degree of regulatory burden imposed on a licensee by either of the SDP options is directly related to the degree to which the color of the finding, particularly a greater-than-green finding, adequately represents its significance. For potentially greater-than-green findings, either of the options would involve the use of an advanced risk assessment (Phase 3) tool and require formal dialogue with the licensee before reaching a final significance determination, as is currently done for the Base Case. Therefore, the Task Group determined that use of either option would produce adequate significance determinations and result in staff actions that are necessary and sufficient to assure safety. Each option was found to "meet the Base Case."
- (9) Enhances Public Confidence. The primary factor used to assess the options against this criterion was the degree to which the options would provide stakeholders with clear and timely information about the significance of inspection findings, as compared to the Base Case. Insights gained from discussions with external stakeholders indicated that, in general, the public is more concerned about the NRC's efforts to assure the clarity and timeliness of significance determinations than with the agency's use of a particular SDP tool. The Task Group determined that there was no discernible difference between the options (in terms of their output) that would impact the clarity and timeliness of the information that is conveyed to the public about the significance of inspection findings. Other elements of the ROP, such as the inspection reporting requirements and implementation of timeliness goals, have a greater impact on

the clarity and timeliness of significance determinations. The Task Group found that each option “meets the Base Case.”

- (10) Provides Reasonably Accurate Results. The primary factor used to assess the options against this criterion was the degree to which the options provided a reasonable estimate of the risk associated with an identified plant condition, as compared to the Base Case. The Task Group decided that the measure of accuracy was the degree to which the option would minimize the likelihood that the Phase 2 output would be significantly modified after a Phase 3 evaluation was conducted.

The Task Group determined that Option 1 “did not meet the Base Case” because the use of non-benchmarked notebooks would not consistently provide reasonable estimates of risk. Options 2 and 3 were determined to “meet the Base Case” because they essentially represent the “answers” derived from the worksheet methodology, but in a more user-friendly format.

Options 4, 5, and 6 would employ more advanced risk assessment tools, such as the SPAR models, which are benchmarked to the licensees’ PRAs and reduce the potential for calculational errors. In this regard, the Task Group assumed that, in most cases, the licensees’ PRAs (if performed in accordance with an NRC-approved PRA standard) would be the best tools available for determining the risk significance of a finding. Options 4, 5 and 6 were found to “exceed” the Base Case.

- (11) Provides Independence from Licensee PRA. The primary factor used to assess the options against this criterion was the degree to which the options would provide for an objective assessment of inspection findings by inspectors when compared to the Base Case. Although the licensees’ PRAs may, in many cases, represent the best-available tool for judging the “accuracy” of SDP risk significance determinations, the Task Group determined that the SDP must be consistent with the NRC Principles of Good Regulation and, therefore, assure a degree of independence and objectivity when assessing the significance of inspection findings. For the Base Case, the site-specific Phase 2 SDP worksheets were developed using generic data, consistent construction rules and functional level accident sequences for similar reactor types. During the benchmarking site visits, the results of selected unavailable equipment cases are compared between the licensee’s PRA and the plant-specific notebook, areas of difference are recognized, reasons for the differences are understood, and appropriate changes to the notebooks are made.

Similar to the Base Case, Options 1, 2, and 3 use the Phase 2 SDP worksheets to support their respective significance determinations. As a result, the Task Group did not identify a discernible difference in the ability of these options to provide for an unbiased assessment. Thus, Options 1, 2 and 3 “met the Base Case.” The Task Group determined that Option 4 would “not meet the Base Case” because it would be based solely on the licensees’ PRA.

This criterion was determined to “not apply” to Option 5 because this option would not include a Phase 2 process, as does the Base Case. Option 6 was judged to be more objective, in that the development of the SPAR models had entailed a more extensive independent review by the staff and the risk assessment tool itself was not solely based on the licensee’s PRAs. The Task Group determined that Option 6 “exceeded the Base Case.”

- (12) User-Friendly. The primary factors used to assess the options against this criterion was the amount of user training required, the amount of time and effort required to determine the significance of a finding, the apparent complexity of the tool, and the extent to which information technology (IT) was employed, as compared to the Base Case. The Task Group observed that the benchmarked notebooks were generally viewed as not user friendly, instead they were often characterized as being cumbersome, time-consuming, and difficult to use. However, to allow for comparison with the other options, the Base Case was set to zero.

Option 1 was viewed to be less advantageous than the Base Case because the current limitations of the Base Case would be preserved. Also, by terminating the benchmarking of the remaining Phase 2 notebooks, the time and effort required for inspectors to determine the significance of some findings would continue to be extended. Option 1 did “not meet the Base Case.”

Options 2, 3, and 4 would likely reduce the amount of time and effort required for inspectors to make significance determinations. In addition, each option would take advantage of IT tools to simplify and automate the process, and would require minimal training for users. Similarly, Option 6 would employ IT tools, allow for more timely significance determinations, and present a simplified conceptual interface for users. Although more extensive training may be warranted for Option 6, the Task Group determined that Options 2, 3, 4, and 6 “exceed the Base Case.”

Option 5 would eliminate the current Phase 2 process from the SDP and require SRAs rather than inspectors to evaluate the significance of potentially greater-than-green findings. The Task Group determined that although this option would increase the SRA workload, it would not significantly impact the training, time and effort, complexity of the tools, or the use of IT by SRAs. The Task Group determined that it “meets the Base Case.”

- (13) Facilitates Inspector Involvement in the SDP. The primary factor used to assess the options against this criterion was the degree to which the options allowed inspectors to be involved in the assessment of potentially greater-than-green findings, as compared to the Base Case. In the Base Case, inspectors are required to conduct the Phase 2 review by completing the Phase 2 SDP worksheets.

Options 1, 2, 3, 4, and 6 were determined to be comparable to the Base Case in terms of inspector involvement. Although the remaining notebooks would not be benchmarked in Option 1 and 4, inspectors would continue to use the

worksheets and the enhanced presolved tables, respectively, to complete the Phase 2 significance determination. Options 2, 3 and 4 would require completion of the benchmarking of the remaining notebooks and would provide user-friendly tools for inspectors to conduct the Phase 2 evaluations. In Option 6, inspectors would use a SPAR-driven user-friendly interface to complete the Phase 2 determination. Options 1, 2, 3, 4, and 6 “meet the Base Case.”

Option 5 would eliminate the current Phase 2 process from the SDP and require SRAs rather than inspectors to evaluate the significance of potentially greater-than-green findings, therefore, it would “not meet the Base Case.”

- (14) Developmental Costs / Time to Develop. The primary factors used to assess the options against this criterion were whether or not the cost and time to develop the options would be the same (0), less than (+2), more than (-2), or significantly more than (-4) the Base Case. For the Base Case, the Task Group used the cost estimates and schedule associated with completing the benchmarking of the remaining Phase 2 notebooks. Based on data obtained from NRR, as of November 12, 2002, the staff had completed benchmarking of 41 Revision 1 notebooks; 24 were issued for staff use and 17 were undergoing quality reviews. Notebooks for 30 plants still required benchmarking. The estimated cost to complete the remaining notebooks, by the end of FY03, was \$25K per notebook, for a total estimated cost of \$750K.

Option 1 would retain the use of the Phase 2 worksheets by inspectors, but would terminate the benchmarking of the remaining notebooks. Option 5 would eliminate the current Phase 2 process altogether and terminate the benchmarking of the remaining notebooks. Options 1 or 5 could be implemented immediately and the estimated costs of completing the benchmarking of the remaining notebooks would be avoided, thus, both options would “exceed the Base Case.”

Options 2, 3, 4, and 6 were determined to involve costs above the Base Case, as well as time to develop beyond the end of FY03; therefore, they did “not meet the Base Case.” Option 2 would require the development of a Quattro-Pro Spreadsheet Presentation of the Phase 2 SDP Worksheets for each plant at a cost of approximately \$850K. Option 3 would require the development of pre-solved Phase 2 SDP tables for each plant at an estimated cost of \$386K (\$216K for the 41 benchmarked notebooks and \$170K for the 30 non-benchmarked notebooks). Both Options 2 and 3 would still require the completion of notebook benchmarking for the remaining plants.

Although Option 4, would not require the benchmarking of the remaining Phase 2 notebooks, it would require the staff to develop pre-solved tables for each plant and a review of the quality of all licensee PRAs. This review would be needed to promote independence and to ascertain the adequacy of licensee PRAs since they would form the basis for the pre-solved tables. The Task Group found that the scope and costs associated with an NRC review of licensee PRAs was difficult to predict. However, the Task Group assumed that the costs and time to develop would significantly exceed those for the Base Case.

Option 6 would eliminate the need to complete the benchmarking of the remaining notebooks, however, the Task Group concluded that the research, development, implementation, and training costs, and developmental time associated with a site specific SPAR-driven interface would significantly exceed those for the Base Case.”

The scores for all six options ranged between -4 and +3. The scores for three of the options (Options 2, 3, and 6) provided very little discrimination because they all fell in the +2 to +3 range. This indicated that each of these options were feasible enhancements to the current Phase 2 process. The team considered these options and determined that Option 3, which also had the highest score (+3), was the preferred Phase 2 SDP enhancement. The Task Group determined that Option 3 eliminates for inspectors the time-consuming calculations associated with the current worksheets. In fact, the tables are simply pre-solved worksheets, with the minimum cut-set sequences already solved for each mitigating strategy and for each of the three exposure time ranges (<3 days, 3 - 30 days, and > 30 days) that were used for the original notebook concept. In addition, the table includes a column that provides an easy-to-understand narrative discussion on the risk insights associated with each of the mitigating functions or initiating events for which consideration was given in the original worksheets. By having the information readily available on the computer and/or in hard-copy notebooks, the inspectors would not have to resort to long mathematical exercises to gain risk insights for inspection planning purposes.

3.1.2 Conclusions

- (1) The SDP, including the Phase 2 process, had generally succeeded in meeting the ROP objectives of providing a more objective, scrutable, and risk-informed process, particularly when compared to the previous NRC inspection, enforcement and assessment processes.
- (2) The four SDP objectives have generally been met by the current SDP process. Although the contribution of the Phase 2 process to the SDP objectives was limited because of its relatively infrequent use, feedback from stakeholders indicates that the Phase 2 process has contributed to the staff’s efforts to characterize the significance of inspection findings, facilitate stakeholder communication, provide a basis for assessment and enforcement actions, and risk inform the inspection program.
- (3) The SDP should continue to facilitate (resident and region-based) inspector involvement in the significance determination of inspection findings beyond the initial screening, Phase 1.
- (4) The SDP should be enhanced to address the current problems with the Phase 2 Worksheets, including the technical inadequacies and the cumbersome, complex and time-consuming characteristics of the worksheets.
- (5) Of the six options that the Task Group evaluated, Option 3 was the preferred method to replace the Phase 2 SDP notebooks as the primary tool for inspectors to perform Phase 2 evaluations. However, the notebooks should be retained for optional use by the NRC staff to gain additional risk insights.

- (6) Most of the NRC interviewees viewed the SDP process as risk-based vs risk-informed. This opinion was based on the fact that the SDP requires a comparison of point estimates to discrete response thresholds and the understanding that considerable staff resources have been expended to develop a precise quantitative estimate of risk for many potentially greater-than-green findings. The interviewees also indicated that this aspect of the SDP appeared to conflict with its initial performance expectation, which was to provide reasonably accurate estimates of risk for timely decisions regarding follow-up inspection (see Section 3.2, Performance Expectation for the SDP). The Task Group observed that the Phase 1 SDP process uses a risk-informed decision logic to screen (Green) findings or determine that the finding needs a more detailed analysis. However, both Phase 2 and Phase 3 of the SDP use probabilistic tools to assess the significance of an inspection finding. This SDP output is then used in the ROP Action Matrix to determine the agency's and expected licensee response to the finding. RG 1.174 indicates that the integration of risk information with traditional engineering decisions signifies that a process is risk-informed. Using the RG 1.174 approach to risk-informed decision-making as a model, the Task Group concluded that the degree to which the SDP represents a risk-informed process is reflected in the degree to which traditional engineering analysis as well as the SDP output are used in the decision-making process. In addition, the current practice of basing the color solely on the SDP output gives credence to the assertion that the SDP has been implemented in a more risk-based than risk-informed manner. Section 3.7.3(2) provides a recommendation for additional staff guidance regarding the use of traditional engineering analysis.

3.1.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) The NRC should retain the Phase 2 process as a screening method for inspectors to screen findings of very low safety significance (Green) and identify potentially greater-than-green findings for further review by SRAs.
- (2) The NRC should develop plant-specific Enhanced Pre-Solved Phase 2 SDP Tables (Option 3) and complete the benchmarking of the remaining Phase 2 SDP notebooks. Once developed, these tables should replace the current Phase 2 notebooks.

3.2 Performance Expectation for the Significance Determination Process

The DPO Ad Hoc Panel report dated June 28, 2002, indicated that the NRC should develop and issue a performance expectation for the SDP. To evaluate this recommendation, the Task Group reviewed SECY-99-007, SECY-99-007A, and IMC 0609, and interviewed internal stakeholders, licensee representatives and other external stakeholders.

3.2.1 Observations

In SECY-99-007, the staff concluded that adequate assurance of licensee performance would be achieved through the use of risk-informed PIs and inspection findings. The staff also highlighted the need to develop a method for characterizing the risk of inspection findings, indicating that a "level of risk significance, based on a risk scale, will be determined and

documented for the findings” and that both the PIs and inspection findings would be evaluated against risk-informed thresholds. SECY-99-007A introduced the SDP as the agency’s method for characterizing the risk of inspection findings. The SDP was designed to provide a means to screen out inspection findings that have minimal or no risk significance and trigger a more detailed analysis of potentially risk-significant findings.

The staff developed IMC 0609, Appendix A to provide guidance for the staff to estimate the unintended increase in risk during at-power plant conditions caused by deficient licensee performance. The guidance was intended to provide a simplified probabilistic framework for use by the staff to identify potentially risk significant findings in the reactor safety area—specifically, the initiating events, mitigation systems, and barrier integrity cornerstones. The reactor safety SDP uses a graduated, three-phase process to differentiate inspection findings based on their risk significance. Phase 1 of the SDP provides a characterization of the finding and an initial screening of very low safety-significance findings for disposition by the licensee’s corrective action program. Phase 2 of the SDP provides an initial approximation of the risk significance of the finding and develops the basis for the significance determination. Phases 1 and 2 of the SDP were intended to be accomplished primarily by inspectors and their supervisors or managers. Phase 3 of the SDP requires an NRC Senior Reactor Analyst (SRA) of NRR Risk Analyst to review and refine, as needed, the risk significance estimate from Phase 2. SRAs were also expected to perform a confirmatory analysis using the SPAR models if a finding screened from Phase 2 as potentially greater-than-green. A Phase 3 review was also required for findings that cannot be evaluated using the Phase 2 (e.g., external events, shutdown and, LERF).

Most NRC interviewees indicated that they understood and were satisfied with the SDP Phase 1 screening expectations. They indicated that the Phase 1 screening appropriately screened inspection findings of very low safety significance, thereby allowing resources to be focused on issues of greater safety significance.

In addition, most NRC interviewees understood that the Phase 2 was intended to be a simple tool that would allow for a relatively easy characterization of the risk significance of a finding. They also indicated that the initial performance expectation for the Phase 2 SDP notebooks was that it would serve as the primary tool to characterize the majority of potentially greater-than-green inspection findings, represent a reasonably accurate estimation of the risk of an inspection finding, and facilitate timely agency decisions regarding the allocation of resources. However, some NRC interviewees observed that the Phase 2 was designed to provide conservative results and that, as a result, a Phase 3 would likely be performed before final significance determinations were made.

The Task Group determined that challenges experienced during and prior to the initial implementation of the Phase 2 notebooks impacted the ability of users to achieve the original performance expectation of the Phase 2 process. For example, the staff planned to have licensees review and comment on the Revision 0 notebooks, and to modify the notebooks to correct any significant errors. However, the Revision 0 notebooks were not distributed to all licensees, many of the licensees that received the notebooks did not provide comments to the staff, and some of the licensees that provided comments to the staff did not receive feedback on how their comments were treated. After initial issuance of the first Revision 0 notebooks, the staff realized that the notebooks contained errors, such as missing initiating events,

modeling errors and inappropriate success criteria, that were deemed significant enough to warrant an independent benchmarking initiative to add quality to the notebooks.

In addition, most Regional interviewees revealed that during the initial implementation of the ROP, the Phase 2 notebooks had not been issued and were not available for the inspectors to use. This fact led the Regions to develop an early reliance on SRAs to evaluate potentially greater-than-green findings. There was no indication that the ongoing benchmarking efforts had reduced this reliance on SRAs. In general, the Regional interviewees considered the Phase 2 worksheets to be cumbersome and difficult to use, and noted that on average, the worksheets were used only a few times a year to evaluate findings. As a result, despite the expectation for inspectors to use the Phase 2 worksheets for potentially greater-than-green findings, questions about the adequacy, infrequent use, and difficulties in use of the worksheets continued to cause many inspectors to seek assistance from an SRA.

The Task Group's interviews highlighted an unanticipated result from the NRC's use of risk assessment tools to evaluate inspection findings. Many of the interviewees indicated that licensees routinely use their PRAs to develop their own estimate of risk (i.e., a quantitative estimate of the change in core damage frequency (Δ CDF) and/or Δ LERF) in response to an inspector's identification of a preliminary finding of greater-than-green safety significance. This had caused the staff to employ Phase 3 tools routinely to confirm the risk estimate and support the formal deliberations with licensees on the Δ CDF and/or Δ LERF, as well as the influential assumptions and sensitivities that effect the inputs to the risk models. This approach differed from the initial performance expectation, which envisioned use of the Phase 2 tool by inspectors to develop the estimate of risk significance for the majority of potentially greater-than-green inspection findings. During interviews with NRR staff, the Task Group determined that a document was under development that would describe the precepts and principles that were used in the development of the SDP (SDP Basis Document). This document will also include the SDP performance expectations.

In a memorandum to the Regional Administrators dated August 9, 2002, the Director of NRR issued guidance to clarify and reemphasize the program office's (current) expectations for inspector use of the SDP. The memo provided guidance in six areas, including the expectation that: (i) inspectors use their initial SDP evaluation of a finding as a basis for early discussion of the finding with the licensee; (ii) inspectors use the most current version of the Phase 2 SDP notebooks, including Revision 0, to better understand differences between the notebooks and the licensee's risk model, including differences in influential assumptions; and (iii) SRAs perform a Phase 3 when the inspector doubts the results of the Phase 2 and if the results are within one order or two orders of magnitude of the Green/White threshold, using the Revision 1 or the Revision 0 notebooks, respectively. However, based on the Task Group interviews with Regional personnel, some were unfamiliar with the guidance and others were unsure of whether or how it had been implemented.

3.2.2 Conclusions

- (1) The performance expectations for Phase 1 of the SDP were clearly documented in IMC 0609, well understood by the staff, and have been used to appropriately screen out inspection findings of very low safety significance.

- (2) The original performance expectations regarding the use and accuracy of the Phase 2 process have not been fully realized due, in large part, to the untimely development and issuance of the Phase 2 notebooks and the errors associated with the Revision 0 notebooks.
- (3) Because of the problems with development and implementation of the Phase 2 notebooks, the potential benefits (e.g. facilitating stakeholder communication, risk informing the inspectors and reducing SRA workload) of the Phase 2 process have not been fully realized.
- (4) The current SDP performance expectations, which are described in an August 9, 2002, memorandum from the Director, NRR, were understandable and capable of being implemented by the Regions. Based on interviews in the Regions, however, some staff were unfamiliar with the guidance and others were unsure of whether and how it had been implemented.
- (5) The use of SDP Phase 3, including the SPAR models or a best-available tool, by SRAs for confirmatory analysis and to facilitate formal discussions between the staff and a licensee on a potentially greater-than-green inspection finding is consistent with the current performance expectation outlined in the August 9, 2002, memorandum from the Director, NRR to the Regional Administrators.

3.2.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) NRR should issue the proposed SDP basis document, including the current performance expectations for the Phase 2 notebooks.
- (2) NRR should engage the Regions to confirm their understanding and implementation of the expectations regarding use of the SDP provided in the August 9, 2002, memorandum from the Director of NRR to the Regional Administrators.
- (3) NRR should reevaluate the performance expectation of the SDP tools after the remaining notebooks have been benchmarked and modify program guidance, as appropriate, to reflect any revision to the expectation.

3.3 Expectations for Use of Significance Determination Process Phase 2

The purpose of the Task Group's review in this area was to respond to issues raised in the OIG audit report (OIG-02-A-15) regarding inspector use of the SDP. The OIG's report indicated that inspectors use the Phase 2 SDP infrequently and are, as a result, hindered in their ability to effectively use the Phase 2 as a risk characterization tool. The Task Group's review also addresses the question raised in the Charter regarding whether the SDP is implemented by the most appropriate agency personnel. To respond to these issue, the Task Group reviewed IMC 0609, IMC 1245, "Inspector Qualification Program For the Office of Nuclear Reactor Regulation Inspection Program," and interviewed internal stakeholders.

3.3.1 Observations

Specific guidance for inspectors to use the Phase 1 SDP screening and Phase 2 SDP risk characterization process is provided in Attachment 1 to IMC 0609. In general, the guidance requires inspectors to use the Phase 1 to initially screen very low safety-significance (Green) findings and the Phase 2 notebooks to screen Green findings and characterize potentially greater-than-green findings. The guidance also indicates that an SRA should perform a confirmatory analysis using the SPAR models for those findings that are characterized as potentially greater-than-green finding from Phase 2, and to evaluate findings that cannot be evaluated using the Phase 2 SDP. As discussed in Section 3.2.1, the current expectations for inspector use of the SDP were also provided in a memorandum dated August 9, 2002, from the Director, NRR to the Regional Administrators. The memo clarified and reemphasized guidance in six areas, including the expectation that inspectors use the most current version of the Phase 2 SDP notebooks and use their initial SDP evaluation of a finding as a basis for early discussions with the licensee.

With few exceptions, the inspectors interviewed by the Task Group indicated that, while they understood the expectations for use of the Phase 2 SDP, they rarely used their site specific Phase 2 notebooks to screen Green findings or to evaluate potentially greater-than-green findings. They indicated that most inspection findings screen out as either Minor, using the criteria for minor findings in IMC 0612, "Power Reactor Inspection Reports," or as Green, using the Phase 1 screening criteria. This feedback appears to be supported by data that the Task Group obtained from the Reactor Programs System and the Regions, which indicated that during FY02, over 500 findings in the IE, MS and BI cornerstones were screened to Green using the Phase 1. 54 findings were evaluated as Green using the Phase 2 (see Section 3.1.1.2). Another 14 findings (12 White & 2 Red) were evaluated using Phase 3, some of which involved an initial risk estimation using Phase 2.

Some inspectors also indicated that they are not confident in the results of the current Phase 2 worksheets because of the extensive usage rules, confusing guidance and organization of the notebooks, and the "perceived" inaccuracies of the notebooks. Most inspectors indicated that they usually engage the SRAs when they use the Phase 2 SDP.

Some of the inspectors interviewed indicated that they use their site specific notebooks for inspection planning. Most inspectors indicated that they also use the licensee's licensee online risk monitor programs, maintenance rule scoping summaries, plant-specific PRA summaries, simplified lists of importance measures (i.e., risk achievement worth values) for plant equipment, etc., to plan inspections.

Although many Regional interviewees indicated that they were aware of the August 9, 2002, memorandum from the Director of NRR and the general subject areas that it addressed, evidence that the guidance had been implemented was unclear. However, the Task Group noted some cases where Regional training and discussions had been conducted to review the guidance.

As discussed in Section 3.1.1.2, notwithstanding the problems encountered to date with use of the Phase 2 SDP, most of the NRC interviewees support the continued use of the process, particularly if the benchmarking of the Phase 2 SDP notebooks is completed and the tool is enhanced to make it more user friendly and less time consuming. In addition, most of the

interviewees stated that it was essential for inspectors to participate in significance determinations beyond the initial screening, Phase 1.

3.3.2 Conclusions

- (1) Resident and region-based inspectors rarely used the Phase 2 notebooks to characterize an inspection finding because the majority of the findings screen (out) as minor or Green prior to meeting a condition that would require use of the Phase 2. Also, most of the inspector interviewees expressed difficulty in using the Phase 2 notebooks because the guidance was poorly organized and the worksheets were time consuming and not user-friendly.
- (2) Some inspectors have used the Phase 2 notebooks to gain risk insights for inspection planning, however, it is one of many tools that inspectors have used for this purpose.
- (3) Most of the NRC interviewees supported the continued use of the Phase 2 process, provided that the current problems are addressed. They also considered it essential for inspectors to participate in determining the significance of inspection findings beyond the initial screening, Phase 1.
- (4) The expectations for inspector use of the SDP are described in IMC 0609 and in an August 9, 2002, memorandum from the Director of NRR. The expectations in the Director's August 9, 2002, memorandum are understandable and capable of being implemented by the Regions, however, based on Regional interviews, some staff were unfamiliar with the guidance and others were unsure of whether and how it had been implemented. This conclusion is similar to Conclusion 3.2.2.4.

3.3.3 Recommendations

To address the issues discussed in this section of the report, the Task Group supports Recommendations 3.1.3(1) and 3.1.3(2).

3.4 Applicability of the Current Significance Determination Process to the Range of Inspection Findings

The purpose of the Task Group's review in this area was to determine whether the applicability of the current SDP to the range of possible inspection findings is clearly articulated in the SDP program guidance. In order to address this question, the Task Group reviewed IMC 0609 and interviewed internal stakeholders.

3.4.1 Observations

The majority of the interviewees stated that the inspection findings related to the following areas cannot be evaluated using the Phase 2 SDP notebooks because the notebooks are limited to core damage sequences for internal initiating events at power:

- (1) External initiating events (e.g., fire, seismic, and high winds). The Task Group noted that there are two types of findings associated with external events:

- (a) findings associated with plant features that are designed to protect the plant against the physical impact of the external initiating event, e.g., tornado missile barriers, seismic restraints, fire barriers; and
 - (b) findings associated with mitigating systems that are used in response to accidents initiated by external events;
- (2) Shutdown; and
 - (3) LERF (or more generally containment issues)

However, the Task Group noted IMC 0609 provides guidance for evaluating shutdown and LERF issues in Appendix G and Appendix H, respectively.

The Task Group determined that, in general, there were no restrictions on Phase 3 evaluations other than the fact that NRC staff does not have ready access to the tools to analyze the risk from external events and for the low power and shutdown modes. However, the staff has had difficulty dealing with other types of findings because the characterization of their impact on the plant components is complex. These types of findings, which have a similar effect on both Phase 2 and Phase 3, include:

- (1) Degraded conditions;
- (2) Concurrent failures of multiple systems/components (guidance was recently provided in IMC 0609); and
- (3) Cross-cutting issues

Many interviewees stated that the inspection findings related to internal events and mitigating systems can and have been evaluated using the SDP. They also acknowledged that IMC 0609 and IMC 0612 provide some guidance on what types of inspection findings can be evaluated using the Phase 2 notebooks. The majority of the inspectors stated that the guidance is difficult to follow and that this is exacerbated by their infrequent use of the Phase 2 notebooks. No specific recommendations were provided to improve the guidance in this area.

Following the first year of ROP implementation, the staff recognized that the quality of the Revision 0, Phase 2 SDP notebooks was not adequate to assess the significance of inspection findings. NRR initiated a project to enhance the quality of the Phase 2 SDP notebooks by comparing the results of the notebooks with other available PRA tools (benchmarking). Lessons learned from an early benchmarking effort highlighted the importance of including external events risk contributions in SDP analyses. The benchmarking included an examination of four plant-specific PRAs with integrated external initiating events risk modeling to determine if the absence of external events in the phase 2 notebooks would result in an underestimation of risk. In three of the four PRAs, systems and components were identified for which the significance of inspection findings using the internal events PRA model would result in an order of magnitude underestimation (e.g., by one color) compared to the integrated PRA model.

Many NRC interviewees stated that the inclusion of external events risk insights is important to properly characterize the risk of inspection findings. The SDP guidance (IMC 0609, Appendix A, Attachment 1, Step 2.5) states that for Phase 2 SDP evaluations that represent an increase

in risk of greater than 1E-7 per reactor-year (Risk Significance Estimation of 7 or less), that an SRA or other NRC risk analyst should perform a Phase 3 analysis to estimate the increase in risk due to external initiators. However, the SRA interviewees stated that the quality of licensee's external events risk information varies significantly and, as a result, there has been general inconsistencies in the inclusion of external event risk insights in SDP analyses. To address this concern, the SRA's requested additional guidance and tools, and recommended that the treatment of external events in the SDP be temporarily suspended. The recommendation to temporarily suspend the treatment of external events was under NRR evaluation during the period of the Task Group review, consequently, the Task Group did not review this area in detail. Recently, however, NRR decided to not suspend the use of external events in the SDP.

3.4.2 Conclusions

- (1) The reactor safety Phase 2 SDP notebooks do not treat inspection findings that are related to external events, shutdown modes and LERF. However, the NRC staff is currently refining the guidance documents for SDP evaluation of shutdown modes, containment issues that relate to LERF (NRR SDP Improvement Task Action Plan (Task 3, Objectives 3.3), and an SDP for fire protection. The Task Group noted that the fire SDP that is under development only addresses fire protection issues, and is not an SDP for fire as an external initiating event in the traditional PRA sense.
- (2) Degraded conditions can be treated using the SDP if agreement can be reached on characterizing the impact of the finding on equipment unavailability or initiating event frequency. However, the notebooks are not benchmarked for multiple findings and the results would be uncertain.
- (3) Because external events can have a significant effect on risk analyses, they should be included in the SDP. Therefore, the current guidance and tools should be improved so that external event risk insights can be applied by the SDP in a consistent manner . NRR should continue its initiatives to develop better tools and guidance in the area of external events as outlined in SDP Improvement Task Action Plan (Task 3, Objectives 3.1a, 3.3g, 3.7).

3.4.3 Recommendations

The Task Group did not provide any recommendations in this area.

3.5 Significance Determination Process Training and Guidance

The purpose of the Task Group's review in this area was to determine if improvement was warranted in SDP training and guidance. This review was prompted by recommendations made by the OIG and the DPV Ad Hoc Panel. The OIG Audit Report (OIG-02-A-15) included a recommendation for the NRC to improve SDP training and guidance for inspectors. The DPV Ad Hoc Panel report, dated January 10, 2002, recommended that improved guidance be developed for Phase 3 analysis. To evaluate these recommendations, the Task Group obtained information on SDP and PRA training, reviewed IMC 0609, and interviewed NRC staff and managers.

3.5.1 Observations

The OIG audit report (OIG-02-A-15, Section E) documented two staff suggested improvements regarding SDP training program. The improvements include developing training on the application of risk to plant operations and SDP refresher training for infrequently used SDPs. The DPV also indicated that the Phase 2 SDP notebooks are difficult to use and there has been inadequate training on their use. The SDP Task Action Plan includes objectives to partially address these concerns. The SDP Task Action Plan (Objective 4.1) provides actions to conduct SDP training on the Revision to IMC 0609A (dated March 18, 2002) at each Region and to generate schedules for the development SDP refresher and initial training. NRC IMC 1245 does not currently require any PRA/SDP refresher training for inspectors.

The inspection staff have been provided two formal SDP training sessions and one computer based training exercise. The first formal SDP training was conducted prior to the initial implementation of the ROP (Spring 2000). The Phase 2 SDP training conducted during the initial implementation of the ROP training was largely ineffective because the SDP notebooks had not been developed at that time. The inspection staff were recently provided additional Phase 2 SDP training (Fall 2002) following the revision to IMC 0609, Appendix A, on March 18, 2002, that significantly revised the methodology for conducting Phase 2 SDP. This training provided the necessary skills to conduct a Phase 2 SDP evaluation using the SDP notebooks; however, this training was attended on an as-available basis and therefore not all inspectors have received this training. The computer-based SDP exercise was completed by all inspectors.

In addition to SDP training, the NRC offers 13 courses on reactor PRA and risk analysis. All qualified inspection staff are required to complete the PRA Technology and Regulatory Perspectives Course (P-111). Many managers have completed the PRA for Technical Managers Course (P-107). Also, several inspectors, project engineers and/or Branch Chiefs, in each Region have completed the series of advanced risk training courses.

Most of the inspectors interviewed stated that they have not been provided adequate Phase 2 SDP training to be proficient at using the notebooks. They stated that the infrequent uses of the Phase 2 SDP made it difficult to retain the skills needed to efficiently implement Phase 2 SDP. The inspectors also indicated that the SRAs were proficient at implementing the SDP and were routinely used to validate that the Phase 2 notebooks were properly completed. While many of the inspectors interviewed indicated that they did not attend the recent Phase 2 training on the notebooks, those who attended this training found it beneficial. Nearly all inspectors interviewed expressed a desire to receive periodic refresher training on Phase 2 of the SDP. Those individuals who had completed the advanced risk training found the training informative and believed that it improved their ability to implement the SDP.

The guidance for implementing all Phases of the SDP is documented in IMC 0609. On March 18, 2002, the guidance for conducting the Phase 2 and 3 SDP (IMC 0609, Appendix A, Attachment 1) was significantly modified. The general consensus among NRC interviewees was that the Phase 2 analysis guidance was complex, but adequate.

The DPV and DPO review panels recommended that the guidance for Phase 3 SDP analyses be enhanced. Additionally, the OIG report recommended that the guidance for using the licensee's PRA in Phase 3 analyses be improved. Based on the Task Group's interviews, many

of the users of the Phase 3 SDP indicated that the guidance could be improved; however, no specific areas for supplementing the current guidance were provided. The SDP Task Action Plan Objective 3.6 includes an action to enhance the guidance provided for Phase 3 analyses.

3.5.2 Conclusions

- (1) Several different SDP training courses and seminars were provided to inspectors, however, many inspectors felt that the training could have been better and that it did not make them proficient in use of the Phase 2 tool. Although training was a factor in inspector proficiency, the Task Group concluded that the complexity of the Phase 2 notebooks, the unavailability of benchmarked notebooks, and the infrequent use of the Phase 2 process were the main hindrances to inspectors' ability to use the Phase 2 SDP. Inspectors routinely used the SRAs as a resource to validate Phase 2 analyses and, with the assistance of the SRAs, the SDP was implemented successfully. As noted in Section 3.1, the Task Group believes that simplifying the Phase 2 SDP will alleviate the need for inspectors' current reliance on the SRAs to conduct the Phase 2 review. The simplified process is also expected to involve minimal training for inspectors.
- (2) A variety of NRC training courses and seminars were administered over a relatively short time frame and a number of training courses have been established to enhance the knowledge of NRC staff and managers in the area of risk. Also, several staff in each Region have participated in the advanced risk training course series, but there has been no significant change in their job task assignments to take advantage of their additional expertise in performing SDP evaluations. Although the general consensus from the Task Group's interviews of internal and external stakeholders was that the staff's knowledge and ability to communicate risk insights has improved due, in part, to staff training, many commented on areas for improvement. Some of the comments centered on the lack of an integrated concept of the knowledge, skills, and abilities (KSAs), and the associated training, required for staff and managers to implement the SDP. This prompted the Task Group to recognize that a systematic assessment of agency training in the area of risk has not been conducted. Such an assessment would consider the ROP requirements, identify the positions that require risk KSAs (e.g., inspectors, Regional Branch Chiefs, senior managers, etc.), identify those KSAs, and develop and/or identify the type and frequency of training required to establish and maintain the KSAs.
- (3) Although the current Phase 2 SDP guidance is complex, it was deemed adequate to implement the current Phase 2 worksheets. Adoption of the Task Group's recommended approach to enhance the Phase 2 process, as discussed in Section 3.1.3(2), will prompt the development of more user-friendly implementation guidance.
- (4) The actions and schedule in the SDP Task Action Plan to enhance the current Phase 3 guidance are appropriate. The Task Group noted that while there have been several recommendations for enhancing the Phase 3 guidance, no examples were cited where the limited guidance has resulted in an unsatisfactory outcome (i.e., inadequate or poor quality Phase 3 analysis).

3.5.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) NRR should encourage the Regions to hold refresher training on the Phase 2 SDP at least annually. This training should be led by a Regional SRA and can also be used to convey best practices and give feedback on common questions and problem areas. (The need for periodic Phase 2 SDP refresher training should be significantly diminished with the use of the enhanced pre-solved SDP tables discussed in Section 3.1.1.3.)
- (2) NRR should implement SDP Task Action Plan Objective 3.6, as planned and scheduled to enhance the guidance for conducting Phase 3 analyses.
- (3) NRR should conduct a systematic assessment of training in the area of risk, with a particular focus on identifying and advancing the knowledge, skills, and abilities (KSAs) for implementing the SDP.

3.6 Significance Determination Process Benchmarking and the Need for Peer Review Criteria

The purpose of the Task Group's review in this area was to address the recommendations in the DPO Ad Hoc Panel report regarding the effectiveness of staff's SDP benchmarking effort. The DPO Panel recommended that: (1) criteria for benchmarking the SDP be subjected to peer review; (2) individuals conducting benchmarking should have statistical and PRA expertise; (3) sequences and cutsets within licensee and NRC plant-specific PRA models should be validated during the benchmarking process; (4) benchmarking should include some independent review of the licensee's PRA; (5) benchmarking should include a comparative analysis of competing tools using standard problems; and (6) benchmarking process should be continuous to capture plant and PRA model changes.

3.6.1 Observations

Following the first year of ROP implementation, the staff recognized that the quality of the Revision 0, Phase 2 SDP notebooks was not adequate to assess the significance of inspection findings. NRR initiated a project to enhance the quality of the notebooks by comparing the results of the notebooks with each licensee's plant-specific probabilistic risk assessments (PRAs) (benchmarking). The benchmarking effort, which began in the Spring 2001, is conducted for each plant during a several-day interface meeting between NRC staff and a licensee's PRA experts or representatives. As of November 2002, the staff had completed benchmarking of approximately 50 percent of the notebooks. The current plan is to complete benchmarking of the remaining notebooks by the end of the fiscal year (FY) 2003. The technical assistance budget allocated for the effort is approximately \$850K. However, there is currently no plan established to periodically update the notebooks beyond the current benchmarking effort.

The benchmarking site visits are conducted in accordance with the guidance provided in "Benchmarking Standard for SDP Phase Two Worksheets." The Task Group determined from

its interviews that this guidance was developed by NRR staff and peer-reviewed by the Regional SRAs prior to implementation.

A regional SRA, NRC Headquarters SRA/Risk Analyst, and a PRA expert from Brookhaven National Laboratory (BNL) typically conduct the benchmarking site visits. The benchmarking site visits have normally also included a PRA expert from Idaho National Engineering and Environmental Laboratory (INEEL), who is responsible for enhancing the agency's plant specific PRA models (SPAR). All individuals participating in the benchmarking trips have experience and/or advanced training in PRA and the statistical methods used in PRAs.

During the benchmarking site visits, the results of selected unavailable equipment cases are compared between the licensee's PRA and the plant-specific notebook, areas of difference are recognized, reasons for the differences are understood, and appropriate changes to the notebooks are made. When the results of the notebook and the licensee's PRA differ, sequences and cutsets are typically reviewed to determine the cause(s) of the differences. However, when the results of the licensee's PRA and the notebooks match, no additional evaluation is performed to determine if the dominant sequences are consistent. At this point, BNL prepares a benchmarking trip report which includes a comparison of the results from the notebook with that of the licensee's PRA. The report includes the benchmarked Revision 1 notebook and the enhancements that result from the benchmarking site visit.

The Task Group interviewed some of the NRC staff who have participated in the benchmarking visits. They indicated that it was not practical to thoroughly review the quality of the licensee's PRA during the benchmarking visits. They also indicated that, in general, the quality of the benchmarking visits was not strictly dependent on the quality of the licensee's PRA because the notebooks are simple, use generally conservative assumptions, use generic initiating event frequencies and data, and employ simplified event trees that are generally consistent for each major reactor design. In addition, the interviewees stated that the notebooks are developed based on "construction rules" that are consistently applied for all plants, however, the Task Group noted that the staff has not documented this information.

The benchmarking process includes a comparison analysis, for selected hypothesized equipment failures, between a plant-specific notebook, licensee's PRA, and, sometimes, the corresponding SPAR model. The comparison between the notebook and licensee's PRA is documented in the benchmarking report. Following the benchmarking site visit, INEEL has made any required changes to the SPAR model and subsequently issued the revised (Revision 3) SPAR model. The documentation of each Revision 3 SPAR model contains data that can be used for a comparison with the results of the corresponding notebook. However, routine comparison of the benchmarking data between the notebooks and SPAR models has not yet been implemented.

The Task Group determined that the ROP feedback forms can be used to initiate a change to correct errors in the current Phase 2 SDP Notebooks. However, there is currently no established agency plan or process to periodically update the Phase 2 SDP notebooks. Some of the interviewees suggested that the NRC should conduct a review or update of the notebooks at least every 5 years. This update would be led by a Regional SRA with additional support, as needed from a Headquarters Risk Analyst and/or contract PRA specialist. The objective of the review would be to identify and resolve any significant differences between the Phase 2 tool and the licensee's updated PRA. The periodic review should target 14 sites per

year beginning in 2008. In the intervening years, the Regions should use inspection insights from Inspection Procedures (IP) 71111.12, "Biennial Periodic Maintenance Effectiveness Evaluation Inspections," and IP 71111.17, "Permanent Plant Modification" to determine if any significant plant or procedure modifications have occurred that may warrant an earlier review and update of the SDP assessment tools. The ROP feedback system should be used to initiate any changes needed to correct errors or omissions in the Phase 2 tool.

The Task Group determined that the staff plans to complete the benchmarking effort to develop the Revision 3 SPAR models by the end of FY 2003. The staff also intends to upgrade and maintain the Revision 3 SPAR models, as needed, to support its use in risk-informed licensing reviews, event risk assessments for event response, the ASP Program, as well as for Phase 3 SDP evaluations. The Task Group determined that there are no near-term plans for a major revision to the SPAR models.

Nearly all the internal and external stakeholders who were interviewed about the benefit of benchmarking the notebooks indicated that the effort significantly improved the quality of the Phase 2 notebooks. There was a general consensus that the current Revision 0 Notebooks are generally of inadequate quality to assess the risk significance of inspection findings and that the benchmarked notebooks exhibited a significant improvement in the adequacy of risk estimates. This view was supported by a BNL report entitled, "Lessons Learned from Early Benchmarking of Inspection Notebooks," dated May 23, 2002. The report cited significant differences between hypothetical findings evaluated using the Revision 0 notebooks and licensee PRAs, highlighting the need for benchmarking of the notebooks. The benchmarking trip reports also indicated that benchmarking results in a substantial improvement in the quality of the Notebooks.

3.6.2 Conclusions

- (1) Benchmarking significantly contributes to improving the quality of the Phase 2 SDP notebooks and is also necessary for the development of the enhanced pre-solved tables described in Section 3.1.1.3. This conclusion was based on the common support for benchmarking from the stakeholders, the insights from the benchmarking trip reports and the BNL report that cited lessons learned from comparing the results of hypothetical findings evaluated using the Revision 0 notebooks and licensee PRAs.
- (2) The staff has not routinely compared the results of the benchmarked SPAR models to those of the benchmarked notebooks. Such a comparison would contribute to validating the adequacy of the notebooks and promote independence from the licensee's PRA .
- (3) Many of the recommendations contained in the DPO Ad Hoc Panel report have already been included in the current benchmarking process. Specifically, each of the staff who conducted the SDP benchmarking was qualified and the benchmarking guidance was peer reviewed by SRAs prior to implementation of the benchmarking effort. The benchmarking process uses generic information and applies construction rules to maintain consistency and to make the notebooks independent of licensee's PRA.
- (4) The "construction rules" for developing the notebooks have not been documented. A clear discussion of how the notebooks are created would enhance stakeholder knowledge and appreciation for the independence of the notebooks.

- (5) There is currently no established agency plan or process to periodically update the Phase 2 SDP notebooks. Because future licensee PRA changes and/or plant modifications can affect the adequacy of the notebooks, a plan to maintain the Phase 2 tool current is warranted.

3.6.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) NRR should complete the benchmarking of the remaining Phase 2 SDP notebooks to support the current Phase 2 SDP as well as the development of the enhanced pre-solved Phase 2 table recommended in Section 3.1.3(2).
- (2) NRR should develop a plan to periodically review and update the Phase 2 SDP assessment tools to address any licensee PRA changes and/or plant modifications.
- (3) NRR and RES should implement a process to compare the results of the benchmarked SPAR model with the results of the benchmarked Phase 2 notebooks.
- (4) NRR should document the “construction rules” for the Phase 2 SDP notebooks. Consideration should be given to including (or referencing) the construction rules in the proposed SDP Basis Document.

3.7 Use of Uncertainty in the Significance Determination Process

The purpose of the Task Group’s review in this area was to address the recommendations in the DPO Ad Hoc Panel report regarding the use of uncertainty analysis in the staff’s assessment of inspection findings. The Panel’s report included the observation that “it is difficult to ascribe meaning to the point estimates that are derived using the plant-specific notebooks. With order of magnitude approximations for the unavailability of systems and components, and the large uncertainties associated with the unreliability of human actions, questions regarding the efficacy of comparing delta core damage frequencies on the order of 1E-6 and 1E-5 naturally arise.” The Task Group’s recommendations in this area were influenced by the insights obtained from interviews of internal and external stakeholders.

3.7.1 Observations

It has become customary to discuss uncertainty in PRA analyses as originating in one of three ways according to RG 1.174:

- (1) parameter uncertainty - which recognizes that the value of such parameters as initiating event frequencies, component failure probabilities or failure rates, human error probabilities cannot be known with precision
- (2) model uncertainty - which recognizes that the relationship between the real plant and its mathematical representation is not known with certainty

- (3) completeness uncertainty - which recognizes that the model may not model every aspect, either because it may relate to an unknown issue, or because models do not exist for some aspects

PRA's are capable of addressing parameter uncertainty explicitly. Model uncertainties that underlie the development of the base PRA model are typically handled by making assumptions which become part of the definition of the PRA model. When there are alternate assumptions that are equally plausible, sensitivity analyses may be conducted, using the alternate assumptions, to assess the robustness of the results with respect to those assumptions. Completeness uncertainties cannot be addressed analytically since, by definition, they result from contributors that are missing from the model. The traditional engineering approaches adopted to deal with uncertainties that cannot be readily analyzed are the establishment of defense-in depth, and of adequate safety margins. For a more complete discussion of uncertainty analysis see RG 1.174.

There is no explicit treatment of uncertainty in the SDP. As described in SECY-99-007A, the Phase 2 SDP was designed to provide a generally conservative estimate of the risk significance of inspection findings. The output of the SDP would then be allocated to a response band, each a decade in width, with boundaries based on the values used in the acceptance guidelines of RG 1.174. The current SDP notebooks are constructed on the basis of accident sequences resulting from initiating events at full power from internal initiating events. Within that context, the use of the notebooks results in generally conservative risk estimates. However, this is an incomplete assessment of the risk significance since many of the potentially significant contributors to risk, including external events (i.e., initiating events resulting from internal fires, internal floods, seismic events, high winds, etc.) and events during low power and shutdown modes of operation are not addressed. The significance of these contributors is plant-specific, but internal fires and shutdown modes of operation have been found to be significant in many PRA studies. Seismic and high wind contributors may also be significant for plants in certain geographic regions. In reaching a conclusion about the risk significance of a finding, these contributions should be taken into account.

Many of the external and internal interviewees expressed concerns that the use of the SDP may convey a false impression of the precision of the PRA derived determination of the risk significance of a finding. Their concern centered on the use of point estimates and recognition that the estimates of CDF obtained from PRA's typically have a significant amount of uncertainty. Some of the concern was associated with the ROP itself in that it requires a comparison of point estimates to discrete response boundary. This is in contrast to the bands used in Management Directive 8.3, "NRC Incident Investigation Program," that overlap by an order of magnitude, allowing other deterministic factors to be considered in deciding the appropriate response. To some interviewees, this contributes to the belief that the use of the SDP is risk-based vs risk-informed. (See Section 3.1.2.)

Based on insights from the Task Group's interviews, one of the most significant sources of uncertainty involves the characterization of the impact of the inspection finding for input to the SDP. This typically involves making assumptions about the impact of the inspection finding on the reliability or unavailability of an SSC or its impact on the initiating event frequency. The view that this is a significant source of uncertainty is substantiated by the staff's experience in its assessment of many contentious issues, including the findings related to the Indian Point Unit 2 steam generator tube leak, the D.C. Cook service water system fouling, and the

degraded reactor vessel head at Davis Besse. For these findings, the complicating factors were independent of the risk assessment tool (i.e., Phase 2 or Phase 3 tools). It is the differences between the staff's engineering judgement and that of the licensees about the assumed impact of the degraded condition that drove the differences in the assessment of safety significance and, hence, generated significant uncertainty about the safety significance.

3.7.2 Conclusions

- (1) In light of the uncertainty arising from incompleteness and model uncertainty, parameter uncertainty is a relatively minor issue. However, there are some conclusions that can be drawn in relation to parameter uncertainty:
 - (a) Since the thresholds between response bands were based on the acceptance guidelines of RG 1.174, it is appropriate to compare mean values of Δ CDF with those thresholds. The DPO Ad Hoc Panel's concerns with the use of point estimates can be addressed only if the point estimates are close enough to mean values for the stated purpose of the SDP.
 - (b) There are several issues that determine whether the Phase 2 evaluation can be regarded as close enough to a mean value to be adequate for the stated purpose of the SDP. First, the values used in the notebooks for system and train unavailabilities and human error probabilities are point estimates that are intended to be somewhat conservative with respect to what would be found in a typical PRA. Typical PRA values would generally represent mean values or, in the case of system or train unavailabilities, point estimates based on using mean values for all the input parameters. The common cause failure (CCF) contributions are included conservatively - redundant systems are given a credit of 1E-3, while a single train gets 1E-2, equating to a (conservative) Beta-factor of 0.1. The principal concern with not performing a complete parametric uncertainty analysis is that the "state of knowledge" correlation, discussed in RG 1.174, cannot be taken into account. Taking this correlation into account can alter the mean overall CDF by up to a factor of 2 in some cases. In the context of the SDP, it is more of a concern if the Δ CDF resulting from the inspection finding is dominated by cutsets that involve several components whose failure probabilities are estimated based on the same parameter and that parameter value is highly uncertain. There are relatively few situations where this is expected to be significant.
 - (c) When inspection findings require a Phase 3 evaluation, more complex models (e.g., SPAR and/or insights from a licensee's PRA model) may be used. In rare cases, particularly if the contributors to Δ CDF are such that the state-of-knowledge correlation can have an impact on the evaluation of Δ CDF, parameter uncertainty can and should be propagated analytically to derive the real mean value.
- (2) It is important to consider the contribution from external events, and low power and shutdown events when making a final assessment of risk significance of a finding (completeness). However, simplified methods similar to the notebooks have not yet been developed. Guidance is needed on how the staff should engage in determining

the significance of a finding associated with the prevention or mitigation of accidents resulting from external events (see Section 3.4.2(4)), or during low power and shutdown. NRR should continue its initiatives to develop better tools and guidance in the area of low power and shutdown as outlined in SDP Improvement Task Action Plan (Task 3, Objectives 3.3e.).

- (3) Model uncertainties associated with the characterization of the impact of the inspection finding on the function of an SSC represent the greatest source of uncertainty. This was particularly clear in the evaluation of several findings that involved a degraded SSC. Relating this degradation to component reliability or the frequency of a failure of a pressure or fission-product boundary can represent a considerable challenge to the staff and the uncertainty is strongly tied to the analytical assumptions, which can vary significantly. When there is substantial disagreement between analysts, the 'mean' value of the assessments has no real significance, and should not be used to determine the color associated with the finding.
- (4) The SDP does not provide for explicit consideration of traditional engineering analysis (deterministic) inputs. This is in contrast to RG 1.174 which uses considerations of defense-in-depth and safety margins to assess whether license amendments should be granted. In that context, defense-in-depth and safety margins are seen as mechanisms to account for incompleteness.

3.7.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) NRR should develop guidance to allow the staff to recognize situations where the "state of knowledge" correlation, which is described in RG 1.174, might warrant a Phase 3 analysis.
- (2) NRR should modify IMC 0609 guidance to explicitly indicate that traditional engineering analysis considerations (e.g., reduction of safety margin, or significant loss of defense-in-depth) should be used to determine an appropriate color to associate with findings where the uncertainty in the risk evaluation arising from the characterization of the impact of the inspection finding is large enough that the color is indeterminate on the basis of the risk analysis. This guidance should be such that it promotes consistency in the staff's use of such analyses and should only be applied to those findings where the uncertainty is significant (e.g., when alternate assumptions yield results which vary over more than two orders of magnitude).

3.8 Evaluation of How Other Inputs are Factored Into the Significance Determination Process

The purpose of the Task Group's review in this area was to respond the Charter directive that the Task Group evaluate whether the ROP (SDP) appropriately allows for consideration of other inputs independent of a best-estimate risk assessment. The Task Group's recommendations in this area were influenced by its review of IMC 0609 and the insights obtained from interviews of internal and external stakeholders.

3.8.1 Observations

The Revised Oversight Program focuses NRC resources in areas where there are existing safety significant performance problems. As a result, the process is largely indicative, in that it directs resources based on a licensee's past performance. However, the ROP also includes a predictive performance element to assess licensee performance in "other" (cross-cutting) areas, which are recognized in the ROP as human performance, problem identification and resolution, and safety conscious work environment.

The ROP was developed based on the presumption that deficiencies in cross-cutting areas would be revealed by safety significant findings and PIs. Accordingly, there must be a significant level of agency concern to believe there is a substantive cross-cutting issue at the plant. Substantive cross-cutting issues are identified in the NRC's Mid-Cycle or Annual Assessment letters when there is evidence of a significant number of current inspection findings with common causal factors, in the area of human performance, problem identification and resolution (PI&R), or safety conscious work environment. There is no additional NRC engagement (i.e. inspections, meetings, correspondence, etc.) with licensees beyond the baseline program as a result of identifying a substantive cross-cutting issue. The licensee's progress in resolving the cross-cutting issue is documented in subsequent assessment letters.

Most of the NRC managers interviewed by the Task Group indicated that they believed that the ROP/SDP would be enhanced by consideration of "other inputs" in the significance determination process. However, nearly all managers cited challenges that would be posed by any effort to include "other inputs" in the ROP in an objective and predictable manner. The "other inputs" that could be considered for including varied considerably and included such areas as the timeliness of issue identification, the adequacy of corrective actions, the effectiveness of extent of condition reviews, programmatic breakdowns, organizational effectiveness, and design control.

Based on insights obtained during the interviews, the Task Group developed several approaches for incorporating "other inputs" into the ROP/SDP. A brief description of the approaches are as follows:

- (1) The Significance and Enforcement Review Panel (SERP) guidance could be modified to allow Senior NRC Managers to modify the significance determination (color) of inspection findings based on "other inputs." This process would be similar to that used in the enforcement process for escalating or mitigating civil penalties. The "other inputs" mitigators and escalators could include items such as: (1) who identifies the issue; (2) timeliness of problem identification; (3) completeness and timeliness of corrective actions; and (4) extent of condition. Guidelines and/or standards to facilitate an objective and predictable consideration of "other inputs" would also need to be developed.
- (2) The ROP could be modified such that "other inputs" could be considered as part of the ROP annual assessment process. The guidance in IMC 0305 could be modified to redirect additional NRC resources into areas where substantive "other inputs" have resulted in degraded performance.

- (3) The existing Action Matrix deviation process could be used to include "other inputs" when the ROP Action Matrix does not provide an appropriate agency response, as determined by NRC management. The Task Group noted that guidance for action matrix deviations is provided in IMC 0305, "Operating Reactor Assessment Program," Section 06.06f.

Most licensee interviewees were less receptive to including other inputs in the ROP. Some representatives indicated that this would represent a return to the Systematic Assessment of License Performance (SALP) system. Some licensee managers also observed that the Institute of Nuclear Power Operations (INPO) has a program to assess "soft issues" such as organizational effectiveness and human performance. They indicated that either the NRC could allow INPO to monitor this area or the NRC could assess the information collected by INPO.

The Task Group asked interviewees to provide examples of where the current ROP provisions regarding the use of "other inputs" may have had an adverse impact on the agency's oversight responsibilities. There were no examples cited where the current provisions for the use of "other inputs" in the ROP had resulted in the agency not allocating resources for a licensee performance problem in a timely manner. Additionally, the Task Group noted that, as discussed in SECY-02-0058, "Results of the Industry Trends Program for Operating Power Reactors and Status of Ongoing Development," dated April 1, 2002, there have been no statistically significant adverse industry trends in safety performance through FY 2001.

NRC Inspection Manual Chapter 0305, Section 06.06.h, "Operating Reactor Assessment Program" provides guidance on how substantive cross-cutting issues are addressed in the ROP. This guidance requires multiple findings documented in the assessment period with causal factors that support the cross-cutting issue. The basis for the substantive cross-cutting issue is then documented in the mid-cycle or annual assessment letter. The guidance does not recommend redirecting NRC resources in response to the identification of a substantive cross-cutting issue nor does it address the expected licensee response. However, it does allow the staff to consider increasing the frequency of the PI&R inspection if the plant enters the degraded cornerstone column of the action matrix. Many NRC Regional managers indicated that the current guidance for defining a substantive cross-cutting issue appears to be applied inconsistently across the Regions.

3.8.2 Conclusions

- (1) There were no examples where the current provisions for treating "other inputs" in the ROP had limited the staff's ability to focus resources in appropriate areas. In addition, the ROP currently allows for deviations from the action matrix when deemed appropriate by senior NRC management; the guidance does not preclude use of "other inputs" as factors in the justification for the deviation.
- (2) Consideration of "other inputs" in the SDP would require the development of guidelines and/or standards to support the staff use of them in objective and predictable manner. Although feasible, the cost and time to develop such guidelines and/or standards would likely be substantial.

- (3) The existing guidance in IMC 0305 regarding deviations from the Action Matrix can be employed, where appropriate, to consider “other inputs” in determining agency response.
- (4) The guidance in IMC 0305 for the identification of significant cross-cutting issues has not been consistently implemented by the Regions. The current guidance is vague on the expected NRC and licensee response to a substantive cross-cutting issue.

3.8.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) The NRC should not modify the SDP to include consideration of “other inputs.” This decision should be re-evaluated as part of the annual ROP self assessment to determine if licensee performance indicates that different treatment of “other inputs” in the ROP is warranted.
- (2) NRR should enhance its oversight of the implementation of the guidance in IMC 0305, Section 06.06.h, for the identification of substantive cross cutting issues to promote consistency application by the Regions.
- (3) NRR should revise the ROP guidance to include consideration of a response to the identification of a substantive cross-cutting issue (only when there is at least one White PI or finding). This response could include a redirection of inspection resources, management meetings, and/or a docketed licensee response describing actions planned or taken to address the cross-cutting issue. This guidance should also include a description of how the NRC will close a substantive cross-cutting issue.
- (4) NRR should supplement the guidance in IMC 0305, Section 06.06.f, with additional guidance that lists the type of information that should be included in a Region’s request to deviate from the Action Matrix (e.g., synopsis of the findings affecting the licensee’s performance; the actions (column) stipulated by the Action Matrix; the Region’s rationale or considerations for taking action different from that stipulated in the Action Matrix, etc.)

3.9 Significance Determination Process Timeliness

The purpose of the Task Group’s review in this area was to respond to recommendations in the OIG audit report (OIG-02-A-15) regarding the timeliness of SDP determinations. The OIG report indicated that SDP evaluations that result in greater-than-green findings are not processed in a timely manner and that the current ROP metrics do not capture the total time of inspection finding evaluations. The Task Group’s recommendations in this area were influenced by its review of IMC 0609 and the insights obtained from interviews of internal and external stakeholders.

3.9.1 Observations

IMC 0609, Exhibit 5 contains “Suggested Timeliness Criteria for SDP Inspection Findings.” The criteria requires the completion of SDP characterizations within 120 days of the first inspection

exit meeting or within 90 days of the issuance of the inspection report. A Staff Requirements Memorandum (SRM) dated August 2, 2001, directs the staff to meet the timeliness goals stated in IMC 0609 for 100% of the inspection findings.

The official data base for tracking the timeliness of the SDP is the Enforcement Action Tracking System (EATS). This data base, which is maintained by staff in the Office of Enforcement OE, provides a comprehensive list of the timeliness milestones for those inspection findings that are potentially greater-than-green, (e.g., inspection exit date, SERP date, Choice Letter issuance date, regulatory conference date, etc.). In addition, the Inspection Programs Branch (IIPB) in NRR, tracks the timeliness of inspection findings from the issuance of the inspection report until issuance of the final significance determination letter. The Task Group determined (based on a review of the NRR tracking system, the data contained in the Reactor Program System, the monthly OE input to the Congressional Report and the EATS data) that the NRC inspection program yielded approximately 600 to 800 inspection findings per year. Of these 600 to 800 findings, approximately 20 to 25 across all cornerstones were preliminarily characterized as greater-than-green, and of these, about 10 to 14 did not meet the timeliness goals. Thus, the data indicates that less than about three percent of the total number of inspection findings did not meet the ROP timeliness goals.

Almost half of the findings that have not met the ROP timeliness goals, have involved findings of potentially higher risk significance. In addition, some of the findings that did not meet the timeliness goals involved fire protection and shutdown conditions, where there are recognized inadequacies in the staff's risk evaluation guidance (see Section 3.7). Most NRC interviewees indicated that the factors that have most significantly impacted SDP timeliness, aside from the aforementioned areas where guidance is lacking, include the development of human reliability assumptions and engineering assumptions regarding the impact of a degraded condition on the ability of an SSC to satisfy its safety function. Differences among NRC staff and between the staff and licensees regarding such assumptions has significantly influenced timeliness.

Both internal and external stakeholders believe that SDP timeliness is a major factor in promoting public confidence in the ROP. External stakeholders indicated that public confidence is particularly affected when findings that appear to have a greater impact on risk are untimely. In addition, several external stakeholders indicated that they believe that NRC management should devote more attention to assuring the timeliness of SDP evaluations of greater-than-green findings. Both internal and external stakeholders stated that they favor the use of a "greater-than-green" characterization for preliminary safety significance determination (Choice) letters. Many of the interviewees believe that this characterization will alleviate the staff's perceived need for precision and allow for greater use of reasonable assumptions in the preliminary safety significance determinations. They indicated that the timeliness of the SDP, including the regulatory conferences and the staff's decisions on the final significance determinations, should improve with the issuance of more timely Choice letters.

Based on feedback from NRC interviewees, many were not aware of the current ROP timeliness goals and most assumed that the goals were the same as the previous enforcement action goals. The OE operating plan measures enforcement timeliness for non-investigation violations (i.e., cases that do not involve an OI investigation) from the date of the exit meeting. The OE operating plan metric requires 100% completion within 180 days, with an average completion time of 120 days. Many NRC interviewee's also indicated that the timeliness of the SDP has often been hindered by protracted deliberations with licensees who routinely challenge

the staff on potentially greater-than-green findings. As discussed in Section 3.2.1, this was an unanticipated result from the NRC's use of risk assessment tools to evaluate inspection findings.

Interviews with several licensee stakeholders indicated that the primary factors that cause licensees to frequently dispute potential greater-than-green findings are the negative reaction within the financial community, the potential adverse effect on bond ratings, and public criticism of licensee performance. While they acknowledged that these factors were beyond the agency's control, the licensee interviewees noted other contributing factors for why licensee's challenge potentially greater-than-green findings, including the potential for incomplete characterization of the significance of the findings in NRC inspection reports, letters, and press releases.

With respect to NRC press releases, most NRC interviewees observed that the policy for issuing a press release for each White finding was misaligned with the significance of many such findings. Some recommended that the issuance of press release be linked to a licensee's performance as indicated by the Action Matrix rather than the licensee's performance reflected in a single White finding. Recently, the Office of Public Affairs (OPA) revised its policy regarding issuance of press releases for White findings. The revised policy requires the issuance of a press release for a single White finding only for those plants that the Director OPA has determined to have a significant amount of public interest. In addition, a press release will be issued for a plant that has two White findings, even if the findings are in different cornerstones. OPA plans to continue its practice of issuing a press release for all public regulatory conferences and regulatory performance meetings.

The Task Group determined that NRR recently adopted an Operating Plan metric which allows for a targeted improvement in SDP timeliness. In FY03, the metric requires 75% of greater-than-green findings to meet the ROP timeliness goals. The metric will be adjusted upwards by 5% until a 90% target is reached in FY06.

3.9.2 Conclusions

- (1) The SDP was designed to generate a reasonably accurate estimate of the risk significance of an inspection finding to facilitate timely agency decisions regarding the allocation of resources. As a result, the Task Group determined that the ROP timeliness goal of completing the SDP within 120 days of the first inspection exit meeting and within 90 days of the issuance of the inspection report is reasonable. However, the Task Group recognized that some findings involve complex engineering issues and may require additional time to adequately assess the safety significance. The NRR Operating Plan metric for greater-than-green findings should provide an appropriate management tool to address the timeliness challenge for the relatively few findings expected to involve such safety significance.
- (2) Significant progress has been made in tracking the timeliness of the issues that are greater than Green and accountability within the responsible offices has been established by identifying responsible managers in the IIPB SDP timeliness matrix. In addition, although the number of untimely SDP evaluations is relatively small, additional management attention is warranted to further improve SDP timeliness. Many of the NRC interviewees indicated that improved management decisiveness in determining the

engineering assumptions used in risk evaluations would contribute to the timeliness of the SDP. The oversight of findings through the SDP, beginning with the initial identification of issues of potential greater-than-green safety significance, through the exit meeting, the SERP, the initial documentation of the finding, and the follow-on public deliberations with the licensees warrants closer management attention to promote timeliness.

- (3) The timeliness goals for characterizing inspection findings in the SDP process were not well understood by all members of the staff. The Task Group also noted that it was likely that licensee representatives were similarly unclear on the agency's SDP timeliness goals.
- (4) The issuance of a press release for a White finding may contribute to the licensees' tendency to dispute preliminary White findings. A White finding, which is indicative of a licensee performance deficiency, represents an unintended (low to moderate) increase in risk and results in actions specified by the Regulatory Response Column of the Action Matrix. However, because a plant in the Regulatory Response Column has still "fully met the related cornerstone objectives," the issuance of a press release for a single White finding may, in many cases, result in unwarranted emphasis on a particular finding. The Task Group concluded that the recent revision to the OPA policy, which requires issuance of a press release for a White findings at plants with significant public interest and to announce regulatory conferences and regulatory performance meetings, was an improvement.

3.9.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) NRR should reinforce the current SDP timeliness goals through management interactions, identifying responsible managers, and establishing accountability for the resolution of overdue significance determinations. The NRR SDP timeliness metrics should be incorporated into the Regional Operating Plans.
- (2) NRR should communicate the agency's SDP timeliness goals to licensees (e.g., include text in Choice Letters to inform licensees of NRC's plan to reach a final significance determination within 90 days; discuss the timeliness goal during regulatory conferences; discuss SDP timeliness, including the timeliness goal during the annual Regulatory Information Conference, etc.)
- (3) NRR should rectify the difference between the metrics identified in the NRR Operating Plan (i.e., 75% timeliness goal in FY03 increasing to 90% timeliness goal by FY06) with the goals stated in IMC 0609 and reiterated by the August 2, 2001, SRM (i.e., 100% timeliness goal).
- (4) NRR should change the guidance in IMC 0609 to allow the Regions the option to use a "preliminary greater-than-very low safety significance" characterization for preliminary safety significance determination (Choice) letters when there is sufficient uncertainty regarding the preliminary risk estimate.

- (5) OPA should further modify its policy for issuing press releases for ROP findings to link the issuance of press release to a finding(s) that results in a Degraded Cornerstone. This modification will better align the emphasis that results from the issuance of a press release with the "moderate degradation in safety performance" associated with a Degraded Cornerstone (i.e., two White inputs (findings and/or Performance Indicators), one Yellow input, or three White inputs in the same Strategic Performance Area).
- (6) NRR should modify IMC 0305 to reference the OPA policy for issuing press releases for ROP inspection findings.

3.10 Reactor Oversight Process Web Site Improvements

The purpose of the Task Group's review in this area was to respond to OIG recommendations regarding the ROP web site. To respond to this issue, the Task Group interviewed the NRR staff and managers who are responsible for the content and maintenance of the web site.

3.10.1 Observations

Section D, "Improve the Web Site to More Fully Inform the Public," of the OIG Audit Report, (OIG-02-A-15) provided the following recommendations to enhance the ROP web site:

- (1) (Recommendation #7) Revise the web page to provide a link from the findings summary web pages to the documents that support any changes from preliminary inspection report significance determinations.
- (2) (Recommendation #8) Expand the web page to provide complete access to inspection report results, not just those that identify operational deficiencies.
- (3) (Recommendation #9) Expand the web page to display all significant findings colors in a cornerstone.
- (4) (Recommendation #10) Revise the web site to fully describe licensee corrective action related to each finding.

The Task Group reviewed a draft response to the OIG report and discussed the responses with cognizant NRR staff. The draft response to the OIG audit report findings was completed by NRR. The responses to the four OIG recommendations provided in the draft NRR response are as follows:

- (1) (Recommendation #7) The NRR draft response letter agrees with this finding and indicates that the web page would be revised by March 2003.
- (2) (Recommendation #8) The web page had been revised to incorporate this comment. The current summary of findings provides a link to the inspection report that documented the finding. The web site was accessed and it was validated by the Task Group that this action is complete.
- (3) (Recommendation #9) The plant findings summary web page does not indicate the number of White findings (if any) that are present in a cornerstone with a Yellow finding.

A cornerstone with a only Yellow findings or White findings is correctly displayed on the summary page. In the case where a Yellow and White findings exist in the same cornerstone, only the Yellow (most significant) finding is displayed. A web site user could easily determine the number of White findings in the cornerstone with a Yellow finding by clicking into a subsequent web page that provides a summary of all findings in the cornerstone. The Action Matrix column designation for a single Yellow finding or a Yellow finding with multiple White findings is identical. Therefore, the current display would correctly indicate that the cornerstone was degraded. There will be very few instances where there will be simultaneous White and Yellow findings in the same cornerstone (currently there are none). The Task Group determined that although it would be feasible to modify the web site to accommodate this recommendation, it would also be complex and costly.

- (4) (Recommendation #10) The IMC 0612 does not provide guidance to describe corrective actions in the summary of findings entry. The Task Group verified that IMC 0612, Section 05.30, "Summary of Findings" does not mention including corrective actions taken by the licensee for all items included in the summary of findings. The report example, Appendix D of IMC 0612 provides an example of a summary of finding entry where the corrective actions are not mentioned. The NRR staff responsible for IMC 0612 indicated that green findings are by definition in the licensee's response band and licensee's are only required to issue a corrective action report for green findings. The corrective actions taken for greater-than-green findings are thoroughly discussed in the supplemental inspection report. Therefore, he indicated that it would not be beneficial to include a detailed discussion of corrective actions in the summary of findings.

3.10.2 Conclusions

- (1) The proposed change for OIG Report recommendation #7, to improve the links for all relevant documents for greater-than-green findings, is appropriate. The proposed completion date for implementing this change is reasonable.
- (2) The OIG Report recommendation #8, to link the summary of findings to the inspection report, had been implemented.
- (3) The OIG Report recommendation #9 would not substantially improve the quality of the information provided on the ROP web page and that there were currently no plans to implement the recommendation. Users are provided ready access to all findings in a cornerstone by hyper-linking to the next web page, and the difficulty and costs of implementing this change appears to exceed the benefit.
- (4) The OIG Report recommendation #10, to revise IMC 0612 to include a brief summary of corrective actions in the inspection report summary of findings, is reasonable. A brief description of the corrective actions taken by the licensee to restore compliance with NRC regulations should be included in the summary of findings.

3.10.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) NRR should change IMC 0612 to require a brief description in the inspection report summary of findings of corrective actions taken by the licensee to restore compliance with NRC regulations, where applicable. (OIG Report recommendation #10)
- (2) The EDO should inform the OIG that the ROP web site will not be revised as described in recommendation #9. Users currently have ready access to all findings in a cornerstone by hyper-linking to the next web page and the OIGs' recommendation would not substantially improve the quality of the information available to users. The difficulty and costs of implementing this change appears to exceed the benefit. (OIG Report recommendation #9)

3.11 Evaluation of Other Reactor Oversight Process and Significance Determination Process Issues

As allowed by the Charter, the Task Group reviewed several other topics related to the SDP to determine if any process changes were warranted. Based on insights from interviews with internal and external stakeholders, the Task Group identified the following three topics for separate discussion: ASP Program and SDP; Limitations on the use of PRA methods in the SDP; and Performance of ROP Action Matrix.

3.11.1 Accident Sequence Precursor Program and Significance Determination Process

In a technical assistance user-need memorandum dated January 31, 2002, (NRR-2002-004), NRR requested RES to validate the output of the SDP for all greater-than-green findings by comparing the significance determinations with preliminary ASP results. Based on the feedback from of the RES validation reviews, many NRC interviewees expressed concern about the impact that potential differences between an ASP and SDP risk assessment might have on public confidence and questioned the efficiency and effectiveness of maintaining both processes. Although the Task Group did not perform an extensive review of this area, the following insights were gained from a review of ASP and SDP basis documents and interviews with NRC staff and managers.

3.11.1.1 Observations

The ASP program provides a measure of how the agency meets two of its Strategic Plan performance goals in the Reactor Safety Arena. These are: (1) no more than one event per year identified as a significant accident precursor (i.e., Conditional Core Damage Probability (CCDP) or importance $\geq 1E-3$) and (2) no statistically significant adverse industry trends in safety performance (the Industry Trends Program is discussed in SECY 01-0111, "Development of an Industry Trends Program for Operating Power Reactors." ASP results are used as input to an annual report to Congress on whether those goals are met. In this regard, the ASP program is not constrained by the SDP timeliness goals, although final analyses are usually completed within two years of an identified plant condition. This allows the ASP risk analysts additional time to confirm the assumptions and inputs used in their risk evaluations. The ASP evaluates all potentially risk significant conditions and events that existed at the time of the identified plant condition, which differs from the SDP which only evaluates inspection issues that result from the licensee's failure to meet a requirement or standard that have an associated licensee performance deficiency (i.e., findings).

The SDP employs three phases: an initial screening - Phase 1; an estimation of risk using a simplified PRA tool - Phase 2; and an estimation of risk using more sophisticated PRA tools - Phase 3. The SDP was intended for use by NRC inspectors, risk analysts and managers to assess the safety significance of inspection findings and facilitate a timely decision regarding the allocation of agency resources. Although the primary risk assessment tool that is used by SRAs to perform the Phase 3 SDP, the SPAR model, is the same tool employed by risk analysts for ASP analyses, the SDP was not intended to provide a precise measurement of the risk of an inspection finding.

Some of the NRC interviewees indicated that it was inappropriate for the ASP program and SDP to reach different risk significance conclusions for the same issue. They believed that public confidence would be eroded if NRC were to issue an ASP and an SDP significance determination (i.e., Δ CDF) with conflicting results. In addition, some of the interviewees stated that they believe that the purposes of ASP can be assumed by the SDP and that the ASP program should be suspended or subsumed by the SDP. They considered the use of both programs to conduct similar independent risk assessment of the same issue was not an efficient use of agency resources.

However, other NRC interviewees stated that the ASP program and the SDP serve different purposes and should continue to be implemented as independent programs. They indicated that the verification of SDP analyses using ASP provides a positive benefit. Given the fact that SDP was not designed nor intended to provide a precise risk determination, the role of the ASP review was to provide an ongoing confirmation of the general assumption that SDP would provide for reasonably accurate assessments of the risk of inspection findings.

Some interviewees suggested that better integration of RES staff responsible for ASP into the development of preliminary significance determinations could enhance both the SDP evaluations and the subsequent ASP analyses. However, given the current construct of the ASP program, which includes multiple peer reviews by the licensees and NRC technical staff, it is not practical to complete ASP analysis within the timeliness goals of the SDP.

The Task Group determined that NRR had identified the need to improve the consistency between ASP and SDP approaches, Objective 6.1 of the SDP Improvement Plan Initiative. This task involves the development of guidance to clearly delineate the role of RES in the SDP and minimize the potential for unexpected or unreasonable differences in the results of the SDP and ASP processes. The action is scheduled for completion by April 2003.

3.11.1.2 Conclusions

- (1) The concern for the potential negative impact on public confidence from the issuance of different NRC risk characterizations for the same issue has merit. Program requirements and/or an RES/NRR office protocol should ensure reasonable consistency in the output of the programs to promote public confidence. The Task Group noted that RES, NRR and Regional management recognize the potential impact of different ASP/SDP risk assessments, as evidenced by the significant resources that were expended to develop a shared understanding of several recent preliminary ASP and SDP analyses.

- (2) The schedule to complete ASP evaluations currently precludes using ASP insights in the SDP; however, many NRC interviewees believe that there are efficiencies that can be gained through a better coordination and/or integration of these two programs.
- (3) The Task Group noted significant differences among many staff in their understanding of the purpose and uses of the ASP. Efforts to enhance the staff's knowledge of the ASP would contribute to better coordination and integration of the ASP and the SDP.

3.11.1.3 Recommendations

- (1) To address the issues discussed in this section of the report, the Task Group made the following recommendation: NRR should broaden the NRR SDP Task Action Plan Objective 6.1 to initiate a cooperative effort between NRR and RES to explore efficiency and quality enhancements that would result in better coordination and/or integration of these two programs.
- (2) NRR and RES should identify avenues to enhance the staff's knowledge of the ASP program, including adding a module to the P-111 course regarding the ASP program.

3.11.2 Objectivity of Probabilistic Risk Assessments

During the Task Group's interviews, some stakeholders expressed a concern that the objectivity introduced by the use of PRA results had been overemphasized. Others expressed a related concern about the quality of the PRA models used to determine the final risk significance. A brief discussion of the staff's insights in these areas follows.

3.11.2.1 Observations

Objectivity of Assessment of Safety Significance - One of the three objectives of the ROP is to improve the objectivity of the reactor oversight process so that subjective decisions and judgement are not central to the process. Based on insights from internal and external stakeholders, the staff has made progress in achieving this important objective. An apparent effect of using the SDP to advance this objective, however, has been the lack of recognition, and perhaps undervaluation, of the importance of informed engineering judgement by the staff. The staff routinely uses engineering judgement in the identification of licensee performance deficiencies, which allows inspection issues that result from the licensee's failure to meet a requirement or standard to be placed in context (i.e., a finding). Engineering judgement is also routinely used by the staff in formulating its assumptions about whether or not a degraded SSC would have performed its safety function given a specific demand. As noted in Section 3.7.1, such assumptions are often the primary determinants of the safety significance of a finding and, hence, the key to the uncertainty of the underlying risk estimate. While there is often a subjective element in the determination of risk significance, the use of the PRA provides a context for that subjectivity.

Quality of Licensee PRAs - Licensee PRAs vary considerably in both quality and scope. This is evidenced, in part, by significant differences in whether and how licensee's account for external events, low power and shutdown modes of operation.

3.11.2.2 Conclusions

- (1) The staff routinely uses engineering judgement in the SDP. The Task Group noted that this practice is consistent with the NRC's PRA Policy Statement which encourages the use of PRA technology to *complement* the staff's deterministic decisions. It is noteworthy that many of the internal and external stakeholders interviewed by the Task Group, indicated that the perceived problems with the SDP, including timeliness, can be attributed more to the challenges associated with making informed engineering decisions (or assumptions), than with limitations of PRA.
- (2) In light of the differences in quality and scope of licensee PRAs, it is inadvisable for the staff to use the results from the licensees' PRA as the sole basis for SDP determinations. Additional guidance is needed for the staff to determine whether the results of a licensee's risk analysis of a finding is of sufficient quality to use as input to the staff's final significance determination.

3.11.2.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendation:

- (1) NRR should develop guidance to allow the staff to determine whether the results of a licensee's risk analysis of a finding is of sufficient quality to use as input to the staff's final significance determination. This guidance should focus on the use of DG-1122, which addresses the Nuclear Energy Institute's (NEI) peer review process (NEI-00-02), and the proposed update, that includes a licensee self-assessment process to confirm conformance with ASME RA-S-2002, "Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications," dated April 5, 2002.

3.11.3 Insights on Performance of ROP Action Matrix

During the Task Group's interviews, NRC staff and licensee representatives expressed concerns that the use of two White findings in a cornerstone as a criterion for entry into a Degraded Cornerstone was overly conservative.

3.11.3.1 Observations

Most internal and external interviewees agreed that the ROP Action Matrix has functioned as designed. However, many NRC interviewees suggested that the criteria in IMC 0305 regarding the number of White inspection findings that result in a "Degraded Cornerstone" should be revisited. Currently, two White inspection findings in a given cornerstone are treated in the Action Matrix the same as a Yellow inspection finding. Some interviewees observed that two White inspection findings could each be near the lower end of the White performance band (i.e., $1.0E-6$ per reactor year), and in such cases, the cumulative impact of those two findings could result in a CDF change that is less than $1.0E-5$ per reactor year, which is in the White performance band. Some licensee representatives indicated that use of this criterion had resulted in unnecessary burden due to the financial implications and public response to the Degraded Cornerstone.

Some interviewees suggested that NRC should consider using three (or more) White inputs as the criteria for determining when a Degraded Cornerstone exists. They also indicated that the risk associated with a White input in the EP cornerstone is not commensurate with the risk in the IE, MS or BI cornerstones, however, such inputs are treated similarly in the Action Matrix and could result in a Degraded Cornerstone. Because the combination of such findings often results in more NRC action than is warranted by the licensee's performance, the interviewees suggested that the NRC review the appropriateness of this criteria.

Despite these concerns, internal and external interviewees indicated that the NRC's response at those plants that have entered the Degraded Cornerstone column of the Action Matrix was, in most cases, merited by the licensee's performance.

3.11.3.2 Conclusions

- (1) Overall, the Action Matrix has fulfilled its purpose in providing an objective, scrutable and predictable framework for NRC actions in response to licensee performance problems. The oversight process also provides sufficient flexibility in use of the Action Matrix for NRC managers to use discretion in decisions concerning the scope and timing of the agency's response to licensee performance problems.
- (2) The staff used reasoned judgement to support its decision to use two White inputs in the same cornerstone as part of the criteria for defining a "Degraded Cornerstone." Although a detailed analysis or evaluation was not developed to support this decision, the Task Group did not identify data or obtain information from its interviews that suggested that the criterion was inappropriate.

3.11.3.3 Recommendations

To address the issues discussed in this section of the report, the Task Group made the following recommendations:

- (1) NRR should review the Action Matrix annually to assess its impact on stakeholders and the appropriateness of the criteria for determining the combination of inputs that dictate a licensee's placement in the Action Matrix. The results of this assessment should be provided in a report to management with recommendations for adjustments, as necessary.

APPENDIX A - CONSOLIDATED LIST OF RECOMMENDATIONS

Recommendation Number	Recommendation
3.1.3(1)	The NRC should retain the Phase 2 process as a screening method for inspectors to screen findings of very low safety significance (Green) and identify potentially greater-than-green findings for further review by SRAs.
3.1.3(2)	The NRC should complete the benchmarking of the remaining Phase 2 SDP notebooks and develop plant-specific Enhanced Pre-Solved Phase 2 SDP Tables (Option 3) as the primary tool for inspectors to perform Phase 2 evaluations. However, the notebooks should be retained for optional use by the NRC staff to gain additional risk insights.
3.2.3(1)	NRR should issue the proposed SDP basis document, including the current performance expectations for the Phase 2 notebooks.
3.2.3(2)	NRR should engage the Regions to confirm their understanding and implementation of the expectations regarding use of the SDP provided in the August 9, 2002, memorandum from the Director, NRR to the Regional Administrators.
3.2.3(3)	NRR should reevaluate the performance expectation of the SDP tools after the remaining notebooks have been benchmarked and modify program guidance, as appropriate, to reflect any revision to the expectation.
3.5.3(1)	NRR should encourage the Regions to hold refresher training on the Phase 2 SDP at least annually. This training should be led by a Regional SRA and can also be used to convey best practices and give feedback on common questions and problem areas. (The need for periodic Phase 2 SDP refresher training should be significantly diminished with the use of the enhanced pre-solved SDP tables discussed in Section 3.1.1.3.)
3.5.3(2)	NRR should implement SDP Task Action Plan Objective 3.6, as planned and scheduled to enhance the guidance for conducting Phase 3 analyses.
3.5.3(3)	NRR should conduct a systematic assessment of training in the area of risk, with a particular focus on identifying and advancing the knowledge, skills, and abilities (KSAs) for implementing the SDP.
3.6.3(1)	NRR should complete the benchmarking of the remaining Phase 2 SDP notebooks to support the current Phase 2 SDP as well as the development of the enhanced pre-solved Phase 2 table recommended in Section 3.1.3(2).

3.6.3(2)	NRR should develop a plan to periodically review and update the Phase 2 SDP assessment tools to address any licensee PRA changes and/or plant modifications.
3.6.3(3)	NRR and RES should implement a process to compare the results of the benchmarked SPAR model with the results of the benchmarked Phase 2 notebooks.
3.6.3(4)	NRR should document the “construction rules” for the Phase 2 SDP notebooks. Consideration should be given to including (or referencing) the construction rules in the proposed SDP Basis Document.
3.7.3(1)	NRR should develop guidance to allow the staff to recognize situations where the “state of knowledge” correlation, which is described in RG 1.174, might warrant a Phase 3 analysis.
3.7.3(2)	NRR should modify IMC 0609 guidance to explicitly indicate that traditional engineering analysis considerations (e.g., reduction of safety margin, or significant loss of defense-in-depth) should be used to determine an appropriate color to associate with findings where the uncertainty in the risk evaluation arising from the characterization of the impact of the inspection finding is large enough that the color is indeterminate on the basis of the risk analysis. This guidance should be such that it promotes consistency in the staff’s use of such analyses and should only be applied to those findings where the uncertainty is significant (i.e., when alternate assumptions yield results which vary over more than two orders of magnitude).
3.8.3(1)	The NRC should not modify the SDP to include consideration of “other inputs.” This decision should be re-evaluated as part of the annual ROP self assessment to determine if licensee performance indicates that different treatment of “other inputs” in the ROP is warranted.
3.8.3(2)	NRR should enhance its oversight of the implementation of the guidance in IMC 0305, Section 06.06.h to promote consistent application by the Regions. The guidance in IMC 0305, Section 06.06.h should be enhanced to provide a more predictable standard/criteria for determining what constitutes a substantive cross cutting issue. Additional oversight in this area is needed to ensure consistency across the regional offices.

3.8.3(3)	NRR should revise the ROP guidance to include consideration of a response to the identification of a substantive cross-cutting issue (only when there is at least one White PI or finding). This response could include a redirection of inspection resources, management meetings, and/or a docketed licensee response describing actions planned or taken to address the cross-cutting issue. This guidance should also include a description of how the NRC will close a substantive cross-cutting issue.
3.8.3(4)	NRR should supplement the guidance in IMC 0305, Section 06.06.f, with additional guidance that lists the type of information that should be included in a Region's request to deviate from the Action Matrix (e.g., synopsis of the findings affecting the licensee's performance; the actions (column) stipulated by the Action Matrix; the Region's rationale or considerations for taking action different from that stipulated in the Action Matrix, etc.).
3.9.3(1)	NRR should reinforce the current SDP timeliness goals through management interactions, identifying responsible managers, and establishing accountability for the resolution of overdue significance determinations. The NRR SDP timeliness metrics should be incorporated into the Regional Operating Plans.
3.9.3(2)	NRR should communicate the agency's SDP timeliness goals to licensees (e.g., include text in Choice Letters to inform licensees of NRC's plan to reach a final significance determination within 90 days; discuss the timeliness goal during regulatory conferences; discuss SDP timeliness, including the timeliness goal during the annual Regulatory Information Conference, etc.)
3.9.3(3)	NRR should rectify the difference between the metrics identified in the NRR Operating Plan (i.e., 75% timeliness goal in FY03 increasing to 90% timeliness goal by FY06) with the goals stated in IMC 0609 and reiterated by the August 2, 2001, SRM (i.e., 100% timeliness goal).
3.9.3(4)	NRR should change the guidance in IMC 0609 to allow the Regions the option to use a "preliminary greater-than-very low safety significance" characterization for preliminary safety significance determination (Choice) letters when there is sufficient uncertainty regarding the preliminary risk estimate.
3.9.3(5)	OPA should further modify its policy for issuing press releases for ROP findings to link the issuance of press release to a finding(s) that results in a Degraded Cornerstone. This modification will better align the emphasis that results from the issuance of a press release with the "moderate degradation in safety performance" associated with a Degraded Cornerstone (i.e., two White inputs (findings and/or Performance Indicators), one Yellow input, or three White inputs in the same Strategic Performance Area).

3.9.3(6)	NRR should modify IMC 0305 to reference the OPA policy for issuing press releases for ROP inspection findings.
3.10.3(1)	NRR should change IMC 0612 to require a brief description in the inspection report summary of findings of corrective actions taken by the licensee to restore compliance with NRC regulations, where applicable. (OIG Report recommendation #10)
3.10.3(2)	The EDO should inform OIG that the ROP web site will not be revised as described in recommendation #9. Users currently have ready access to all findings in a cornerstone by hyper-linking to the next web page and the OIGs' recommendation would not substantially improve the quality of the information available to users. The difficulty and costs of implementing this change appears to exceed the benefit. (OIG Report recommendation #9)
3.11.1.3(1)	NRR should broaden the NRR SDP Task Action Plan Objective 6.1 to initiate a cooperative effort between NRR and RES to explore efficiency and quality enhancements that would result in better coordination and/or integration of these two programs.
3.11.1.3(2)	NRR and RES should identify avenues to enhance the staff's knowledge of the ASP program, including adding a module to the P-111 course regarding the ASP program.
3.11.2.3(1)	NRR should develop guidance to allow the staff to determine whether the results of a licensee's risk analysis of a finding is of sufficient quality to use as input to the staff's final significance determination. This guidance should focus on the use of DG-1122, which addresses the Nuclear Energy Institute's (NEI) peer review process (NEI-00-02), and the proposed update, that includes a licensee self-assessment process to confirm conformance with ASME RA-S-2002, "Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications," dated April 5, 2002.
3.11.3.3(1)	NRR should review the Action Matrix annually to assess its impact on stakeholders and the appropriateness of the criteria for determining the combination of inputs that dictate a licensee's placement in the Action Matrix. The results of this assessment should be provided in a report to management with recommendations for adjustments, as necessary.

APPENDIX B - LIST OF ACRONYMS

Δ CDF	Change in Core Damage Frequency
Δ LERF	Change in Large Early Release Frequency
ASP	Accident Sequence Precursor
BI	Barrier Integrity
BNL	Brookhaven National Laboratory
CCDP	Conditional Core Damage Probability
CDF	Core Damage Frequency
DPO	Differing Professional Opinion
DPV	Differing Professional View
EATS	Enforcement Action Tracking System
EDO	Executive Director for Operations
IE	Initiating Events
IIPB	Inspection Program Branch, Division of Inspection Program Management, Office of Nuclear Reactor Regulation
IMC	Inspection Manual Chapter
INEEL	Idaho National Engineering and Environmental Laboratory
IT	Information Technology
LERF	Large Early Release Frequency
MS	Mitigating Systems
NRC	Nuclear Regulatory Commission
NRR	Office of Nuclear Reactor Regulation
NSIR	Office of Nuclear Security Incident and Response
OE	Office of Enforcement
OIG	Office of the Inspector General
OPA	Office of Public Affairs
PRA	Probabilistic Risk Assessment
RES	Office of Nuclear Regulatory Research
RG	Regulatory Guide
ROP	Reactor Oversight Process
SDP	Significance Determination Process
SECY	Office of the Secretary
SERP	Significance and Enforcement Review Panel
SPAR	Standardized Plant Analysis Risk
SRA	Senior Reactor Analyst
SRM	Staff Requirements Memorandum
SSC	Structure, System, or Component

APPENDIX C - LIST OF DOCUMENTS REVIEWED

- (1) SECY-99-007, "Recommendations for Reactor Oversight Process Improvements"
- (2) SECY-99-007A, "Recommendations for Reactor Oversight Process Improvements (Follow-up to SECY-99-007)"
- (3) Inspection Manual Chapter 0609, Sections 01 and 02, "Significance Determination Process"
- (4) Inspection Manual Chapter 2515, "Operating Reactor Assessment Program"
- (5) Inspection Manual Chapter 0612, "Power Reactor Inspection Reports"
- (6) Correspondence: ML013550087 Staff response to ACRS comments on the SDP (1/10/02)
- (7) Correspondence: ML020110121 Staff response to RIV & OE request for review of SDP(1/15/02)
- (8) Correspondence: ML020420587, ML020370605, ML020420589 Staff response to DPV (2/18/02)
- (9) Correspondence: ML020920470 Staff response to Commission SRM (2/5/02)
- (10) Correspondence: ML020440182 (pkg.) SDP Improvement Plan issuance (3/18/02)
- (11) Correspondence: G20020209 Staff comments on OIG draft audit report on the SDP (5/14/02)
- (12) Correspondence: ML021760004 Response to SRM M020319 Differences between SDP, ASP, & INES (7/12/02)
- (13) Correspondence: ML021750054 Expectations for Inspector Use of the SDP (8/9/02)
- (14) Correspondence: ML013530458 Update of Active NRR Requests for Assistance (1/31/02)
- (15) Correspondence: ML020810004 Reactor Oversight Process Self-Assessment Support (3/21/02)
- (16) Correspondence: ML021770453 Reactor Oversight Process Self-Assessment Support (6/26/02)
- (17) Correspondence: ML022410392 Reactor Oversight Process Self-Assessment Support (8/29/02)
- (18) "Understanding Risk - Informing Decisions in a Democratic Society," (summary), National Academy Press, 1996
- (19) Documents related to SDP results and analyses for:
 - Cooper environmental qualification finding
 - Indian Point steam generator tube degradation finding
 - Davis-Besse reactor vessel head degradation significance characterization (no finding yet)
- (15) ROP and SDP Program Guidance

APPENDIX D - LIST OF PERSONS INTERVIEWED

HEADQUARTERS - Management & Supervisors

Baranowsky, Patrick, Branch Chief, RES
Barrett, Richard, Director, DE, NRR
Beckner, William, Program Director, Operating Reactor Improvements, NRR
Black, Suzanne, Deputy Director, DSSA, NRR
Boger, Bruce, Director, DIPM, NRR
Borchardt, R. William, ADIP, NRR
Carpenter, Cynthia, Branch Chief, IIPB, DIPM, NRR
Cheok, Michael, Assistant Branch Chief, OERAB, DRAA, RES
Coe, Douglas, Section Chief, RIS, IIPB, NRR
Collins, Samuel, Director, NRR
Congel, Frank, Director, OE
Dean, William, Deputy Director, DE, NRR
Gillespie, Frank, Deputy Director, DRIP, NRR
Johnson, Jon, Deputy Director, NRR
Johnson, Michael, Branch Chief, SPSB, DSSA, NRR
Leuhman, James, Deputy Director, OE
Lieberman, James, Special Counsel for Rulemaking & Fuel Cycle ,OE
Madison, Alan, Branch Chief, RSOS, NSIR
Newberry, Scott, Director, DRAA, RES
Reinhart, F. Mark, Licensing Section, SPSB, DSSA, NRR
Rubin, Mark, Section Chief, SPSB, DSSA, NRR
Ruland, William, Project Directorate IV, DLPM, NRR
Sheron, Brian, ADPT, NRR
Strosnider, Jack, Deputy Director, RES

HEADQUARTERS - Staff

Arrighi, Russell, Project Manager, RLEP, DRIP, NRR
Franovich, Michael, Risk Analyst, SPSB, DSSA, NRR
Gibbs, Russell, Sr. Reactor Analyst, IIPB, DIPM, NRR
Houghton, James, RES
Jacobson, Jeffrey, Program Manager, IIPB, DIPM, NRR
Johnson, James, Special Assistant, RES
Koltay, Peter, IIPB, DIPM, NRR (former RI at DC Cook, Region III)
Long, Steven, Sr. Reliability and Risk Analyst, SPSB, DSSA, NRR
Nelson, David, Enforcement Specialist, OE
O'Neal, Daniel, Risk Analyst, SPSB, DSSA, NRR
O'Reilly, Patrick, Sr. Reliability and Risk Engineer, RES
Sykes, Marvin, Reactor Operations Engineer, IIPB, DIPM, NRR
Wilson, Peter, PRAB, DSSA, NRR
Wong, See-Meng, Sr. Reactor Analyst, SPSB, DSSA, NRR

APPENDIX D - LIST OF PERSONS INTERVIEWED (Cont'd.)

Regional Managers

Brockman, Kenneth, DRP, Division Director, Region IV
Caniano, Roy, Deputy Director, DRS, Region III
Christensen, Harold, Deputy Director, DRS, Region II
Collins, Elmo, Acting Division Director, DRS, Region IV
Dyer, James, Regional Administrator, Region III
Grant, Geoffrey, DRP Division Director, Region III
Grobe, Jack, DRS, Division Director, Region III
Gwynn, Thomas P., Deputy Regional Administrator, Region IV
Holian, Brian, Deputy Director, DRP, Region I
Lanning, Wayne, Division Director, DRS, Region I
Merschhoff, Ellis, Regional Administrator, Region IV
Miller, Hubert, Regional Administrator, Region I
Pederson, Cindy, Director, DRS, Region III
Plisco, Loren, Director, DRP, Region II
Reyes, Luis, Regional Administrator, Region II
Wiggins, James, Deputy Regional Administrator, Region I

Regional Supervisors

Bonser, Brian, Branch Chief, DRP, Region II
Burgess, Bruce, Branch Chief, DRP, Region III
Cahill, Stephen, Branch Chief, DRP, Region II
Conte, Richard, Branch Chief, DRS, Region I
Doerflein, Lawrence, Branch Chief, Systems Branch, DRS, Region I
Gody, Tony, Operations Branch Chief, DRS, Region IV
Haag, Robert, Branch Chief, Region II
Jones, William, Branch Chief, DRP, Region IV
Kennedy, Kriss, Branch Chief, DRP, Region IV
Landis, Kerry, Branch Chief, DRP, Region II
Lanksbury, Roger, Branch Chief, DRP, Region III
Lew, David, Branch Chief, DRS, Region I
Marschall, Charlie, Branch Chief, DRS, Region IV
McDermott, Brian, Branch Chief, DRP, Region I
Meyer, Glenn, Branch Chief, DRP, Region I
Ogle, Charles, Branch Chief, Region II
Riemer, Kenneth, Branch Chief, DRS, Region III
Shanbaky, Mohamed, Branch Chief, DRP, Region I
Smith, Linda, Branch Chief, DRP, Region IV
Veget, Anton, Branch Chief, DRP, Region III
Wert, Leonard, Branch Chief, DRP, Region II

APPENDIX D - LIST OF PERSONS INTERVIEWED (Cont'd.)

Regional Inspectors/Project Engineers

Brown, Eva, Resident Inspector, Brunswick, RII (currently DLPM, NRR)
Caldwell, Robert, Resident Inspector, Farley, Region II (currently RORP, DRIP, NRR)
Carroll, Robert, DRP, Region II
Clark, Jeff, Project Engineer, Region IV (former SRI, Cooper, Region IV)
Cook, William, Sr. Project Engineer, Branch 2, DRP, Region I
Coyne, Kevin, Resident Inspector, DC Cook, Region III (currently IEHB, DIPM, NRR)
Falevits, Zelig, Electrical Inspector, DRS, Region III
Gage, Paul, Reactor Inspector, Division of Reactor Safety, Region IV
Gray, Mel, Sr. Reactor Inspector, Systems Branch, DRS, Region I
Haire, Mark, Reactor Operations Inspector, Division of Reactor Safety, Region IV
Loughead, Patricia, Mechanical Inspector, DRS, Region III
MacDonald, George, DRP, Region II
McKenzie, Thomas, Inspector, DRS, Region II
Passehl, David, Region III
Paulk, Chuck, DRP, Region IV
Schin, Robert, Inspector, DRS, Region II
Schmidt, Wayne, Sr. Reactor Inspector, DRS, Region I
Walker, Wayne, DRP, Region IV

Residents

Allen, Don, Sr. Resident Inspector, Commanche Peak
Bower, Fred, Resident Inspector, Salem 1 & 2
Bywater, Russ, SRI, Arkansas Nuclear One
Cox, Mark, Resident Inspector, Indian Point 3
Dipalo, Eugene, Resident Inspector, McGuire
Drysdale, Peter, Sr. Resident Inspector, Indian Point 3
Duncan, Eric, Sr. Resident Inspector, La Salle
Habighorst, Peter, Sr. Resident Inspector, Indian Point 2
James, Lois, Resident Inspector, Indian Point 2
Krohn, Paul, Sr. Resident Inspector, Point Beach
Lorson, Raymond, Sr. Resident Inspector, Salem 1 & 2
McCoy, Gerald, Resident Inspector Surry
Morris, R. Michael, Resident Inspector, Point Beach
Sanchez, Fred, Resident Inspector, Commanche Peak
Schoppy, Joseph, Sr. Resident Inspector, Hope Creek
Shaeffer, Scott, Sr. Resident Inspector, McGuire
Weaver, Kathy, RI, Arkansas Nuclear One

SRAs

Bernhard, Rudolph, Region II
Burgess, Sonia, Region III
Cobey, Eugene, Region I
Loveless, David, Region IV
Pruett, Troy, Region IV
Rasmussen, Richard, SPSB, DSSA, NRR (in training)
Rogers, Walt, Region II

APPENDIX D - LIST OF PERSONS INTERVIEWED (Cont'd.)

External Interviews

Anderson, Ross, Licensee Risk Analyst, North Anna
Ashley, Glenn, Licensing Manager, Arkansas Nuclear One, Region IV Licensee
Bement, Robert, General Manager, Arkansas Nuclear One, Region IV Licensee
Berchall, William, PRA Manager, Exelon
Brewer, Duncan, PRA Supervisor, Duke Energy
Bryant, Julius, Licensing Engineer, McGuire, Duke Energy
Bucheit, David, Licensee Risk Analyst, Supervisor, North Anna
Canyia, Fred, Site Vice President, Point Beach
Crossman, James, Licensing Manager, North Anna, Dominion
DeRoy, Joseph, Plant Manager, Indian Point 3
Fricker, Carl, Operations Manager, Salem
Ho, Wei, Salem
Kaegi, Glen, Regulatory Affairs Manager, La Salle
Kitlan, Michael, Jr., PRA Engineer, Duke Energy
Krause, Charles, Sr., Licensing Engineer, Point Beach
Kreieger, Kurt, Salem
Lanc, Terry, Site Risk Analyst, La Salle, Exelon
Masterlark, James, Licensee Risk Analyst, Point Beach, Nuclear Management Company
McCann, John, Licensing Manager, Indian Point 2
Michael, Lloyd, Region IV Licensee, Arkansas Nuclear One
Moore, David, Plant Manager, Commanche Peak
Nagle, John, Salem
Ritzman, Robin, Salem
Salamon, Gabe, Salem
Schiavoni, Mark, Plant Manager, La Salle
Schwarz, Christopher, Plant Manager, Indian Point 2
Small, Michal, Licensing Manager, Surry, Dominion
Sowers, Thomas, III, Director, Station Operations and Maintenance, Surry
Steinmetz, John, PRA Senior Engineer, Exelon
Thomas, Charles, Licensing Manager, McGuire, Duke Energy
Tirsun, Daniel, Risk Analyst, Region IV Licensee, Comanche Peak
Waldinger, Lon, Salem
Walker, Jessica, Region IV Licensee, Arkansas Nuclear One
Walker, Roger, Licensing Manager, Commanche Peak
Walker, Woody, Region IV Licensee, Arkansas Nuclear One
Webb, Thomas, Regulatory Affairs Manager, Point Beach

NEI

Floyd, Steven

Other External

Dyckman, Dennis, Pennsylvania Department of Environmental Protection
Lipoti, Jill, New Jersey Department of Environmental Protection
Lochbaum, David, Union of Concerned Scientists
Settles, Cecil, Illinois Department of Nuclear Safety
Shadis, Raymond, New England Coalition on Nuclear Pollution