

Item #30

Status of Transmission Line Upgrade & statement of compliance with 5 milliamp limit. The planned reconfiguration of the Summer - Denny Terrace #1 and Parr - Edenwood transmission lines has not been performed as of January 8, 2003. The modification is awaiting appropriate electrical load and weather conditions. The planned reconfiguration has been designed to comply with the 2002 National Electric Safety Code so there should be no concern related to induced shock.