

RAS 5583

72-22-ISFSI - State Exhibit 124 - Rec'd 5/17/02

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

DOCKETED  
USNRC



November 19, 2001

2003 JAN 29 PM 3: 16



OFFICE OF THE  
SECRETARY

OFFICE OF THE SECRETARY  
RULEMAKINGS AND  
ADJUDICATIONS STAFF

MEMORANDUM TO: William D. Travers  
Executive Director for Operations

FROM: Annette L. Vietti-Cook, Secretary

SUBJECT: STAFF REQUIREMENTS - SECY-01-0178 - MODIFIED  
RULEMAKING PLAN: 10 CFR PART 72 -- "GEOLOGICAL AND  
SEISMOLOGICAL CHARACTERISTICS FOR SITING AND  
DESIGN OF DRY CASK INDEPENDENT SPENT FUEL  
STORAGE INSTALLATIONS"

This is to advise you that the Commission has not objected to the staff's plan to revise the approved rulemaking plan for the geological and seismological characteristics for the siting and design of dry cask independent spent fuel storage installations (10 CFR Part 72), subject to the comments provided below.

Central to this rulemaking is the determination of the mean annual exceedance probability of an earthquake at a proposed ISFSI. The proposed rule should solicit comment on a range of probability of exceedance levels from 5.0E-04 through 1.0E-04. Staff should undertake further analysis to support a specific proposal.

The proposed rule should be submitted to the Commission for review prior to publication.  
(EDO) (SECY Suspense: 3/22/02)

CLEAR REGULATORY COMMISSION

Docket No. \_\_\_\_\_ Official Ex. No. 134  
 In the matter of PFS  
 Staff \_\_\_\_\_ IDENTIFIED   
 Applicant \_\_\_\_\_ RECEIVED \_\_\_\_\_  
 Intervenor  \_\_\_\_\_ REJECTED \_\_\_\_\_  
 Other \_\_\_\_\_ WITHDRAWN \_\_\_\_\_  
 DATE 5-17-02 Witness \_\_\_\_\_  
 Clerk D. Keat

- cc: Chairman Meserve
- Commissioner Dicus
- Commissioner Diaz
- Commissioner McGaffigan
- Commissioner Merrifield
- OGC
- CFO
- OCA
- OIG
- OPA
- Office Directors, Regions, ACRS, ACNW, ASLBP (via E-Mail)
- PDR

Template = SECY-028

State's  
Exhibit 124  
SECY-02