

From: Thomas Alexion
To: DMILLAR@entergy.com; SBENNE2@entergy.com
Date: 1/21/03 4:27PM
Subject: RAI FOR EDG/AOT EXTENSION

Dana, Steve,

See the attached.

Tom

REQUEST FOR ADDITIONAL INFORMATION
EXTENSION OF EMERGENCY DIESEL GENERATOR ALLOWABLE OUTAGE TIME
ARKANSAS NUCLEAR ONE, UNIT 2

1. Please describe the methodology used to generate the external events risk numbers, including the final numbers generated for each external event. If aspects of the external events analysis approach used in this application are substantially different from the methods described in previous recent applications (e.g., the power uprate application), please explain and justify the use of the different approach.

2. For the fire analyses, as an alternative to justifying the use of a different approach discussed in Question 1 above, the licensee could describe how this application would impact each of the unscreened fire quadrant analyses and results identified in the June 28, 2001, letter to the U.S. Nuclear Regulatory Commission (NRC) regarding its power uprate application. The NRC staff notes that in this letter, the licensee identified 17 unscreened fire quadrants involving 15 fire areas and provided the associated post-uprate core damage frequency for each quadrant.

Mail Envelope Properties (3E2DBB4D.7FE : 0 : 20628)

Subject: RAI FOR EDG/AOT EXTENSION
Creation Date: 1/21/03 4:27PM
From: Thomas Alexion

Created By: TWA@nrc.gov

Recipients	Action	Date & Time
entergy.com	Transferred	01/21/03 04:27PM
DMILLAR (<u>DMILLAR@entergy.com</u>)		
SBENNE2 (<u>SBENNE2@entergy.com</u>)		

Post Office	Delivered	Route
		entergy.com

Files	Size	Date & Time
EDG.AOT.RAI	2829	01/21/03 04:19PM
MESSAGE	663	01/21/03 04:27PM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened