

Kevin J. Nietmann
Plant General Manager
Calvert Cliffs Nuclear Power Plant
Constellation Generation Group, LLC

1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101
410 495-4787 Fax



February 13, 2003

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
January 2003 Operating Data Reports

The subject reports are being sent to you as required by Technical Specification 5.6.4.

Should you have questions, please contact Mr. Thomas S. O'Meara at (410) 495-6940.

Very truly yours,

A handwritten signature in black ink, appearing to read "Kevin J. Nietmann".

KJN/CAN/bjd

Attachments

cc: J. Petro, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC
D. M. Skay, NRC
H. J. Miller, NRC

Resident Inspector, NRC
R. I. McLean, DNR
J. Wright, INPO
K. N. Larson, ANI

IE24

UNIT SHUTDOWNS

DOCKET NO.	50-317
UNIT NAME	Calvert Cliffs - U1
DATE	February 5, 2003
COMPLETED BY	Herman O. Olsen
TELEPHONE	(410) 495-6734

REPORTING MONTH January 2003

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE/CORRECTIVE ACTIONS COMMENTS
						There were no shutdowns this month.

¹ Reason:

- A - Equipment Failure
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & License Examination
- F - Administrative
- G - Operational Error
- H - Other

² Method:

- 1 - Manual
- 2 - Manual Scram.
- 3 - Automatic Scram.
- 4 - Continued
- 5 - Other

DOCKET NO. 50-317
CALVERT CLIFFS - UNIT 1
February 5, 2003

SUMMARY OF OPERATING EXPERIENCE

January 2003

The unit began the month at 100% reactor power.

On 01/31/03 at 2200, power was reduced to 85% for Main Turbine Valve Testing.

The unit remained at 85% power for the remainder of the month.

UNIT SHUTDOWNS

DOCKET NO.	50-318
UNIT NAME	Calvert Cliffs-U2
DATE	February 5, 2003
COMPLETED BY	Herman O. Olsen
TELEPHONE	(410) 495-6734

REPORT MONTH January 2003

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE/CORRECTIVE ACTIONS COMMENTS
						There were no shutdowns this month.

¹ Reason:

- A - Equipment Failure
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training & License Examination
- F - Administrative
- G - Operational Error
- H - Other

² Method:

- 1 - Manual
- 2 - Manual Scram.
- 3 - Automatic Scram.
- 4 - Continued
- 5 - Other

DOCKET NO. 50-318
CALVERT CLIFFS - UNIT 2
February 5, 2003

SUMMARY OF OPERATING EXPERIENCE

January 2003

The unit began the month at 100% reactor power.

On 01/27/03 at 0605, power was reduced to 99% due to a temperature instrumentation problem. Power was returned to 100% at 2100.

The unit operated at 100% reactor power for the remainder of the month.