ATTACHMENT 41A

AP1000 SPECIFIC MAAP4.04 ANALYSES

	Table 41A-1 (Sheet 1 of 7)														
	SUMMARY OF SYSTEM ASSUMPTIONS FOR AP1000 MAAP4.04 HYDROGEN ANALYSES Accident Class 1A														
	Accident Class 1A														
:	Equipment Availability Assumptions														
		ADS Gravity													
Case Name	Initiating Event	1	1 2/3 4 A/M CMT ACC PRHR Injection/ Recirc. Cavity IGN Cavity Flooding												
1A-3	FW	2	2+2	4	М	2	2	Failed	2/2	N	2	• Acc Scqs 20, 36, 39			
	Failure											• ADS @ core-exit temperature > 922 K (1200°F) + 20 min			
1A-3a	FW	0	2+0	0	М	2	2	Failed	2/2	N	2	• Acc Seqs 20, 36, 39			
	Pallure											• ADS @ core-exit temperature > 922 K (1200°F) + 20 min			
1A-4	FW	2	2+2	4	М	Failed	2	Failed	2/2	N	N	Acc Seq 28			
	Failure											• ADS @ core-exit temperature > 922 K (1200°F) + 20 min			
												• Failure of CMT draining fails ADS, gravity injection/recirc.			
												• Gravity injection is recovered when ADS-4 is manually activated			
1A-4a	FW	0	2+0	0	М	Failed	2	Failed	2/2	N	N	Acc Seq 28			
	Failure											• ADS @ core-exit temperature > 922 K (1200°F) + 20 min			
											1	• Failure of CMT draining fails ADS, gravity injection/recirc.			
												• Gravity injection is recovered when ADS-4 is manually activated			

The 1A hydrogen sequences may produce little core damage, even with the reduced availability of the CMTs, accumulators, and gravity injection. That is acceptable because they are core damage sequences recovered by operator action.

٩.

	Table 41A-1 (Sheet 2 of 7)														
	SUMMARY OF SYSTEM ASSUMPTIONS FOR AP1000 MAAP4.04 HYDROGEN ANALYSES														
	Accident Class 1AP														
	Equipment Availability Assumptions														
	ADS Gravity														
Case Name	Initiating Event	1	1 2/3 4 A/M CMT ACC PRIR Injection/ Recirc. IGN Cavity Flooding Comments												
1AP-3	2" hot leg break to SG Compt	2	2+2	4	М	failed	2	Y	2/2	N	2	 Acc Seq 26, 30 Failure to drain CMT fails ADS, gravity injection and recirc. ADS @ core-exit temperature > 922 K (1200°F) + 20 min Gravity Injection recovered when ADS-4 manually activated 			
1AP-4	2" hot leg break to SG Compt	2	2+2	4	М	2	2	Y	2/2	N	N	 Acc Seq 38, 40 ADS @ core-exit temperature > 922 K (1200°F) + 20 min Gravity Injection recovered when ADS-4 manually activated 			

The 1A hydrogen sequences may produce little core damage, even with the reduced availability of the CMTs, accumulators, and gravity injection. That is acceptable because they are core damage sequences recovered by operator action.

	Table 41A-1 (Sheet 3 of 7)													
	SUMMARY OF SYSTEM ASSUMPTIONS FOR MAAP4.04 HYDROGEN ANALYSES													
	Accident Class 3C													
	Equipment Availability Assumptions													
			A	DS	-				Gravity					
Case Name	Initiating Event	1	2/3	4	A/M	СМТ	ACC	PRHR	Injection/ Recirc.	IGN	Cavity Flooding	Comments		
3C-1	Vessel Rupture	2	2+2	4	A	2	2	N	2/2	N	N	 Acc Seq 5 Large LOCA at belt of vessel into Cavity 		

	Table 41A-1 (Sheet 4 of 7)														
	SUMMARY OF SYSTEM ASSUMPTIONS FOR MAAP4.04 HYDROGEN ANALYSES														
	Accident Class 3D														
	Equipment Availability Assumptions														
	ADS Gravity														
Case Name	Initiating Event	1	2/3	4	A/M	СМТ	ACC	PRHR	Injection/ Recirc.	IGN	Cavity Flooding	Comments			
3D-1	Spurious ADS-4 (one valve)	0	0	0	N	0	2	N	0/0	N	2	 Acc Seq 3 One 79 in² valve from hot leg to SG Compt Failure to drain CMTs fails ADS, gravity injection/recirc. 			
3D-2	Spurious ADS-2 (two valves)	0	0	0	N	0	2	N	0/0	N	2	 Acc Seq 3 Two 27 in² stage 2 ADS pzr to IRWST Failure to drain CMTs fails ADS, gravity injection/recirc. 			
3D-3	DVI Line Break to PXS Compt	0	0	0	N	1	1	N	0/0	N	2	 Acc Seq 4 Flood PXS compt through broken gravity injection line No low CMT-2 signal 			
3D-5	2" hot leg break to SG Compt	0	2+0	0	A	2	2	Y	2/2	N	2	• Acc Seq (8), 9			

	Table 41A-1 (Sheet 5 of 7)													
	SUMMARY OF SYSTEM ASSUMPTIONS FOR MAAP4.04 HYDROGEN ANALYSES													
	Accident Class 3BR													
	Equipment Availability Assumptions													
	ADS Gravity													
Case Name	Initiating Event	1	2/3 4 A/M CMT ACC PRHR Recirc. IGN Flooding Comments											
3BR-1	DEGB cold leg to SG Compt	2	2+2	4	A	1	0	N	1/0	N	N	 Acc Scq 2,10 Void vessel and reflood with gravity injection 		
3BR-1a	DEGB cold leg to SG Compt	2	2+2	4	A	2	0	N	0/0	N	N	 Acc Seq 2,10 Void vessel and reflood with gravity injection 		

NB: If 1 CMT and 1/1 grav. inj./recirc. are available, there is no core degradation.

	Table 41A-1 (Sheet 6 of 7)														
	SUMMARY OF SYSTEM ASSUMPTIONS FOR MAAP4.04 HYDROGEN ANALYSES														
	Accident Class 3BL														
	Equipment Availability Assumptions														
	ADS Gravity Injection Contra														
Case Name	Event	1	2/3 4 A/M CMT ACC PRIIR Injection Cavity 2/3 4 A/M CMT ACC PRIIR /Recirc. IGN Flooding Comments												
3BL-1	2" LOCA hot leg to SG Compt	2	2+2	4	A	2	2	N	2/0	N	N	 Acc Seq 6,7 ABB=0 after ADS-4 to prevent reflood through break Fail gravity recirc. 			
3BL-2	DVI line break to PXS Compt	2	2+2	4	A	1	1	N	1/0	N	N	Acc Seq 12 No PXS flood			

NB: for 3BL cases, N1SHRB(28) = 6 and N1SHRB(29) = 6 will be taken into account in the input files.

	Table 41A-1 (Sheet 7 of 7)														
		SU	MMA	RY OF	SYSTE	EM ASSU	JMPTIO	NS FOR I	MAAP4.04	HYDROG	GEN ANAL	YSES			
	Accident Class 3BE														
		Equipment Availability Assumptions													
Corre	T		ADS Gravity												
Case Name	Event	1	2/3	4	A/M	СМТ	ACC	PRHR	Recirc.	IGN	Flooding	Comments			
3BE-1	DVI line break to PXS Compt	2	2+2	4	A	1	1	N	0/0	N	2	 Acc Seq 1 Flood PXS compt through broken DVI line 			
3BE-2	DVI line break to PXS Compt	2	2+2 4 A 1 1 N 0/0 N 2 • Acc Seq 1 • Do not flood PXS com through broken DVI line												
3BE-4	Spurious ADS-4 (1)	2	2+2	4	A	2	2	N	0/0	N	2	Acc Seq 11			
3BE-5	2" break hot leg to SG Compt	2	2+2	4	A	2	2	N	0/0	N	2	• Acc Scq 15, 16			
3BE-6	2" break hot leg to SG Compt	2	2+2 4 A 2 2 N 0/0 N 1 • Acc Seq 15, 16												
3BE-8	SGTR	0	2+0 0 A 2 2 Y 2/2 N 2 • Acc Seq 24												
3BE-9	SGTR	2	2+2	4	A	2	2	Y	0/0	N	2	Acc Seq 35			

41A-8

Table 41A-1 (cont.)

SUMMARY OF SYSTEM ASSUMPTIONS FOR MAAP4.04 HYDROGEN ANALYSES

List of abbreviations:

- A: automatic
- ACC: accumulator
- ADS: automatic depressurization system
- CMT: core makeup tank
- DVI: direct vessel injection (safety injection)
- FW: feed water
- IGN: igniters
- M: manual
- N: off or failed
- PRHR: passive residual heat removal
- SG: steam generator
- SGTR: steam generator tube rupture
- Y: on
- @: manual actuation per AFR-C.1
- NB: All sequences defined in the above table will be used for H₂ mixing analyses (igniters off). They will also be used as a basis for H₂ burning analyses with the igniters on.

ء دورور

Table 41A-2													
SUN	SUMMARY OF HYDROGEN GENERATION RESULTS MAAP4 HYDROGEN MIXING ANALYSES												
	Accident Class 1A												
Mass of H2 Generated IA Case NameFraction of Active Clad Reacted (788 kg)H2 Generation Duration (min)H2 Generation Rate (kg/min)													
1A-3-ADS2	321	0.41	Early – None	22	116								
1A-4-ADS2	278	0.35	Early – None	22	41								
Table 41A-3													
SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES													

SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES

				Accident Class 1A							
1A Com		IR	WST		Valve Vault						
Name	X ₁₁₂	X _{ST}	X ₀₂	Eq. Ratio	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio			
1A-3-ADS2	0.64	0.36	< 0.01	1385	0.03	0.10	0.17	< 0.08			
1A-4-ADS2	0.69	0.30	< 0.01	1105	0.04	0.10	0.17	< 0.10			

Table 41A-4													
SUMMARY	OF EARLY C	OMPARTMEN'	T GAS COMP	OSITION RESU	LTS FOR MA	AP4 HYDROC	GEN MIXING	ANALYSES					
			1	Accident Class 1A									
1A CMT Room SG Room													
Case Name	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio					
1A-3-ADS2	0.02	0.71	0.05	0.20	0.04	0.53	0.09	0.20					
1A4-ADS2	0.05	0.24	0.14	0.18	0.05	0.26	0.14	0.18					
Table 41A-5													
SUMMARY OF HYDROGEN GENERATION RESULTS MAAP4 HYDROGEN MIXING ANALYSES													

1

Accident Class 1AP												
1AP Case Name	Mass of H2 Generated In-Vessel (kg)	Fraction of Active Clad Reacted	Core Reflood	II2 Generation Duration (min)	H2 Generation Rate (kg/min)							
1AP-3	617	0.78	Early	19	637							
1AP-4	471	0.60	Early	17	138							

+

	Table 41A-6													
SUMMARY	Y OF EARLY C	OMPARTMEN	IT GAS COMH	POSITION RESU	LTS FOR MA	AP4 HYDRO	GEN MIXING	ANALYSES						
			A	Accident Class 1AP										
1AP	IAP IRWST Valve Vault													
Case Name	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio						
1AP-3	0.54	0.47	< 0.01	2549	0.07	0.10	0.17	< 0.19						
1AP-4	0.38	0.62	< 0.01	<10 (12100s)	0.06	0.11	0.16	< 0.17						
	<u></u>	<u></u>		Table 41 A 7										

Tahl	le	41	Α	-7	
rao		- 1	n	-,	

SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES

ACCIUCIII CIASS IAI	Accident	Class	1AP
---------------------	----------	-------	-----

1AP	CMT Room				SG Room			
Case Name	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio
1AP-3	0.06	0.58	0.07	< 0.38	0.06	0.69	0.05	0.59
1AP-4	0.08	0.47	0.09	0.29	0.03	0.75	0.04	0.29

	Table 41A-8											
SU	SUMMARY OF HYDROGEN GENERATION RESULTS MAAP4 HYDROGEN MIXING ANALYSES											
	Accident Class 3Be											
3Be Case Name	Mass of H2 Generated In-Vessel (kg)	Fraction of Active Clad Reacted	Core Reflood	H2 Generation Duration (min)	H2 Generation Rate (kg/min)							
3BE-1	465	0.59	Early	12	320							
3BE-2	265	0.34	None	16	113							
3BE-4	282	0.36	None	20	104							
3BE-5	338	0.43	Early-Slow	50	187							
3BE-6	392	0.50	Early-Slow	45	2314							
3BE-8	325	0.41	None	15	163							
3BE-9	468	0.59	None	120	106							

.

	Table 41A-9											
SUMMAR	SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES											
	Accident Class 3Be											
3Be	3Be IRWST					Valv	ve Vault					
Case Name	X ₁₁₂	X _{ST}	X ₀₂	Eq. Ratio	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio				
3BE-1	0.06	0.88	0.01	1.94	0.04	0.12	0.17	< 0.11				
3BE-2	0.08	0.20	0.14	< 0.26	0.03	0.16	0.16	< 0.10				
3BE-4	0.08	0.19	0.15	< 0.26	0.03	0.15	0.16	0.1 (< 0.08)				
3BE-5	0.05	0.79	0.03	0.70	0.02	0.09	0.18	0.1 (< 0.06)				
3BE-6	0.04	0.57	0.08	0.27	0.03	0.09	0.18	0.1 (< 0.07)				
3BE-8	0.30	0.70	< 0.01	> 10 (152 200 s)	0.05	0.23	0.14	< 0.18				
3BE-9	0.04	0.89	0.01	1.53 (159800 s)	0.04	0.15	0.16	< 0.13				

(

	Table 41A-10											
SUMMAR	SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES											
Accident Class 3Be												
3Be	3Be CMT Room					SG	Room	_				
Case Name	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio	X ₁₁₂	X _{ST}	X ₀₂	Eq. Ratio				
3BE-1	0.11	0.38	0.11	0.28	0.08	0.34	0.12	0.32				
3BE-2	0.03	0 63	0.07	< 0.22	0.04	0.58	0.08	< 0.23				
3BE-4	0.03	0.66	0.06	< 0.22	0.04	0.60	0.07	< 0.23				
3BE-5	0.06	0.29	0.13	0.21	0.11	0.37	0.10	0.50				
3BE-6	0.07	0.26	0.13	0.24	0.10	0.17	0.14	0.33				
3BE-8	0.03	0.55	0.08	0.96	0.04	0.42	0.11	0.20				
3BE-9	0.05	0.62	0.07	< 0.32	0.18	0.45	0.07	1.18				

į* l

	Table 41A-11									
SUN	SUMMARY OF HYDROGEN GENERATION RESULTS MAAP4 HYDROGEN MIXING ANALYSES									
	Accident Class 3BR									
3BR Case Name	3BR CaseMass of H2 GeneratedFraction of ActiveH2 GenerationH2 GenerationNameIn-Vessel (kg)Clad ReactedCore RefloodDuration (min)(kg/min)									
3BR-1	279	0.35	None	16	60					

Revision 1

3

	Table 41A-12										
SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES											
Accident Class 3BR											
3BR		IRV	VST			Valv	e Vault				
Case Name	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio			
3BR-1	0.07	0.10	0.17	< 0.21	0.06	0.13	0.16	< 0.17			
SUMMAR	Y OF EARLY C	COMPARTMEN	T GAS COMP	Table 41A-13 OSITION RESU	JLTS FOR MA	AAP4 HYDROO	GEN MIXING	ANALYSES			
			A	ccident Class 3BR							
3BR		СМТ	Room	.	SG Room						
Name	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio			
3BR-1	0.07	0.14	0.16	< 0.21	0.07	0.15	0.16	< 0.21			

ſ

	Table 41A-14									
SU	SUMMARY OF HYDROGEN GENERATION RESULTS MAAP4 HYDROGEN MIXING ANALYSES									
	Accident Class 3BL									
3BL Case Name	Mass of H2 Generated In-Vessel (kg)	Fraction of Active Clad Reacted	Core Reflood	H2 Generation Duration (min)	H2 Generation Rate (kg/min)					
3BL-1	552	0.70	None	135	54					
3BL-2	455	0.58	None	210	85					

Table 41A-15										
SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES										
Accident Class 3BL										
3BL		IRWST				Valve Vault				
Case Name	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio	X ₁₁₂	X _{ST}	X ₀₂	Eq. Ratio		
3BL-1	0.04	0.95	< 0.01	15.73	0.05	0.39	0.11	< 0.19		
3BL-2	0.02	0.78	< 0.01	1.95	0.05	0.16	0.16	< 0.15		

Table 41A-16

SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES

	Accident Class 3BL										
3BL Case Name		СМТ	Room		SG Room						
	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio			
3BL-1	0.05	0.67	0.06	< 0.39	0.36	0.26	0.08	2.21			
3BL-2	0.04	0.64	0.06	< 0.32	0.26	0.33	0.08	1.54			

	Table 41A-17									
SUI	SUMMARY OF HYDROGEN GENERATION RESULTS MAAP4 HYDROGEN MIXING ANALYSES									
	Accident Class 3C									
3C Case Name	3C CaseMass of H2 GeneratedFraction of ActiveH2 GenerationH2 GenerationNameIn-Vessel (kg)Clad ReactedCore RefloodDuration (min)(kg/min)									
3C-1	307	0.39	Early	10	192					

Revision 1

				Accident Class 3C				
3C		IRV	VST			Valv	e Vault	
Case Name	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio
3C-1	0.07	0.95	0.16	0.21	0.05	0.20	0.15	< 0.14
				T 11 11 10				
CUMMAD	νοεελαινς	OMDA DTMEN	T C AS COM		I TS EOD MA		TEN MIVINO	
SUMMAR	Y OF EARLY C	OMPARTMEN	T GAS COMF	POSITION RESU	LTS FOR MA	AP4 HYDROG	GEN MIXING	ANALYSES
SUMMARY 3C	Y OF EARLY C	OMPARTMEN CMT	T GAS COMF	Table 41A-19 POSITION RESU Accident Class 3C	LTS FOR MA	AP4 HYDROO SG	GEN MIXING Room	ANALYSES
SUMMAR 3C Case Name	Y OF EARLY C X ₁₁₂	OMPARTMEN CMT X _{st}	T GAS COMF Room X ₀₂	Table 41A-19 POSITION RESU Accident Class 3C Eq. Ratio	LTS FOR MA	AP4 HYDROO SG X _{ST}	GEN MIXING Room X ₀₂	ANALYSES

---- -

	Table 41A-20						
SUMI	SUMMARY OF HYDROGEN GENERATION RESULTS MAAP4 HYDROGEN MIXING ANALYSES						
	Accident Class 3D						
3D Case Name	Mass of H2 Generated In-Vessel (kg)	Fraction of Active Clad Reacted	Core Reflood	H2 Generation Duration (min)	H2 Generation Rate (kg/min)		
3D-1	264	0.34	None	15	138		
3D-2	293	0.37	None	15	42		
3D-3	588	0.75	None	45	792		
3D-5	329	0.41	Late-Slow	20	76		

	Table 41A-21							
SUMMAR	SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES							
			1	Accident Class 3D				
3Be		IRV	VST	•		Valv	e Vault	
Case Name	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio	X _{II2}	X _{ST}	X ₀₂	Eq. Ratio
3D-1	0.05	0.11	0.17	< 0.14	0.03	0.13	0.17	< 0.1 (< 0.08)
3D-2	0.67	0.33	< 0.01	> 10 (4151 s)	0.03	0.11	0.17	< 0.1 (< 0.09)
3D-3	0.09	0.10	0.16	< 0.26	0.05	0.15	0.16	< 0.15
3D-5	< 0.01	0.99	< 0.01	> 10 (19150 s)	0.06	0.17	0.15	< 0.17

41A-20

	Table 41A-22								
SUMMAR	SUMMARY OF EARLY COMPARTMENT GAS COMPOSITION RESULTS FOR MAAP4 HYDROGEN MIXING ANALYSES							ANALYSES	
	Accident Class 3D								
3D		СМТ	Room		SG Room				
Case Name	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio	X _{H2}	X _{ST}	X ₀₂	Eq. Ratio	
3D-1	0.03	0.61	0.07	< 0.18	0.03	0.62	0.07	< 0.18	
3D-2	0.04	0.52	0.09	0.19	0.04	0.39	0.11	0.19	
3D-3	0.23	0.27	0.11	1.01	0.20	0.22	0.11	0.85	
3D-5	0.03	0.64	0.07	< 0.21	0.03	0.60	0.07	0.21	

Table 41A-23					
SEQUENCE 1A-3a					
Description Time (s)					
Reactor scram	3.8				
Main coolant pumps off	4020.7				
Core uncovery	11160.3				
Beginning of core relocation	21137				
Accumulator water depleted	14074.9				
PCS actuation	4020.7				
ADS-1	N/A				
ADS-2	13642.2				
ADS-3	N/A				
ADS-4	N/A				
CMT actuation	4020.7				
Cavity flooding actuation	1743.4				
Open recirculation lines if IRWST is drained to low level	26587.4				
PRHR actuation	N/A				

Table 41A-24					
SEQUENCE 1A-4a					
Description Time (s)					
Reactor scram	3.8				
Main coolant pumps off	4020.7				
Core uncovery	4972.3				
Beginning of core relocation	13654.6				
Accumulator water depleted	7456				
PCS actuation	4020.7				
ADS-1	N/A				
ADS-2	7048.6				
ADS-3	N/A				
ADS-4	N/A				
CMT actuation	N/A				
Cavity flooding actuation	N/A				
Open recirculation lines if IRWST is drained to low level	_				
PRHR actuation	N/A				

.

1

Table 41A-25					
SEQUENCE 1AP-3					
Description	Time (s)				
Reactor scram	149.1				
Main coolant pumps off	165.7				
Core uncovery	7447.6				
Beginning of core relocation	14176.7				
Accumulator water depleted	6738.3				
PCS actuation	292				
ADS-1	9274.9				
ADS-2	9394.9				
ADS-3	9514.9				
ADS-4	9634.9				
CMT actuation	N/A				
Cavity flooding actuation	8582.6				
Open recirculation lines if IRWST is drained to low level	13415.2				
PRHR actuation	167.7				

.

121

.

ţ

ļ,

ſ

Table 41A-26					
SEQUENCE 1AP-4					
Description Time (s)					
Reactor scram	149.1				
Main coolant pumps off	165.7				
Core uncovery	9970.5				
Beginning of core relocation	-				
Accumulator water depleted	8929.7				
PCS actuation	307.5				
ADS-1	11894				
ADS-2	12014				
ADS-3	12134				
ADS-4	12254				
CMT actuation	165.7				
Cavity flooding actuation	N/A				
Open recirculation Lines if IRWST is drained to low level	11269				
PRHR actuation	167.7				

٦

Table 41A-27					
SEQUENCE 3D-1					
Description	Time (s)				
Reactor scram	5				
Main coolant pumps off	5.3				
Core uncovery	838.8				
Beginning of core relocation	3472				
Accumulator water depleted	372.3				
PCS actuation	5.3				
ADS-1	N/A				
ADS-2	N/A				
ADS-3	N/A				
ADS-4	N/A				
CMT actuation	N/A				
Cavity flooding actuation	1489.9				
Open recirculation lines if IRWST is drained to low level	N/A				
PRHR actuation	N/A				

j

Table 41A-28					
SEQUENCE 3D-2					
Description Time (s)					
Reactor scram	2.9				
Main coolant pumps off	4.1				
Core uncovery	2565.3				
Beginning of core relocation	5825.8				
Accumulator water depleted	1927.5				
PCS actuation	N/A				
ADS-1	N/A				
ADS-2	N/A				
ADS-3	N/A				
ADS-4	N/A				
CMT actuation	N/A				
Cavity flooding actuation	3427.4				
Open recirculation lines if IRWST is drained to low level	N/A				
PRHR actuation	N/A				

.

Table 41A-29					
SEQUENCE 3D-3					
Description	Time (s)				
Reactor scram	20.5				
Main coolant pumps off	25.3				
Core uncovery	2275.6				
Beginning of core relocation	7639.8				
Accumulator water depleted	4227.9				
PCS actuation	56.1				
ADS-1	N/A				
ADS-2	N/A				
ADS-3	N/A				
ADS-4	N/A				
CMT actuation	25.3				
Cavity flooding actuation	4767.8				
Open recirculation lines if IRWST is drained to low level	N/A				
PRHR actuation	N/A				

Revision 1

Table 41A-30					
SEQUENCE 3D-5					
Description Time (s)					
Reactor scram	149.1				
Main coolant pumps off	165.7				
Core uncovery	5741.9				
Beginning of core relocation	9942.5				
Accumulator water depleted	3949.5				
PCS actuation	307.5				
ADS-1	N/A				
ADS-2	3767				
ADS-3	N/A				
ADS-4	N/A				
CMT actuation	165				
Cavity flooding actuation	6871.7				
Open recirculation lines if IRWST is drained to low level	15987.2				
PRHR actuation	167.7				

Table 41A-31		
SEQUENCE 3BL-1		
Description	Time (s)	
Reactor scram	149	
Main coolant pumps off	165.3	
Core uncovery	25779.2	
Beginning of core relocation	31272.2	
Accumulator water depleted	2511.1	
PCS actuation	289.6	
ADS-1	2043.7	
ADS-2	2163.7	
ADS-3	2283.7	
ADS-4	2945.3	
CMT actuation	165.4	
Cavity flooding actuation	N/A	
Open recirculation lines if IRWST is drained to low level	N/A	
PRHR actuation	N/A	

Table 41A-32			
SEQUENCE 3BL-2			
Description	Time (s)		
Reactor scram	20.5		
Main coolant pumps off	25.3		
Core uncovery	38424.7		
Beginning of core relocation	54174.3		
Accumulator water depleted	901.9		
PCS actuation	55.9		
ADS-1	617.2		
ADS-2	737		
ADS-3	857		
ADS-4	1594		
CMT actuation	25.3		
Cavity flooding actuation	N/A		
Open recirculation lines if IRWST is drained to low level	N/A		
PRHR actuation	N/A		

Table 41A-33		
SEQUENCE 3C-1		
Description	Time (s)	
Reactor scram	0.1	
Main coolant pumps off	0.6	
Core uncovery	6	
Beginning of core relocation	1544.8	
Accumulator water depleted	302.9	
PCS actuation	0.645	
ADS-1	555.5	
ADS-2	675.5	
ADS-3	795.5	
ADS-4	1312.5	
CMT actuation	0.6	
Cavity flooding actuation	N/A	
Open recirculation lines if IRWST is drained to low level	-	
PRHR actuation	N/A	

Table 41A-34			
SEQUENCE 3BR-1a			
Description	Time (s)		
Reactor scram	0.2		
Main coolant pumps off	0.7		
Core uncovery	12.7		
Beginning of core relocation	5155.3		
Accumulator water depleted	N/A		
PCS actuation	0.7		
ADS-1	372.3		
ADS-2	492.3		
ADS-3	612.3		
ADS-4	1131.5		
CMT actuation	0.7		
Cavity flooding actuation	N/A		
Open recirculation lines if IRWST is drained to low level	N/A ′		
PRHR actuation	N/A		

Table 41A-35		
SEQUENCE 3BE-1		
Description	Time (s)	
Reactor scram	20.5	
Main coolant pumps off	25.3	
Core uncovery	2479.4	
Beginning of core relocation	-	
Accumulator water depleted	901	
PCS actuation	56	
ADS-1	615.7	
ADS-2	735.7	
ADS-3	855.7	
ADS-4	1594.2	
CMT actuation	25.3	
Cavity flooding actuation	3359.3	
Open recirculation lines if IRWST is drained to low level	N/A	
PRHR actuation	N/A	

Table 41A-36			
SEQUENCE 3BE-2			
Description	Time (s)		
Reactor scram	20.5		
Main coolant pumps off	25.3		
Core uncovery	2476.8		
Beginning of core relocation	5892.5		
Accumulator water depleted	901.4		
PCS actuation	56.1		
ADS-1	616.4		
ADS-2	736.4		
ADS-3	856.4		
ADS-4	1594.4		
CMT actuation	25.3		
Cavity flooding actuation	25.28		
Open recirculation lines if IRWST is drained to low level	N/A		
PRHR actuation	N/A		

Table 41A-37		
SEQUENCE 3BE-4		
Description	Time (s)	
Reactor scram	5	
Main coolant pumps off	5.3	
Core uncovery	2295.5	
Beginning of core relocation	5612.8	
Accumulator water depleted	371.5	
PCS actuation	5.3	
ADS-1	659.6	
ADS-2	779.6	
ADS-3	899.6	
ADS-4	1416	
CMT actuation	5.3	
Cavity flooding actuation	3156.5	
Open recirculation lines if IRWST is drained to low level	N/A	
PRHR actuation	N/A	

.. .

j

.....
41. Hydrogen Mixing and Combustion Analysis

-

Table 41A-38 SEQUENCE 3BE-5		
Reactor scram	149.1	
Main coolant pumps off	165.2	
Core uncovery	3816	
Beginning of core relocation	7557.9	
Accumulator water depleted	2514.5	
PCS actuation	289.3	
ADS-1	2047.4	
ADS-2	2167.4	
ADS-3	2287.4	
ADS-4	2946	
CMT actuation	165.2	
Cavity flooding actuation	4792.3	
Open recirculation lines if IRWST is drained to low level	N/A	
PRHR actuation	N/A	

٠

Table 41A-39		
SEQUENCE 3BE-6		
Description	Time (s)	
Reactor scram	149.1	
Main coolant pumps off	165.7	
Core uncovery	3816	
Beginning of core relocation	7523.8	
Accumulator water depleted	2511.5	
PCS actuation	287.8	
ADS-1	2043.6	
ADS-2	2163.6	
ADS-3	2283.6	
ADS-4	2283.6	
CMT actuation	165.7	
Cavity flooding actuation	4793.2	
Open recirculation lines if IRWST is drained to low level	N/A	
PRHR actuation	N/A	

41. Hydrogen Mixing and Combustion Analysis

Table 41A-40		
SEQUENCE 3BE-8		
Description	Time (s)	
Reactor scram	164.9	
Main coolant pumps off	181.7	
Core uncovery	149178.3	
Beginning of core relocation	157707.5	
Accumulator water depleted	112312	
PCS actuation	11515.3	
ADS-1	N/A	
ADS-2	144811.2	
ADS-3	_	
ADS-4	N/A	
CMT actuation	181.7	
Cavity flooding actuation	151996.8	
Open recirculation lines if IRWST is drained to low level	160690	
PRHR actuation	183.4	

Table 41A-41 SEQUENCE 3BE-9		
Reactor scram	164.9	
Main coolant pumps off	181.7	
Core uncovery	148640	
Beginning of core relocation	159243.2	
Accumulator water depleted	112312	
PCS actuation	11515.3	
ADS-1	144571.2	
ADS-2	144691.2	
ADS-3	144811.2	
ADS-4	145192	
CMT actuation	181.7	
Cavity flooding actuation	151241.9	
Open recirculation lines if IRWST is drained to low level	N/A	
PRHR actuation	183.4	



Figure 41A-1

Case 3BE-1: Reactor Coolant System Pressure DVI Line Break for Containment Water Level



Figure 41A-2

Case 3BE-1: Core-Exit Gas Temperature DVI Line Break for Containment Water Level



Figure 41A-3

Case 3BE-1: Reactor Vessel Mixture Level DVI Line Break for Containment Water Level



Figure 41A-4

Case 3BE-1: Hydrogen Generated In-Vessel DVI Line Break for Containment Water Level



Case 3BE-1: Containment Gas Temperature DVI Line Break for Containment Water Level



Figure 41A-7

Case 3BE-1: Containment Compartments Water Level DVI Line Break for Containment Water Level









Figure 41A-9

Case 3BE-1: Well-Mixed Compartment Steam Concentration DVI Line Break for Containment Water Level











Figure 41A-13

Case 3BE-1: Confined Compartment Oxygen Concentration DVI Line Break for Containment Water Level



Case 3BE-1: Equivalence Ratio in SG Room DVI Line Break for Containment Water Level





Case 3BE-1: Equivalence Ratio in CMT Room **DVI Line Break for Containment Water Level**



Figure 41A-16

Case 3BE-1: Equivalence Ratio in IRWST **DVI Line Break for Containment Water Level**



Figure 41A-17

Case 3BE-1: Equivalence Ratio in PXS DVI Line Break for Containment Water Level



Figure 41A-18





Case 3BE-2: Reactor Vessel Mixture Level DVI Line Break with Failed Gravity Injection and No PXS Flooding



Figure 41A-21

Case 3BE-2: Hydrogen Generated In-Vessel DVI Line Break with Failed Gravity Injection and No PXS Flooding



Figure 41A-22

Case 3BE-2: Containment Pressure DVI Line Break with Failed Gravity Injection and No PXS Flooding





Figure 41A-24

Case 3BE-2: Containment Compartments Water Level DVI Line Break with Failed Gravity Injection and No PXS Flooding





Case 3BE-2: Well-Mixed Compartment Hydrogen Concentration DVI Line Break with Failed Gravity Injection and No PXS Flooding



Figure 41A-26

Case 3BE-2: Well-Mixed Compartment Steam Concentration DVI Line Break with Failed Gravity Injection and No PXS Flooding



Case 3BE-2: Confined Compartment Hydrogen Concentration DVI Line Break with Failed Gravity Injection and No PXS Flooding



Figure 41A-29





Figure 41A-30





Figure 41A-31

Case 3BE-2: Equivalence Ratio in SG Room DVI Line Break with Failed Gravity Injection and No PXS Flooding



Figure 41A-32

Case 3BE-2: Equivalence Ratio in CMT Room DVI Line Break with Failed Gravity Injection and No PXS Flooding



Figure 41A-33

Case 3BE-2: Equivalence Ratio in IRWST DVI Line Break with Failed Gravity Injection and No PXS Flooding



Case 3BE-2: Equivalence Ratio in PXS DVI Line Break with Failed Gravity Injection and No PXS Flooding



Figure 41A-35

Case 3BE-4: Reactor Coolant System Pressure Spurious ADS, Failed Gravity Injection



Figure 41A-36

Case 3BE-4: Core-Exit Gas Temperature Spurious ADS, Failed Gravity Injection



Figure 41A-37

Case 3BE-4: Reactor Vessel Mixture Level Spurious ADS, Failed Gravity Injection



Figure 41A-38

Case 3BE-4: Hydrogen Generated In-Vessel Spurious ADS, Failed Gravity Injection



Case 3BE-4: Containment Gas Temperature Spurious ADS, Failed Gravity Injection



Figure 41A-41

Case 3BE-4: Containment Compartments Water Level Spurious ADS, Failed Gravity Injection







3BE-4: Well-Mixed Compartment Oxygen Concentration Spurious ADS, Failed Gravity Injection

ł



Case 3BE-4: Confined Compartment Hydrogen Concentration Spurious ADS, Failed Gravity Injection







Figure 41A-47





Case 3BE-4: Equivalence Ratio in SG Room Spurious ADS, Failed Gravity Injection



Figure 41A-49

Case 3BE-4: Equivalence Ratio in CMT Room Spurious ADS, Failed Gravity Injection



Figure 41A-50

Case 3BE-4: Equivalence Ratio in IRWST Spurious ADS, Failed Gravity Injection



Figure 41A-51





Figure 41A-52

Case 3BE-5: Reactor Coolant System Pressure SBLOCA with Failed Gravity Injection





Figure 41A-55

Case 3BE-5: Hydrogen Generated In-Vessel SBLOCA with Failed Gravity Injection



Figure 41A-56

Case 3BE-5: Containment Pressure SBLOCA with Failed Gravity Injection



Case 3BE-5: Containment Gas Temperature SBLOCA with Failed Gravity Injection



Figure 41A-58

Case 3BE-5: Containment Compartments Water Level SBLOCA with Failed Gravity Injection

.



Case 3BE-5: Well-Mixed Compartment Steam Concentration SBLOCA with Failed Gravity Injection





Case 3BE-5: Well-Mixed Compartment Oxygen Concentration SBLOCA with Failed Gravity Injection



Figure 41A-62

Case 3BE-5: Confined Compartment Hydrogen Concentration SBLOCA with Failed Gravity Injection



Case 3BE-5: Confined Compartment Oxygen Concentration SBLOCA with Failed Gravity Injection


Figure 41A-65





Case 3BE-5: Equivalence Ratio in CMT Room SBLOCA with Failed Gravity Injection



Case 3BE-5: Equivalence Ratio in PXS SBLOCA with Failed Gravity Injection

.); ~ ;;









Case 3BE-6: Core-Exit Gas Temperature SBLOCA with Failed Gravity Injection



Figure 41A-71

and the second





Figure 41A-72

Case 3BE-6: Hydrogen Generated In-Vessel SBLOCA with Failed Gravity Injection

41. Hydrogen Mixing and Combustion Analysis



Figure 41A-73

Case 3BE-6: Containment Pressure SBLOCA with Failed Gravity Injection



Loop Compartments IRWST Compartment

Figure 41A-74

Case 3BE-6: Containment Gas Temperature SBLOCA with Failed Gravity Injection



Case 3BE-6: Containment Compartments Water Level SBLOCA with Failed Gravity Injection



Figure 41A-76

Case 3BE-6: Well-Mixed Compartment Hydrogen Concentration SBLOCA with Failed Gravity Injection



Case 3BE-6: Well-Mixed Compartment Steam Concentration SBLOCA with Failed Gravity Injection



Figure 41A-78

Case 3BE-6: Well-Mixed Compartment Oxygen Concentration SBLOCA with Failed Gravity Injection



Figure 41A-79

Case 3BE-6: Confined Compartment Hydrogen Concentration SBLOCA with Failed Gravity Injection



Case 3BE-6: Confined Compartment Steam Concentration SBLOCA with Failed Gravity Injection



Figure 41A-81

Case 3BE-6: Confined Compartment Oxygen Concentration SBLOCA with Failed Gravity Injection



Case 3BE-6: Equivalence Ratio in SG Room SBLOCA with Failed Gravity Injection

41. Hydrogen Mixing and Combustion Analysis



Figure 41A-83

Case 3BE-6: Equivalence Ratio in CMT Room SBLOCA with Failed Gravity Injection



Figure 41A-84

Case 3BE-6: Equivalence Ratio in IRWST SBLOCA with Failed Gravity Injection



Figure 41A-85





Figure 41A-86

Case 3BE-8: Reactor Coolant System Pressure SGTR



e Level SGTR



Figure 41A-89

Case 3BE-8: Hydrogen Generated In-Vessel SGTR



Figure 41A-90

Case 3BE-8: Containment Pressure SGTR



Case 3BE-8: Containment Gas Temperature SGTR



Figure 41A-92

Case 3BE-8: Containment Compartments Water Level SGTR

- * - * - *



```
Figure 41A-93
```









Figure 41A-95

Case 3BE-8: Well-Mixed Compartment Oxygen Concentration SGTR



Figure 41A-96





Figure 41A-97

Case 3BE-8: Confined Compartment Steam Concentration SGTR







Figure 41A-100





Case 3BE-8: Equivalence Ratio in PXS SGTR

.



Figure 41A-103

Case 3BE-9: Reactor Coolant System Pressure SGTR



Figure 41A-104

Case 3BE-9: Core-Exit Gas Temperature SGTR



Figure 41A-105

Case 3BE-9: Reactor Vessel Mixture Level SGTR



Figure 41A-106

Case 3BE-9: Hydrogen Generated In-Vessel SGTR



Case 3BE-9: Containment Gas Temperature SGTR



Case 3BE-9: Containment Compartments Water Level SGTR



Figure 41A-110

Case 3BE-9: Well-Mixed Compartment Hydrogen Concentration SGTR



Case 3BE-9: Well-Mixed Compartment Oxygen Concentration SGTR



Figure 41A-113

Case 3BE-9: Confined Compartment Hydrogen Concentration SGTR



Figure 41A-114





Figure 41A-115

Case 3BE-9: Confined Compartment Oxygen Concentration SGTR



Figure 41A-116

1.

i

Case 3BE-9: Equivalence Ratio in SG Room SGTR



Figure 41A-117

Case 3BE-9: Equivalence Ratio in CMT Room SGTR



Figure 41A-118





Figure 41A-119





Figure 41A-120

Case 3BL-1: Reactor Coolant System Pressure SBLOCA with Failed Gravity Recirculation



Case 3BL-1: Reactor Vessel Mixture Level SBLOCA with Failed Gravity Recirculation



Figure 41A-123

Case 3BL-1: Hydrogen Generated In-Vessel SBLOCA with Failed Gravity Recirculation



Figure 41A-124

Case 3BL-1: Containment Pressure SBLOCA with Failed Gravity Recirculation



Case 3BL-1: Containment Gas Temperature SBLOCA with Failed Gravity Recirculation



Figure 41A-126

Case 3BL-1: Containment Compartments Water Level SBLOCA with Failed Gravity Recirculation



Case 3BL-1: Well-Mixed Compartment Steam Concentration SBLOCA with Failed Gravity Recirculation





Figure 41A-129

Case 3BL-1: Well-Mixed Compartment Oxygen Concentration SBLOCA with Failed Gravity Recirculation







Figure 41A-131

Case 3BL-1: Confined Compartment Steam Concentration SBLOCA with Failed Gravity Recirculation



Figure 41A-132

Case 3BL-1: Confined Compartment Oxygen Concentration SBLOCA with Failed Gravity Recirculation



Figure 41A-133

Case 3BL-1: Equivalence Ratio in SG Room SBLOCA with Failed Gravity Recirculation



Figure 41A-134

Case 3BL-1: Equivalence Ratio in CMT Room SBLOCA with Failed Gravity Recirculation



Case 3BL-1: Equivalence Ratio in PXS SBLOCA with Failed Gravity Recirculation


Figure 41A-137

Case 3BL-2: Reactor Coolant System Pressure DVI Line Break with Failed Gravity Recirculation



Figure 41A-138

Case 3BL-2: Core-Exit Gas Temperature DVI Line Break with Failed Gravity Recirculation



Revision 1



Case 3BL-2: Containment Gas Temperature DVI Line Break with Failed Gravity Recirculation



Figure 41A-143

Case 3BL-2: Containment Compartments Water Level DVI Line Break with Failed Gravity Recirculation



Figure 41A-144





Figure 41A-145

Case 3BL-2: Well-Mixed Compartment Steam Concentration DVI Line Break with Failed Gravity Recirculation



Figure 41A-146

Case 3BL-2: Well-Mixed Compartment Oxygen Concentration DVI Line Break with Failed Gravity Recirculation







Figure 41A-149





Case 3BL-2: Equivalence Ratio in SG Room DVI Line Break with Failed Gravity Recirculation



Case 3BL-2: Equivalence Ratio in IRWST DVI Line Break with Failed Gravity Recirculation



Figure 41A-153

Case 3BL-2: Equivalence Ratio in PXS DVI Line Break with Failed Gravity Recirculation



Figure 41A-154

Case 3BR-1: Reactor Coolant System Pressure CL LBLOCA with Accumulator Failure





Figure 41A-157

Case 3BR-1: Hydrogen Generated In-Vessel CL LBLOCA with Accumulator Failure



Figure 41A-158

Case 3BR-1: Containment Pressure CL LBLOCA with Accumulator Failure

.



Figure 41A-159

Case 3BR-1: Containment Gas Temperature CL LBLOCA with Accumulator Failure



Figure 41A-160

Case 3BR-1: Containment Compartments Water Level CL LBLOCA with Accumulator Failure





Figure 41A-161

Case 3BR-1: Well-Mixed Compartment Hydrogen Concentration CL LBLOCA with Accumulator Failure



Figure 41A-162

Case 3BR-1: Well-Mixed Compartment Steam Concentration CL LBLOCA with Accumulator Failure



Case 3BR-1: Well-Mixed Compartment Oxygen Concentration CL LBLOCA with Accumulator Failure



Figure 41A-164

Case 3BR-1: Confined Compartment Hydrogen Concentration CL LBLOCA with Accumulator Failure



Figure 41A-165

Case 3BR-1: Confined Compartment Steam Concentration CL LBLOCA with Accumulator Failure







Figure 41A-167

Case 3BR-1: Equivalence Ratio in SG Room CL LBLOCA with Accumulator Failure



Figure 41A-168

Case 3BR-1: Equivalence Ratio in CMT Room CL LBLOCA with Accumulator Failure

л Е



Figure 41A-169





Case 3BR-1: Equivalence Ratio in PXS CL LBLOCA with Accumulator Failure



Figure 41A-171

Case 3BR-1a: Reactor Coolant System Pressure CL LBLOCA with Accumulator Failure



Figure 41A-172

Case 3BR-1a: Core-Exit Gas Temperature CL LBLOCA with Accumulator Failure





Figure 41A-173

Case 3BR-1a: Reactor Vessel Mixture Level CL LBLOCA with Accumulator Failure



Figure 41A-174

Case 3BR-1a: Hydrogen Generated In-Vessel CL LBLOCA with Accumulator Failure



41A-128



Case 3BR-1a: Containment Compartments Water Level CL LBLOCA with Accumulator Failure



Figure 41A-178

Case 3BR-1a: Well-Mixed Compartment Hydrogen Concentration CL LBLOCA with Accumulator Failure



Case 3BR-1a: Well-Mixed Compartment Oxygen Concentration CL LBLOCA with Accumulator Failure



Figure 41A-181

Case 3BR-1a: Confined Compartment Hydrogen Concentration CL LBLOCA with Accumulator Failure



Figure 41A-182

Case 3BR-1a: Confined Compartment Steam Concentration CL LBLOCA with Accumulator Failure



Figure 41A-183





Figure 41A-184

Case 3BR-1a: Equivalence Ratio in SG Room CL LBLOCA with Accumulator Failure



Figure 41A-185

Case 3BR-1a: Equivalence Ratio in CMT Room CL LBLOCA with Accumulator Failure



Figure 41A-186

Case 3BR-1a: Equivalence Ratio in IRWST CL LBLOCA with Accumulator Failure



Revision 1



Case 3C-1: Core-Exit Gas Temperature Vessel Rupture



Figure 41A-190

Case 3C-1: Reactor Vessel Mixture Level Vessel Rupture



Figure 41A-192

Case 3C-1: Containment Pressure Vessel Rupture

1.54





Case 3C-1: Containment Gas Temperature Vessel Rupture





Figure 41A-194

Case 3C-1: Containment Compartments Water Level Vessel Rupture



Case 3C-1: Well-Mixed Compartment Hydrogen Concentration Vessel Rupture



Figure 41A-196





```
Figure 41A-197
```

Case 3C-1: Well-Mixed Compartment Oxygen Concentration Vessel Rupture



Figure 41A-198

Case 3C-1: Confined Compartment Hydrogen Concentration Vessel Rupture



Figure 41A-199





Figure 41A-200

Case 3C-1: Confined Compartment Oxygen Concentration Vessel Rupture









Case 3C-1: Equivalence Ratio in CMT Room Vessel Rupture



Figure 41A-203

Case 3C-1: Equivalence Ratio in IRWST Vessel Rupture



Figure 41A-204

Case 3C-1: Equivalence Ratio in PXS Vessel Rupture





Case 3D-1: Reactor Coolant System Pressure Spurious ADS-4 with Failed CMTs



Figure 41A-206

.

Case 3D-1: Core-Exit Gas Temperature Spurious ADS-4 with Failed CMTs



Figure 41A-207

いないていてい

Case 3D-1: Reactor Vessel Mixture Level Spurious ADS-4 with Failed CMTs



Figure 41A-208

Case 3D-1: Hydrogen Generated In-Vessel Spurious ADS-4 with Failed CMTs


Case 3D-1: Containment Gas Temperature Spurious ADS-4 with Failed CMTs



Case 3D-1: Containment Compartments Water Level Spurious ADS-4 with Failed CMTs



Figure 41A-212

Case 3D-1: Well-Mixed Compartment Hydrogen Concentration Spurious ADS-4 with Failed CMTs







Spurious ADS-4 with Failed CMTs







Case 3D-1: Confined Compartment Hydrogen Concentration Spurious ADS-4 with Failed CMTs



Figure 41A-216

.;¢

18

Case 3D-1: Confined Compartment Steam Concentration Spurious ADS-4 with Failed CMTs



Figure 41A-217

Case 3D-1: Confined Compartment Oxygen Concentration Spurious ADS-4 with Failed CMTs



Case 3D-1: Equivalence Ratio in SG Room Spurious ADS-4 with Failed CMTs



Figure 41A-219

Case 3D-1: Equivalence Ratio in CMT Room Spurious ADS-4 with Failed CMTs



Figure 41A-220

Case 3D-1: Equivalence Ratio in IRWST Spurious ADS-4 with Failed CMTs



Figure 41A-221

Case 3D-1: Equivalence Ratio in PXS Spurious ADS-4 with Failed CMTs



Figure 41A-222

Case 3D-2: Reactor Coolant System Pressure Spurious ADS-2, Failed CMTs







Case 3D-2: Containment Pressure Spurious ADS-2, Failed CMTs



Figure 41A-228

Case 3D-2: Containment Compartments Water Level Spurious ADS-2, Failed CMTs



Figure 41A-229

Case 3D-2: Well-Mixed Compartment Hydrogen Concentration Spurious ADS-2, Failed CMTs



Case 3D-2: Well-Mixed Compartment Steam Concentration Spurious ADS-2, Failed CMTs



Spurious ADS-2, Failed CMTs



Figure 41A-233





Case 3D-2: Confined Compartment Oxygen Concentration Spurious ADS-2, Failed CMTs



Figure 41A-235





Figure 41A-236

Case 3D-2: Equivalence Ratio in CMT Room Spurious ADS-2, Failed CMTs



Figure 41A-237

Case 3D-2: Equivalence Ratio in IRWST Spurious ADS-2, Failed CMTs



Figure 41A-238

Case 3D-2: Equivalence Ratio in PXS Spurious ADS-2, Failed CMTs



Figure 41A-239

Case 3D-3: Reactor Coolant System Pressure DVI Line Break with no ADS



Figure 41A-240

Case 3D-3: Core-Exit Gas Temperature DVI Line Break with no ADS

ما يغتنيه





Figure 41A-241

Case 3D-3: Reactor Vessel Mixture Level DVI Line Break with no ADS



Figure 41A-242

Case 3D-3: Hydrogen Generated In-Vessel DVI Line Break with no ADS



se 3D-3: Containment Gas Temperature DVI Line Break with no ADS



Case 3D-3: Containment Compartments Water Level DVI Line Break with no ADS



Figure 41A-246



٦



DVI Line Break with no ADS



Figure 41A-249

Case 3D-3: Confined Compartment Hydrogen Concentration DVI Line Break with no ADS



Figure 41A-250





Figure 41A-251





Case 3D-3: Equivalence Ratio in SG Room DVI Line Break with no ADS



Figure 41A-253

Case 3D-3: Equivalence Ratio in CMT Room DVI Line Break with no ADS



Figure 41A-254

Case 3D-3: Equivalence Ratio in IRWST DVI Line Break with no ADS



Case 3D-5: Reactor Coolant System Pressure Spurious ADS-2, Failed CMTs, Diffusion Flame



Case 3D-5: Reactor Vessel Mixture Level Spurious ADS-2, Failed CMTs, Diffusion Flame



Case 3D-5: Containment Pressure Spurious ADS-2, Failed CMTs, Diffusion Flame



Case 3D-5: Containment Gas Temperature Spurious ADS-2, Failed CMTs, Diffusion Flame



Figure 41A-262

Case 3D-5: Containment Compartments Water Level Spurious ADS-2, Failed CMTs, Diffusion Flame



Case 3D-5: Well-Mixed Compartment Steam Concentration Spurious ADS-2, Failed CMTs, Diffusion Flame





Case 3D-5: Well-Mixed Compartment Oxygen Concentration Spurious ADS-2, Failed CMTs, Diffusion Flame







Figure 41A-268





Figure 41A-269

Case 3D-5: Equivalence Ratio in SG Room Spurious ADS-2, Failed CMTs, Diffusion Flame



Case 3D-5: Equivalence Ratio in CMT Room Spurious ADS-2, Failed CMTs, Diffusion Flame

.1 +

5



Figure 41A-272

+ .1 25

Case 3D-5: Equivalence Ratio in PXS Spurious ADS-2, Failed CMTs, Diffusion Flame

20

. Time (hr)

10

15



Figure 41A-273

Case 1A-3: Reactor Coolant System Pressure FW Failure with Creep of SG Tubes



Case 1A-3: Core-Exit Gas Temperature FW Failure with Creep of SG Tubes



Figure 41A-275

Case 1A-3: Reactor Vessel Mixture Level FW Failure with Creep of SG Tubes



Figure 41A-276

Case 1A-3: Hydrogen Generated In-Vessel FW Failure with Creep of SG Tubes



Case 1A-3: Containment Gas Temperature FW Failure with Creep of SG Tubes



Case 1A-3: Containment Compartments Water Level FW Failure with Creep of SG Tubes



Figure 41A-280

Case 1A-3: Well-Mixed Compartment Hydrogen Concentration FW Failure with Creep of SG Tubes




Case 1A-3: Well-Mixed Compartment Oxygen Concentration FW Failure with Creep of SG Tubes



Figure 41A-283

Case 1A-3: Confined Compartment Hydrogen Concentration FW Failure with Creep of SG Tubes







Figure 41A-285

Case 1A-3: Confined Compartment Oxygen Concentration FW Failure with Creep of SG Tubes



Case 1A-3: Equivalence Ratio in SG Room FW Failure with Creep of SG Tubes



Figure 41A-287

Case 1A-3: Equivalence Ratio in CMT Room FW Failure with Creep of SG Tubes



Figure 41A-288

Case 1A-3: Equivalence Ratio in IRWST FW Failure with Creep of SG Tubes



Figure 41A-289

Case 1A-3: Equivalence Ratio in PXS FW Failure with Creep of SG Tubes



Figure 41A-290

Case 1A-3a: Reactor Coolant System Pressure Transient with Creep of SG Tubes



1

あいていたい

41A-186



Figure 41A-293

Case 1A-3a: Hydrogen Generated In-Vessel Transient with Creep of SG Tubes



Case 1A-3a: Containment Pressure Transient with Creep of SG Tubes



Figure 41A-295

Case 1A-3a: Containment Gas Temperature Transient with Creep of SG Tubes



Figure 41A-296

Case 1A-3a: Containment Compartments Water Level Transient with Creep of SG Tubes



•6







Figure 41A-298

Case 1A-3a: Well-Mixed Compartment Steam Concentration **Transient with Creep of SG Tubes**



Case 1A-3a: Confined Compartment Hydrogen Concentration Transient with Creep of SG Tubes



Figure 41A-301

Case 1A-3a: Confined Compartment Steam Concentration Transient with Creep of SG Tubes







Figure 41A-303

Case 1A-3a: Approximate Detonation Cell Width in SG Room Transient with Creep of SG Tubes



Case 1A-3a: Approximate Detonation Cell Width in CMT Room Transient with Creep of SG Tubes



Figure 41A-305

Case 1A-3a: Equivalence Ratio in IRWST Transient with Creep of SG Tubes







Figure 41A-307

Case 1A-4: Reactor Coolant System Pressure FW Failure with Creep of SG Tubes



Figure 41A-308

Case 1A-4: Core-Exit Gas Temperature FW Failure with Creep of SG Tubes





Figure 41A-309

Case 1A-4: Reactor Vessel Mixture Level FW Failure with Creep of SG Tubes



Figure 41A-310

Case 1A-4: Hydrogen Generated In-Vessel FW Failure with Creep of SG Tubes



Case 1A-4: Containment Gas Temperature FW Failure with Creep of SG Tubes



Figure 41A-313

Case 1A-4: Containment Compartments Water Level FW Failure with Creep of SG Tubes







FW Failure with Creep of SG Tubes

J A





Figure 41A-317

Case 1A-4: Confined Compartment Hydrogen Concentration FW Failure with Creep of SG Tubes











Figure 41A-320

Case 1A-4: Equivalence Ratio in SG Room FW Failure with Creep of SG Tubes



Figure 41A-321

Case 1A-4: Equivalence Ratio in CMT Room FW Failure with Creep of SG Tubes



Figure 41A-322

Case 1A-4: Equivalence Ratio in IRWST FW Failure with Creep of SG Tubes



Figure 41A-323





Figure 41A-324

Case 1A-4a: Reactor Coolant System Pressure Transient with Creep of SG Tubes 41. Hydrogen Mixing and Combustion Analysis

)



Figure 41A-326

Case 1A-4a: Reactor Vessel Mixture Level Transient with Creep of SG Tubes



Figure 41A-327

Case 1A-4a: Hydrogen Generated In-Vessel Transient with Creep of SG Tubes



Figure 41A-328

Revision 1

Case 1A-4a: Containment Pressure Transient with Creep of SG Tubes



Figure 41A-329

Case 1A-4a: Containment Gas Temperature Transient with Creep of SG Tubes



Figure 41A-330

Case 1A-4a: Containment Compartments Water Level Transient with Creep of SG Tubes



Case 1A-4a: Well-Mixed Compartment Steam Concentration Transient with Creep of SG Tubes





Figure 41A-333

Case 1A-4a: Well-Mixed Compartment Oxygen Concentration Transient with Creep of SG Tubes



Case 1A-4a: Confined Compartment Hydrogen Concentration Transient with Creep of SG Tubes



Figure 41A-335

Case 1A-4a: Confined Compartment Steam Concentration Transient with Creep of SG Tubes



Figure 41A-336

Case 1A-4a: Confined Compartment Oxygen Concentration Transient with Creep of SG Tubes



Figure 41A-337

Case 1A-4a: Approximate Detonation Cell Width in SG Room Transient with Creep of SG Tubes



Case 1A-4a: Equivalence Ratio in CMT Room Transient with Creep of SG Tubes



;! `{

Case 1A-4a: Equivalence Ratio in PXS Transient with Creep of SG Tubes



Figure 41A-341

Case 1AP-3: Reactor Coolant System Pressure SBLOCA, Failed PRHR and CMTs



Case 1AP-3: Core-Exit Gas Temperature SBLOCA, Failed PRHR and CMTs



Figure 41A-343

Case 1AP-3: Reactor Vessel Mixture Level SBLOCA, Failed PRHR and CMTs



Figure 41A-344

3

٦,

Case 1AP-3: Hydrogen Generated In-Vessel SBLOCA, Failed PRHR and CMTs



Figure 41A-345

Case 1AP-3: Containment Pressure SBLOCA, Failed PRHR and CMTs



Loop Compartments

Figure 41A-346

Case 1AP-3: Containment Gas Temperature SBLOCA, Failed PRHR and CMTs



Figure 41A-347

Case 1AP-3: Containment Compartments Water Level SBLOCA, Failed PRHR and CMTs



Figure 41A-348

Case 1AP-3: Well-Mixed Compartment Hydrogen Concentration SBLOCA, Failed PRHR and CMTs





Figure 41A-349

Case 1AP-3: Well-Mixed Compartment Steam Concentration SBLOCA, Failed PRHR and CMTs



Figure 41A-350

Case 1AP-3: Well-Mixed Compartment Oxygen Concentration SBLOCA, Failed PRHR and CMTs



SBLOCA, Failed PRHR and CMTs

41A-216


Figure 41A-353

Case 1AP-3: Confined Compartment Oxygen Concentration SBLOCA, Failed PRHR and CMTs



Case 1AP-3: Equivalence Ratio in SG Room SBLOCA, Failed PRHR and CMTs



Figure 41A-355

Case 1AP-3: Equivalence Ratio in CMT Room SBLOCA, Failed PRHR and CMTs



Figure 41A-356

Case 1AP-3: Equivalence Ratio in IRWST SBLOCA, Failed PRHR and CMTs



Figure 41A-357

Case 1AP-3: Equivalence Ratio in PXS SBLOCA, Failed PRHR and CMTs



Case 1AP-4: Reactor Coolant System Pressure SBLOCA with Failed PRHR and ADS



SBLOCA with Failed PRHR and ADS



Figure 41A-361

Case 1AP-4: Hydrogen Generated In-Vessel SBLOCA with Failed PRHR and ADS



Figure 41A-362

Case 1AP-4: Containment Pressure SBLOCA with Failed PRHR and ADS



Case 1AP-4: Containment Gas Temperature SBLOCA with Failed PRHR and ADS





Figure 41A-364







Case 1AP-4: Well-Mixed Compartment Steam Concentration SBLOCA with Failed PRHR and ADS



Case 1AP-4: Confined Compartment Hydrogen Concentration SBLOCA with Failed PRHR and ADS



Figure 41A-369

Case 1AP-4: Confined Compartment Steam Concentration SBLOCA with Failed PRHR and ADS







Figure 41A-371

Case 1AP-4: Equivalence Ratio in SG Room SBLOCA with Failed PRHR and ADS



Figure 41A-372

Case 1AP-4: Equivalence Ratio in CMT Room SBLOCA with Failed PRHR and ADS



Case 1AP-4: Equivalence Ratio in PXS SBLOCA with Failed PRHR and ADS

ATTACHMENT 41B

ANALYSIS OF HYDROGEN BURNING AT IGNITERS

This section demonstrates the effectiveness of the AP1000 hydrogen igniter system as placed in the passive containment geometry (subsection 6.2.4 of the DCD). The AP1000 containment has 64 igniters. Below the operating deck and inside the steam generator doghouses, the igniters are placed as in the AP600. Above the operating deck, in the upper compartment, the AP1000 has the same number of igniters as the AP600, but they have been redistributed to provide appropriate coverage given the taller containment shell. Igniters located in the IRWST, PXS and CVS compartments, CMT room, and various elevations in the upper compartment provide coverage for hydrogen that may be released through the IRWST, through the PXS/CVS, or in the CMT room.

The igniter system maintains the global uniform hydrogen concentration in the containment at or below lower flammability limits. In the most likely severe accidents, the hydrogen is burned primarily in a favorable location that protects the integrity of the containment and mitigative and monitoring equipment.

One MAAP4 igniter burning case is presented. The case is considered to be bounding as it releases hydrogen to the containment at an artificially rapid rate (~300 kg/min) to tax the igniter performance. Typical hydrogen release rates during a reflooded case are expected to be on the order of 100 kg/min. The case is initiated by a large loss-of-coolant accident with failure of accumulators. The core uncovers during the blowdown, and gravity injection is unable to recover it before it overheats. The accident produces 100-percent cladding reaction, much of it generated during reflooding. The reactor coolant system is depressurized before hydrogen generation. Hydrogen is released to the containment through the break as it is generated in the core.

Burning at Igniters Results and Conclusions

The MAAP4 results are presented in Figures 41B-1 through 41B-17. The reactor coolant system is depressurized (Figure 41B-1) by the break, and the core uncovers early in the accident (Figures 41B-2 and 41B-3) and is reflooded. Decay heat is high early in the accident, and the cladding is overheated at the time of the reflood. Hydrogen is produced rapidly early in the accident with some residual oxidation occurring over time (Figure 41B-4). Burning at the igniters is evident from the fluctuations in the containment pressure and temperature (Figures 41B-5 and 41B-6).

The results show that the igniters keep the overall hydrogen concentration at the lower flammability limit (Figure 41B-7), except during the large release of hydrogen and steam into the loop compartment (Figure 41B-8) before the containment mixes. During this time, the gas concentrations (Figures 41B-9, 41B-10, and 41B-11) in the loop compartment will not support combustion in this compartment. As the containment begins to mix, the loop compartment mixture becomes flammable. The steam concentration is high and the minimum detonation cell width (Figure 41B-12) in the loop compartment is large at the time when the hydrogen concentration is greater than 10 percent and the compartment is predicted to be

flammable. Therefore, there is no potential for detonation in the loop compartment during the mixing.

Hydrogen is released directly into the IRWST (Figure 41B-14) after the water level in the compartment (Figure 41B-13) drops low enough to allow flow from the pressurizer through to the spargers. The hydrogen concentration in the IRWST (Figure 41B-15) is never predicted to exceed 6 percent.

The hydrogen igniters effectively control the containment hydrogen concentration for this bounding hydrogen release case.











Y

Case 3BR – LLOCA with Accumulator Failure Hydrogen Generated In-Vessel 41. Hydrogen Mixing and Combustion Analysis



(1) (1)

Figure 41B-6

Case 3BR – LLOCA with Accumulator Failure Containment Gas Temperature



Case 3BR – LLOCA with Accumulator Failure Containment Compartment Hydrogen Concentration



Case 3BR – LLOCA with Accumulator Failure Hydrogen Flow Rate Through Break



Figure 41B-9

Case 3BR – LLOCA with Accumulator Failure Well-Mixed Compartment Hydrogen Concentration



Figure 41B-10

Case 3BR – LLOCA with Accumulator Failure Well-Mixed Compartment Oxygen Concentration



Case 3BR – LLOCA with Accumulator Failure Approximate Detonation Cell Width in Steam Generator Compartment



Figure 41B-13

Case 3BR – LLOCA with Accumulator Failure Containment Compartments Water Level



Figure 41B-14

Case 3BR – LLOCA with Accumulator Failure Hydrogen Flow Rate Through ADS to IRWST



Case 3BR – LLOCA with Accumulator Failure Confined Compartment Hydrogen Concentration



Figure 41B-16

Case 3BR – LLOCA with Accumulator Failure Confined Compartment Oxygen Concentration



Case 3BR – LLOCA with Accumulator Failure Confined Compartment Steam Concentration