

50-387/388

MANUAL HARD COPY DISTRIBUTION

DOCUMENT TRANSMITTAL 2003-5469

USER INFORMATION:

[REDACTED] CA#: 0363
[REDACTED]
[REDACTED]

TRANSMITTAL INFORMATION:

[REDACTED] 02/06/2003

LOCATION: DOCUMENT CONTROL DESK
FROM: NUCLEAR RECORDS DOCUMENT CONTROL CENTER
(NUCSA-2)

THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY
OR ELECTRONIC MANUAL ASSIGNED TO YOU:

130 - 130 - HP II DOSE CALCULATOR: EMERGENCY PLAN-
POSITION SPECIFIC PROCEDURE

REMOVE MANUAL TABLE OF CONTENTS DATE: 01/17/2003

ADD MANUAL TABLE OF CONTENTS DATE: 02/05/2003

CATEGORY: PROCEDURES TYPE: EP

ID: EP-PS-130

REPLACE: REV:15

REPLACE: REV:15

UPDATES FOR HARD COPY MANUALS WILL BE DISTRIBUTED
WITHIN 5 DAYS IN ACCORDANCE WITH DEPARTMENT
PROCEDURES. PLEASE MAKE ALL CHANGES AND
ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON
RECEIPT OF HARD COPY. FOR ELECTRONIC MANUAL USERS,
ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND
ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

A045

PAVSS INSTRUCTIONS

INITIALIZATION OF PAVSS CHANNELS WILL BE PERFORMED BY CHEMISTRY.

A. PLACE "SPING" IN STANDBY

1. Turn "COMMAND ENABLE" key or "EDIT ENABLE" key.
2. Press [STAND-BY] [SPING #] [-] [0] [ENTER].

B. DELETE "SPING"

1. Press [FILE] [0] [ENTER].
2. Press arrow key (↑ or ↓) to scroll to "DEL UNIT adv-ch".
3. Turn the "EDIT ENABLE" key.
4. Press [EDIT].
5. Press [SPING #] [-] [0] [ENTER].
6. When message "DELETE CH.FILE" appears, answer [0] for "NO", [ENTER].

C. INITIALIZE "PAVSS"

1. Scroll to "ADD UNIT adv-ch".
2. Ensure the "EDIT ENABLE" key has been turned.
3. Press [EDIT].
4. Press [PAVSS #] [-] [0] [ENTER].
5. Press [FILE] [PAVSS #] [-] [CHANNEL #] [ENTER].
6. Scroll to inspect the file while comparing it to the calibration data sheet.

NOTE: Calibration data sheets can only be obtained from the Chemistry Lab.

PAVSS INSTRUCTIONS

D. DEALING WITH LIMITED IODINE-131/PARTICULATE DATA

The following are options when dose calculations must be performed, but valid I-131 and/or particulate release rate updates are not available:

1. If SPING Noble Gas data is available use:
 - a. The last available SPING Noble Gas (NG)/ I-131 and/or NG/Particulate ratio if plant conditions are not changing significantly, or
 - b. Use a default NG/I-131 of 1,000 and/or a default NG/Particulate ratio of 10,000 if Chemistry data is not available, or
 - c. Use Chemistry SPING sample results when available.
2. If PAVSS is in-service use:
 - a. The last available SPING Noble Gas (NG/I-131) and/or NG/Particulate ratio if plant conditions are not changing significantly, or
 - b. Use a default NG/I-131 ratio of 1,000 and/or a default NG/Particulate ratio of 10,000 if Chemistry data is not available, or
 - c. Use Chemistry SPING sample results if available, or
 - d. Use Chemistry PAVSS sample results when available.

Total Iodine Release Rate ($\mu\text{Ci} / \text{min}$) = Noble Gas Release Rate ($\mu\text{Ci} / \text{min}$) / Ratio(NG/I - 131)

Total Particulate Release Rate ($\mu\text{Ci} / \text{min}$) = Noble Gas Release Rate ($\mu\text{Ci} / \text{min}$) / Ratio(NG/Particulate)