

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.1.7.1	<p>-----NOTES-----</p> <ol style="list-style-type: none"> 1. Not required to be met for vacuum breakers that are open during Surveillances. 2. Not required to be met for vacuum breakers open when performing their intended function. <p>-----</p> <p>Verify each vacuum breaker is closed.</p>	14 days
SR 3.6.1.7.2	<p>-----NOTE-----</p> <p>Not required to be met for vacuum breaker 2ISC*RV36B for the remainder of Cycle 9.</p> <p>-----</p> <p>Perform a functional test of each vacuum breaker.</p>	<p>31 days</p> <p><u>AND</u></p> <p>Within 12 hours after any discharge of steam to the suppression chamber from the safety/relief valves</p>
SR 3.6.1.7.3	Verify the opening setpoint of each vacuum breaker is ≤ 0.25 psid.	24 months