



**Pacific Gas and
Electric Company**

James R. Becker
Vice President-Diablo Canyon
Operations and Station Director

Diablo Canyon Power Plant
PO Box 56
Avila Beach, CA 93424

805 545 3462
Fax 805 545 4234

February 14, 2003

PG&E Letter DCL-03-015

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2
Monthly Operating Report for January 2003

Dear Commissioners and Staff:

Attached is the Monthly Operating Report for Diablo Canyon Power Plant,
Units 1 and 2, for January 2003. This report is submitted in accordance with Technical
Specification 5.6.4 and NRC Generic Letter 97-02.

Sincerely,



James R. Becker

LMP/1713/R0241347

Enclosures

cc/enc: Paul R. Fox, American Nuclear Insurers
Robert D. Glynn, Jr.
Ellis W. Merschoff, NRC Regional Administrator, Region IV
David L. Proulx, NRC Senior Resident Inspector
Gregory M. Rueger
Girija S. Shukla, NRC Project Manager
INPO Record Center

IE24

**JANUARY 2003, OPERATION SUMMARIES
DIABLO CANYON POWER PLANT
UNITS 1 AND 2**

Summary of Unit 1 Operation

Unit 1 began January in Mode 1 (Power Operation) at approximately 100 percent power. There were no significant operational activities.

Summary of Unit 2 Operation

Unit 2 began January in Mode 1 at approximately 100 percent power. There were no significant operational activities. Unit 2 ended the month at approximately 95 percent power, coasting down to the 11th refueling outage scheduled to start February 3rd.

Actuations of Safety or Pressurizer Power Operated Relief Valves

There were no challenges to the pressurizer power operated relief valves, pressurizer safety valves, or steam generator safety valves.

OPERATING DATA REPORT

DOCKET NO.: 50-275
UNIT NAME: Diablo Canyon Unit 1
DATE: 2/03/2003
COMPLETED BY: L. M. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: January 2003

1.	Design Electrical Rating (MWe - Net):	1,103
2.	Maximum Dependable Capacity (MWe - Net):	1,087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	744.0	134,970.8
4.	Number of Hours Generator On-Line:	744.0	744.0	133,441.0
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	821,465	821,465	138,027,764

UNIT SHUTDOWNS

DOCKET NO.: 50-275
 UNIT NAME: Diablo Canyon Unit 1
 DATE: 2/03/2003
 COMPLETED BY: L. M. Parker
 TELEPHONE: (805) 545-3386

REPORT MONTH: January 2003

NO.	DATE (YYMMDD)	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F- Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

2. Method

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation from Previous Month
- 5-Other

OPERATING DATA REPORT

DOCKET NO.: 50-323
UNIT NAME: Diablo Canyon Unit 2
DATE: 2/03/2003
COMPLETED BY: L. M. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: January 2003

1.	Design Electrical Rating (MWe - Net):	1119
2.	Maximum Dependable Capacity (MWe - Net):	1087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	744.0	132,102.5
4.	Number of Hours Generator On-Line:	744.0	744.0	130,631.9
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	809,894	809,894	137,501,884

UNIT SHUTDOWNS

DOCKET NO.: 50-323
 UNIT NAME: Diablo Canyon Unit 2
 DATE: 2/03/2003
 COMPLETED BY: L. M. Parker
 TELEPHONE: (805) 545-3386

REPORT MONTH: January 2003

NO.	DATE (YYMMDD)	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason
- A-Equipment Failure (Explain)
 - B-Maintenance or Test
 - C-Refueling
 - D-Regulatory Restriction
 - E-Operator Training/License Examination
 - F- Administrative
 - G-Operational Error (Explain)
 - H-Other (Explain)

2. Method
- 1-Manual
 - 2-Manual Trip/Scram
 - 3-Automatic Trip/Scram
 - 4-Continuation from Previous Month
 - 5-Other