



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc
James A Fitzpatrick NPP
P O Box 110
Lycoming, NY 13093
Tel 315 349 6024 Fax 315 349 6480

February 14, 2003
JAFP-03-0022

T.A. Sullivan
Vice President, Operations-JAF

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station O-P1-17
Washington, DC 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Monthly Operating Report

Dear Sir:

Enclosed is the Monthly Operating Report for the James A. FitzPatrick Nuclear Power Plant for the month of January 2003.

Should you have any questions concerning this report, please direct them to Mr. Mick Baker, Thermal Performance Engineer, at (315) 349-6181.

Very truly yours,

A handwritten signature in cursive script, appearing to read "T.A. Sullivan".

T. A. SULLIVAN

TAS:BO:SB:SA:tmb
Enclosure

IE24

cc: Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
James A. FitzPatrick Nuclear Power Plant
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. Guy Vissing, Project Manager
Project Directorate I
Division of Licensing Project Management
U.S. Nuclear Regulatory Commission
Mail stop OWFN 8C2
Washington, DC 20555

Mr. R. Toole
ENN BWR SRC Operations Subcommittee Chairman
605 West Horner Street
Ebensburg, PA 15931

JENG JAFP Files
RMS (JAF)
RMS (WPO)

**ENTERGY NUCLEAR NORTHEAST
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

REPORT MONTH: JANUARY 2003

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	February 3, 2003
Completed By:	M. Baker
Telephone:	(315) 349-6181

DAY	NET AVERAGE DAILY POWER LEVEL	DAY	NET AVERAGE DAILY POWER LEVEL
1	848	17	848
2	848	18	847
3	848	19	848
4	848	20	847
5	848	21	848
6	848	22	847
7	848	23	848
8	848	24	848
9	848	25	848
10	848	26	848
11	848	27	847
12	848	28	482
13	848	29	441
14	848	30	652
15	848	31	833
16	848		

REPORT MONTH: JANUARY 2003

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	February 3, 2003
Completed By:	M. Baker
Telephone:	(315) 349-6181

NO.	DATE	TYPE	DURATION HOURS	REASON	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT NO.	SYSTEM CODE	COMPONENT CODE	CAUSE and CORRECTIVE ACTION TO PREVENT RECURRENCE

F: FORCED
S: SCHEDULED

REASON:
 A. Equipment failure (explain)
 B. Maintenance or Test
 C. Refueling
 D. Regulatory Restriction
 E. Operator training and license examination
 F. Administrative
 G. Operational error (explain)
 H. Other (explain)

METHOD:
 1. Manual
 2. Manual Scram
 3. Automatic Scram
 4. Continued
 5. Reduced load
 9. Other

EXHIBIT G: Instructions for preparation of data entry sheets for Licensee Event Report (LER) file (NUREG-0161)

REPORT MONTH: JANUARY 2003

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	February 3, 2003
Completed By:	M. Baker
Telephone:	(315) 349-6181

OPERATIONAL SUMMARY

The FitzPatrick plant – with the exception of minor derates for rod adjustments - operated at or near rated power for the duration of the month of January 2003 with the exception of the following:

- January 28, 2003 – 0200 Commenced scheduled down power to perform sequence exchange and to remove “A” Reactor Feed Pump from service to perform maintenance. After the “A” Reactor Feed Pump was returned to service, the “B” Reactor Feed Pump was removed from service to perform maintenance. For this evolution, reactor power was reduced to 49% on January 28, 2003 – 0323. The reactor was maintained at approximately 55% power until January 30th at 09:55 when the second Reactor Feed Pump was started to permit return of the reactor to full power.
- January 30, 2003 – 1000 RX power ascension commenced.
- January 30, 2003 – 1203 Core Thermal Power was raised to 95%.