Official Transcript of Proceedings ACRST-3231

NUCLEAR REGULATORY COMMISSION

Title:

Advisory Committee on Reactor Safeguards

499th Meeting

PROCESS USING ADAMS TEMPLATE: ACRS/ACNW-005

Docket Number:

(not applicable)

Location:

Rockville, Maryland

Date:

Thursday, February 6, 2003

Work Order No.:

NRC-764

Pages 1-311

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005

ACRS Office Copy - Retain for the Life of the Committee

| 1 | UNITED STATES OF AMERICA |
|----|---|
| 2 | NUCLEAR REGULATORY COMMISSION |
| 3 | + + + + |
| 4 | ADVISORY COMMITTEE ON REACTOR SAFEGUARDS |
| 5 | 499 th MEETING, DAY 2 |
| 6 | + + + + |
| 7 | THURSDAY, FEBRUARY 6, 2003 |
| 8 | + + + + + |
| 9 | ROCKVILLE, MARYLAND |
| 10 | + + + + |
| 11 | The Committee met at the NRC, Two White Flint |
| 12 | North, Room T2B3, 11545 Rockville Pike, at 8:30 |
| 13 | a.m., Dr. Mario V. Bonaca, Chairman, presiding. |
| 14 | COMMITTEE MEMBERS PRESENT: |
| 15 | MARIO V. BONACA Chairman |
| 16 | GEORGE E. APOSTOLAKIS Member |
| 17 | F. PETER FORD Member |
| 18 | THOMAS S. KRESS Member |
| 19 | GRAHAM M. LEITCH Member |
| 20 | DANA A. POWERS Member |
| 21 | VICTOR H RANSOM Member |
| 22 | STEPHEN L. ROSEN Member |
| 23 | WILLIAM J. SHACK Member |
| 24 | JOHN D. SIEBER Member |
| 25 | GRAHAM B. WALLIS Member |
| ı | |

| 1 | ACRS STAFF PRESENT: | |
|----|------------------------|---------------------|
| 2 | JOHN T. LARKINS | Director |
| 3 | SHER BAHADUR | Associate Director |
| 4 | SAM DURAISWAMY | Technical Assistant |
| 5 | HOWARD J. LARSON | Special Assistant |
| 6 | TIMOTHY KOBETZ | |
| 7 | | |
| 8 | ALSO PRESENT: | |
| 9 | CHRISTINA E. ANTONESCU | |
| 10 | RALPH E. ARCHITZEL | |
| 11 | MARK CUNNNINGHAM | |
| 12 | RANI FRANOVICH | |
| 13 | ROBERT L. GILL, JR. | |
| 14 | ED HACKETT | |
| 15 | GARY M. HOLAHAN | |
| 16 | BP JAIN | |
| 17 | ALAN KOŁACZKOWSKI | |
| 18 | KOFI KORSAH | |
| 19 | PT KUO | |
| 20 | JOHN LEHNING | |
| 21 | GREGORY D. ROBISON | |
| 22 | NATHAN SIU | |
| 23 | SUNIL WEERAKKODY | |
| 24 | RICHARD T. WOOD | |
| 25 | | |

C-O-N-T-E-N-T-S

| 2 | PAGE |
|----|---|
| 3 | <u>Catawba-McGuire License Renewal</u> : |
| 4 | Introduction, Dr. PT Kuo |
| 5 | Applicant's Presentation, Greg Robison |
| 6 | and Bob Gill |
| 7 | NRC Staff Presentation, Rani Franovich 40 |
| 8 | Draft Req. Guide DG-1107 and Draft Generic Letter |
| 9 | 2003-XX: |
| 10 | Introduction, Dr. Graham Wallis 86 |
| 11 | NRC Staff Presentation: |
| 12 | Gary Holahan |
| 13 | Ralph Architzel |
| 14 | PTS Reevaluation Project: Technical Bases for |
| 15 | Potential Revision to PTS Screening Criterion |
| 16 | William Shack |
| 17 | John Cunningham |
| 18 | Draft Final Version of Regulatory Guide DG-1077 |
| 19 | John Sieber |
| 20 | Christina Antonescu 237 |
| 21 | • |
| 22 | |
| 23 | |
| 24 | |
| 25 | |
| 1 | |

P-R-O-C-E-E-D-I-N-G-S

CHAIRMAN BONACA: The meeting will come

1 2

(8:32 a.m.)

3

4

3

to order.

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

This meeting is being conducted in

accordance with the provisions of the Federal

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N W. WASHINGTON, D C 20005-3701 (0102 011001,

This is the first day of the 499th meeting of the Advisory Committee on Reactor Safequards.

During today's meeting, the committee will consider the following: Catawba-McGuire license renewal application; draft regulatory guide DG-1107; water sources for long-term recirculation cooling following a loss of coolant accident; and draft generic letter 2003-XX, related to the resolution of GSI-191; assessment of debris accumulation on PWR sump performance.

Three, PTS reevaluation project;
technical basis for potential revision to PTS
screening criterion; draft final version of
regulatory guide DG-1077, guidelines for
environmental qualification of microprocessor based
equipment important to safety in nuclear power
plants.

And finally, proposed ACRS reports.

NEAL R. GROSS

www nealrgross com

Advisory Committee Act. Dr. Larkins is the 1 designated federal official for the initial portion 2 3 of the meeting. We have received written comments from 4 Mr. William Horin of Winston & Strawn, counsel to 5 Nuclear Utility Group on equipment qualification 6 7 regarding draft regulatory guide DG-1077. We have received no requests for time to 8 make oral statements from members of the public 9 10 regarding today's sessions. A transcript of portions of the meeting 11 is being kept, and it is requested that the speakers 12 use one of the microphones, identify themselves, and 13 speak with sufficient clarity and volume so that 14 they can be readily heard. 15 We do not have in front of us any item 16 17 of interest yet. So I'll announce that when we get 18 that. With that, we will start with the first 19 presentations on our agenda. That's the Catawba and 20 McGuire license renewal application. 21 We met as a subcommittee for this 22 license renewal application on October 8, 2002. 23 that time the SER came to us with the 41 open items, 24 and by the time we got into the meeting, I believe 25

| 1 | the open items were reduced to only 11. |
|----|--|
| 2 | Since that time, those open items have |
| 3 | been resolved. The final SER with all closed items |
| 4 | came to us on January 6th, 2003, and I believe we |
| 5 | are ready to hear from the staff and the applicant. |
| 6 | And so I will turn to Dr. PT Kuo for the |
| 7 | presentation. |
| 8 | I would like to just be aware of the |
| 9 | time restrictions. We have many items on our |
| 10 | agendas. You have time scheduled until 10:15 a.m., |
| 11 | and I believe the applicant is pretty anxious to go |
| 12 | to the presentation and beat the snow storm. |
| 13 | (Laughter.) |
| 14 | CHAIRMAN BONACA: So that would be an |
| 15 | incentive for us to stay on schedule. |
| 16 | MEMBER POWERS: So we can really ask a |
| 17 | lot of questions here and stretch this one out a |
| 18 | little bit for these guys. |
| 19 | CHAIRMAN BONACA: All right, okay. |
| 20 | MEMBER SIEBER: Mr. Chairman, I'd like |
| 21 | to point out that I must recuse myself due to |
| 22 | conflict of interest from the Duke Energy situation. |
| 23 | PARTICIPANT: Thank you. |
| 24 | CHAIRMAN BONACA: So noted. |
| 25 | With that, Dr. Kuo. |

1 DR. KUO: Thank you. 2 Good morning. We will try to keep the schedule as much as we can. 3 CHAIRMAN BONACA: Yes, sure. 4 5 DR. KUO: The presentation will be 6 pretty brief. 7 My name is PT Kuo, the Program Director 8 for the License Renewal and Environmental Impacts 9 Program. With me on my right is Rani Franovich. 10 She is the Safety Project Manager for the review of 11 the McGuire-Catawba license renewal application. 12 She will be leading the staff presentation today, 13 with the support from the technical reviewers. 14 In addition to those who will be sitting 15 in from at the table with her, we will also have the key tech. reviewers sitting in the audience and 16 17 ready to answer any questions you may have. 18 As, Dr. Bonaca, you pointed out, at the 19 last subcommittee meeting we had about 11 open items, and since we have resolved all the open 20 items, and Ms. Franovich will be briefing the 21 22 committee on most of these open items. 23 I would also want to point out that in response to your comment in previous meetings on the 24 25 commitment list, Duke has submitted a commitment

list to the staff for review. The staff has since 1 reviewed, verified, and included the list in the 2 SER. 3 In the previous meetings I have also 4 informed the committee that the staff was in the 5 process of finalizing inspection procedure post 6 7 renewal inspection procedure. That is IPE 71003. We have since finalized the issue, dated 8 December 9th, 2002. I believe you all have a copy 9 10 in front of you. With that, if you don't have any 11 questions, I will turn the briefing over to Duke 12 followed by the staff presentation. 13 CHAIRMAN BONACA: One thing I would like 14 to just note, that in fact the commitment list 15 attached to the SER, it's the first time we've seen 16 That's extremely useful. 17 DR. KUO: Great. 18 CHAIRMAN BONACA: And I think it would 19 be desirable to see that in every SER to follow. 20 DR. KUO: Thank you. 21 CHAIRMAN BONACA: Thank you. 22 MR. ROBISON: Good morning. Thank you, 23 first, for the opportunity to come and speak this 24 25 morning.

4 5

My name is Greg Robison. I'm the
Project Manager for License Renewal at Duke Energy.
With me today is Bob Gill, our licensing lead for
license renewal. Bob and I have been doing this a
long time, and we're very glad to get to this day
and glad to be back with you again.

Later this morning, as Rani presents detailed technical information about several of the open items, we'll have a chance to dialogue on those items. What we thought we would do for the Duke presentation is do a small bit of background and then tell you where we're going in the future and give you a little bit of a feel for how we plan to manage the commitments you just spoke of into the future and how we're preparing for those things today so that we'll be ready for them tomorrow.

I begin with my typical pictures of our power plants. It's always good for visual folks to realize these are on beautiful lakes there in the Carolinas. On the left side is McGuire. It's north of Charlotte, North Carolina, on Lake Norman. Lake Catawba is on the right, and it's on Lake Wylie south Charlotte.

The next page for those who like details is a little bit of the stats of the plant. They are

four sister units, four Westinghouse plants, construction finished in the '80s, employ about 2,200 people combined between the two sites. So we're real pleased with the plants. They're running very well, and I'm glad we can take them through license renewal.

Go on to five.

All right. I guess the first thing to point out on the application background, and Dr. Powers and I were talking about this just a moment ago, is we took the same team that we used out of Oconee and we continued them on into McGuire-Catawba. So we had a good, solid core of experience as we began the McGuire and Catawba license renewal process.

We did ask for and receive approval of an exemption request for the 20 year requirements because Catawba -- McGuire Unit 2 and Catawba 1 and 2 were younger than 20 years, and collectively, again, the four sister units, we felt like we had a good operating experience and could proceed with renewal.

We submitted the application June of 2001. The site supplemental environmental impact statements were issued December of 2002. SER, as

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE, N W. WASHINGTON, D C 20005-3701

was mentioned, was issued in January of 2003, and
the safety and environmental reviews, the details of
them in themselves covered a review period of 60
years.

Going forward, we had planned to go ahead and implement the UFSAR supplement at the next UFSAR update, go ahead an incorporate it. It is Chapter 18 of our UFSAR. We've trained the site, both sites completely on this. They're aware that it's there. They're aware of their responsibilities.

We wanted to make it as normal a part of the UFSAR, nothing extraordinary, nothing that would be out of the norm. So it's right there in the book or right there in the electronic file with the other parts of the UFSAR.

Currently we have completed our training. We're going through the process of marking up procedures and implementing things in the plant. We'll take a good portion of the remainder of this year post approval to complete those procedure updates, and then we will be up and running and be able to manage the commitments from there.

We have put in place plans to evaluate

NEAL R. GROSS

plant changes as time goes on, and Bob is going to present the details of some of that.

And then as to the future, we'll maintain the records to support future assessments by our in-house team and also any further NRC inspections that may come along in order to validate the commitments that are being managed or the one-times that are being taken care of as we move into the renewal period.

So that's a little bit of background on where we are, how we got to today, and Bob is going to give you the next level of detail from here.

MEMBER LEITCH: Greg, you mentioned training. Could you say just a word about the scope of the training necessitated by this license renewal effort?

MR. ROBISON: Well, there are really two levels for the training. The first was to create an awareness that this new commitment set was there. We've spent about ten years at Duke creating an awareness that aging management is important. It's not just creating a program that a bunch of specialists run, but creating an understanding by the whole work force that as the plant ages we're all responsible for managing aging.

Well, the license renewal led to a set 1 2 of specific commitments. So the training was to help them understand now we've gone publicly and 3 committed to certain activities and details of those 4 activities, and we wanted to train them on that. 5 In addition, we wanted to train them on 6 7 the process that we had put in place or were putting 8 in place to maintain those commitments. So we packaged all of that in a -- how 9 10 long was the training program, Bob? 11 MR. GILL: Several months last summer. 12 MR. ROBISON: Hours? 13 MR. GILL: A couple hours. 14 MR. ROBISON: And we took all of the key 15 staff at both of the sites and our general office 16 through this training. 17 MEMBER LEITCH: Okay. Thank you. Okay. I'm going to go into a 18 MR. GILL: 19 little bit more detail on what Greq has mentioned. 20 Early this last month I, in fact, sent 21 the FSAR supplements to each site so that we'd start 22 getting in the process to make an amendment or an update to the FSAR. Each FSAR is updated 23 24 periodically six months after the Unit 2 outage, not 25 to exceed two years.

4 5

So within the next couple of years we'll have updates with Chapter 18 already in the SAR.

So the plants are going through their formal review process to assure that all of the owners of those sections are aware what the commitments are and start taking ownership of the programs we have.

We've created several documents, and I'm going to go through these to help implement the commitments in the plant. The first one is this plant specific turnover specification, or Spec 16, and that specifically identifies the detailed changes to each and every procedure that is needed to implement the commitments. These could be plant procedures, inspection modules, surveillance procedures, that type of things, maintenance work orders, work orders where a craftsperson would go down and perhaps look at a strainer or the inside of a pump or something along those lines.

Certain hardware, aging management programs, such as the flow accelerated corrosion program or the fluid leak management. Each one is going to be annotated to indicate that it is now a license renewal commitment to do that.

There's also other documents we had

called engineering support programs which will also indicate that this is a license renewal related item.

The Spec 16 also includes something that we call inspection monitoring plans for future inspection activities, and if you'll turn in your handouts, you'll see a copy of the page. I don't have it as an overhead, but this is a copy of the page that we have for the pressurizer spray head examination.

This is right out of Spec 16. This is the typical format for each and every one of the programs that we've credited, and it has a title. It lists all of the references that we have for it, including the FSAR section where it is further described in detail, and in this case it's 18.2.20. It refers to the SER section. It will refer to where it came from in the application, and in this case it was really a response to a request for additional information from the staff.

There's also a Spec 05 which has even more detail in programs and inspection activities.

So we have a reference there, and then any other piece of correspondence that we might have. In this case it was response to a particular open item.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE, N W WASHINGTON, D C 20005-3701

| 1 | This is something that the plant |
|----|---|
| 2 | CHAIRMAN BONACA: I thought you had that |
| 3 | changed for VT-1 inspections. |
| 4 | MR. GILL: Yes, this was the one to go |
| 5 | from VT-3 to VT-1. So that was an open item we had. |
| 6 | So you're exactly right, Dr. Bonaca. |
| 7 | CHAIRMAN BONACA: Okay. |
| 8 | MR. GILL: So there's a brief |
| 9 | description of what the program is, the activity, |
| 10 | and then you see we have internal milestones. |
| 11 | Dr. Kress? |
| 12 | MEMBER KRESS: I didn't want to dwell on |
| 13 | the details of this, but I was just reading it, and |
| 14 | if you go in with a visual inspection, how do you |
| 15 | find thermal embrittlement? |
| 16 | MR. GILL: You find the results of that |
| 17 | which could be cracking, and that's why |
| 18 | MEMBER KRESS: You're looking for |
| 19 | cracks? |
| 20 | MR. GILL: You're looking for cracks |
| 21 | really. |
| 22 | MEMBER SHACK: Well, why does it say |
| 23 | initially VT-3 and then you do a VT-1? |
| 24 | MR. GILL: Well, a VT-3 is just a little |
| 25 | further away. It should be a VT-1. I think if you |

| 1 | go down further we've got a VT-1. |
|----|--|
| 2 | MEMBER SHACK: That's what caught my |
| 3 | eye. |
| 4 | MR. GILL: Yeah. We'll fix that in the |
| 5 | next revision. |
| 6 | CHAIRMAN BONACA: Originally it was VT- |
| 7 | 3. |
| 8 | MR. GILL: It was VT-3. |
| 9 | CHAIRMAN BONACA: to a VT-1 because |
| 10 | of the |
| 11 | MR. GILL: And this may be one of the |
| 12 | reasons that is uncontrolled is it's still in |
| 13 | review, and we'll make sure that change gets in |
| 14 | before the next revision comes out. |
| 15 | The main point here is you see the |
| 16 | milestones in the future, and we've incorporated the |
| 17 | fact that we've committed to look at Unit 1 |
| 18 | specifically, and then if necessary look at Unit 2, |
| 19 | and then from there possibly Catawba, and Catawba |
| 20 | would have a similar chart on that. |
| 21 | So there is a synergy between the two |
| 22 | Westinghouse plants. |
| 23 | I also want to point out we've already |
| 24 | committed to look at the Oconee pressurizer spray |
| 25 | heads, which will occur much earlier than this, and |

so there may be some lessons learned as we have 1 It's the same type of material, but it's a 2 3 different design. So we're not quite sure what we're going 4 to find when we go in there, but I had --5 CHAIRMAN BONACA: At Oconee you're б looking only at Oconee 1 or all repressurized? 7 can't remember. 8 I think it's just Oconee 1, MR. GILL: 9 and then from there we decide. 10 CHAIRMAN BONACA: Oconee 1, okay. 11 It's a spray head design, and MR. GILL: 12 13 so it's got fine holes. It's spherical shape. asked the question at McGuire when I was doing 14 management training, information exchange, and 15 nobody at the site today has ever seen what the 16 pressurizer spray head looks like. They've never 17 looked into it. 18 MR. ROBISON: We actually talked to the 19 manufacturer in the process of digging out this 20 It's got an interesting design to it 21 information. that's different than the Oconee design, and of 22 course, this brings up a good point about the one 23 time inspections. 24 They were never geared to go find aging

that we thought was occurring. 1 CHAIRMAN BONACA: Right. 2 They were geared to deal 3 MR. ROBISON: with those doubts when we did not really feel like 4 5 we had an aging problem. We just absolutely So we wanted to go look again. 6 couldn't be sure. 7 We want to be conservative as we look to run the 8 units many more years. So this was another one of those 9 10 opportunities to take a look. MR. GILL: But it is cast all in 11 stainless steel and certainly thermal embrittlement 12 13 with the temperatures and cycles and all of that. So anyway, that's typically what a Spec 14 16 program description would be. They are signed 15 off by all of the program owners and who created it. 16 So there is some ownership that would occur there, 17 18 and this is what we have in the interim used to get 19 all of our plants' procedures going. This one has no current plant 20 procedures, but I'll get into what we do for 21 22 preparing for long-term inspections in the next set of overheads. 23 Anymore questions on this phase? 24

CHAIRMAN BONACA: And the last

| 1 | 20 |
|----|---|
| 1 | commitment |
| 2 | MR. GILL: This is more sort term. |
| 3 | CHAIRMAN BONACA: The last commitment |
| 4 | you have is develop dramatic oversight. So prior to |
| 5 | entering the renewal period |
| 6 | MR. GILL: That's correct. |
| 7 | CHAIRMAN BONACA: you will have it. |
| 8 | MR. GILL: If there's a need for |
| 9 | periodic inspections |
| 10 | CHAIRMAN BONACA: Exactly. |
| 11 | MR. GILL: or whatever, we would have |
| 12 | that in place prior to entering the period of |
| 13 | extended operation. |
| 14 | CHAIRMAN BONACA: Okay. Good. |
| 15 | MR. GILL: That's correct. |
| 16 | We feel that commitments made for |
| 17 | license renewal must be maintained obviously, |
| 18 | particularly pursuant to 5437(b), and that changes |
| 19 | to the FSAR commitments are going to be made by the |
| 20 | existing 5059 program. |
| 21 | The concern is how do you make sure that |
| 22 | happens in the future when you have new people |
| 23 | perhaps 15 or 20 years from now trying to manage |
| 24 | these commitments that one has. |
| 25 | What we're created are we did a lot of |

21 brainstorming over the past couple of years of how can you actually change the plant and perhaps impact a commitment you've made for license renewal, and through a lot of iterative processes we came down to you can physically modify the plant to add or delete something that might change the commitment. You can make operational changes to the plant that may change ambient conditions that are worked there. It may change a flow path, a few open valves that were isolated for some reason. In fact, we had that at Oconee where some heat exchangers were valved in when we had them valved out when we did the initial review.

You can also have current licensing bases changed by bulletins, generic letters, regulations. Perhaps some more will come out on the control rod drive mechanisms that will supersede what we've already committed to.

So there are numerous ways you have to So you have to look at your existing internal processes to see how best that can be accomplished and how do you make sure that if something does change you don't undo a commitment that we've already made for license renewal.

Site engineering is the key in these

NEAL R. GROSS

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

areas, and they were heavily involved in the training that we did last summer at all three stations in this area, and what we've come up with is an engineering oversight document that's corporately owned, and it's a common process for all three sites.

I think Greg briefly alluded to this at our last meeting we had in October, and it's the process for maintaining the license renewal scope, an aging management of components within the license renewal scope. It's an overall. It's a very high level process document that actually has a flow chart in it, and I have copies of it.

I don't have an overhead I can show you, but it basically takes those three sources of changes that you could have, plant modifications, operational changes or CLB changes and works them through a process of will it do this, can it do this, do you have to make a change, are you within the bounds of what you've already analyzed.

If you're replacing a carbon steel component with another carbon steel component, perhaps there's no change at all. You know, these are one out of 1,000 items that get changed and they cause a change to the commitments one has made.

If you change your reactor vessel head, 1 do you need to change now your CRDM nozzle 2 That would have to be looked at 3 inspection program? to see what would the appropriate change be. 4 would manifest itself in perhaps a change to the 5 FSAR supplement. 6 It certainly defines the specific 7 responsibilities in establishing the aging 8 I think at the last meeting management SPOC. 9 someone called it "Dr. SPOC." 10 Well, those are all three established 11 They're in training. now, one at each site. 12 13 in fact, meet periodically. There is a corporate 14 sponsor that helps facilitate the communications They share lessons learned amongst the three sites. 15 as they start doing some of these reviews, and it 16 provides the method to make sure that we do the 17 reviews when we need to have the reviews done and 18 that we make the right decisions on what additional 19 programs might be needed or changes to existing 20 21 programs or whatever. MEMBER KRESS: Is SPOC an acronym for 22 23 something? MR. GILL: Single point of contact. 24 25 MEMBER KRESS: Single?

1 MR. GILL: Site point of contact, and 2 that person has been introduced to the site 3 personnel at McGuire. She has a sponsor in the engineering area, and the engineering manager is a 4 5 middle manager, and that person talks to everybody else. 6 7 So there's a lot of communication and 8 dialogue to make sure that they know who the person 9 There's a lot of responsibility on the front Modification engineers who are making plant 10 11 mods to make decisions and only if they need to do 12 they go to the SPOC. 13 Hopefully, there will be a selfsufficient, and when you go through a mod checklist 14 15 to see what documents you need to change, you've answered the question of am I changing something 16 with EQ, am I changing something with fire 17 protection, am I making a new safety related system 18 19 adding a new piece of paper or whatever. That's covered in the mod process, and 20 only if you really get something different like 21 titanium versus stainless steel would you go to the 22 23 SPOC to see what to do. MEMBER KRESS: If I could have seen the 24

slide, I would have known it was an acronym, but --

| 1 | MR. GILL: We try to do that, Dr. Kress. |
|----|--|
| 2 | MEMBER KRESS: Yeah. |
| 3 | MR. GILL: Spell it out the first time. |
| 4 | MEMBER KRESS: What does that third |
| 5 | bullet mean, specially the "should they be required" |
| 6 | part? |
| 7 | MR. GILL: If you put in a new material |
| 8 | and |
| 9 | MEMBER KRESS: Oh, if you do something |
| 10 | on this page that could impact your commitments? |
| 11 | MR. GILL: Yeah. Say you put Alloy 690 |
| 12 | in instead of Alloy 600. |
| 13 | MEMBER KRESS: Yeah. |
| 14 | MR. GILL: Perhaps you'd have to do a |
| 15 | new review for that because you hadn't completed it |
| 16 | or titanium or some other material that may not have |
| 17 | been used in that system before. You would do a |
| 18 | review to make sure. |
| 19 | MR. ROBISON: We were concerned that we |
| 20 | had the expertise, of course, to do the aging |
| 21 | management reviews for renewal, but we needed to |
| 22 | leave that process somewhere so that |
| 23 | MEMBER KRESS: You need to pass it on as |
| 24 | corporate memory. |
| 25 | MR. ROBISON: Right. |

| 1 | MR. GILL: That's right. |
|----|---|
| 2 | MR. ROBISON: And so what we've done is |
| 3 | created this 229 document that sort of embodies all |
| 4 | of that, gotten a number of people to own it, |
| 5 | plugged it back into the site. So hopefully there |
| 6 | will be enough people around as time moves on. |
| 7 | There will be a general awareness of how to do this |
| 8 | and at least know where the resources are should |
| 9 | they want to do a new material selection and go |
| 10 | through this review process. |
| 11 | MEMBER KRESS: About to have a loss of |
| 12 | power accident. |
| 13 | MR. GILL: Active/passive component |
| 14 | here. |
| 15 | CHAIRMAN BONACA: I hesitate to ask. |
| 16 | MEMBER POWERS: Where's the back-up |
| 17 | generator? |
| 18 | MEMBER KRESS: Do you have a diesel for |
| 19 | that? |
| 20 | MEMBER POWERS: Let me ask you this |
| 21 | question. Who does the SPOC report to? |
| 22 | MR. ROBISON: The SPOC reports to the |
| 23 | civil mechanical manager inside of the engineering |
| 24 | department at each of the three sites. |
| 25 | MEMBER POWERS: Is that too far down the |

| 1 | line of management to be effective? |
|----|--|
| 2 | MR. ROBISON: I don't know. |
| 3 | MEMBER POWERS: I mean, how do you look |
| 4 | at that? |
| 5 | MR. ROBISON: The civil mechanical |
| 6 | managers supervise the majority of the program |
| 7 | office. |
| 8 | MEMBER POWERS: I know they do, but the |
| 9 | question is SPOC is in the business of making work |
| 10 | for people. Most people kind of resent that. |
| 11 | MR. ROBISON: You're right. I haven't |
| 12 | really given that a lot of thought. |
| 13 | MEMBER POWERS: I want to give some |
| 14 | thought to it because both for optics and for the |
| 15 | ability to impose new requirements on people that |
| 16 | they're not going to like. |
| 17 | MR. ROBISON: It's a good suggestion. |
| 18 | Thank you. |
| 19 | MR. GILL: A good point. |
| 20 | Anymore questions on the previous slide? |
| 21 | We're up to Slide 11 now. |
| 22 | EDM 229 defines the aging management of |
| 23 | SPOC duties. It's the site technical point of |
| 24 | contact for this program. Again, there's one at |
| 25 | each site plus a corporate sponsor. So they share |

(202) 234-4433

the lessons learned amongst all three sites and are 1 not on an island by themselves. 2 They can provide any quidance for the 3 aging management reviews that are done by other 4 They also are independent checkers of 5 engineers. the Chapter 18 program changes that may occur so 6 7 that again we don't undo something. 8 And I expect Greg and I will be in a role of consulting over the next year or two as 9 people try to make even more changes that they want 10 now that they're finally reading the document in 11 detail, and we've already had some of that. 12 Screech. MEMBER POWERS: 13 MR. GILL: Screech. We're committed to 14 do what? 15 (Laughter.) 16 DR. LEITCH: Is operating experience at 17 other plants fed into the SPOC somehow or how does 18 that information get in? 19 MR. GILL: That would be under the CLB 20 type changes that might occur, any operating 21 experience that might occur that rises to the level 22 of a notice or some other generic communication 23 24 coming down. It really feeds in at two 25 MR. ROBISON:

places. It feeds into the program owners who are there and as part of their program keep up with industry operating experience, and it feeds to the SPOC, and that's where that sort of independent review role comes in for them.

At least that was what we envisioned. This has obviously not been up and running that long, but that would be our thought. It would create several people who would be interested in a topic and a good dialogue to start at their own site.

MR. GILL: Particularly the control rod drive, the head issue. Certainly the program owner of that is well versed in what's going on with the other units in the country, their inspection results and all of that, and that's the program owner.

That's why on those program summaries we had them sign to make sure they knew what the commitments were, and they would maintain ownership as long as they had that position and for the duration.

An additional tool we have is the license renewal handbook, and this is Spec 017.

This was developed as an aid to the aging management SPOCs in evaluating the impact of plant changes on license renewal programs and scope. It contains a

lot of information, license renewal scope definitions, smart charts, the implementation plans we noted earlier.

In some cases it has drawings to help clarify when something is in scope, and it will be a living document to be updated as changes that might occur in the future.

The next slide in your handout, the next overhead page in your handout is a copy of the smart chart from Spec 17. This is McGuire, and this is the auxiliary feedwater system. And what we have done is collapsed all of the aging management reviews that we did for this system down onto one page. So instead of having multiple pages of tables like we had in the application, in fact, we have more information here because the mechanisms are listed.

But you can see for the aux. feedwater system -- and this is it for the aux. feedwater system, just this one page. You can have carbon steel and stainless steel. The external environments would be reactor building and sheltered and then treated water is the internal environment.

And then you see the programs that we actually credited for that, what the type of aging

effects were, what the aging mechanisms were, and then a summary listing of the component types that are included in that part of the system and what the functions are.

So this allows engineers in the future

So this allows engineers in the future to help decide if I'm making a plant change to the aux. feedwater system and I'm using carbon steel or stainless steel, I can see that all of these reviews have already been done, and I know that I don't have to go in and change any of these particular programs.

If I come in with some new material that's not covered here, then I would have to do the aging management review, and this has been repeated for every system at the site, and this is true at McGuire, Catawba, and Oconee, and it's what we call a smart chart. It's real simple to use.

MR. ROBISON: An example of how the operating experience may fit, for example, in the middle of the page where the words "lubricating oil" are mentioned, suppose an aging phenomenon for lubricating oil came via operating experience. This gives you very quick reference to say where have we credited lubricating oil and what did we do with it.

Well, there was no aging effects and no

| 1 | program was required. Operating experience may |
|----|--|
| 2 | change that in the future. This would then be a |
| 3 | quick reminder of where that's supplied, and then we |
| 4 | could proceed from there to make the changes. |
| 5 | CHAIRMAN BONACA: Now, for the |
| 6 | auxiliary, for the other system you have made a |
| 7 | commitment to internal inspection, one internal |
| 8 | inspection, right? |
| 9 | MR. ROBISON: I'm sorry? |
| 10 | CHAIRMAN BONACA: As part of the as |
| 11 | inclusion of an open item, I think you made a |
| 12 | commitment to inspect the internals of this. |
| 13 | MR. GILL: Right. |
| 14 | MR. ROBISON: Yes. |
| 15 | CHAIRMAN BONACA: So that would be under |
| 16 | one of these programs here, right? |
| 17 | MR. GILL: Well, it's a separate |
| 18 | commitment that's contained separately. It's more |
| 19 | to gain information to demonstrate that the |
| 20 | chemistry program was okay. |
| 21 | CHAIRMAN BONACA: Okay. |
| 22 | MR. GILL: So that's a separate it's |
| 23 | not |
| 24 | CHAIRMAN BONACA: All right. |
| 25 | MR. GILL: It's a commitment to do |
| | NEAL P. CPOSS |

inspections. It's not really an aging management 1 2 program. MR. ROBISON: These are more the ongoing 3 4 programmatic. CHAIRMAN BONACA: Okay. 5 MR. ROBISON: The individual commitments 6 7 that may have just a single action to be taken, we 8 have a separate section in the UFSAR and track them 9 separately. MR. GILL: We have a separate appendix. 10 11 It would be Appendix B that has all of those committed actions. 12 CHAIRMAN BONACA: Yeah, I understand 13 I just was -- I thought that I would find it 14 that. here under aging management even if it is one time 15 inspection. 16 MR. GILL: Right. 17 CHAIRMAN BONACA: You wouldn't include 18 19 it here. MR. GILL: No. 20 The last slide I have is on our 21 maintenance of records. Once we go through all of 22 23 these review processes, we will document the answers by the 5059, by the mod process, by operating 24 experience review determinations. All of this will 25

effectively manage whatever the license renewal commitments are. So what we have today and any changes that might occur over the future, we should have the records available for whenever an assessment occurs internally, and we do plan to do those over the next several years, as well as the NRC inspection that Dr. Kuo mentioned, some time late in the initial 40 year license.

So we will have the records available.

We may or may not have the same people available.

People do change jobs and all of that, but we should have the records for all of the changes that have been made. We know where we started. We know what the changes are, and we should be in compliance through the 40 year period and the plus 20 years.

Any questions?

CHAIRMAN BONACA: I appreciate the presentation. I think it gives us a feeling for, you know, what you have to do to track it, and of course, it gives us also -- I mean, this is 20 years to go before you get into this license period. A lot of people will have retired by that time, and now we've got to see how the NRC is going to be able to track it.

But I quess if you have this kind of

NEAL R. GROSS

structured program, it should be easier to verify the commitments.

MR. GILL: There should be more efficient inspection, we would think. I've been through those, and a lot of the preparation for team inspections is gathering up the records that have occurred.

CHAIRMAN BONACA: Sure.

MR. GILL: And if you've got, like you said, ten, 15, 20 years' worth of records, that's a lot of information to go back and track through.

Another point we were trying to make when I was talking to McGuire management was there may be opportunities over the next few years to go in and look at the pressurizer. If you're there for some other reason, you need to put that in the planning schedule, and if they have scaffolding built and they're already climbing all over the pressurizer for in-service inspection perhaps, maybe that's the time to go in and look at the pressurizer spray head and to start formulating the plans.

You don't have to wait until the last outage at year 39 to do these inspections. There may be more appropriate, opportune times over the next five or ten years perhaps that one can do those

1 inspections. CHAIRMAN BONACA: Now, as you explained 2 before, you know, in 20 years the plant will look 3 quite different from what it is today in materials, 4 5 in changes. There will be a lot of things happening 6 there. 7 You do have a process that you have 8 established to track of those changes. 9 MR. GILL: To keep track of those, 10 right. 11 CHAIRMAN BONACA: Now, I'm trying to 12 understand how the NRC will come in with an inspection and interpret all the changes or verify 13 commitments to all of those changes. It's going to 14 15 be a challenging thing. MR. GILL: I think it will be a 16 challenge. I think if you break the inspection into 17 two parts, one of have you completed your inspection 18 commitments, the one time inspections, if you will, 19 20 and how have you maintained the changes that might have occurred over time, and that will be a 21 22 challenge because we're updating the FSAR every two 23 years or so or in some plants maybe doing it

That's a lot of changes, a lot of plant

annually.

24

1 mods to go through. CHAIRMAN BONACA: If you change a 2 component with a different material, the basis for 3 the commitments that you have given the NRC will 4 change. 5 6 MR. GILL: Right. CHAIRMAN BONACA: You will make 7 decisions on your own that say, well, now we change, 8 9 you know, 600 to 690. Therefore, we don't have to 10 do this anymore. Right. 11 MR. GILL: 12 CHAIRMAN BONACA: Now, you don't know if the NRC will agree with that assessment. 13 MR. GILL: That's correct. 14 CHAIRMAN BONACA: Is it going to be a 15 surprise for the inspection team of the NRC to come 16 in and find that you do not perform a certain 17 committed function because you have replaced the 18 material? But you haven't gone back to the NRC to 19 20 see if it's okay with them. MR. GILL: Right. It may be a challenge 21 because of the time lag from the time you made that 22 change until the inspection actually occurs. 23 changes the FSAR summary description, that would be 24 part of the update that's periodically sent into the 25

WASHINGTON, D.C. 20005-3701

1 staff and then reviewed by the staff.
2 It is a concern though, I think, if a
3 lot of that occurs in trying to reconstruct history
4 well down the pike when none of us are around.
5 CHAIRMAN BONACA: Well, this tells me
6 that probably before you enter the renewal period

that probably before you enter the renewal period and if you have an inspection, there may be another iteration of the SER with additional open items coming in and a debate on what else you need to do

MR. GILL: Yeah, I don't know that --

DR. KUO: Dr. Bonaca, if I may comment on these changes, generally when they make a change according to 5059, the changes will have to be subject to three tests, whether the changes will affect the previous calculation in terms of risk, in terms of mode of failure and all of that.

So if, say, for instance, you talk about the change of materials, certainly it will change the failure mode and all of that. So in that case, my thought is that it probably will have to submit it to the staff for review.

It's their determination whether it will change the accident sequence or not, but if you do have a material change, that's a major change in my view.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N W WASHINGTON, D C. 20005-3701

| 1 | CHAIRMAN BONACA: Yeah. No, I recognize |
|----|--|
| 2 | there are processes in place, including 5059 that |
| 3 | would allow to track that. I'm thinking about there |
| 4 | are probably 40 or 50 plants in the period of six or |
| 5 | seven years will go into renewal, and that's going |
| 6 | to be a heck of a challenge for the staff to track. |
| 7 | DR. KUO: It will be a challenge, yes. |
| 8 | CHAIRMAN BONACA: Because this is a |
| 9 | major resource, the demand for the Commission. |
| 10 | DR. KUO: Yeah, it will be a challenge |
| 11 | for sure, but the mechanism is there. |
| 12 | CHAIRMAN BONACA: Okay. Thank you. |
| 13 | DR. KUO: Rani Franovich will make the |
| 14 | staff presentation. |
| 15 | MS. FRANOVICH: Good morning. I'm Rani |
| 16 | Franovich. I was the Project Manager for the |
| 17 | staff's safety review of the Catawba-McGuire license |
| 18 | renewal application. |
| 19 | And to my right I have Jim Medoff, who |
| 20 | is a reviewer in the Division of Engineering. He |
| 21 | managed the contractor who performed the staff's |
| 22 | review of the aging management of reactor coolant |
| 23 | system and associated components. |
| 24 | To my left is Tanya Eaton, who performed |
| 25 | the scoping and screening review for the staff of |

fire protection equipment.

Before I proceed with my presentation,
I'd like to talk a little bit about my background.
I've been with the NRC for about 12 years; spent
eight years in Region II, where I certified as a
reactor or resident inspector, and McGuire was my
reference plant for certification; spent six years
at Catawba as a resident inspector. So it was a
good segue to come in and manage this license
renewal project, and it has been a pleasure to
manage.

MEMBER POWERS: So you know these plants.

MS. FRANOVICH: I know these plants.

So with that, I'll go on and get started.

When we last met, I think there may have actually been, Dr. Bonaca, 13 SER open items and then one extra one that we added that was not documented in the SER, and I'd like to go over the ones that I think are of most interest to the members.

When we last met, we were in a disagreement with Duke as to whether or not fan and damper housings met the scoping criteria for license

NEAL R. GROSS

The staff believed they did. 1 renewal. believed that they did not, but ultimately Duke did 2 identify fan and damper housings associated with 3 ventilation systems within the scope of license 4 renewal, provided the aging management reviewers 5 results for those components. The staff completed 6 its review of the AMR results, and that resolved the 7 open item. 8 In fact, there were two open items on 9 these two issues. 10 Another issue had to do with building 11 sealant, structural sealants, especially for those 12 13 structures where ventilation systems either 14 maintained a positive pressure or processed potentially radioactive gases from the buildings. 15 And Duke identified an aging management 16 17 program that was satisfactory to the staff for these structural sealants. It involves a one time 18 inspection of structure sealants to insure that 19 there's no cracking or other degradation associated 20 with aging, and the staff found that to be 21 22 acceptable. MEMBER WALLIS: Let's look at, say, 23 24 damper housing. Damper housings apparently are in scope because they do not move, and the damper that 25

| - 1 | |
|-----|--|
| 1 | moves is not in scope. |
| 2 | MS. FRANOVICH: Correct. |
| 3 | MEMBER WALLIS: It seems a little bit |
| 4 | bizarre to make the distinction, but I realize this |
| 5 | is the way it's done. It just seems rather strange. |
| 6 | MS. FRANOVICH: Yeah. |
| 7 | MEMBER WALLIS: The operation of the |
| 8 | damper depends upon both of these things functioning |
| 9 | right, and it doesn't move very often presumably. |
| 10 | MS. FRANOVICH: Right. If you look at |
| 11 | it as kind of like pump casings or valve bodies, |
| 12 | it's really a pressure boundary function that we're |
| 13 | interested in. |
| 14 | MEMBER WALLIS: I see. That's what |
| 15 | you're interested in. |
| 16 | MS. FRANOVICH: Exactly. |
| 17 | CHAIRMAN BONACA: And the interesting |
| 18 | thing is that Duke took the position that the |
| 19 | failure of these components would be identified by |
| 20 | the functional failure of the component itself. I |
| 21 | mean, if you have failure of pressure boundary, you |
| 22 | would see it, the same way in which you would have a |
| 23 | failure of the active component. |
| 24 | MS. FRANOVICH: Correct. |
| 25 | CHAIRMAN BONACA: But you took the more |

| 1 | strict consistency with award of the rule and the |
|----|---|
| 2 | example of the pump casing. And during the |
| 3 | subcommittee meeting we discussed this, but the |
| 4 | feeling was that it doesn't harm to do a visual |
| 5 | inspection of the passive component anyway, and so |
| 6 | we felt that there was consistency with the letter |
| 7 | of the law and also it was beneficial to have a |
| 8 | walk-down and just look at these components for |
| 9 | physical conditions. |
| 10 | MS. FRANOVICH: Correct, and the staff |
| 11 | felt that a minor breach in the pressure boundary |
| 12 | may not reveal itself in a fan surveillance test |
| 13 | failure or a damper failure. |
| 14 | And when these systems conveyed |
| 15 | potentially hazardous gases, that's important. So |
| 16 | Duke brought them in scope. Duke disagreed with the |
| 17 | staff, but brought them in scope nonetheless, and |
| 18 | provided aging management results, and it resolved |
| 19 | the open item. |
| 20 | MEMBER WALLIS: Well, presumably these |
| 21 | dampers are in some sort of a pipe work or ducting |
| 22 | and everything. That's in scope presumably. |
| 23 | MS. FRANOVICH: Correct. The ducting is |
| 24 | in scope. |
| 25 | MEMBER WALLIS: So it would be rational |

| 1 | to have the whole encasement in scope, wouldn't it? |
|----|--|
| 2 | MS. FRANOVICH: That's the way the staff |
| 3 | felt. |
| 4 | MEMBER SHACK: But, I mean, this is an |
| 5 | issue that seems to come up quite frequently in |
| 6 | license renewal space. |
| 7 | MS. FRANOVICH: Yeah. |
| 8 | MEMBER SHACK: You would think that we |
| 9 | have, you know, provided guidance to sort of settle |
| 10 | this issue by this time. |
| 11 | MS. FRANOVICH: Yes. We have issued an |
| 12 | interim staff guidance document on this issue, and I |
| 13 | believe that the status of the document is not yet |
| 14 | final. So once it is final, then we will feed that |
| 15 | guidance back into our GALL report and standard |
| 16 | review plan. |
| 17 | PT, did you want to comment on that ISG? |
| 18 | DR. KUO: You are correct that we have |
| 19 | issued a draft position to the industry. We have |
| 20 | had meetings, but it hasn't been finalized yet, but |
| 21 | as soon as it's finalized, we will incorporate that |
| 22 | guidance into the GALL and SRP in the next revision. |
| 23 | MS. FRANOVICH: Any other questions on |
| 24 | these open items? |
| 25 | Okay. |

1 MEMBER WALLIS: Well, just that they seem so trivial compared with all of those other 2 things that matter in the whole system. 3 Thank you. 4 MS. FRANOVICH: Okay. 5 Another area where there was a lot of disagreement between the staff and the applicant had 6 7 to do with scoping and screening of fire protection 8 equipment. When we last met, Duke had brought 9 everything into the scope of license renewal that 10 11 the staff took issue with, with the exception of jockey pumps, which maintain pressure of the fire 12 water system, and manual suppression equipment for 13 certain areas that the staff felt were potential 14 15 fire exposure areas. To resolve these two open items, Duke 16 17 disagreed with the staff on both of them, but nonetheless brought into the scope of license 18 19 renewal an entire pressure maintenance system for both McGuire and Catawba, which included not only 20 the jockey pumps, but associated piping. 21 There were some tanks; there were some strainers for the jockey 22 pumps, and other miscellaneous equipment. 23 So they gave us a very full response to 24

that SER open item to resolve it.

When it came to the manual suppression and potential fire exposure areas, the staff was interested in two areas, in particular. One area was in the yard, and the other areas was in the turbine building.

And the staff and applicant got together and discussed these two areas and the applicant was able to demonstrate that there weren't any fire exposure areas in the yard that required manual suppression to meet the requirements of 10 CFR 5048. So that was resolved, and the staff accepted their position.

However, with respect to the turbine building, the staff felt strongly that manual suppression capability was necessary to insure that you could mitigate the effects of a fire even though the applicant took credit for a three hour barrier in addition to that to prevent the spread of the fire.

The staff felt that the fire barrier really wasn't sufficient alone to meet the requirements of 5048, and they also needed to put the fire out. So Duke again disagreed with the staff, but identified those hose racks within the scope of license renewal, providing the aging

management review results and an aging management 1 program for those components, and that resolved that 2 3 open item. Any other questions on any of these open 4 items? 5 MEMBER SHACK: The jockey pumps seem 6 like another familiar topic in license renewal. Do 7 we have an ISG for those? 8 Well, actually I'm the MS. FRANOVICH: 9 lucky person to have written that ISG as a result of 10 11 a request from our Region II license renewal inspector, Caudle Julian, who leads the license 12 renewal inspection teams in Region II, indicated 13 that this does come up often. It's not just jockey 14 pumps, although that's a popular topic of debate, 15 but a lot of other fire protection equipment as 16 well. 17 So I've written an interim staff 18 guidance document on that, with the help of Tanya 19 and her group. It is out for comment, public 20 comment, from stakeholders, NEI, Union of Concerned 21 Scientists, and we haven't gotten those comments 22 yet. So we're embarking upon dialogue with the 23 24 industry on this ISG.

DR. KUO:

In fact, this subject will be

the discussion of a meeting with the industry on 1 February the 13th. 2 MEMBER SHACK: Just sort of a general, 3 How many ISGs are in play at the moment? 4 you know. DR. KUO: We have a total of 14 ISG 5 right now, but the four of them have already been 6 finalized. So ten is in active discussion or 7 8 development. MR. ROSEN: And the fact of an ISG is 9 ultimately to be incorporated into the GALL 10 11 report --DR. KUO: That is correct. 12 MR. ROSEN: -- and deleted. 13 MS. FRANOVICH: Correct. 14 MR. ROSEN: The ISG, once it is 15 incorporated in the Gall report, goes away. 16 That's correct. DR. KUO: 17 MS. FRANOVICH: Okay. We had an open 18 item on volumetric examination of Class 1 small bore 19 pipe. Duke uses a risk informed approach to 20 identifying the piping that they perform in-service 21 inspection of. 22 The staff does not have a problem with 23 the risk informed inspection approach. However, the 24 staff felt that there was no guarantee that in their 25

| 1 | risk informed identification of piping, small bore |
|----|--|
| 2 | piping would be included in the sample of the |
| 3 | population for inspection. |
| 4 | So Duke has specifically committed to |
| 5 | identifying a sample of small bore pipe based on the |
| 6 | potential for degradation, considering a number of |
| 7 | degradation mechanisms, and the staff found that to |
| 8 | be satisfactory, and that resolved that open item. |
| 9 | CHAIRMAN BONACA: Is the one time |
| 10 | inspection? |
| 11 | MS. FRANOVICH: That is I'm sorry. |
| 12 | In the past the staff, I think, has found one time |
| 13 | inspection acceptable, but Duke is actually doing |
| 14 | this as part of their interim. |
| 15 | MR. ROBISON: We have already |
| 16 | incorporated risk informed techniques, particularly |
| 17 | in our McGuire ISI plant, and have already |
| 18 | identified small bore locations and have that |
| 19 | ongoing today. |
| 20 | CHAIRMAN BONACA: Okay. |
| 21 | MR. ROBISON: So it will be an ongoing |
| 22 | part of our ISI plan in the future. |
| 23 | CHAIRMAN BONACA: Okay, and these are |
| 24 | acceptable locations, not necessarily risk |
| 25 | significant locations, but the most acceptable ones. |

1 MR. ROBISON: Right, yes. 2 Greg Robison from Duke Energy. MS. FRANOVICH: Thank you, Greq. 3 The other open item had to do with a 4 5 rubber expansion joint in the circulating water system, the condenser circulating water system that 6 was brought into scope by a request for additional 7 information and response to that request, but no 8 9 aging effects were identified for this component, 10 this expansion joint. The staff asked the applicant to 11 12 consider the effects of ultraviolet radiation since the expansion joint is located in the yard outside 13 the turbine building, and the applicant came back 14 and indicated that there was no operating experience 15 to indicate that -- I apologize. That's not really 16 17 what they said. They said that these expansion joints 18 were located 30 feet down in a pit where the 19 20 circulating water pumps are, and that they really didn't -- they weren't exposed to much UV radiation. 21 However, the staff felt that there were 22 other aging effects that could cause degradation 23 over time and it didn't seem like this expansion 24

joint could last for 60 years without any

degradation. 1 So the applicant identified aging 2 effects for this component and proposed a one time 3 visual inspection of the component to verify that 4 aging effects are not causing degradation of the 5 component, and that was acceptable to the staff and 6 7 resolved the open item. Any questions on this slide? 8 MEMBER WALLIS: This was a one time 9 10 inspection? 11 MS. FRANOVICH: It's a one time inspection, and the reason --12 MEMBER WALLIS: Just don't these things 13 deteriorate over a period of five or ten years 14 rather than --15 Well, there are two MS. FRANOVICH: 16 components that the staff looked at. One is the 17 expansion joints in the condenser seals or the 18 condenser seals themselves which are exposed to 19 somewhat higher temperatures of condensed steam and 20 circulating water. 21 But the expansion joints that were in 22 question for this open item are actually just in the 23 condenser circulating water system itself out in the 24

yard.

Cold. MEMBER WALLIS: 1 It can get cold, sure. MS. FRANOVICH: 2 Oh, I'm sorry. You're talking about the water 3 Right, it's temperature is typically below 4 100 degrees from what I understand. 5 It doesn't fluctuate MEMBER WALLIS: 6 7 very much. So MS. FRANOVICH: Correct, correct. 8 there really isn't much experience, much operating 9 experience to indicate that these things have 10 failed, and without that operating experience we 11 didn't feel like more than one time was warranted, 12 but it will at least verify that there is no 13 degradation that could be occurring. 14 MEMBER WALLIS: And presumably if it 15 degrade, it will leak and then this will be 16 detected and it will be fixed. It's not as if it's 17 18 MS. FRANOVICH: One would expect so, 19 It's not a very high pressure system, 20 correct. correct. 21 MEMBER SHACK: And, again, what's the 22 It's before the 23 timing of the one time inspection? end of the license, but obviously you'd sooner wait 24 a reasonable amount of time to do it. 25

| L | |
|----|---|
| 1 | MS. FRANOVICH: I agree, and it's really |
| 2 | up to Duke. The only thing they're required to do |
| 3 | is have that inspection completed before the period |
| 4 | of extended operation begins. |
| 5 | But you're absolutely correct. It would |
| 6 | be more prudent to give it more opportunity to |
| 7 | reveal itself before you inspect it. |
| 8 | So with that, I'll turn it over to Duke |
| 9 | and you can indicate, Greg. |
| 10 | MR. ROBISON: This is Greg Robison, Duke |
| 11 | Energy. |
| 12 | I think the example we used this |
| 13 | morning, the pressurizer spray where the dates are |
| 14 | included in your handout, is an example of the time |
| 15 | frame we would do these inspections on. |
| 16 | As Bob Gill mentioned, we will find an |
| 17 | appropriate point in time somewhere toward the end |
| 18 | of the initial four year period. It could be two |
| 19 | years short, five years short, just when we happen |
| 20 | to be there, and we'll go in and do these types of |
| 21 | things, but it will be toward the end of the |
| 22 | initial |
| 23 | PARTICIPANT: Twenty years. |
| 24 | MR. ROBISON: will not. |
| 25 | And one other point. I think this is |
| | II |

Catawba only, and these things are -- physically 1 you're looking at a component that's about a foot in 2 length, 42 inches in diameter. So it's not a huge 3 4 mechanical component. It's a rather small component, very much in the bottom of a pump pit out 5 in the yard. 6 So that was the basis of our it doesn't 7 8 see a lot of sunlight, because it's hard to get the sun to shine that deep into the pump pit. 9 MR. ROSEN: As I recall, there has been 10 11 a failure of those components in an operating nuclear plant, and the results are quite 12 interesting. It's an amazing amount of water can 13 come out of those things into the basement, turbine 14 15 building basement. Then maybe we need to go 16 MS. FRANOVICH: back and look at that. Okay. 17 Thank you. Any other questions on this slide? 18 19 (No response.) 20 MS. FRANOVICH: Okay. We had a couple of other open items that are related. They had to 21 do with aging effects and aging management of 22 23 concrete structures and structural components that are not exposed to a harsh environment. Duke's 24 position was that there are no aging effects, and 25

1 the staff's position was that there are and that 2 they need to be monitored. So Duke ultimately disagreed with the 3 Nonetheless they specified an aging 4 staff. management program to monitor concrete structures 5 that are not located in a harsh environment, and a 6 7 couple of those concrete components involve 8 accessible portions of concrete components in the ice condenser, which they also specified in the 9 aging management program for. That resolved those 10 11 open items. Can you tell me more 12 MEMBER POWERS: 13 about that one? MS. FRANOVICH: What would you like to 14 15 know? Where it is, how it's MEMBER POWERS: 16 going to be managed, how it's going to be monitored. 17 18 MS. FRANOVICH: Sure. The aging 19 management program that they specified is the civil structures inspection or -- I'm sorry -- the 20 21 inspection program for civil structures and It's a visual inspection components, I believe. 22 23 program. MEMBER POWERS: -- accessible? 24 MS. FRANOVICH: For the accessible 25

| 1 | concrete, yes. |
|----|--|
| 2 | MEMBER POWERS: When I look at the |
| 3 | concrete, it's not the concrete we're interested in. |
| 4 | MS. FRANOVICH: Can you repeat your |
| 5 | question? |
| 6 | MEMBER POWERS: Well, the issue is the |
| 7 | inaccessible concrete structures. |
| 8 | MS. FRANOVICH: The inaccessible |
| 9 | concrete structures. Are you talking about those |
| 10 | that are below grade? |
| 11 | MEMBER POWERS: I'm talking about the |
| 12 | ones that are in the bullet two on your slide. |
| 13 | CHAIRMAN BONACA: Yeah, you have |
| 14 | inaccessible concrete. |
| 15 | MS. FRANOVICH: Right. The open item |
| 16 | had to do with concrete components that the staff |
| 17 | believed were inaccessible in the ice condenser. As |
| 18 | it turned out in the RAI response, the applicant |
| 19 | indicated that this concrete is accessible from |
| 20 | other areas. I think one of the structures was the |
| 21 | was it the structural wall that you could see |
| 22 | form the other side? I'm not real familiar with the |
| 23 | details, but |
| 24 | MEMBER POWERS: Maybe Duke can help. |
| 25 | MS. FRANOVICH: Do you want to take it, |

| 1 | concrete, yes. |
|----|--|
| 2 | MEMBER POWERS: When I look at the |
| 3 | concrete, it's not the concrete we're interested in. |
| 4 | MS. FRANOVICH: Can you repeat your |
| 5 | question? |
| 6 | MEMBER POWERS: Well, the issue is the |
| 7 | inaccessible concrete structures. |
| 8 | MS. FRANOVICH: The inaccessible |
| 9 | concrete structures. Are you talking about those |
| 10 | that are below grade? |
| 11 | MEMBER POWERS: I'm talking about the |
| 12 | ones that are in the bullet two on your slide. |
| 13 | CHAIRMAN BONACA: Yeah, you have |
| 14 | inaccessible concrete. |
| 15 | MS. FRANOVICH: Right. The open item |
| 16 | had to do with concrete components that the staff |
| 17 | believed were inaccessible in the ice condenser. As |
| 18 | it turned out in the RAI response, the applicant |
| 19 | indicated that this concrete is accessible from |
| 20 | other areas. I think one of the structures was the |
| 21 | was it the structural wall that you could see |
| 22 | form the other side? I'm not real familiar with the |
| 23 | details, but |
| 24 | MEMBER POWERS: Maybe Duke can help. |
| 25 | MS. FRANOVICH: Do you want to take it, |

|| Greg?

MR. ROBISON: Greg Robison, Duke Energy.

You're correct. We can access several of the ice condenser structures from the other side to do an inspection there. One other point is the philosophy here for inaccessible concrete structural areas would be when we did our aging management evaluation, we looked for environments that were different from accessible areas, and if we found one, then we had to make provision to get to that inaccessible, unique environment somehow.

We didn't find any unique, inaccessible environments. We found out environments of our exposed concrete similar to our environments of our inaccessible concrete. So feel good that we can do our inspections and sampling over in the accessible area and apply that to all of the concrete.

MS. FRANOVICH: Right, but I think I understand Dr. --

MEMBER POWERS: The last time we got together we discussed a lot about water chemistry.

MS. FRANOVICH: Oh, yeah.

MEMBER POWERS: A little bit about water chemistry and the issue of whether you had sulfates and phosphates and the groundwater.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE, N.W. WASHINGTON, D.C. 20005-3701

| | 58 |
|----|---|
| 1 | Here you had looked at, as I recall, the |
| 2 | sulfate contents and concluded that they were low |
| 3 | enough concentration they were benign. You had not |
| 4 | looked at the phosphate contents. |
| 5 | MS. FRANOVICH: Let me see. The last |
| 6 | time we met, we had looked at pH, chlorides, and |
| 7 | sulfates. Phosphates were not included in that |
| 8 | list. You're absolutely right. |
| 9 | I don't know if David Jeng would like to |
| 10 | address this or if we may have addressed it in the |
| 11 | last meeting, but we did not look at phosphates. |
| 12 | David. |
| 13 | MR. JENG: I'm David Jeng of the |
| 14 | Division of Engineering. |
| 15 | During the last subcommittee meeting, |
| 16 | questions were raised whether phosphate was a |
| 17 | concern. The staff position, based on the expert, |
| 18 | having the main concern are the sulfate, chlorides |
| 19 | and the pH vary. So each of the three parameters we |
| 20 | decided to measure with acceptance |
| 21 | criteria, and phosphate was not particularly of |
| 22 | concern based on our expert evaluation. |
| 23 | MEMBER POWERS: Oh, that's great. What |
| 24 | was your expert valuation? |
| 25 | MR. JENG: It's |

| 1 | MEMBER POWERS: Apatites don't form. I |
|----|--|
| 2 | mean is that what you're telling me? |
| 3 | MR. JENG: I am not a chemical |
| 4 | MEMBER POWERS: But you never get the |
| 5 | chemical expert. We only get the reference that the |
| 6 | chemical experts tell us that this is not important, |
| 7 | but he never shows up. Where is this guy? I mean, |
| 8 | he's the guy that believes that apatite doesn't |
| 9 | form. He has no teeth. I know this. I will |
| 10 | recognize this guy because he has no teeth. |
| 11 | MEMBER WALLIS: Excuse me. Appetite? |
| 12 | MEMBER POWERS: Yeah. It's calcium |
| 13 | phosphate. |
| 14 | MEMBER WALLIS: But it's spelled like |
| 15 | "appetite"?? |
| 16 | MEMBER POWERS: And it's spelled like |
| 17 | "apatite." |
| 18 | MEMBER WALLIS: Thank you. |
| 19 | MR. JENG: I would like to take back |
| 20 | your very important question and come up with |
| 21 | additional supplemental information. |
| 22 | MEMBER POWERS: That's what I heard last |
| 23 | time. I'd like to see it some day. |
| 24 | MEMBER FORD: The question was also |
| 25 | asked last time about corrosion of the rebar and |
| | NEAL R. GROSS |

WASHINGTON, D.C. 20005-3701

whether that would necessarily be detected by a 1 visual inspection of the outside of the concrete. 2 Obviously the concrete spalls off and you see it, 3 but the damage is done before that occurs. 4 5 What was the resolution of that? I seem to recall, and I 6 MS. FRANOVICH: 7 could be wrong, and I may need to rely on my staff or Duke to chime in, that with the staff's feeling 8 9 that the groundwater was not aggressive, that the concrete would be able to prevent the seepage of 10 water into the rebar, but I'm not sure if that's the 11 correct recollection or not. 12 If Duke or the staff wants to chime in. 13 David? 14 15 DR. KUO: Let me just comment on that. A long time ago, about ten years ago the industry 16 had submitted to the staff for review what's called 17 an industry report, and that included the 18 containment, office buildings, and all of that 19 concrete, other Class 1 concrete structures. 20 During the review of these industry 21 22 reports, we had a roomful of concrete experts 23 together and discussed this subject, and that is how that limit that Rani just read to the committee --24 you know, that limit was set during those meetings, 25

WASHINGTON, D.C. 20005-3701

| 1 | and it really reflects the knowledge in this field. |
|----|--|
| 2 | I don't know if that satisfied Dr. |
| 3 | Powers' question or not. |
| 4 | MEMBER POWERS: Dr. Powers will be |
| 5 | satisfied when he sees solubility relations and |
| 6 | concentrations and aqua solutions. I mean, having |
| 7 | someone say, "Gee, I've never heard of calcium |
| 8 | phosphate. Therefore it can't be important, " is not |
| 9 | a persuasive case. |
| 10 | DR. KUO: No. I think what we have |
| 11 | concluded in those meetings, that we never saw an |
| 12 | operating experience in that fashion. That is |
| 13 | basically what the conclusion was from those |
| 14 | meetings. |
| 15 | MEMBER POWERS: There are two reasons |
| 16 | that one never sees something. It doesn't occur and |
| 17 | you haven't looked. Okay? |
| 18 | Now, there has to be some basis for |
| 19 | concluding that it's not important. That's what I |
| 20 | want to see. |
| 21 | DR. KUO: Yes. Well, like Mr. Jeng |
| 22 | said, we will come back to you on that. |
| 23 | MEMBER FORD: Could you call us or get |
| | |
| 24 | back to us on the rebar corrosion aspect? |

| 1 | MEMBER FORD: In this industry rebar |
|----|--|
| 2 | corrosion is a big item. |
| 3 | MS. FRANOVICH: Even if |
| 4 | DR. KUO: I understand that, Dr. Ford. |
| 5 | For that to happen, of course, the concrete has to |
| 6 | crack, and we have several cases like that of, for |
| 7 | instance |
| 8 | MEMBER FORD: The concrete is really |
| 9 | porous, and all you have to do is get water to the |
| 10 | rebar. |
| 11 | MS. FRANOVICH: It does degrade. |
| 12 | MEMBER FORD: And it's not water any |
| 13 | longer. It's a fairly complex environment once it |
| 14 | hits the rebar. |
| 15 | MS. FRANOVICH: Okay. We have an action |
| 16 | item to get back to you both on these two items, and |
| 17 | I'll make sure that the staff gets something to you. |
| 18 | But, Dr. Powers, I understand your |
| 19 | question on my slide because I did characterize it |
| 20 | as inaccessible. It turns out that there are |
| 21 | accessible portions of these components. So I |
| 22 | apologize for that confusion. |
| 23 | Any other questions on this slide? |
| 24 | (No response.) |
| 25 | MS. FRANOVICH: We had an open item on |
| ı | 1 |

1 the aging management program proposed by the applicant to monitor insulation degradation of 2 electrical cables, in particular neutron monitoring 3 and radiation monitoring cables. 4 5 And the staff's feeling was that a visual inspection of the insulation looking for 6 7 deterioration was really not sufficient to insure that there was no degradation of these cables before 8 9 loop accuracy could be effected. 10 The staff has previously accepted a loop calibration procedure which is a common surveillance 11 12 procedure that is already being performed at most of It ultimately proposed a the nuclear power plants. 13 combination of surveillance requirements that would 14 15 fulfill the loop calibration, aging management program, and that resolved the open item. 16 17 Any questions on this item? (No response.) 18 That concludes my 19 MS. FRANOVICH: presentation of the SER open items. If there are 20 any other open items that I did not discuss that 21 anyone has a question on, feel free to ask. 22 23 MEMBER RANSOM: I had a question on hydrogen mitigation and the power for those in the 24 event of station blackout. It was mentioned in some 25

of the discussion, but is any of that an issue with these plants? MS. FRANOVICH: Well, it's a timely topic to bring up because we're involved in some legal proceedings where that is a concern of one of our petitioners, and the generic safety issue, I think it's 189, which involved combustible gas mitigation with igniters. This is really a current operating issue of a current concern that the staff is addressing through the generic safety issue process. Nonetheless, we did have some contentions that were proffered by intervenor groups that were admitted into the proceeding for hearing. The contentions have since been rendered moot by some staff RAIs, requests for additional information, and responses from the applicant that consider information in aa Sandia report on direct containment heating that touches on this very topic.

So the status of that legal proceeding is that the contention has been rendered moot. Nonetheless there are eight late filed contentions that are associated with that contention that we are going to engage in oral argument on in a couple of weeks here.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 So the legal proceedings are still When we first started out, there was also 2 ongoing. a contention on the potential use of MOX at Catawba-3 That contention also was admitted by the 4 McGuire. ASLB, but subsequently appealed by Duke and the 5 staff and reversed by the Commission. 6 There was another contention that was 7 8 certified to the Commission on the potential for terrorism at these two plants, and the Commission 9 advised the Board not to consider that contention 10 11 for the license renewal proceeding. So where we are right now is there are 12 some eight late filed contentions that are related 13 to that very issue, and we're still going through 14 15 that process. CHAIRMAN BONACA: My understanding, for 16 example, for the severe accident mitigation analysis 17 is that it's not that it's not an issue. 18 issue being dealt with under the current license 19 20 basis. So, therefore, it was taken out from the 21 license renewal proceedings because it was an issue 22 that affects actual operations right now in the 23 covered licensing basis. 24 So it's not that it's not being dealt 25

| 1 | with. It's begin dealt under a different kind of |
|----|---|
| 2 | process. |
| 3 | MS. FRANOVICH: Correct., |
| 4 | CHAIRMAN BONACA: Okay. |
| 5 | MS. FRANOVICH: Thank you, Mr. Bonaca. |
| 6 | MEMBER POWERS: Am I correct in my |
| 7 | recollection that one of the plants I think it |
| 8 | was Catawba had an important flooding hazard in |
| 9 | its IPEEE. |
| 10 | MS. FRANOVICH: Yes. |
| 11 | MEMBER POWERS: And that it has agreed |
| 12 | to mitigate that? |
| 13 | MS. FRANOVICH: Yes, sir, I think it |
| 14 | agreed to build flood barriers for these auxiliary |
| 15 | transformers located in the basement of its turbine |
| 16 | buildings, correct. |
| 17 | MR. ROSEN: Where the condenser seals |
| 18 | are. |
| 19 | MS. FRANOVICH: Pardon? |
| 20 | MR. ROSEN: Adjacent to the condenser |
| 21 | seals like we talked about earlier. |
| 22 | MS. FRANOVICH: No. Actually those |
| 23 | condenser seals are outside the turbine building. |
| 24 | MR. ROSEN: Oh, okay. I have one |
| 25 | concern that comes up. It's really more generic, |
| | NEAL D. CDOCC |

not specifically about Catawba or McGuire, and that isi that we talked to PT about 14 ISGs that are open that have come up as a result of this and prior license extension requests. MS. FRANOVICH: Correct. MR. ROSEN: And that those are moving it through a process to become aspects of the GALL report, and my question is given that we're learning things and putting them into ISGs and ultimately into the GALL, what about the plants that have previously had their licenses extended? Are they subject to these new or is there any process for going back and thinking about the plants that have previously had their license extended? DR. KUO: Dr. Rosen, it's a real good Yes, we are thinking about it, and we are guestion. dealing with it. Actually for those plants to had renewal licenses we are considering whether we should backfit them or not. This is really a -- now that once they got the renewal license, they are in the operating reactor space. We have to follow the backfitting So we are in the process of developing procedure to deal with that.

MS. FRANOVICH: In fact, I think that

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

when we develop new ISGs now, we consider the 1 implications for backfit, and it's part of the 2 process for developing the ISG. 3 MEMBER POWERS: Let me ask you about 4 It seems like a real good route to assure 5 there's no -- to inhibit the evolution of our 6 understanding, you're saying, "Gee, before I develop 7 an ISG, I have to think about everything that I've 8 done before," and even though it's a good idea, it 9 may not pass the backfit rule in those plants that 10 have license extensions. It's still a good idea. 11 Are you really condemning yourself to 12 mediocrity in everything that goes forward because 13 you're wedded to your past sins? 14 DR. KUO: No, it is not. Yes, we will 15 consider the backfit, but backfit, it doesn't 16 necessarily mean that we have to ask those plants to 17 do anything. This is going to become compliance 18 backfit because of a Part 50 rule. 19 So in the space of a compliance backfit, 20 there is some consideration as to whether this is, 21 22 indeed warranted or not. So in case like, Dr. Powers, you said, 23 maybe it's a good idea to do it now and later maybe 24 we really don't have to backfit all the others. 25

| Ī | 69 |
|----|--|
| 1 | It's not an inhibitor for the staff to raise any |
| 2 | ISGs because, you know, in this consideration of a |
| 3 | compliance backfit we do have that what do we |
| 4 | say? the consideration whether we need, we do |
| 5 | need to backfit or not. |
| 6 | So if an issue is a really good idea for |
| 7 | today, for the future applicants |
| 8 | MR. ROSEN: Good enough to get into the |
| 9 | GALL report. |
| 10 | DR. KUO: Right, but really it doesn't |
| 11 | warrant any additional action for those plants who |
| 12 | have renewed their license. We wouldn't do that, |
| 13 | but the thing that we were talking about is at the |
| 14 | time of identifying this ISC, must give |
| 15 | consideration of whether there is the backfit needed |
| 16 | or not. |
| 17 | For instance, we have four |
| 18 | MEMBER POWERS: That's the part that I |
| 19 | find really troubling. I'm sitting there, and I |
| 20 | said, gee, this is a really good idea, but if I |
| 21 | think about it a little bit, it will never pass the |
| 22 | backfit on those other plants. So I'm not going to |
| 23 | bring this thing up. |
| 24 | MS. FRANOVICH: Yeah. I think Bob |

mentioned that --

MEMBER POWERS: I think you've got to 1 separate these things. 2 Yeah, when I mentioned MS. FRANOVICH: 3 that we consider the implications for backfit, some 4 of what we put into ISGs don't involve that 5 potential at all, and so we indicate that when we 6 issue the ISG, that we've reviewed it and there are 7 8 no backfit implications. For others we just indicate that there 9 are, and that's the kind of review that we do. It's 10 not a consideration as to whether or not we issue 11 the ISG or develop the ISG. It's that we indicate 12 up front whether or not it has those implications. 13 Well, I think the ones that MR. ROSEN: 14 15 you say have backfit implications will ultimately fail the backfit test, substantial additional 16 protection, 5109 cost-benefit test. 17 So I think Dr. Powers is exactly right. 18 We are condemned to basically not being able to use 19 new insights in plants that have previously 20 licensed. As a process what that means is that 21 we're not going to do a better and better and better 22 23 job. That's right. MEMBER POWERS: 24 MR. ROSEN: We're just kind of stuck 25

where we are. Whatever kind of insight right now when you're getting ready to relicense, for example, Catawba, that's all the benefit that the regulatory system is going to be able to give. Future understandings and insights, it will be up to Duke to decide whether they want to put them in or not because the regulatory system simply won't be able to pass the 5109 backfit test, unless -- unless the staff decides to take a harder line on compliance backfitting.

Now, there you'd have to make the case,

I think that there's some compliance issue under the
relicensing rule brought up by a given ISG. That's
such a revelation that, gee, we wish we really had
thought about it for all of those other plants, but
you know, we're going to go back to the previous X
number of plants that have previously had their
license extended and order them to include it in
their licenses.

MS. FRANOVICH: Right.

CHAIRMAN BONACA: One aspect is,
however, that many of these issues are really border
line. That's why they've been open until now.
They've been debated, and this is not necessarily
the one for which a hard decision was easy to reach

because it was more like issues were there on the fence between, for example, the functionality test, that you have a passive component in a housing where, you know, the perspective of the licensee here, it's pretty valid, too. I mean, you could rely on the failure.

So I'm saving these are issues that have

So I'm saying these are issues that have been debated for a long time, and I don't think they're so significant to the safety of those plants.

MR. ROSEN: I think you're right that a lot of them are borderline, but I think there are a number of them that are not, and I'll take the jockey pumps as one, speaking for the Fire Protection Subcommittee of the ACRS. You know, there are some issues that are very plain that ought to be, to me, that ought to be included in the scope and treated as with an aging management program properly, and that's something that I feel badly about, for the plants that have already had their licenses extended, have no requirement on their jockey pumps.

MS. FRANOVICH: Well, it's interesting that you bring up this particular ISG because this is one that we feel a backfit is not implicated. I

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

think that the staff supplied the same review for all previous plants, applicants, and it's a battle every time, but the staff has gotten those things in scope that it felt should be in scope or applicants have already identified them.

This ISG was really written at the request of our inspector to preclude expenditure of tremendous resources during the inspections, fighting these issues out. We wanted to get our guidance out to future applicants to make sure that they understand that if they don't apply some of their current licensing basis documents in their review, there's going to be bumps in the road.

So this is one where I think we've always applied the same standards. We're just getting the ISG out to avoid unnecessary debate with future applicants.

CHAIRMAN BONACA: Yeah. We do have a commitment to the Commission to report to them in the springtime, spring to summer, on potential improvements to the license renewal process, and I think it will be interesting to hear from the staff at one of the upcoming meetings for license renewal what the issues are and the potential impact for those plants which have been licensed before, and

they have a different position than those 1 recommended now by the staff. 2 So that we can have a sense of whether 3 or not we should have a recommendation for the 4 Commission. 5 If I may, Dr. Bonaca, I just DR. KUO: 6 want to make one additional comment. Out of the 7 four IC I said that we have completed, only one that 8 we are considering backfit. That's the station 9 The other three are not being backfitted. 10 blackout. MEMBER SHACK: Yeah, but are you not 11 considering a backfit because they've always been 12 included? I mean the fan housings have always been, 13 you know, a contentious thing. You've always 14 insisted they go in. I just sort of figured by now 15 people would stop fighting the battle. 16 I mean it seemed like a waste of 17 It didn't really change the 18 resources. They were always there. requirements. 19 DR. KUO: Correct. 20 MEMBER SHACK: And so are these like 21 I mean, they're asking for things that have 22 been asked in every license renewal. You're just 23 24 codifying the guidance. CHAIRMAN BONACA: By the way, jockey 25

| 1 | pumps have been previously included even at Oconee. |
|----|--|
| 2 | MS. FRANOVICH: Right. |
| 3 | CHAIRMAN BONACA: That was a disputed |
| 4 | issue, but I remember that you verified it, and then |
| 5 | for Oconee they were put in the license renewal. |
| 6 | MS. FRANOVICH: Right. |
| 7 | CHAIRMAN BONACA: Anyway, I think we |
| 8 | have an opportunity at one of the upcoming meetings |
| 9 | to hear about what these issues are, what the |
| 10 | exposure would be to the previous licensees for not |
| 11 | doing that. In many cases it may not be exposure at |
| 12 | all because they are already committed to, and so we |
| 13 | have a sense as a committee if we should see this |
| 14 | issue as a recommendation to the Commission. |
| 15 | MS. FRANOVICH: What can we do to help? |
| 16 | I mean would you |
| 17 | CHAIRMAN BONACA: Just simply bring a |
| 18 | list of those |
| 19 | MS. FRANOVICH: A list? |
| 20 | CHAIRMAN BONACA: how do you call it, |
| 21 | ISGs? |
| 22 | MS. FRANOVICH: ISGs? |
| 23 | CHAIRMAN BONACA: And then, you know, |
| 24 | maybe tell us if previous applications, in fact, did |
| 25 | not have these commitments in. |
| | NEAL D. GDOSS |

1 MS. FRANOVICH: Okay. MEMBER SHACK: Do 14 ISGs include the 2 one that the industry submitted on environmental 3 4 fatique? 5 DR. KUO: That is correct. That is The ROIC process actually made it very 6 correct. 7 clear that anybody, including the public, can 8 propose an IC. In this case the industry proposed an IC on the fatigue, involvement to assist fatigue. 9 And let me go back to also the 5109 10 11 process. There are two kinds of backfits. One kind is adequate protection, and Dr. Rosen was right. 12 Some of these ISGs cannot really pass backfit test 13 there, but there is also this compliance backfit 14 15 just simply because the rule requires that. That in some cases may be less of a 16 requirement than adequate protection. 17 Well, when you come back you 18 MR. ROSEN: can tell us the status of the 14 ISGs and the ones 19 that you think need to be backfitted, whether they 20 fit the 5109 test or whether they would rise to a 21 compliance backfit as PT has suggested. 22 DR. KUO: Right. We will come back with 23 24 that as a generic topic. CHAIRMAN BONACA: Okay. Good. 25

| 1 | MS. FRANOVICH: Okay. Any other |
|----|---|
| 2 | questions on my presentation? |
| 3 | DR. KUO: Thank you, Rani. |
| 4 | And as a result of this presentation, I |
| 5 | have two take-back actions. One is to provide the |
| 6 | additional information to Dr. Powers on the |
| 7 | inaccessible concrete, and the other is the |
| 8 | CHAIRMAN BONACA: Specifically on the |
| 9 | issue of phosphates? |
| 10 | DR. KUO: Yeah, and also the rebar |
| 11 | corrosion. |
| 12 | CHAIRMAN BONACA: Oh, the rebar. |
| 13 | DR. KUO: And also, Dr. Rosen, you |
| 14 | mentioned that there was some operating experience. |
| 15 | I'm sorry. Dr. Rosen was talking about the |
| 16 | operating experience related to the seal, the pump |
| 17 | seal. |
| 18 | MR. ROSEN: I will talk to you off line |
| 19 | about that. |
| 20 | DR. KUO: Okay, okay. And if you can |
| 21 | just hold a moment and let me check, maybe Mr. Hans |
| 22 | Asher here would say something about concrete. |
| 23 | Hans, the question is: how do you deal |
| 24 | with the aging management of an inaccessible area |
| 25 | concrete? The fact that we had some limit, but |
| | II |

yeah. Go ahead.

MR. ASHER: Well, the way we approach in GALL, the issue of inaccessible area, for containment, for example, they are supposed to look at just by the rule, regulation requires them to -- applicant's licensees to look at the area, inaccessible area when there's some finding or there's some symptoms of degradation or corrosion in certain areas in containment surface. So they are to look into it. Regard the number of licensees have done that historically, and I get so many reports on this kind of a thing, like the junction of liner plate and the concrete interface. There's always corrosion there, and they are investigating throughout.

Now, for the other areas, for example, which are in the basement areas, which are normally emitted by soil, by another structure or something, and so in that area what we did in GALL was to establish some safe limits for certain contaminants which could degrade concrete competence.

There are three items that we felt and NEI, NUMARC at that time, agree with those three items and therefore limited the SEC (phonetic).

Three items are the chlorides, the sulfates, and the

pH level of the soil, water which is surrounding 1 that particular concrete item. 2 For chloride I think we set 500 ppm as 3 the limit. For sulfate, we set at 1,500 ppm, and 4 5 for pH where we said anything lower than 5.5 pH level would be something that we would have to 6 7 further evaluate and see what is the degradation or 8 what they plan to monitor those areas. 9 This is what we have right now on the license renewal context. 10 Is there a hint of a 11 MEMBER POWERS: reason for choosing 500 ppm for chloride instead of 12 13 650 ppm? MR. ASHER: Please? 14 MEMBER POWERS: Why 500 ppm instead of 15 650? 16 17 MR. ASHER: Yeah, okay. That is a value that we picked up from American Concrete Institute's 18 19 direct reports in American Concrete Institute. One 20 is ACI 222, which is simply related to the corrosion related event for reinforcing bars mainly in 21 22 concrete. 23 And secondly is ACI 318. After 1980, ACI 318 established certain requirements for 24 25 chloride even in fresh concrete, not in the concrete

which is hardened concrete, but in the fresh 1 concrete also, and based on what we understood and 2 what we knew about, I think we felt that 400 ppm is 3 a safe limit. 4 5 Industry and we had dialogue of this particular item for a long time in the 1993 to 1995, 6 7 1996, before it became a part of NUMARC document. What is it technically we're using? Understanding 8 industry report. 9 So that is where it was established for 10 11 inaccessible areas. MS. FRANOVICH: I just wanted to add to 12 that that the last time we met the staff had a 13 slide, and I still have it with me. I can put it up 14 15 on the overhead projector, of the data that Duke had collected over the last 20-plus years. These are 16 17 lake water data that indicate what the pH, chloride and sulfate levels have been. 18 And the staff's basis for determining 19 that the groundwater was not aggressive is based on 20 So if you would like to see them, I can 21 these data. put them up. I have them right here. 22 23 MEMBER POWERS: Well, I mean, you did show them to us before. 24 25 MS. FRANOVICH: Yeah.

MEMBER POWERS: And they elicited exactly the same response. There's no phosphate indication there. It is not a useful thing to take lake water and then infer that is what groundwater is. The two are just not the same. Okay? Because if nothing else, the groundwater goes through the ground.

The acceptance of 500 ppm for chloride and 1,500 ppm is always referred to ACI 318. ACI 318 does not tell you why they took those values. So you haven't got a clue why the staff is doing things. Okay?

I give in on ACI 318. You're accepting an industry standard there, and the Commission says. It's not consistent with what we expect from the staff, which is a good science based understanding of what it's requiring, but okay. There's a point where you give up and say, "Okay. We'll take it."

But now we raise this issue of phosphate, and all we hear is the experts say it's not important. We know positively that appetites do form, that they're volumetrically large, that they cause spallation in the intragranular, interaggregate spaces, and for the same reason that gypsum formation causes concrete spallation. So why

| 1 | shouldn't they be considered? |
|----|--|
| 2 | I mean, I never get an answer to that, |
| 3 | except the experts say it's not important. The |
| 4 | experts could well be right. I just don't |
| 5 | understand why. |
| 6 | MS. FRANOVICH: Perhaps what we need to |
| 7 | do is take a look at the same references that you're |
| 8 | familiar with and see if we can |
| 9 | MEMBER POWERS: Well, you're looking at |
| 10 | ACI 318. I mean, it's kind of a little button on |
| 11 | concrete placement and maintenance. Okay? |
| 12 | DR. KUO: Dr. Powers, I guess, you know, |
| 13 | this is really not the forum of the discussion, and |
| 14 | I will take this back and come back to the |
| 15 | committee. |
| 16 | MEMBER POWERS: Yeah. I'll just simply |
| 17 | say I've heard that before. |
| 18 | DR. KUO: Okay. If there are no other |
| 19 | questions, that concludes the staff's presentation |
| 20 | on the SER for McGuire and Catawba license renewals. |
| 21 | Thank you. |
| 22 | DR. KUO: And, Dr. Bonaca, this |
| 23 | concludes the staff's presentation. |
| 24 | CHAIRMAN BONACA: Thank you. |
| 25 | I would like to go around the table here |
| - | 1 |

| 1 | and see if any of the members have additional |
|----|---|
| 2 | questions for the staff or for the licensee. |
| 3 | Insofar as this information on having to |
| 4 | look for additional information on the issue of |
| 5 | concrete. |
| 6 | DR. KUO: Right. |
| 7 | CHAIRMAN BONACA: Okay, and |
| 8 | DR. KUO: I will come back and arrange |
| 9 | with the ACRS staff and see. |
| 10 | CHAIRMAN BONACA: Yeah. Please speak |
| 11 | with me and se can set up a time. |
| 12 | DR. KUO: Certainly. |
| 13 | MEMBER APOSTOLAKIS: So can we write a |
| 14 | letter then? |
| 15 | CHAIRMAN BONACA: Could you also include |
| 16 | the rebar? |
| 17 | MEMBER APOSTOLAKIS: I think first we |
| 18 | should write a letter. |
| 19 | CHAIRMAN BONACA: I'm sorry. |
| 20 | MEMBER APOSTOLAKIS: Aren't we supposed |
| 21 | to write a letter this time? |
| 22 | CHAIRMAN BONACA: Yes, but hopefully we |
| 23 | can hear something before. |
| 24 | MEMBER APOSTOLAKIS: Huh? |
| 25 | CHAIRMAN BONACA: We can hear maybe |
| ļ | NEAL D. ODOGG |

| ₊ | something from the staff before we get to that. |
|--------------|--|
| 2 | MEMBER APOSTOLAKIS: Oh, before. |
| 3 | CHAIRMAN BONACA: And then we will look |
| 4 | at that. |
| 5 | MR. ROSEN: And we have an issue that |
| 6 | maybe we don't address in the McGuire and Catawba |
| 7 | letter, but we address in our opportunity to talk to |
| 8 | the Commission about improvements to the license |
| 9 | renewal process about previously relicensed plants |
| 10 | no being able to gain the benefit of new GALL |
| 11 | provisions. |
| 12 | CHAIRMAN BONACA: That's right. So we |
| 13 | will handle it that way under that umbrella. |
| 14 | Okay. If there are no further questions |
| 15 | on this issue, I will thank the staff for the |
| 16 | presentation. I think that the SER was, in general, |
| 17 | a very quality document. So I commend you for that. |
| 18 | And with that we'll take a break. Since |
| 19 | we're ahead of time, we'll start the meeting at |
| 20 | 10:20. |
| 21 | (Whereupon, the foregoing matter went |
| 22 | off the record at 10:04 a.m. and went |
| 23 | back ion the record at 10:31 a.m.) |
| 24 | CHAIRMAN BONACA: Let's resume the |
| 25 | meeting. |

The next item on the agenda is the draft 1 regulatory guide, the G-1107, "Water Sources for 2 Long-Term Recirculation Cooling Following a Loss of 3 Coolant Accident, and Draft Generic Letter 2003-XX, 4 related to the resolution of GSI 191, "Assessment of 5 Debris Accumulation on PWR Sump Performance." 6 7 And Dr. Wallis will guide us through 8 this presentation. Thank you, Mr. Chairman. 9 MEMBER WALLIS: We heard about this issue in 2001. 10 11 concerns the debris which is released into a containment building during a LOCA, for instance, 12 and it falls or it is transported in the building. 13 It may reach the region of the strainers for the 14 pumps which are relied upon for long-term cooling by 15 recirculation. 16 And the question is: what is the effect 17 of this debris on the functioning of that system? 18 We wrote one of the shortest letters 19 20 we've ever written in September, on September 14, 21 2001, where we said the NRC staff should 22 expeditiously resolve GSI 191, and we stated if 23 plant specific analyses are required, guidance for performing these analyses should be developed. 24 25 The staff has now prepared a generic

1 letter, which is their answer to resolving the issue, and they have, along with that generic 2 letter, prepared a draft guide, a reg guide which 3 will provide this guidance for performing the 4 analysis which the licensees will be asked to do. 5 And so things are moving along. 6 Thermal Hydraulic Subcommittee heard about this a 7 8 couple of days ago, and the staff is here today to present to the full committee. I think Gary Holahan 9 10 is going to start us off. 11 Please do so, Gary. Thank you. MR. HOLAHAN: 12 My name is Gary Holahan. I'm the 13 Director of the Division of Systems Safety and 14 Analysis at NRR. 15 The NRR and the research staff will go 16 through and present you the details of the generic 17 letter and where we're going on this issue. 18 wanted to make a few introductory remarks to remind 19 the committee that there was a research study that 20 we're basing our actions on, and basically the 21 conclusions of that research study was that PWR sump 22 concerns were credible, but that we couldn't really 23 address them without more plant specific 24 information, and that's what led us to the path of 25

going out and getting more information, involving licensees and also developing technical guidelines by which we can judge the status of individual plants and what sorts of corrective actions might be needed and whether those corrective actions were, in fact, sufficient. And you'll hear about that in our presentations today.

The reason we're here with the committee is because this activity involves both the resolution of a generic safety issue for which the ACRS' role is important, and it also involves generic communication for which both the CRGR and the ACRS have roles.

And I think although it is sort of voluntary for the ACRS to involve itself in a generic letter, I think it makes sense in this context since it's an important one and also because it really is the key resolution path to the generic safety issue itself.

May I have the second viewgraph?

One thing I wanted to make clear, and you won't hear this too much later on in the presentation because most of what we're talking about is forward looking in how we're going to resolve the issue, but to remember that we always

ask ourselves the safety questions.

Why is it okay to continue operation, if that's appropriate?

How long would that be appropriate? We recognize there are a lot of issues that can't be resolved on a short term basis. It requires information.

So when a generic safety issue is first identified, we have to ask ourselves: why is it okay to allow plant operation while we're studying it?

We also have to ask that question on a sort of continuing basis. Whether a generic letter or a bulletin or an order or whatever action we take, there are some time frames involved and implied, and we have to ask ourselves, again, are we comfortable with the information and the state of the plants so that we can in this case take the time to develop guidance, to send out a generic letter, in this case even send it out in a draft form for public comment.

And so we're just going to remind the committee that we do such things, that we consider things such as the probability of meeting the sump, what compensatory actions are possible, the

advantage one has from a leak-before-break point of view, the fact that there are some additional margins which because we didn't do plant specific analyses may be available as you'll hear in the discussions.

What we really looked at was areas and concerns about losing net positive suction head to the recirculation or containment spray pumps. But, in fact, there's some margin in that approach. There's more margin than just the design margins, and we don't give credit for containment over pressure and those sorts of issues.

We also are --

MEMBER POWERS: Gary, is that a universality? I think you do give credit for containment over pressure in some cases.

MR. HOLAHAN: For the boiling water reactors.

MR. ARCHITZEL: There are a couple PWRs where over pressure, very few, but as part of this process, we are recognizing that over pressure that we're carrying, and that's part of the regulatory guide changes. Our practices are incorporated into the reg guide that's in front of you, and it is the minimal possible. You do a different analysis.

There are very few PWRs, more BWRs, but there are some that have over credit pressure, not total, but partial.

MR. HOLAHAN: In addition to that, we are aware and have been working with the industry on some interim actions they're taking even before we issue the generic letter. They've been, I think, rather proactive in responding directly as a result of the research study before waiting for our generic letter to go out.

And so a number of plants have been following a guidance from generic program developed through NEI of looking at maybe not the issue in all of its ramifications, but at least looking at where they are with their particular sump; certainly doing walk-downs in containment and looking at cleanliness and related issues.

And there are at least two PWRs that have decided already to make improvements to their sumps. So the combination of these things together gives us enough comfort for moving ahead on a schedule that we've proposed. These considerations don't make the issue go away. They don't completely resolve the issue. We think it's still an important issue and it needs to be, you know, driven to an

NEAL R. GROSS

1 appropriate conclusion. But at least there's a certain comfort 2 level that we're going to maintain safety in the 3 4 interim. If I could have the fourth viewgraph. 5 This is somewhat vaque, MEMBER WALLIS: 6 7 the word "a certain comfort level." It would be 8 nice if you had a more specific measure of this comfort about maintaining safety. 9 MR. HOLAHAN: Well, part of the 10 11 difficulty is the nature of this issue. The fact that we have to go out and get plant specific 12 information leaves us in a condition where we can't 13 definitively say how much margin there is at any 14 given plant. So part of the imperative for getting 15 the generic letter out is so that we are more 16 informed, but I think --17 MEMBER WALLIS: So you don't know enough 18 to make this assessment that I want more specific. 19 The information isn't there. 20 MR. HOLAHAN: That's correct, and I 21 think if it were, perhaps we'd be approaching the 22 issue a little differently. So if we knew that 23 there were three plants that had very little or no 24 margin, then we'd deal with that differently.

MEMBER WALLIS: I think we determined at 1 2 the subcommittee meeting this is what you are going You're going to find out this information. 3 4 MR. HOLAHAN: that's right. 5 MEMBER WALLIS: Then it may be clear what specific actions you need to take. 6 7 MR. HOLAHAN: Yes, indeed. 8 And what information? I mean, we may 9 very well accelerate our activities on a few plants 10 that are problems and may be more tolerant of plants that have only minor issues. 11 12 MEMBER WALLIS: Okay. 13 The three major activities MR. HOLAHAN: 14 that are going on really have to do with a draft 15 regulatory quide, which is really a revision to 16 Regulatory Guide 1.82. 17 An industry initiative activity, which 18 is developing specific technical guidance that can 19 be used by individual plants to test where they are 20 with respect to this issue and what they need to do 21 and the generic letter itself, which is our 22 regulatory tool for kicking off that activity. 23 At the bottom of the viewgraph you see 24 basically the closeout activities are after the 25 generic letter goes out we'll get responses from

1 each plant. We'll review those. Hopefully in a 2 short order, because of the guidance available, we 3 think maybe this can be an efficient review; come to closure on what actions we think need to be taken 4 5 and on what time frame. Where there are some difficult or 6 7 technical issues, we may do sample audits or 8 independent calculations as we did for the case of 9 the BWR sump strainers, and in the normal course of 10 action, we would issue a temporary instruction, 11 which is an instruction to our resident inspectors 12 to see that appropriate closeout activities are taken. So that's a general overview of where we are and how the program works, and what we're going to do today is kind of walk you through the structure and the technical expectations in the generic letter. John Lehning, are you going to do that for us? Ralph. MR. ARCHITZEL: Well, I'll try and go through quickly. My name is Ralph Architzel. with Plant Systems Branch at NRR. I'll try and

> **NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS** 1323 RHODE ISLAND AVE., NW. WASHINGTON, D.C. 20005-3701

quickly go through some of my slides from the other

day.

13

14

15

16

17

18

19

20

21

22

23

24

4 5

Can I have the next slide, John?

First, I'd like to note that Generic
Safety Issue 191 is related to the Regulation 5046
and Criterion 35 for long-term recirculation. It's
sort of critical. We consider this a compliance
issue in some instances, and those are the
regulations involved.

As Gary has mentioned, the reblockage may prevent the injection of water into the reactor core or containment spray operation.

of note, USI A-43 did examine this. It was principally focused on vortex formation, along with debris blockage by fibrous insulation. It was closed in 1985 with a recommendation going forward that mechanistic analyses be performed by licensees as they changed out insulation, et cetera.

A specific decision was made not to backfit at that that time as it wasn't cost beneficial, but forward looking plants had to do deterministic analyses, and the current fleet of plants should consider that when they changed out insulation because of the expenses involved.

So GSI-191 was opened in 1996 because of events that happened at the BWRs and also because of new information during the BWR resolution that was

identified, such as the thin bed effect and other 1 2 aspects of that. So we reexamined USI A-43 and 3 resultant GSI-191 being initiated. Research 4 completed their technical assessment, concluding 5 that there was a sufficient basis to conclude it's a 6 credible concern, and we're in the process of 7 developing regulations. 8 The current generic letter you have in 9 front of you today is based on a -- has actions that 10 require us to consider this a compliance backfit. So now we're reversing that position at least in the 11 12 draft staff position and considering this to be a 13 compliance backfit issue associated with the generic 14 letter. 15 We realize this is a pre-decisional 16 document. We still have to go through the CRGR. 17 the moment it is a compliance backfit. MEMBER APOSTOLAKIS: What is it that --18 19 let's go back. What is it that USI A-43 missed when 20 you closed it? The principal concern 21 MR. ARCHITZEL: was the new information. I mean it didn't miss that 22 23 It did say we have a 50 percent criteria on 24 blockage of some screen that we put out with not a 25 good, sound basis way back in the beginning.

WASHINGTON, D.C. 20005-3701

identified that as being faulted. It picked that up.

What it didn't pick up, the large blankets and the transport of large fiberglass break-up, and it finds that new transport, et cetera, generation should be considered mechanistically. It didn't have effects like the thin bed effect where you have a very fine fibrous in the suppression pool at the boilers that resulted in those events, and then you have the particulate debris that goes along with that and can result in some clogging at much different configurations that were assessed at the time of USI A-43, some of the paint chips, you know, different particulates.

There was more information that was identified after that point in time that would change the balance of a cost-benefit.

MEMBER APOSTOLAKIS: And this information came from where?

MR. ARCHITZEL: Well, the Barseback event, or a lot of research that has been done since then, the transport mechanisms, how the debris is -- I mean, we had a presentation the other day by Los Alamos about a lot of the testing they've done, and there is a lot more information today than there was

then.

MEMBER POWERS: I have, quite frankly, lost track of the experimental bases for a lot of these discussions. I guess I'm familiar with some of the Los Alamos sponsored experiments on beds and things like that affecting the screen.

It seems to me that when Los Alamos was before us, there was quite a lot of discussion about uncertainties in the analyses of, one, what kind of debris was formed during a break, what range of it of area was affected, and the subsequent transport of that debris from whence it was formed to the sump itself.

Could you give us a thumbnail sketch of what the experimental support there is for those aspects of the analyses?

MR. ARCHITZEL: Are you talking about the uncertainties? I'm not -- I mean, if I went into the parametric and looked at how you took all of the parametric cases and --

MEMBER POWERS: I'm not so concerned about the analysis itself. I'm trying to recall what the experimental data base is.

MR. ARCHITZEL: It wasn't just the work Los Alamos did. It also was based on the work that

was done for the boiling water reactors and the 1 foreign experience in testing. 2 For the generation transport, like the 3 4 steam air jet test, there is a tremendous history of testing associated with this issue, and still 5 uncertainties, too, as you --6 7 MEMBER POWERS: Oh, sure, and there 8 always will be. I guess what I'm asking really is do we have reasonable qualitative understanding of 9 the phenomena associated with first the formation of 10 11 the debris and the subsequent transport of it. I mean, you try to calculate transport 12 of debris particles, and you're going to run into 13 serious problems knowing what drag coefficients are 14 15 used and flow pathways and things like that. wonder do we have large scale tests that give us 16 some confidence that these models that Los Alamos 17 was using are roughly correct. 18 DR. WEERAKKODY: This is Sunil 19 Weerakkody. I'm the Section Chief in the Plant 20 Systems Branch. 21 I am not familiar about the 22 I can try. 23 historical aspects of this issue, but I have visited the experimental facilities both at LANL and also at 24 25 University of New Mexico which were constructed just

for this purpose.

MEMBER POWERS: Incidentally, the folks at University of New Mexico just before Christmas invited me down to visit their experimental facilities, and so I'm reasonably familiar with what they've done there, and quite frankly, their work puts a perspective on this that you might not derive from just looking at the raw paper work.

MR. ARCHITZEL: March 4th there's another meeting coming up at New Mexico, and the French are coming to that meeting also.

MEMBER POWERS: This committee is not.

DR. WEERAKKODY: Well, I can try to answer some of the parameters to the limited knowledge I have that Los Alamos did look at. One of the parameters they looked at in the University of New Mexico facility is how the velocity of -- I don't know the exact term -- the velocity of water that approaches the sump, how that affects the transport of different natures of debris because you have debris like RMI, and I'm sure you have seen, you know, that's metallic and what kind of velocities are necessary to transport that type of debris up to the screen where it is transporting things like fiber. What type of velocities are

needed to transport that type?

So that was one parameter I know for a fact that they did look at. Then when I think of the facility at Los Alamos, you said you have seen that. In all of there they construct an apparatus where they have a pump and the screens, and then they introduce, you know, debris that they would think would be the type of debris that could be created during the loss of coolant accidents and missile delta Ps.

So there was real hard data that were generated to support this issue. I'm not sure I answered fully all of your questions, but --

MEMBER POWERS: Well, I'm sure that a fool can generate questions that a wise man would take a lifetime to answer, and so I'll play the fool here a little bit.

MR. ARCHITZEL: And let me just clarify one thing. If there's a lot of detailed information, and BP will talk about, second, there's some knowledge based documents and final preparation. It's a fairly thick document, but it's a track record back to the other experimental. You can go in there and you can go to the other NUREGS and the other historical aspects.

MEMBER POWERS: I think that's the news 1 2 I wanted to hear. MR. ARCHITZEL: And that document will 3 4 be useful for industry in resolving this as well, and BP should be talking about this versus me, but 5 that's the key document. We've been reviewing that. 6 7 MEMBER POWERS: So eventually we'll have 8 a nice handbook that says here's all that we know about this issue from an experimental point of view. 9 DR. WEERAKKODY: Absolutely right. 10 11 MEMBER POWERS: I think that's a -- you guys deserve big credit for pulling that all 12 I hope you do a great job on that because 13 together. that would be of historical value. It will be of 14 15 value to people designing new reactors. I mean, do a good job on that one. That's great. 16 MEMBER WALLIS: Dr. Powers, we had a 17 presentation from Los Alamos at the subcommittee 18 meeting, and there was quite an extensive give-and-19 take, and talked about their ways of approaching the 20 generation of debris, the way in which they defined 21 the area in which the insulation was destroyed and 22 essentially broken up into small particles of 23 various sizes and fibers and so on, and they 24 25 essentially said that for a large LOCA, the material

1 within that region was disbursed throughout containment and the velocities and so on. 2 MEMBER POWERS: Well, I know that's what 3 The question is is that true. 4 they say. MEMBER WALLIS: Well, again, that is a 5 I think one would have to -- someone has 6 question. to peer review that and so on, but then that is to 7 say that they were addressing the questions of 8 transport in the water with CFD and all of that. 9 So we did have a look at that, and I 10 guess you're right to say how far do you have to go 11 to verify that the models are okay. 12 The way this is evolving is that the 13 ball is very much in industry's court, that generic 14 15 letter says you will analyze these things for your plant because each plant is different, and not only 16 is it in industry's court, but NEI has promised to 17 provide the guidance on the matters that you've been 18 asking questions about. 19 So the success of this process depends 20 very much on the response of industry and NEI, and I 21 think the Los Alamos work has been very, very useful 22 in establishing some of the things one needs to 23 worry about. It's ongoing, and I hope it results in 24 the document that you're suggesting, but the process 25

here is to get the letter out and get information back from industry and get them to get NEI to develop this, industry to develop the methods for analyzing individual plants.

MEMBER POWERS: Well, I guess I agree with you that the strategy that the staff has approached here seems appropriate. They've done their analyses enough to see that they have a real issue here, and then they've said, well, but the issue really belongs to the industry and now they're turning it over.

I still think that this data document that you're putting together is just a great idea.

There is going to be a DR. WEERAKKODY: I'd like to add one caveat to what data document. Dr. Wallis said, which is we have made it clear to the industry that whenever they develop guidance, we We don't do review them, review our comments. safety value in some of them, but even in our generic letter, we make it clear in that that if we feel that they're not going in the right direction, then we would come back and say, 'No. That's not the first direction. So, you know, we try to the extent possible work with them, but at the same time, given the significance of this issue, we keep

WASHINGTON, D.C. 20005-3701

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

an eye on what, you know, is happening on all aspects.

MEMBER LEITCH: Ralph, a few minutes ago you used the term "compliance backfit." Could you explain the implications of that?

MR. ARCHITZEL: When you do a backfit like was done with -- the regulatory analysis guidelines have changed somewhat since '85. They allow now for compliance backfits. When you do a compliance backfit, a simplified cost-benefit, it still needs to be a significant issue, but you don't need to show a positive cost-benefit.

If we had to do a cost-benefit even today with an industry program and the way the regulatory analysis guidelines are set up, you have to factor in that program. You have to do best estimate with the program, without the program, and then you do the cost benefit, and that's a regulatory analysis without a compliance backfit basis.

It would be very hard probably even still to pass such a program with an industry program in place, but we can still, even if we didn't do compliance backfit, we can choose to do a backfit on that basis. We'd have to do that and

then show a net benefit would go up. That's 1 noncompliance backfit. 2 Okav. So we could still do that, but 3 it's unlikely at this stage with an industry program 4 to pass muster. A compliance backfit says that 5 considering the way we've established the 6 guidelines, we don't believe the ECCS system is in 7 compliance with what we're looking for for long-term 8 recirculation, those regulations I quoted. 9 Therefore you need to change your analysis, 10 mechanistically evaluate that phenomenon, and that's 11 what we're imposing, is actions in the draft generic 12 letter. 13 That is pre-decisional. We haven't gone 14 through the CRGR yet. So we could come back with 15 this, an information generic letter that wouldn't 16 have any compliance aspects to it. It has the same 17 impact, but it's not quite as hard an action as the 18 compliance backfit generic letter. 19 MEMBER LEITCH: So the main difference 20 is that a cost-benefit analysis does not have to be 21 22 done or has that --MR. ARCHITZEL: A simplified one has to 23 be done for a compliance backfit, but not a rigorous 24 We still need to do some type of -- and the 25

| 1 | one we're referring to now is the one that was done |
|----|--|
| 2 | two years ago by research. You had it in the |
| 3 | package, but it's not a rigorous regulatory |
| 4 | analysis. It would be a different one if we had to |
| 5 | do one today. |
| 6 | MEMBER WALLIS: This is really |
| 7 | compliance. I mean, the LOCA system has to work, |
| 8 | and if the debris prevents the system, the mitigated |
| 9 | system, from working, then this is not mitigating |
| 10 | the LOCA. |
| 11 | MR. ARCHITZEL: But from a compliance |
| 12 | backfit standpoint, we're changing the way you say |
| 13 | it works. We said 50 percent clean screens or 50 |
| 14 | percent blocked is the guidance, and we agreed to |
| 15 | that and we accepted that, and that's how these |
| 16 | plants were designed and operated. |
| 17 | So they're in compliance today until we |
| 18 | take an action to say different. |
| 19 | MEMBER LEITCH: Okay. Thank you. |
| 20 | MEMBER APOSTOLAKIS: So, I mean, this is |
| 21 | telling us what Los Alamos did, but what did they |
| 22 | find? I mean, address testing or knowledge based |
| 23 | uncertainties. Can you tell us in one or two |
| 24 | sentences what the conclusion there was? |

MR. ARCHITZEL: I've got a back-up. Let

| 1 | me just give you the typical numbers. Whether those |
|----|---|
| 2 | are actually the numbers, we've had numbers |
| 3 | portrayed, how many plants, good, bad, et cetera. |
| 4 | The bottom line was there was a significant |
| 5 | additional core damage frequency projected by the |
| 6 | Los Alamos work. |
| 7 | MEMBER APOSTOLAKIS: Okay. |
| 8 | MR. ARCHITZEL: For the current |
| 9 | condition it was less of a core damage frequency if |
| 10 | you assume large break LOCA initiating events, and |
| 11 | then if you factor in operator actions, one of the |
| 12 | things in my slide here, to evaluate the potential |
| 13 | recovery actions. We're finishing up with a report |
| 14 | on that right now. |
| 15 | Then, for example, in a large break LOCA |
| 16 | case, it might be an increase in CDF on the average |
| 17 | of two, without operator action, it might be like |
| 18 | 17. There's numbers like that out there. |
| 19 | MEMBER WALLIS: Would you tell him the |
| 20 | number that Los Alamos gave us? |
| 21 | MR. ARCHITZEL: Yeah, these are I've |
| 22 | got the studies. |
| 23 | MEMBER WALLIS: Well, we heard a number |
| 24 | 170. |
| 25 | MR. ARCHITZEL: Well, that's without |

| 1 | that number should have been 140. |
|--|---|
| 2 | MEMBER WALLIS: It's still a big number |
| 3 | without these other operator actions and so on. |
| 4 | MR. ARCHITZEL: But whether that's a |
| 5 | best estimate PRA, you know, there's some question. |
| 6 | We've got that's what Los Alamos did for us to |
| 7 | evaluate this associated with the |
| 8 | MEMBER APOSTOLAKIS: And how were the |
| 9 | operator recovery actions evaluated? |
| 10 | MR. ARCHITZEL: On the same basis of |
| 11 | do you mean how many operator? |
| 12 | MEMBER APOSTOLAKIS: Presumably they put |
| 13 | some probabilities there. |
| 14 | MR. ARCHITZEL: Oh, yes. |
| | |
| 15 | MEMBER APOSTOLAKIS: How? |
| 15 16 | MEMBER APOSTOLAKIS: How? MR. ARCHITZEL: Like the operator |
| | |
| 16 | MR. ARCHITZEL: Like the operator |
| 16 17 | MR. ARCHITZEL: Like the operator availability of taking the water storage tank and |
| 16 17 18 | MR. ARCHITZEL: Like the operator availability of taking the water storage tank and getting another source into the refueling water, to |
| 16 17 18 | MR. ARCHITZEL: Like the operator availability of taking the water storage tank and getting another source into the refueling water, to keep the ECS running and whether the operator turns |
| 16 17 18 19 20 | MR. ARCHITZEL: Like the operator availability of taking the water storage tank and getting another source into the refueling water, to keep the ECS running and whether the operator turns off the pump and starts it again and can if that |
| 16 17 18 19 20 | MR. ARCHITZEL: Like the operator availability of taking the water storage tank and getting another source into the refueling water, to keep the ECS running and whether the operator turns off the pump and starts it again and can if that would be effective in clearing the insulation. |
| 16 17 18 19 20 21 22 | MR. ARCHITZEL: Like the operator availability of taking the water storage tank and getting another source into the refueling water, to keep the ECS running and whether the operator turns off the pump and starts it again and can if that would be effective in clearing the insulation. MEMBER APOSTOLAKIS: Do you happen to |
| 16 17 18 19 20 21 22 23 | MR. ARCHITZEL: Like the operator availability of taking the water storage tank and getting another source into the refueling water, to keep the ECS running and whether the operator turns off the pump and starts it again and can if that would be effective in clearing the insulation. MEMBER APOSTOLAKIS: Do you happen to recall what model they used for these things? |

| 1 | you. |
|----|--|
| 2 | MEMBER APOSTOLAKIS: I am interested. |
| 3 | MR. ARCHITZEL: It's a draft though. |
| 4 | DR. WEERAKKODY: We can provide it to |
| 5 | you later. |
| 6 | MR. ARCHITZEL: We can provide it to |
| 7 | you. |
| 8 | DR. WEERAKKODY: I don't have the |
| 9 | answer. |
| 10 | MEMBER SHACK: MEMBER APOSTOLAKIS: Are |
| 11 | we writing a letter on this today? No. |
| 12 | MEMBER WALLIS: Do you want to talk |
| 13 | about that now or do you wish to talk about it |
| 14 | later? |
| 15 | MEMBER APOSTOLAKIS: Oh, it's up in the |
| 16 | air. |
| 17 | DR. WEERAKKODY: But one thing I wanted |
| 18 | to add to what Carl said, Dr. Apostolakis, is in |
| 19 | terms of the knowledge base uncertainty, it's not |
| 20 | just the core damage frequency numbers that the Los |
| 21 | Alamos contributed. If you look at the history of |
| 22 | this issue, for boilers the agency could take a much |
| 23 | more rigorous approach because of events where the |
| 24 | screen was blocked. |
| 25 | So in terms of uncertainty, there's |

quite a bit of certainty that this is a problem, and the agency issued a bulletin, then a letter, and had the boilers -- initiate the boilers to address that.

When it came to pressurized water reactors, we have never had an actual case where sump recirc. was actually demanded. All of the small LOCA events we had in the industry were mitigated before proceeding with the sump. recirc. stage. So it was a case of zero demands and zero failures.

In a situation like that, now you need some original experimental data to establish the credibility of what you postulate, and I think the Los Alamos study significantly contributed to the issue so that we can engage the industry with strength in saying, "Look. We did the experiments. We think there's a potential issue here." So we all should pay attention and resolve this.

So I think if I summarize the knowledge base uncertainty that LANL contributed, that's that. In terms of the recovery actions, you know, we would provide you the numbers and the basis that they gave us, but I just want to tell you that the type of operator actions, the operators can take in situations like this, we don't normally assign. I

| 1 | don't think they can assign very high failure |
|----|---|
| 2 | probabilities. |
| 3 | So whatever are the CDF numbers that we |
| 4 | came with were not |
| 5 | MEMBER APOSTOLAKIS: Now, why is that? |
| 6 | DR. WEERAKKODY: Because, again, you run |
| 7 | into situation of limited demands and limited |
| 8 | failures. If you look at the type of operator |
| 9 | actions the operators must take in a scenario like |
| 10 | this, one of the things you talk about is refilling |
| 11 | the RWST, and this has to be done. First there |
| 12 | should be a water source available. Cross-ties have |
| 13 | to be made, and this kind of action has to be done |
| 14 | within a short time frame under stressful |
| 15 | conditions. |
| 16 | A second operator action, again |
| 17 | MEMBER APOSTOLAKIS: So wait a minute. |
| 18 | DR. WEERAKKODY: Yeah. |
| 19 | MEMBER APOSTOLAKIS: Maybe I didn't |
| 20 | understand what you said. You said you cannot |
| 21 | assign verified probabilities of failure? |
| 22 | DR. WEERAKKODY: You cannot assign |
| 23 | oh, well, maybe I used the wrong word. |
| 24 | MEMBER APOSTOLAKIS: Because your |
| 25 | argument is you |

| 1 | DR. WEERAKKODY: Yes, yes. |
|----|--|
| 2 | PARTICIPANT: Low probability. |
| 3 | MEMBER APOSTOLAKIS: A low probability, |
| 4 | but what is a low probability of failure? |
| 5 | DR. WEERAKKODY: When you look at |
| 6 | operator actions and the failure probabilities, you |
| 7 | see numbers like .001, .5 and |
| 8 | MEMBER APOSTOLAKIS: For failure? |
| 9 | DR. WEERAKKODY: For failure, yes. So |
| 10 | you wouldn't see failure probabilities such as .001 |
| 11 | in a situation like this. Again, what I would |
| 12 | MEMBER WALLIS: I'm confused. You will |
| 13 | see big numbers like .5. Is that what you're |
| 14 | saying? |
| 15 | DR. WEERAKKODY: Yes. |
| 16 | MEMBER WALLIS: If it's .5, it doesn't |
| 17 | matter whether it's failure or success, does it? |
| 18 | MEMBER APOSTOLAKIS: But didn't se just |
| 19 | hear that without recovery actions the delta CDF was |
| 20 | very high and then with recovery went down? |
| 21 | MR. ARCHITZEL: About an order of |
| 22 | magnitude. |
| 23 | MEMBER APOSTOLAKIS: About an order of |
| 24 | magnitude. How do you go down by an order of |
| 25 | magnitude if the failure probability of the |

1 operators is .5? DR. WEERAKKODY: Because it's a 2 3 combination of operator actions. You know, again, what I would rather do is give you a copy of the 4 5 report we have because right now I'm speaking from the overall knowledge I have rather than the 6 7 specific numbers that are in this report. 8 But the short answer to your question 9 would be it is not just one operator action. have a couple of operator actions, such as another 10 11 action I know that the operators can take is stopping and restarting the pumps, and I don't know 12 how that has been factored into the support because 13 we just got the report a couple of days ago. 14 15 MEMBER APOSTOLAKIS: From where? DR. WEERAKKODY: From Los Alamos. 16 17 MR. ARCHITZEL: But it's delayed recirculation by not having both trains working, you 18 19 know, delayed if you can avoid the containment spray starting. There's different things that can be 20 done, and they are factored in there, and they are 21 analyzed on that analysis. 22 23 MEMBER APOSTOLAKIS: Yeah, I'd like to

NEAL R. GROSS

MEMBER LEITCH:

see that.

24

25

Is it not also a factor

| 1 | that even if the operator does all of the things |
|----|---|
| 2 | that this procedure prescribes that it may not be |
| 3 | successful? |
| 4 | MR. ARCHITZEL: Right. |
| 5 | MEMBER LEITCH: Is that factored into |
| 6 | the issue? In other words |
| 7 | MR. ARCHITZEL: Sure. |
| 8 | MEMBER LEITCH: I presume the |
| 9 | procedures could prescribe some remedial operator |
| 10 | actions, but they may not be successful at removing |
| 11 | the debris from the |
| 12 | MEMBER APOSTOLAKIS: That's right. |
| 13 | MEMBER LEITCH: So is that when you |
| 14 | talk about the success of operator actions, are you |
| 15 | talking about the faithfulness with which he does |
| 16 | them versus whether those actions are successful or |
| 17 | not? Are both of those factors included? |
| 18 | MR. ROSEN: You fraction for both. You |
| 19 | have an event tree. |
| 20 | MEMBER LEITCH: Right. |
| 21 | MR. ROSEN: You fraction for both. |
| 22 | DR. WEERAKKODY: What you say is |
| 23 | correct, yes. |
| 24 | MEMBER LEITCH: Okay. |
| 25 | MEMBER WALLIS: The probability of |
| | |

| 1 | clearing the screens by playing with the pumps is |
|----|---|
| 2 | probably pretty small. |
| 3 | CHAIRMAN BONACA: We are back in |
| 4 | session, and we have now a presentation on the PTS |
| 5 | and evaluation project, technical basis for |
| 6 | potential revision to PTS clinical materials, and |
| 7 | Dr. Kress will take us through that presentation. |
| 8 | MEMBER KRESS: No, Dr. Shack will. |
| 9 | CHAIRMAN BONACA: Dr. Shack. Okay. I |
| 10 | guess your initials have been changed. |
| 11 | MEMBER SHACK: They have been changed, |
| 12 | right. We had a presentation to the subcommittee on |
| 13 | |
| 14 | MEMBER WALLIS: Are these your |
| 15 | regulatory initials, or your real initials? |
| 16 | MEMBER SHACK: Add 60 degrees to |
| 17 | CHAIRMAN BONACA: Well, that is the |
| 18 | reason for the change. Okay. |
| 19 | MEMBER SHACK: We had a subcommittee |
| 20 | meeting where we went over this in some detail, and |
| 21 | the staff will now have the difficult task of |
| 22 | distilling a days worth of discussion down to their |
| 23 | allotted time, whatever that is. Nathan, are you |
| 24 | going to lead off, or Mark? |
| 25 | MR. CUNNINGHAM: Good afternoon. Mark |

| 1 | Cunningham from the Office of Research, and Ed |
|----|---|
| 2 | Hackett and Nathan Sunil from the Office as well |
| 3 | here, as well as Alan Kolaczkowski, and David |
| 4 | Bessette will be making the presentation in some |
| 5 | sort of fashion this afternoon. |
| 6 | First off, Mark Kirk was here yesterday |
| 7 | making a lot of the presentations, and something |
| 8 | came up today and he couldn't be here, and so Ed is |
| 9 | just think of Ed as Mark today. |
| 10 | MEMBER KRESS: Is that his regulatory |
| 11 | name, or is that |
| 12 | MEMBER SHACK: And will he mess up the |
| 13 | power point? |
| 14 | MR. HACKETT: We have already done that. |
| 15 | We have already taken care of that one. |
| 16 | MR. CUNNINGHAM: Just by way of a short |
| 17 | introduction |
| 18 | MEMBER WALLIS: This sounds a little bit |
| 19 | since he couldn't be here like the Politburo, where |
| 20 | one of our members isn't here today, and you wonder |
| 21 | what has happened. |
| 22 | MR. CUNNINGHAM: After the savage |
| 23 | beating that Mike Mayfield administered |
| 24 | MEMBER ROSEN: They beamed him up. |
| 25 | MR. CUNNINGHAM: Something like that. |
| | NEAL D. CDOCC |

Not guite though. By way of introduction the 1 committee has been involved with listening to us and 2 talking with us over several years now on the PTS 3 work that we have had underway. 4 We are kind of in an transition period 5 right now, where we are moving from a state of 6 having a technical basis for possible rule changes, 7 8 and making a transition into considerations by our colleagues at NRR about real rule changes. 9 What you will hear today is kind of a 10 11 summary of where we are with respect to the technical basis. You have been provided a document 12 or two and those are summaries of where we are so 13 far. So you are getting in a sense a summary of a 14 15 summary today. Again, the big point is that we are in a 16 transition, and NRR will be coming back, I'm sure, 17 and have lots of opportunities to talk to you or 18 with you as well about the proposed rule as they get 19 20 into that. We will be back with them to help them 21 discuss technical issues associated with it, and so 22 23 MEMBER APOSTOLAKIS: Is there a request 24 25 for a letter today?

MR. HACKETT: There is a request. 1 2 Thanks, Mark. MR. CUNNINGHAM: Go ahead. Mark will 3 continue from here. 4 5 MR. HACKETT: A couple of other items There are also with us Roy Woods, and Roy, if 6 here. 7 you want to raise your hand; and Donnie Whitehead is 8 over on the wall there, too. Matt Mitchell, 9 representing NRR, in the back, and so if there are 10 any hard questions on the regulatory aspects, we 11 will go to Matt. 12 And Terry Dickson is here also from the Oak Ridge National Laboratory. And James Chang 13 from Maryland is here, too. Sorry about that. 14 15 emphasized the fact that this is not our final product, and I think that is where we didn't quite 16 17 lead off the day real well yesterday. So this will not be the committee's 18 final crack at this. There is quite a road ahead of 19 20 us ultimately. 21 MEMBER APOSTOLAKIS: It this is not the 22 final product, then what kind of letter are we 23 supposed to write? Where we are, and I will 24 MR. HACKETT: 25 try and set the stage for that, as Mark indicated,

what we have right now is a draft technical basis that the team here feels supports a revision to the PTS rule. But it is exactly that.

It is a draft and there is some more work to be done. We took some very good comments yesterday on the report itself and the structure, and the content, and some things that we need to address there.

So really what we are looking for from the committee at this point is a thumbs up that the committee feels that they are on the same page, and that this is something that at least merits going ahead and considering rule making at some point.

And that is not to say that that is even going to get engaged this year or even next. I mean, that is a decision for NRR, and we are here just to discuss the technical basis. That said, I guess I will go to the next slide if I can do that without Mark.

I think I basically already said most of what is on here. We did spend a full day yesterday, where we went through a lot of this in detail, and we can go through as much or as little of that as the committee needs hopefully, but we do have obviously reduced time.

24

25

We have only about a 16 or 17 slide presentation today, compared to probably about 50 or 60 yesterday. And we plan on going through all the things that you see here.

MEMBER WALLIS: You said 50 or 60? There was 150.

That was Mark's MR. HACKETT: presentation, that's right. And unfortunately Mark could not be with us today as Mark Cunningham pointed out, and that is certainly a deficiency for us in several respects.

And also most notably with respect to power point, and I don't think that any of us here at the table is equivalent in that regard. regard to the rule, and maybe this is one that I could stand up for if you quys can still hear me, the basis was documented for the rule a long time ago now, in 1982 SECY-82-465.

What you are really looking at is a methodology construct to protect the reactor vessel in the event of an over cooling event, and it really boils down to as simple as two things; having a materials metric, which is here on the X-axis, and which was the subject of much debate yesterday in the way of RTNDTs, versus a screening criterion, or

rather an acceptability when run through a wall 1 2 cracking. When that was all put together, 3 basically you ended up with a criterion, 4 acceptability criterion for through wall cracking 5 frequency 5 times 10 to the 6th, minus 6. 6 And then a metric and RTNDT space at 7 either 270 or 300, depending on the exact material 8 consideration that you were looking at. And that 9 just sets the construct for 10 CFR 50.61, which is 10 11 the upper bullet that you see there. If necessary, people could employe flux 12 reduction measures to keep the flux down, and keep 13 the embrittlement down for the plant in particular 14 for the future. 15 And then if necessary perform plant 16 specific analyses for Reg Guide 1.154 to justify 17 continued operation if that particular trip wire was 18 lauNched, and that happened --19 MEMBER WALLIS: Wait a minute now. Is 20 this your old basis? 21 This is the old basis. 22 MR. HACKETT: All I was doing here was just revisiting what is 23 24 currently today. MEMBER WALLIS: So this is the current 25

| 1 | basis? |
|----|--|
| 2 | MEMBER APOSTOLAKIS: Yes. So it is 210 |
| 3 | from there, plus 60. |
| 4 | MR. HACKETT: That was the fix that we |
| 5 | put on, and the other part that we covered |
| 6 | yesterday, and I know that Professor Apostolakis |
| 7 | wasn't here. We did receive some feedback from Dr. |
| 8 | Shack and Dr. Wallis about the incorrectness of |
| 9 | this, and the way that it is shown in your draft |
| 10 | report is not correct. |
| 11 | It was really keyed to 210, and the |
| 12 | margins were I don't know if we want to get into |
| 13 | all of that. |
| 14 | MEMBER APOSTOLAKIS: Now, wait a minute. |
| 15 | Wait a minute. The current screening criteria is |
| 16 | 270? |
| 17 | MR. HACKETT: That's correct. |
| 18 | MEMBER APOSTOLAKIS: This is consistent |
| 19 | with that? |
| 20 | MR. HACKETT: Yes, it is. |
| 21 | MEMBER APOSTOLAKIS: So it is wrong. |
| 22 | MR. HACKETT: I am trying to think of |
| 23 | the |
| 24 | right |
| 25 | MEMBER APOSTOLAKIS: It is not the |
| | NEAL P. GPOSS |

figure that is wrong. It is the criterion that is 1 wrong, because if you move to the right, you are 2 increasing the frequency. 3 MEMBER SHACK: The number that they 4 report, the 270, is this number to which they have 5 sort of been told to add 60 degrees. So they 6 7 correspond. The 210 is sort of the real 8 embrittlement, and the 270 is the regulatory embrittlement. 9 MEMBER APOSTOLAKIS: But I don't 10 understand that. Why do you add 60 degrees? 11 MEMBER SHACK: Because the reg guide 12 13 tells you to do that. MEMBER KRESS: Because that is more 14 15 conservative when it comes down to trying to decide 16 MEMBER APOSTOLAKIS: Well, that is what 17 I am saying, these are more conservative. 18 MEMBER APOSTOLAKIS: Well, you move to 19 the right and so you go up and the frequency is now 20 less and the failure is higher, right? 21 The average value of an 22 MEMBER SHACK: RTNDT is still 210. Whether the number that they 23 report, because of the way that they are told to 24 25 compute it, corresponds to an average of 210.

| 2 | |
|----------------------|--|
| 3 | degrees, the 270, but they are equivalent in terms |
| | of this plot. |
| 4 | MEMBER APOSTOLAKIS: This screening |
| 5 | criterion is 270? |
| 6 | MEMBER SHACK: Yes. |
| 7 | MEMBER APOSTOLAKIS: So 60 degrees have |
| 8 | been added to this number here from the curve to |
| 9 | produce a screening |
| 10 | MEMBER SHACK: No, to get this number |
| 11 | from the reported number, you subject 60 degrees. |
| 12 | MR. HACKETT: Right. |
| 13 | MEMBER SHACK: The reported number |
| 14 | computed according to Reg Guide 199, Rev. 2. |
| 15 | MEMBER APOSTOLAKIS: Okay. So the |
| 16 | utility calculates |
| 17 | MEMBER SHACK: 270, and that really |
| - 11 | corresponds to 210 on this plot. |
| 18 | corresponds to 210 on this plot. |
| 18 | MEMBER WALLIS: Why does it really |
| | <u>-</u> |
| 19 | MEMBER WALLIS: Why does it really |
| 19 | MEMBER WALLIS: Why does it really correspond? |
| 19 20 21 | MEMBER WALLIS: Why does it really correspond? MEMBER APOSTOLAKIS: I don't understand |
| 19 20 21 22 | MEMBER WALLIS: Why does it really correspond? MEMBER APOSTOLAKIS: I don't understand that. How does it do that? |

| 1 | MEMBER APOSTOLAKIS: When you develop |
|----|--|
| 2 | screening criteria don't you try to be conservative? |
| 3 | MR. HACKETT: Absolutely. |
| 4 | MEMBER APOSTOLAKIS: Right. And so here |
| 5 | the conservative thing to do would be to say 210 |
| 6 | from the curve, minus 60. |
| 7 | MEMBER SHACK: No, the 210 is |
| 8 | conservative here because of all of the |
| 9 | conservatisms in the analysis. In 1982, and I am |
| 10 | not sure that I can reconstruct the argument, but I |
| 11 | would guess that they said, Jesus, we did all sorts |
| 12 | of conservative things to get to this 210, and we |
| 13 | are not going to then add 60 more degrees of margin |
| 14 | to cover it. |
| 15 | Everything else that we did to get to |
| 16 | the 210 number was already conservative. |
| 17 | MEMBER WALLIS: So what is the 210 now? |
| 18 | I mean |
| 19 | MEMBER SHACK: Because for other |
| 20 | reasons, you report a number from Reg Guide 1.99, |
| 21 | Rev. 2, that is told to compute it. So you don't |
| 22 | want to have two numbers around it. |
| 23 | MEMBER WALLIS: Well, why not |
| 24 | MEMBER APOSTOLAKIS: What does a utility |
| 25 | do? |
| | 1 |

| 1 | MR. HACKETT: They do just what Bill |
|----|--|
| 2 | said. They do the regulatory thing, which is |
| 3 | MEMBER APOSTOLAKIS: They follow the |
| 4 | regulatory guide ? |
| 5 | MR. HACKETT: They follow 1.99, and they |
| 6 | compare it to the 270. |
| 7 | MEMBER APOSTOLAKIS: So the number is |
| 8 | 280 that they calculate? |
| 9 | MEMBER SHACK: Let's not. |
| 10 | MEMBER APOSTOLAKIS: Let's say it is, |
| 11 | and then what happens? |
| 12 | MR. HACKETT: Well, then actually you |
| 13 | would have gone to that second bullet well before |
| 14 | then, and if necessary, you would have gone down |
| 15 | here. |
| 16 | MEMBER APOSTOLAKIS: But wouldn't it be |
| 17 | more logical to say that you calculate your number |
| 18 | to 80, and then subtract 60? Wouldn't that be the |
| 19 | logical thing to do? |
| 20 | MR. HACKETT: You could say it that way, |
| 21 | too. |
| 22 | MEMBER WALLIS: So why didn't you do |
| 23 | that? |
| 24 | MEMBER APOSTOLAKIS: So under 60 |
| 25 | degrees, the subjective estimate is well, I am |
| | NEAL P. ODOGO |

| 1 | trying to give you a way out. |
|----|--|
| 2 | MEMBER WALLIS: There is no way out. |
| 3 | MEMBER APOSTOLAKIS: There is no easy |
| 4 | way out, but our judgment is that this low curve is |
| 5 | too conservative, and so the screening criterion is |
| 6 | moving up. |
| 7 | MEMBER KRESS: You guys are arguing |
| 8 | about (inaudible) and the Rule is in the new one. |
| 9 | MR. HACKETT: That is what we are |
| 10 | hoping. |
| 11 | MEMBER APOSTOLAKIS: It is important to |
| 12 | understand where the |
| 13 | MEMBER SHACK: The important thing to |
| 14 | understand is that the current is not |
| 15 | unconservative. |
| 16 | MR. HACKETT: It is actually very |
| 17 | conservative, at least that is what we think. |
| 18 | Anyway, maybe we will see if we |
| 19 | MEMBER WALLIS: You are sort of lucky |
| 20 | that by you understanding it in terms of that it is |
| 21 | very conservative. If you try to argue with George |
| 22 | on the basis of this figure, you will probably be in |
| 23 | deep water for a long time. |
| 24 | MEMBER APOSTOLAKIS: Well, tell me why |
| 25 | not? I mean, we need to learn. |
| | |

1 MEMBER SHACK: Because they have always 2 used -- if you computed the number the way they 3 computed this number, they have always used 210. The number that they happen to report is computed 4 5 slightly differently, but it is equivalent to the 210 number. 6 7 I think that Matt Mitchell MR. HACKETT: 8 is here from the NRR, and Matt has got some 9 comments. 10 MR. MITCHELL: Yes, I am Matt Mitchell, 11 from NRR, and we are the folks that are responsible 12 for this on the NRR side of the house. I will try 13 to sort of repeat Bill's explanation as to how this 14 figure fits together with what is in 50.61. There could be a limit in 50.61 that 15 16 says or would set a screening criteria of 210 17 degrees based Upon this nominal mean RTNDT value. What has been done, and what was done in 18 19 SECY.82.465. 20 To the best of my understanding is that there were 60 degrees added to the 210 value, and in 21 22 recognition of uncertainties which were involved in 23 the probablistic calculations which were used to 24 develop the screening criteria.

And that same 60 degrees in effect was

25

| 1 | added to the other side of the equation when a |
|----|--|
| 2 | licensee calculates the RTPTS value. If you were |
| 3 | comparing to 210 and you looked at Reg. Guide 1.99 |
| 4 | methodology, you would take the initial RTNDT value |
| 5 | and you would add the shift. |
| 6 | And you would stop at that point. To |
| 7 | compare to 270, you would take the methodology which |
| 8 | is the initial property, the shift, plus the margin |
| 9 | turn from Reg Guide 1.99 Rev. 2. |
| 10 | So what in effect has been done is that |
| 11 | 60 degrees has been added to each side of the |
| 12 | equation. I agree completely that it is confusing |
| 13 | and is not clear. But if you look at it as sort of |
| 14 | a balancing of the scales, you have essentially put |
| 15 | 60 degrees on both sides. |
| 16 | MEMBER APOSTOLAKIS: So you need at |
| 17 | least 210. |
| 18 | MEMBER WALLIS: No. |
| 19 | MEMBER KRESS: If you use this mean |
| 20 | MR. MITCHELL: The number is 270 in |
| 21 | regulation. |
| 22 | MEMBER APOSTOLAKIS: Sure, but that has |
| 23 | already been |
| 24 | MR. SIU: And it is related to a mean of |
| 25 | 210. |

| 1 | MEMBER SHACK: The criterion it |
|----|--|
| 2 | consistent with this graph. |
| 3 | MEMBER APOSTOLAKIS: But is it also |
| 4 | consistent with 1.1? |
| 5 | MEMBER SHACK: No, 1.1 is wrong. |
| 6 | MR. MITCHELL: 1.1 is wrong. |
| 7 | MEMBER APOSTOLAKIS: And then why is 1.1 |
| 8 | wrong? |
| 9 | MEMBER SHACK: Because they pretend that |
| 10 | the 60 degrees is margin. If we could get margin |
| 11 | that way, we would just add 120 degrees, and we |
| 12 | could walk out of here real fast. It would be more |
| 13 | conservative and everybody could meet it. It is |
| 14 | just wrong, and just forget it. |
| 15 | MEMBER WALLIS: The 60 degrees cannot be |
| 16 | justified, but the 56 degrees, which is the margin |
| 17 | in 1.99, is put on because of uncertainties. So you |
| 18 | calculate your RTNDT and then you add 56 degrees for |
| 19 | uncertainties. |
| 20 | MEMBER APOSTOLAKIS: In your |
| 21 | calculation, or in your |
| 22 | MEMBER WALLIS: In the calculation, and |
| 23 | then it is all taken away again by the 60 degrees. |
| 24 | MEMBER APOSTOLAKIS: Right. |
| 25 | MR. MITCHELL: In the calculation of |

RTPTS, the actual material property value for a 1 licensee's vessel, Dr. Wallis is correct that 2 nominally it is about 56. There are some nuances in 3 the reg guide which allow margin terms to be -- the 4 so-called margin term to be modified, but nominally 5 correct. 6 And it was believed that was 7 sufficiently close to the 60 that was added to the 8 other side of the equation, the 210 plus 60 to 9 arrive at 270, and that it was essentially 10 11 equivalent. MEMBER APOSTOLAKIS: Do you at least 12 agree that this is an odd way of doing business? 13 MR. MITCHELL: Absolutely. Without 14 doubt, and we would certainly hope that as a result 15 of any changes to the regulations which might result 16 from the work that the Office of Research has done 17 that we can clarify it and make it much more 18 simpler, and much more straightforward. 19 CHAIRMAN BONACA: I hope that the 20 licensee will who submit this data for license 21 renewal will understand the nuances of all this, and 22 do the proper numbers compared to the right numbers. 23 MR. HACKETT: I think they are painfully 24 aware of that and have been for a long time, as I 25

completely concur with Matt, and it is confusing, and it is a construct that we are hoping to be able to improve upon.

However, as we go through, we see that we have some more complexity to add before we get there. At any rate the first one out of the box that got tested for this -- and of course the committee probably remembers this, or maybe certain members maybe do with Yankee Rowe, which tripped the screening criteria and got into the Reg Guide 1.154 analysis --

MEMBER APOSTOLAKIS: I can't wait to make a copy of this and give it to Andy Kadac at MIT.

MR. HACKETT: The plant attempted to make this case with the NRC and one of their problems in doing that is that they felt that the guidance was not clear is probably an understatement in 1.154 and it led to a fairly protracted debate with the NRC staff which ultimately ended up in the shut down of Yankee Rowe.

They decided that they were not going to be able to prosecute that case effectively because of the lack of clarify of the guidance. The upshot for this presentation is that because of that, as

part of the NRC's lessons learned activities, the 1 Commission directed the staff to address this in 2 1991. 3 Here we are over 12 years later trying 4 to still do that effectively, but sometimes these 5 things take that long. In terms of other 6 7 motivations, that is one primary motivation. motivations are listed here in terms of technical 8 improvements that have been made over many years. 9 This is a slide that I know that we 10 11 shared with the committee, and we spent a lot of time on this yesterday. We have been asked about 12 13 the magnitude of these arrows. The green arrows are indicating where 14 15 you might expect improvement, and the red arrows are cases where we might have actually seen things 16 that have acted in a non-conservative manner. 17 With the ultimate or the bottom line 18 here being that we are looking at something that is 19 pointing towards burden reduction and an extension 20 of the screening criteria. 21 But in terms of that magnitude, a couple 22 of things on here I think -- and the team can 23 24 correct me if I am wrong here, but I think we are 25 seeing a fairly large down arrow on more refined

binning in the use of the probabilistic risk assessment methodology.

And in particular in probabilistic

fracture mechanics, we have a significant

conservative bias that has been eliminated in the

model, and which I will talk a bit more about later,

because it unfortunately gets back to RTNDT and a

new version of RTNDT.

MEMBER WALLIS: Yes, but it is a bias of -- well, it is something like a hundred degrees, compared with all the arguments that we have had previously about maybe 60 degrees. So it overwhelms that 60 degrees right there.

MR. HACKETT: It does. It does. There is also spatial variations in the fluence, and maybe somewhere between these two the flaw distribution is a major element for the material aspects of this task, in that when it was done previously in 82.465, it was a Marshall distribution that was used, which came from the U.K., and wa the best that folks could do at that time, but it didn't actually involve looking at flaws from reactor vessels for the most part.

We have been able to do a lot of work in that area since most of it has been sponsored by the

| 1 | NRC, and it has really shown as a bottom line that |
|----|--|
| 2 | we see flaws in vessel welds, but they are very |
| 3 | small and largely do not participate as being |
| 4 | problematic in a PTS transient. |
| 5 | MR. KOLACZKOWSKI: And if I highlight |
| 6 | the bottom red arrow, because that changes the whole |
| 7 | reason why meeting a large break LOCA is considered, |
| 8 | because that changes the whole reason why certain |
| 9 | sequences are important, the fact that we have added |
| 10 | that. |
| 11 | Whereas, the original analysis back in |
| 12 | the '80s did not include medium and large LOCAs, and |
| 13 | we talked to the subcommittee at length about that. |
| 14 | MEMBER APOSTOLAKIS: They ignored them |
| 15 | or they lumped them? |
| 16 | MR. KOLACZKOWSKI: Basically, they |
| 17 | ignored them. |
| 18 | MEMBER ROSEN: I thought what you told |
| 19 | us was that you thought this was an undercooling |
| 20 | transient driven process, and undercooling because |
| 21 | of what happened in the secondary side, and is not a |
| 22 | primary side issue. |
| 23 | MEMBER WALLIS: They thought that the |
| 24 | pressure vessel needs to be the pressure from a PTS |
| 25 | event, rather than just pure thermal shock, and then |

they realized that the pure thermal shock could be 1 2 significant and so LOCAs had to be considered. 3 Once the vessel is depressurized it is no longer under stress from the pressure, but you 4 5 can still have thermal shock. MEMBER ROSEN: All right. 6 So at the end 7 of the day what you find out is that this 8 pressurized thermal shock problem is really a little 9 pea-big pea shock problem. Little pressure, large 10 thermal stresses, and that is what you worry about. 11 MR. HACKETT: That is what we are seeing now, and indeed Terry Dickson went back and ran an 12 older version of the code that was applicable at 13 around the time of Yankee Row, and it was exactly 14 15 These just were not addressed previously, and when you do address them, even with the older 16 version of the code, it looks like that has always 17 been the case. That it is much more of a thermal 18 19 driven --MEMBER ROSEN: With that understanding, 20 George says that is why large LOCAs are important, 21 22 because those are depressurized events. 23 MEMBER APOSTOLAKIS: Yes MEMBER ROSEN: And before we didn't 24 25 think that was important to this problem.

| 1 | MEMBER APOSTOLAKIS: Okay. |
|----|--|
| 2 | MEMBER ROSEN: Because they were not |
| 3 | pressurized, and as it turns out it is the thermal |
| 4 | shock that is important. |
| 5 | MEMBER APOSTOLAKIS: Are you going to |
| 6 | discuss the acts of commission that are considered? |
| 7 | I mean, did you quantify those things? |
| 8 | MEMBER ROSEN: We are prepared to |
| 9 | discuss that, and we could do that now, or we could |
| 10 | wait until the appropriate point. But Alan is |
| 11 | available to do that. |
| 12 | MR. KOLACZKOWSKI: Yes, George, in this |
| 13 | shortened version, we don't have any specific slides |
| 14 | on that. But I guess at the appropriate point that |
| 15 | we could certainly address whatever |
| 16 | MEMBER APOSTOLAKIS: What method should |
| 17 | you use to quantify those? |
| 18 | MR. KOLACZKOWSKI: Well, as was |
| 19 | explained in previous presentations, the use of the |
| 20 | ATHEANA at least qualitatively was sort of the basis |
| 21 | behind all of the human errors that we analyzed, |
| 22 | whether they were errors of omission or errors of |
| 23 | co-mission. |
| 24 | And in terms of coming up with the |
| 25 | probabilities, again as we have explained before, |

that was an expert elicitation process, and a very systematic process, where we tried to figure out 2 what are the issues that could effect this particular error. And through the expert elicitation process, using people both at the utilities either in a review role, or actually in a participation role and in a collaborative arrangement as we did with Palisades, we had trainers, EOP writers, actual crew members, along with the NRC contractors, essentially putting the HRA numbers --MEMBER ROSEN: With due consideration of the works of Apostolakis, et al? MR. KOLACZKOWSKI: Yes, absolutely. MEMBER APOSTOLAKIS: I mean, it is a side remark, but this morning also we had a presentation on the accumulation of debris in the sump, and they also considered human errors, and they took upper bounds and the probabilities, and in fact pretty high numbers. And which now raises the question is there really a need for the agency to develop a model for human reliability performance, or human reliability? I mean, people seem to be happy that

they are using what is available.

1

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25