



**Constellation
Energy Group**

Nine Mile Point
Nuclear Station

February 10, 2003
NMP2L 2084

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Nine Mile Point Unit 2
Docket No. 50-410; NPF-69

Monthly Operating Report for January 2003

Gentlemen:

Submitted herewith is the Operating Data Report, the Unit Shutdowns, and Summary of Operating Experience for January 2003.

Very truly yours,

Lawrence A. Hopkins
Plant General Manager

LAH/jm
Attachments

cc: Mr. H. J. Miller, NRC Regional Administrator, Region I
Mr. G. K. Hunegs, NRC Senior Resident Inspector

IE24

NINE MILE POINT NUCLEAR STATION UNIT #2

SUMMARY OF OPERATING EXPERIENCE

Nine Mile Point Unit Two operated with a capacity factor (MDC) of 103.7 % and an availability factor of 100% for the month of January, 2003.

There were no challenges to the safety relief valves during this reporting period.

OPERATING DATA REPORT

DOCKET NO 50-410
DATE 02/04/2003
COMPLETED BY: T. P. McMahon
TELEPHONE (315) 349-4045

OPERATING STATUS

Unit Name: Nine Mile Point Unit #2
Reporting Period: January 2003
1. Design Electrical Rating (MWe) 1,143.3
2. Maximum Dependable Capacity (Net MWe) 1,119.8

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours Reactor was Critical:	744.0	744.0	103,527.0
4 Hours Generator On-Line.	744.0	744.0	100,600.4
5. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
6. Net Electrical Energy Gen (MWH)	863,973.9	863,973.9	105,339,810.4

UNIT SHUTDOWNS

DOCKET NO: 50-410

UNIT NAME: NMP#2

DATE: 2/03/03

Prepared by: T. McMahon

TELEPHONE: (315) 349-4045

APPENDIX B REPORTING PERIOD – JANUARY 2003

No	Date	Type F Forced S Scheduled	Duration (Hours)	Reasons ¹	Method of Shutting Down ²	Cause & Corrective Actions Comments
-- NONE --						

¹

Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training & License Exam
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

²

Method.

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)