

February 25, 2003

LICENSEE: Tennessee Valley Authority

FACILITY: Sequoyah Nuclear Plant, Unit 1

SUBJECT: SUMMARY OF FEBRUARY 12, 2003, MEETING WITH TENNESSEE VALLEY AUTHORITY (TVA) TO DISCUSS THE SEQUOYAH, UNIT 1, STEAM GENERATOR COMPARTMENT ROOF MODIFICATIONS (TAC NO. MB5387)

On February 12, 2003, the U.S. Nuclear Regulatory Commission (NRC) staff met with representatives of TVA and Bechtel at the NRC Headquarters in Rockville, Maryland. TVA requested this meeting to discuss an alternative to the through-bolted splice-plated methodology proposed in Bechtel's Topical Report No. 24370-TR-C-003. The licensee discussed the selected alternative for the repair of the steam generator (SG) compartment roof modifications during the replacement of the SG for Sequoyah Nuclear Plant, Unit 1. The alternative proposed uses steel reinforced beams to re-establish the SG compartment roofs. TVA provided to the staff a draft copy of the revised Bechtel's Topical Report dated February 7, 2003, for Sequoyah, Unit 1, SG Replacement Compartment Roof Modification. The revised report addresses responses to the NRC staff requests for additional information.

The licensee discussed the selected alternative for the repair. The participants discussed the boundary condition analysis, the tensioning of the bolts, and the shim placement. TVA and Bechtel representatives answered the staff's questions. Bechtel will be revising the topical report to address the identified issues. The staff had no additional questions. TVA indicated that the final version of the topical report would be submitted to the NRC by February 14, 2003.

This meeting was classified as a Category 1 meeting, which provided an opportunity for members of the public to communicate with the NRC staff after the business portion, but before the meeting was adjourned. However, there were no members of the public in attendance. Attachment 1 is a list of attendees, Attachment 2 is a copy of TVA's handout distributed during the meeting, and Attachment 3 is a copy of the draft Bechtel's topical report.

The staff noted that the above meeting was beneficial in gaining an understanding of TVA's plans and activities regarding the pending SG replacement for Sequoyah, Unit 1.

Sincerely,

*/RA/*

Raj K. Anand, Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-327

Attachments: As stated

cc w/Attachments: See next page

February 25, 2003

LICENSEE: Tennessee Valley Authority

FACILITY: Sequoyah Nuclear Plant, Unit 1

SUBJECT: SUMMARY OF FEBRUARY 12, 2003, MEETING WITH TENNESSEE VALLEY AUTHORITY (TVA) TO DISCUSS THE SEQUOYAH, UNIT 1, STEAM GENERATOR COMPARTMENT ROOF MODIFICATIONS (TAC NO. MB5387)

On February 12, 2003, the U.S. Nuclear Regulatory Commission (NRC) staff met with representatives of TVA and Bechtel at the NRC Headquarters in Rockville, Maryland. TVA requested this meeting to discuss an alternative to the through-bolted splice-plated methodology proposed in Bechtel's Topical Report No. 24370-TR-C-003. The licensee discussed the selected alternative for the repair of the steam generator (SG) compartment roof modifications during the replacement of the SG for Sequoyah Nuclear Plant, Unit 1. The alternative proposed uses steel reinforced beams to re-establish the SG compartment roofs. TVA provided to the staff a draft copy of the revised Bechtel's Topical Report dated February 7, 2003, for Sequoyah, Unit 1, SG Replacement Compartment Roof Modification. The revised report addresses responses to the NRC staff requests for additional information.

The licensee discussed the selected alternative for the repair. The participants discussed the boundary condition analysis, the tensioning of the bolts, and the shim placement. TVA and Bechtel representatives answered the staff's questions. Bechtel will be revising the topical report to address the identified issues. The staff had no additional questions. TVA indicated that the final version of the topical report would be submitted to the NRC by February 14, 2003.

This meeting was classified as a Category 1 meeting, which provided an opportunity for members of the public to communicate with the NRC staff after the business portion, but before the meeting was adjourned. However, there were no members of the public in attendance. Attachment 1 is a list of attendees, Attachment 2 is a copy of TVA's handout distributed during the meeting, and Attachment 3 is a copy of the draft Bechtel's topical report.

The staff noted that the above meeting was beneficial in gaining an understanding of TVA's plans and activities regarding the pending SG replacement for Sequoyah, Unit 1.

Sincerely,

/RA/

Raj K. Anand, Project Manager, Section 2  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-327

Attachments: As stated

cc w/Attachments: See next page

Distribution: See next page

ADAMS Accession No. ML030560724

OFFICE	PDII-2\PM	PDII-2\LA	PDII-2\SC
NAME	RAnand	BClayton	AHowe
DATE	2/19/03	2/19/03	2/23/03

OFFICIAL RECORD COPY

Distribution:

PUBLIC

PDII-2 R/F

JZwolinski/LMarsh

HBerkow

AHowe

RAnand

EBrown

BClayton (hard copy)

OGC

ACRS

MKotzalas (e-mail)

JMa

GHarrity

BSmith (e-mail)

SCahill, RII

**ATTENDANCE LIST**

**NUCLEAR REGULATORY COMMISSION (NRC) MEETING**

**WITH TENNESSEE VALLEY AUTHORITY (TVA) AND BECHTEL**

**AT NRC HEADQUARTERS**

**FEBRUARY 12, 2003**

**NRC**

Allen Howe  
Raj Anand  
Eva Brown  
John Ma  
Michael Dudek

**TVA**

Pedro Salas  
David Ryder  
Paul Trudel

**Bechtel**

J. V. Smith  
Eugene Thomas  
Myron Anderson

Tennessee Valley Authority

**SEQUOYAH NUCLEAR PLANT**

cc:

Mr. J. A. Scalice  
Chief Nuclear Officer and  
Executive Vice President  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

Mr. Karl W. Singer, Senior Vice President  
Nuclear Operations  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. James E. Maddox, Acting Vice President  
Engineering & Technical Services  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Richard T. Purcell  
Site Vice President  
Sequoyah Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Soddy Daisy, TN 37379

General Counsel  
Tennessee Valley Authority  
ET 11A  
400 West Summit Hill Drive  
Knoxville, TN 37902

Mr. Robert J. Adney, General Manager  
Nuclear Assurance  
Tennessee Valley Authority  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager  
Nuclear Licensing  
Tennessee Valley Authority  
4X Blue Ridge  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. Pedro Salas, Manager  
Licensing and Industry Affairs  
Sequoyah Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Soddy Daisy, TN 37379

Mr. D. L. Koehl, Plant Manager  
Sequoyah Nuclear Plant  
Tennessee Valley Authority  
P.O. Box 2000  
Soddy Daisy, TN 37379

Senior Resident Inspector  
Sequoyah Nuclear Plant  
U.S. Nuclear Regulatory Commission  
2600 Igou Ferry Road  
Soddy Daisy, TN 37379

Mr. Lawrence E. Nanney, Director  
Division of Radiological Health  
Dept. of Environment & Conservation  
Third Floor, L and C Annex  
401 Church Street  
Nashville, TN 37243-1532

County Executive  
Hamilton County Courthouse  
Chattanooga, TN 37402-2801

Ms. Ann P. Harris  
341 Swing Loop Road  
Rockwood, Tennessee 37854