Draft Submittal (Pink Paper)

1. Operating Test Simulator Scenarios

VOGTLE EXAM 2002-301 50-424 AND 50-425

NOVEMBER 26, & DECEMBER 2 - 13, 2002

PRAFT

Appendix D

Scenario Outline

Facility: _	Vogtle		Scenario No.: _		Op-Test No.:
Examine	rs:			_Operators:	· · · · · · · · · · · · · · · · · · ·
Initial Col been isol	nditions: <u>P</u> ated due te	lant operat o external l	ing at 90% powe eakage. Heavy	er. 'B' train e thunderstorn	quipment in service. PORV has as in the area.
Turnover <u>been retu</u> <u>met on th</u> <u>has been</u> <u>service.</u>	: <u>Spray va</u> urned to se ie previous i increased	lve has mir ervice. 20 g s shift. You I, swap to "	nor seat leakage apd leak on 'A' S a have been dire A" Train Compo	. 'A' train cor /G All prereq cted to increa nent Cooling	nponent cooling pump has just uisites for power increase were use power to 95%. Once power and remove "B" train pump from
Event No.	Malf. No.	Event Type*		De	Event scription
1		R-RO	Raise Power to	o 95%	
2		C-RO	Just Before rea Failure. Rods	aching 95% p to manual to	ower. RD09 Control Rod Urgent correct.
3		N-RO	swap to "A" Tr pump from ser	ain Compone vice.	nt Cooling and remove "B" train
4		C-BOP	EL09 Loss of 4 overcurrent tri	480V SWGR. o.	Ground fault causes
5		I-BOP	pressurizer lev	el control fail	ure- system ends up in manual -
6		I-RO	FW16 heater 4 increases due are in Manual manually to co	4 level Transr to decreased from Event # rrect for feed	nitter Failure - (reactor power I feed water temperature) Rods 2 Operator must raise power water malfunction.
7		M-ALL	Main Feedwate Of Control Roc planned; howe Dilution event Setback Pushl Third Condens reactor fail. R alternate Boro	er Pump-B Tr ds, Borate as over water, no now in progr button to atte sate Pump fa eactor must b n Source.	ip. Enter AOP -Rapid Insertion Necessary (appears to go as t Boron is injected from system) ess. Operators depress Start mpt to lower Load To 850 Mwe, Is to start. All Attempts to trip be shutdown manually, with
				·····	

			 · · · · · · · · · · · · · · · · · · ·		
	· ···				
1					
 	·				
 	·····			······································	
		·	 		

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Scenario Outline

DRHFT Form ES-D-1

raciiny: <u>v</u>	ogtle		Scenario No.: _	2	Op-Test No.:
Examiners:	:			_Operators:	
Initial Conc been isolat alarmed.	ditions: <u>Pl</u> ted due to Heavy thu	ant operati o external l understorm	ing at 90% powe eakage. 'C' acc s in the area.	r. 'B' train e umulator pre	quipment in service. PORV has ssure HI/LO annunciator has just
Turnover: <u>service for</u>	<u>Spray val</u> maintena	ve <u>has mir</u> ance (clear	or seat leakage. ing tags). 20 gp	<u>'A' train co</u> d leak on 'A'	mponent cooling pump OOS ' S/G.
Event No.	Malf. No.	Event Type*		De	Event escription
1	-	N-RO	Raise 'C' accu	mulator pres	sure
2		I-RO	Pressurizer pre	essure contro	ol channel fails HI.
			Spray valve sti	cks open.	
3		I-BOP	'C' steamline fl	ow transmitt	er fails low.
4		C-BOP	Loss of operat	ing compone	ent cooling water train.
5	· ···	C-RO	RCP 'A' #1 se	al failure	
6	.	R-ALL	SRO directs po	ower reduction	on
7	· • • • • •	M-ALL	RCP 'A' #1 sea	al failure res	ults in RCP seal LOCA
			'B' train equipr train ECCS eq	nent fails to uipment	auto SI. Manually actuate 'B'
			'A' charging pu	imp sheared	shaft
			Fail bank 1 ste	am dump va	lve open
					····
	<u></u>	ļ		···	<u></u>

Scenario Outline

Form ES-D-1

...

ORAFT

Facility: <u>Vogtle</u>		Scenario No.: _	3	Op-Test No.:
Examiners:			_Operators:	
Initial Conditions: T	ne plant is a	at 85% power w	ith #3 conder	nsate pump out of service and the
<u>'A' train MDAFW pu</u> The bistables have	<u>mp is OOS</u> been trippe	<u>S, and the NR te</u> ed for this failure	mperature in:	strument loop 1 has failed low.
	ower ie 95	% MOI The f	- Nowing Tech	Specs components are failed:
• <u>'A' MDAFW</u>	pump is O	OS due to mech	anical seal fa	illure. It has been OOS for 48
hours & not	expected to	<u>o RTS within the</u> has been writte	<u>e remaining L</u> n.	CO time due to parts
<u>Also affectin</u>	g AFW is a	severe packing	leak that ha	s occurred on the high pressure
'A' S/G to th	01-04-051, e TDAFW	a chemical clea pump. As a res	ult, 1HV-3009	a steam supply to the TDAFW
pump from '	A' S/G is ta	igged shut and j	bower has be	en removed from the valve. The
work.	ream isola		<u>14-04-000, 15</u>	also lagged shut to allow the
<u>As a result o</u> 3712 due	o <mark>f this work</mark> to 2 inoper	<u>, the plant is in a</u> able trains of AF	<u>a 6 hour shute</u> W	down requirement per Tech Spec
 <u>Loop 1 NR t</u> 	emp instru	ment has failed	low 5 hours a	igo, the bistables have been
 tripped, and Also, the #3 	<u>I&C is wor</u> Condensa	<u>king on the worl</u> te pump is OOS	<u>k package.</u> due to a mo	tor failure that occurred 3 days
ago. No RT	S date has	been set.		deurs to Made Quithin the post
 <u>Plant manac</u> 3.5 hours. 	gement has	s directed the pla	ant to be shut	down to Mode 3 within the next
• <u>The system</u>	operator h	as been notified	of the pendir	ng power reduction.
monthe on '	as been op A' S/G. Th	e leak rate has	been stable a	t this value since onset.
• In addition a	tornado a	ert has been iss	ued for Burk	e and Richmond counties. There
been comple	eted in the	last hour.		e severe weather checkinst has
	<u> </u>			
Event Malf.	Event			Event
NO. NO.				
	R-RO	Power reduction	on IAW Tech	Spec snutdown requirements.
2	C-RO	CCP 'A' trips.		
3	I-BOP	SJEA/SPE Ra	d monitor fail	s off scale high.
4	I-BOP	Controlling fee	ed flow chann	el fails low on 'B' S/G.

.

5	I-RO	Controlling PZR pressure transmitter fails at 100%
6	N-RO	
7	M-ALL	500 GPM SGTR on 'A' S/G
8		Primary reactor trip handswitch fails to function (ATWS)
9		Auto reactor trip fails to occur.
10		MDAFW pump fails to auto start

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Event No. Malf. No. Event Type* Event Description 1 N-RO Place NCP in service 2 RO-R Increase power to 98% 3 SG03a BOP-I SG Pressure Transmitter fails low 4a EL13 SRO-C BOP-C RO-C Loss of 120 VAC vital power 1AY1A (channel 1 instrumentation), (M41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 C005b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary. Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Root. Crew enters 1921-10-C start manual rod insertion, the Purbined, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C the TDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after pr	Event No. Maif. No. Event Type* Event Description 1 N-RO Place NCP in service 2 RO-R Increase power to 98% 3 SG03a BOP-I SG Pressure Transmitter fails low 4a EL13 SRO-C BOP-C RO-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 CO05b O/R AF03b ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating O/R AF03b 7 CO05b O/R AF03b ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating O/R AF03b				
1 N-RO Place NCP in service 2 RO-R Increase power to 98% 3 SG03a BOP-I SG Pressure Transmitter fails low 4a EL13 SRO-C BOP-C RO-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 CO05b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room. Crew enters 1921-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW pump will trip on overspeed and the Train "B' MDAFW pump will heap an broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedur	1 N-RO Place NCP in service 2 RO-R Increase power to 98% 3 SG03a BOP-I SG Pressure Transmitter fails low 4a EL13 SRO-C BOP-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level loss of extraction steam (AOP 18016- C) 7 CO05b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate are necessary. Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Rom Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 1900-C after completion of 19211-C. Upon entry into 1900-C after progressing through the procedure the TDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW pump will be reatinter and the plant	Event No.	Malf. No.	Event Type*	Event Description
2 RO-R Increase power to 98% 3 SG03a BOP-I SG Pressure Transmitter fails low 4a EL13 SRO-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level loss of extraction steam (AOP 18016-C) 7 CO05b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods. Borate as necessary. Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor due to the feedwater condition. Reactor is locally tripped and crew transition to 1900-C after completion of 19211-C. Upon entry into 1900-C after completion of 19211-C. Upon entry into 1900-C after completion of 19211-C. Upon entry into 1900-C after progressing through the procedure the TDAFW pump will trip on overspeed and the Train "B" MDAFW pump will trip on overspeed and the Train "B" MDAFW pump will a a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be paint will recover.	2 RO-R Increase power to 98% 3 SG03a BOP-I SG Pressure Transmitter fails low 4a EL13 SRO-C BOP-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 CO05b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary. Operating Crew recognize the need to manually trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, if the Turbine, initiate emergency boration. Ro attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion if the Turbine, initiate emergency boration. Ro atter ris locally tripped and crew transition to 19000-C after completion of 19211-C. Upon entry into 19000-C after progressing through the procedure the TDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW pump will be paired and the plant	1		N-RO	Place NCP in service
3 SG03a BOP-I SG Pressure Transmitter fails low 4a EL13 SRO-C BOP-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 C005b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 1900-C atter completion of 19211-C. Upon entry into 19000-C atter completion of 19211-C. Upon entry into 19000-C atter completion of 19211-C. Upon entry into 19000-C atter completion of 19211-C. Upon entry into 1900-C atter completion of 19211-C. Upon entry into 1	3 SG03a BOP-I SG Pressure Transmitter fails low 4a EL13 SRO-C BOP-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 CO05b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually tip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C after completion of 19211-C. Upon entry into 19000-C after completion of 19211-C. Upon entry in	2		RO-R	Increase power to 98%
4a EL13 SRO-C BOP-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 CO05b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor due to the feedwater conditions. RO attempts to trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C the TDAFW pump will trip on overspeed and the Train "B" MDAFW pump will trip on overspeed and the Train 'B'' MDAFW pump will they a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant will recover.	4a EL13 SRO-C BOP-C RO-C Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation) 5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 C005b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid Insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor due to the feedwater condition. Reactor is locally tripped and crew transition to 19000-C ther CDAFW pump will trip on overspeed and the Train "B" MDAFW pump will trip on overspeed and the Train "B" MDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 1923 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant	3	SG03a	BOP-I	SG Pressure Transmitter fails low
5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 CO05b Cond Pump O/R AF03b ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C after completion of 19211-C. Upon entry into 19000-C the TDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant will recover.	5 Panel Draw O/R RO-C Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level. 6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level Joss of extraction steam (AOP 18016- C) 7 CO05b Cond Pump O/R ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C after completion of 19211-C. Upon entry into 19000-C the TDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant	4a 4b 4c	EL13	SRO-C BOP-C RO-C	Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation)
6 FW16 SRO-I RO-I BOP-I Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C) 7 CO05b Cond Pump O/R AF03b ALL-M Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C the TDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant will recover.	6FW16SRO-I RO-I BOP-IFeedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C)7CO05b Cond Pump O/R AF03bALL-MCondensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C the TDAFW pump will trip on overspeed and the Train "B" MDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant	5	Panel Draw O/R	RO-C	Following the loss of power to 1AY1A CVCS letdown isolation valve 1LV-0459 will not reopen when normal letdown is being restored. The RO will be required to place CVCS excess letdown in service to allow control of Pressurizer level.
7 CO05b Cond Pump O/R AF03b AF	7CO05b Cond Pump O/RALL-MCondensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C after completion of 19211-C. Upon entry into 19000-C the TDAFW pump will trip on overspeed and the Train "B" MDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant	6	FW16	SRO-I RO-I BOP-I	Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C)
	will recover.	7	CO05b Cond Pump O/R AF03b	ALL-M	Condensate Pump "B" trips with the failure of Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C after completion of 19211-C. Upon entry into 19000-C the TDAFW pump will trip on overspeed and the Train "B" MDAFW pump will trip on overspeed and the Train "B" MDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant will recover.

2 of 30

ppendix D	Scenario Outline	Form ES-D-1
Ecollit <i>u</i>		-Test No · 1
		-reaction <u></u>
Examiners.	Operators	
Initial Cond conditions.	litions: The plant is at 95%. RCS boron concentration is at 1308 B Train equipment in service.	ppm, BOL
<u>Turnover:</u>		
1Pl	lant Startup is in progress.	
2R	x power is 95%.	
3T f	rain "A" MDAFW Pump is OOS due to mechanical seal failure. It or 48 hours and not expected to return to service within the remair due to parts unavailability, (T.S. 3.7.5 Condition "B") LCO has bee	has been OOS ning LCO time n written.
4TI	he NCP has just been returned to service following maintenace PM	∕ľs.
5TI b p	he Aux Bldg SO has been dispatched to the NCP and the pre-star een performed. When you assume the shift the SS has directed t laced in service for engineering.	t checks have he NCP be
7A 98 o ir	fter the NCP has been placed in service you are to continue the po 3% per 12004-C. (step 4.1.xx) All prerequisites for the power incre on the previous shift. The Load Dispatcher has been notified of the increase.	ower increase to ease were met power
8T g	he last shift entered AOP 18009-C due to a 20 GPD tube leak on S Jenerator #1. All actions of Section "B" have been completed with of the radiation monitors which still need to be reset.	Steam the exception
9 li	n addition a tornado alert has been issued for Burke and Richmon There are heavy thunderstorms occuring at this time. The severe checklist has been completed in the last hour.	d Counties. weather
. · · · · · · · · · · · · · · · · · · ·		

Malf. No.	Event Type*	Event Description
	N-RO	Place NCP in service
	RO-R	Increase power to 98%
SG03a	BOP-I	SG Pressure Transmitter fails low
EL13	SRO-C BOP-C RO-C	Loss of 120 VAC vital power 1AY1A (channel I instrumentation), (N41 failure, Steam Generator Control Instrument failure letdown isolation)
FW16	SRO-I RO-I BOP-I	Feedwater Heater 4 level transmitter failure & Feedwater Heater 5A Hi-Hi level ,loss of extraction steam (AOP 18016- C)
CO05b Cond Pump O/R AF03b	ALL-M	Condensate Pump "B" trips with the failure on Condensate Pump "C" to start. Crew enters AOP-18016-C; Rapid insertion of control rods, Borate as necessary . Operating Crew recognize the need to manually trip the Reactor due to the feedwater conditions. RO attempts to trip the Reactor however it cannot be tripped from the Control Room Crew enters 19211-C start manual rod insertion, trip the Turbine, initiate emergency boration. Reactor is locally tripped and crew transition to 19000-C after completion of 19211-C. Upon entry into 19000-C the TDAFW pump will trip on overspeed and the Train "B" MDAFW pump will have a broken pump coupling resulting in a loss of heat sink. The Crew will enter 19231 to perform actions for recover of secondary heatsink, after progressing through the procedure the TDAFW Pump will be repaired and the plant will recover.
	Malf. No. SG03a EL13 FW16 CO05b Cond Pump O/R AF03b	Malf. No.Event Type*N-RORO-RSG03aBOP-IEL13SRO-C BOP-C RO-CFW16SRO-I BOP-ICO05b Cond Pump O/R AF03bALL-M

.

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor, (P)RA, (L)ow Power

PREINSERTS:

Initial Conditions:

- _____ Reset to IC #____ (NRC #1 snap)
- Insure Information Board in Control Room is updated
- Shift sign in and reactivity breifing sheets provided
- RO & BOP Name plates on Panel D
- Check EOP's, AOP's, UOP's, SOP's used in the last scenario clear of red marks
- IPC is Mode 1
- Check Control Rod Group Step Counters
- _____ Unit 2 suppling the Aux Steam Header

Select to following QMCB positions:

- _____ Steam Seals System "Caution Tag" supplied from Aux Stm Hdr
- Hotwell Makeup Controller "Caution Tag" in manual at 50%
- _____ Train "B" CCP in service
- All Controlling channels selected to channel #1
- All Train "B" Equipment Running
- Align plant for operation with minor S/G tube leak per AOP-18009-C section "B"
- Ensure all QPCP and QHVC recorders running in auto
- Train "A" MDAFW Pump is "<u>Tagged Out</u>" due to mechanical seal failure

Insert simulator malfunctions:

- (Malfunction SG01e at 20%) 20 GPD tube leak on Steam Generator #1
 malfunction (Let run for 11 minutes to stablize)
- (ES01) Failure of the Automatic Reactor Trip
- (ES02) Failure of the Manual Reactor Trip
- (RD07) Control Rods Fail to move in Automatic
- (AF03b) Broken Pump coupling on Train "B" MDAFW Pump

Simulator Overrides & Remote Functions:

- Condensate Pump "C" fails to start malfunction
 Panel Drawings-B1-AFW-Cond Pump "C"-STOP
- ALB50 (CR HI/LO △P)
 Panel Drawings-HV1-ALB50-CR Hi/Lo Diff Press-OFF
- ALB20 (Turbine/Gen Trouble)
 Panel Drawings-B2-ALB20-E01-OFF
- ALB62 (Gen Gas Non Sys Alarm)
 Panel Drawings-QPLP2-ALB62-F02-OFF
- ALB36 (1ABB Trouble)
 Panel Drawing-EAB3-ALB36 C02-OFF

Event D	escription:	Swap CVCS Charging Pumps (Start NCP; Stop CCP "B")
Time	Position	Applicant's Actions or Behavior
	SRO	Actions: • Gives direction for RO to start NCP and stop CCP "B" per SC 13006-1
	RO	 <u>Actions:</u> Refers to SOP-13006-1 "Section 4.2.1" Verifies Boron concentration in CCP "B" using control status Verifies 1HV-8110 OPEN Places 1FIC-0121 in manual control Starts NCP (1HS-0275) Observe increase in charging flow Stops CCP "B" (1HS-0274A) Adjust RCP seal injection between 8-13 GPM Returns CVCS System controls to automatic after conditions stablize
,	BOP	Actions: Assists RO in Monitoring plant paramenters during pump sv

Operator Actions

Op-Test No.: 1 Scenario No.: 1 Event No.: 2 Page 3 of 9 Event Description: Increase Power to 98%					
Time	Position	Applicant's Actions or Behavior			
	SRO	 <u>Actions:</u> Gives crew briefing on the power increase Directs Operators to increase power to 98% Refers to UOP 12004-C, Power Operation 			
	RO	Actions: Commences dilution Maintains rods above insertion limits Maintains Tave within 2 deg Tref Maintains AFD within target band			
	BOP	Actions: • Loads Turbine per SOP.			

Op-Test Event D	t No.: <u>1</u> escription:	Scenario No.: <u>1</u> Event No.: <u>3</u> Page <u>5</u> of <u>9</u> Steam Generator #1 Controlling Pressure Channel Fails Low
Malfunc	tion: SG03a	n at 0% (1PT-514)
Time	Position	Applicant's Actions or Behavior
	BOP	 Actions: Take manual control of Steam Generator #1 MFRV and MFP ∆P controllers to stablize Steam Generator #1 level and match steam and feed flows. (Immediate Operator Action) Maintain S/G #1 level between 60-70% NR Swap controlling channel per USS direction
	SRO	 Actions: Enter AOP-18001-C Section "F" for failed Steam Generator Pressure channel. Direct (BOP) to select unaffected controlling channel per Table F2 Return MFRV and MFPs to auto Notify Operations duty manager Have Maintenance Work order written Refer to Technical Specifications 3.3.2 (SI) Functional Unit 1.e condtion D 3.3.2 (SLI) Functional Unit 4.d(1) condition D 3.3.4 (Remote S/D) Functional Unit 13 Condition A

v

Op-Test No.: 1 Scenario No.: 1 Event No.: 4 Page 4 of 9

Event Description: Loss of vital AC Bus 1AY1A

Simulator operator CUE: When SO or maintenance is dispatched report back, 1AY1A normal incoming breaker (02) is tripped and the flag for the ground relay is actuated. Maintenance recommends 1AY1A be inspected because they are unsure where the fault originated.

Malfunction: EL13A

Time	Position	Applicant's Actions or Behavior
	RO/BOP	Actions: Identify loss of 1AY1A. ARP on electrical panel (BOP) Recognize failed channel 1 instruments. (RO/BOP) Manually Control Steam Generator Levels and MFP speed (BOP) Swap Steam Generator Controlling channels per USS direction (BOP) Return Steam Generator Level Control to automatic when conditions are stablized (BOP) Recognize CVCS letdown has isolated. (RO) Select Non affected controlling channel per USS direction for Pressurizer level control (RO) Recognize Train A pressure instrument failure 1-PT-455. (RO) Perform actions for failed Pressurizer pressure channel as directed by the USS. (RO) Sprays in manual control (RO) 1HS-455A in close (RO) Control Pressurizer pressure operate heaters and spray to maintain Pressurizer pressure between 2220-2250 psig.(RO) 1PIC-455A in manual at 25% demand (RO) Swap controlling channels(457/456). (RO) Return control system to automatic.(RO) Place recorder 1PS-455G to channel 457 position (RO) Place recorder 1PS-455G to channel 457 position (RO) Return control system to automatic.(RO) Return control system to service per SOP-13006-1 (RO) CLOSE 1-HV-8149A, 1-HV-8149B, and 1-HV-8149C CLOSE 1-HV-8145 OPEN 1-HV-15214

Op-Test No.: 1 Scenario No.: 1 Event No.: 4 Page 4 of 9

Event Description: Loss of vital AC Bus 1AY1A

Simulator operator CUE: When SO or maintenance is dispatched report back, 1AY1A normal incoming breaker (02) is tripped and the flag for the ground relay is actuated. Maintenance recommends 1AY1A be inspected because they are unsure where the fault originated.

Malfunction: EL13A

Time	Position	Applicant's Actions or Behavior
		 OPEN 1-HV-8160 OPEN 1-HV-8152 1-PIC-0131 LETDOWN PRESS in MANUAL and output adjusted to 50% to 75% 1-TIC-0130 LETDOWN HX OUTLET TEMP in MANUAL and output adjusted to 50% Check Pressurizer level >17% Raise charging flow to between 80-90 GPM Maintain seal injection flow between 8-13 GPM Verify OPEN 1-HV-8106 and 1-HV-8105 OPEN 1-LV-0460 and 1-LV-0459 OPEN 1-HS-8149B or 1-HS-8149C When 1-PI-0131A LETDOWN PRESS stabilizes between 360 and 380 psig, PLACE 1-PIC-0131 in AUTO PLACE 1-TIC-0130 LETDOWN HX OUTLET TEMP in AUTO and ENSURE it maintains temperature less than or equal to 115°F Return charging to automatic when conditions allow Block Channel 1 rod stop (BOP) Place Steam Dumps in "Steam Pressure Mode" per USS direction (BOP) Verify P-13 BPLP Status light per USS direction (RO/BOP) Maintain Stable Plant Conditions (RO/BOP) Verify NI-41 Interlocks per Tech Spec required actions for T.S.3.3.1-1 Functions (16)a,b,c,d,e,f and 3.3.2-1 function 8b Dispatch Control Buliding SO and Maintenance to investigate problem Shutdown any standby CCW, NSCW or ACCW pump that automaticily started due to the power loss per USS direction (RO/BOP)

Op-Test No.: 1 Scenario No.: 1 Event No.: 4 Page 4 of 9

Event Description: Loss of vital AC Bus 1AY1A

Simulator operator CUE: When SO or maintenance is dispatched report back, 1AY1A normal incoming breaker (02) is tripped and the flag for the ground relay is actuated. Maintenance recommends 1AY1A be inspected because they are unsure where the fault originated.

Malfunction: EL13A

Time	Position	Applicant's Actions or Behavior	
		 Block failed NI channel. Rod stop bypass for failed channel Comparator channel defeat for failed channel Power mismatch bypass for failed channel Upper section for failed channel Lower section for failed channel 	
	SRO	 <u>Actions:</u> Enter AOP 18032-C Section "A" "Loss of vital instrument panel 1AY1A". Enter AOP 18001-C Section "A" "Due to 1PI-455 controlling channel". Dispatch operator/maintenance to investigate 120 VAC instrument panel 1AY1A power loss. (Do Not Restore Power until maintenance has investigated cause of the power loss) Enter AOP 18001-C "Section H" due to 1PT-505 failure. Direct (RO/BOP) in swap controlling channels for Steam Generator Level, Pressurizer Level and Pressurizer pressure and return to normal operation. Defeat Failed loop 1 Tavg and ΔT. Verify TS interlocks. Tech Spec 3.3.1-1 functions 16a,b,c,d,e, and 3.3.2-1 function 8b. Enter AOP-18002-C for failed NI. Block failed NI channel. Notify Operations duty manager. Have Maintenance Work order written. Refer to Technical Specifications. Apply TS 3.8.9 Condition B 	

Operator Actions

Form ES-D-2

Op-Test	No.: <u>1</u> Sc	enario No.: <u>1</u> Event No.: <u>5</u> Page <u>6</u> of <u>9</u>		
Event De	escription: Los	ss Of Feedwater Heaters results in Reactor Power increase		
Malfunct	ion: FW16A			
Simulator Operator: Override 1HS4302A Feedwater Heater 5A Extraction Steam Stop Valve to the closed position Panel Drawing-B2-TUR-HS4302A-CLOSED (5A) Panel Drawing-B2-TUR-HS4343A-CLOSED (4A)				
Time	Position	Applicant's Actions or Behavior		
	RO/BOP	 Actions: Recognizes Reactor Power is increasing due to the lower main feedwater temperature (RO/BOP) Manual Control rod insertion to lower Reactor Power below 100% as required (RO) Lower Main Turbine Load to maintain Reactor Power below 100% (BOP) Restore Tavg to program. (RO/BOP) Verify plant parameters are within normal operating range ; Pressurizer Level / Pressure, Steam Generator Levels. Actions: Refers to AOP 180016-C Section "C" and directs crew operations Directs (RO/BOP) to maintain Reactor Power below 100% by all indications Initiate maintenance. Notify Operations duty manager. Have Maintenance Work Order written. 		

Appendix D

Operator Actions

Operator Actions

Form ES-D-2

Op-Test	No.: <u>1</u> Sc	enario No.: <u>1</u> Event No.: <u>6</u> Page <u>6</u> of <u>9</u>			
Event De	escription: Co Au	ndensate Pump "B" trips and Pump "C" fails to start tomatically or manually.			
Malfunct	Malfunction: CO05b				
Simulator Operator: Insure malfunctions are in place to prevent automatic, manual Reactor Trip & Automatic Control Rods Movement.					
Time	Position	Applicant's Actions or Behavior			
	RO/BOP	 <u>Actions:</u> Recognizes Condensate Pump "B" has tripped and initiates: (BOP): Load Setback circuit Condensate Pump "C" manual start (Note Pump will NOT start due to simulator override) Main Feedwater Pump "A" is at maximum output Manual Control rod insertion to lower Reactor Power to within the copacity of one MFP (RO) Recognizes that Condensate Pump "C" failing to start will required a manual Reactor Trip; informs operating crew of problem (BOP) Actions: Refers to AOP 180016-C Section "C" and directs crew operations Directs (RO/BOP) to reduce Reactor Power to within the emistive of the "A" MEP 			
		Direct (RO) to manually trip the Reactor			

Appendix D

Operator Actions

Operator Actions

Op-Test	No.: 1 Sc	enario No.: <u>1</u> Event No.: <u>6</u> Page <u>7</u> of <u>9</u>			
Event De	Event Description: When the Operating Crew attempts to manually trip the Reactor following the MFP trip, it will fail to trip. The crew will enter 19211-C (ATWT) for required actions to shutdown the plant. Following the Reactor trip the crew will transition to back to 19000-C at which time the TDAFW Pump will trip on overspeed (MDAFW Pump "B" will be running with a broken pump coupling).				
Simulato	 Simulator Operator: Allow crew to progress past step 7 in 19211-C and if a reasonable amount of time has elapsed, insert Reactor trip. Remove malfunction (ES01) Failure of the Automatic Reactor Trip. TDAFW Pump trips on overspeed (AF02C) Remote Function (AF22) will be used to reset the T&TV. 				
Cue: Time Dispatched Report Back • The Train "B" MDAFW pump motor is running but the pump coupling is broken. • Maintenance engineering report the TDAFW Pump tripped due to a slug of water in the steam line and can be operated after reset.					
Time	Position	Applicant's Actions or Behavior			
	RO/BOP	 Actions: (19211-C) Attempt to manually trip the Reactor using BOTH Control Room Handswitches (RO) Dispatches the Control Building SO to Locally Manually trip the Unit 1 Reactor (USS/RO/BOP) Manually insert Control Rods (RO) Note: When the RO places the Rod Control System in Automatic they must recognize the failure of the system to automatically insert the Control Rods and return to manual insertion Manually Trip the Main Turbine (BOP) Start AFW System (BOP) Identify that Reactor Power is >5% (RO) Initiate Emergency Boration (RO/BOP) Align CVI per USS direction (BOP) 			

Op-Test	No.: <u>1</u> Sc	enario No.: <u>1</u> Event No.: <u>6</u> Page <u>7</u> of <u>9</u>			
Event De	escription: When follov (ATW Reac the T runn	In the Operating Crew attempts to manually trip the Reactor wing the MFP trip, it will fail to trip. The crew will enter 19211-C (T) for required actions to shutdown the plant. Following the stor trip the crew will transition to back to 19000-C at which time DAFW Pump will trip on overspeed (MDAFW Pump "B" will be ing with a broken pump coupling).			
Simulato	 Simulator Operator: Allow crew to progress past step 7 in 19211-C and if a reasonable amount of time has elapsed, insert Reactor trip. Remove malfunction (ES01) Failure of the Automatic Reactor Trip. TDAFW Pump trips on overspeed (AF02C) Remote Function (AF22) will be used to reset the T&TV. 				
Cue: Ti	ime Dispatcheo Report Back	±			
	 The Train "B" MDAFW pump motor is running but the pump coupling is broken. Maintenance engineering report the TDAFW Pump tripped due to a slug of water in the steam line and can be operated after reset. 				
Time	Position	Applicant's Actions or Behavior			
		 Verify Core Exit TC's less than 1200 degrees F.(BOP) Perform first 16 steps of 19000-C as time permits if Safety Injection is automatically actuated (BOP) Actions: (19000-C) Following the Reactor trip and completion of 19211-C the crew will transition back to 19000-C. Verify Rx Trip (RO) Verify turbine trip. (BOP) Verify power to AC emergency busses. (BOP) Check if SI Actuated. (RO) Verify Feedwater isolation. (BOP) Verify MLB indications for both trains of ECCS equipment aligning for injection phase. (RO) Verify containment isolation Phase A actuated. (RO) MDAEW Pumps running (NOTE: operator should recognize 			

Op-Test	No.: <u>1</u> Sco	enario No.: _1 Event No.:6 Page_7_ of _9			
Event Description: When the Operating Crew attempts to manually trip the Reactor following the MFP trip, it will fail to trip. The crew will enter 19211-C (ATWT) for required actions to shutdown the plant. Following the Reactor trip the crew will transition to back to 19000-C at which time the TDAFW Pump will trip on overspeed (MDAFW Pump "B" will be running with a broken pump coupling).					
Simulato	 Simulator Operator: Allow crew to progress past step 7 in 19211-C and if a reasonable amount of time has elapsed, insert Reactor trip. Remove malfunction (ES01) Failure of the Automatic Reactor Trip. TDAFW Pump trips on overspeed (AF02C) Remote Function (AF22) will be used to reset the T&TV. 				
Cue: Ti	ime Dispatched				
F	Report Back				
The Train "B" MDAFW pump motor is running but the pump coupling is					
proken.					
	Mainte	enance engineering report the TDAFW Pump tripped due to a			
	siug o				
Time	Position	Applicant's Actions or Behavior			
	· · · · ·	Check CCP status (RO)			
		 Check RCS pressure <2335 psig (RO) 			
		Check S/G levels (BOP)			
		Try to establish AFW flow (BOP)(Check alignment)			
		SGBD valves shut			
		Check suction to AEW numps			
		Check AFW discharge throttle valve open			
		Check TDAFW Pump:			
		• 1HV-5106 open			
		 1PV-15129 is Closed (due to the overspeed) 			
		Governor Valve operating properly.			
		The BOP directs the Outside Building SO to locally reset the The BOP directs the Outside Building SO to locally reset the			
	SRO	Actions:			
		Directs/Insures the RO has manually tripped the Reactor Using			
		BOTH Control Room Handswitch.			
		• Enters 19211-C (ATWT).			
1					
		Directs/Insures the BOP has manually tripped the Main Turbine			

Op-Test	No.: <u>1</u> Sc	enario No.: <u>1</u> Event No.: <u>6</u> Page_7 of <u>9</u>			
Event De	escription: Wher follow (ATW Reac the T runni	In the Operating Crew attempts to manually trip the Reactor wing the MFP trip, it will fail to trip. The crew will enter 19211-C (T) for required actions to shutdown the plant. Following the tor trip the crew will transition to back to 19000-C at which time DAFW Pump will trip on overspeed (MDAFW Pump "B" will be ing with a broken pump coupling).			
Simulato	r Operator: Allo amo • Re • TD • Re	w crew to progress past step 7 in 19211-C and if a reasonable bunt of time has elapsed, insert Reactor trip. move malfunction (ES01) Failure of the Automatic Reactor Trip. AFW Pump trips on overspeed (AF02C) mote Function (AF22) will be used to reset the T&TV.			
Cue: Ti F	 Cue: Time Dispatched Report Back The Train "B" MDAFW pump motor is running but the pump coupling is broken. Maintenance engineering report the TDAFW Pump tripped due to a slug of water in the steam line and can be operated after reset. 				
Time	Position	Applicant's Actions or Behavior			
		 locally manually trip the Unit 1 Reactor. Insure AFW in service Direct the BOP to initiate Emergency Boration Direct BOP to align CVI Direct isolation of dilution paths Directs RO to check Reactor Power <5% Actions: Direct RO to check CCP status Directs RO to Check RCS pressure <2335 psig Direct BOP to check S/G levels Try to establish AFW flow (BOP)(Check alignment) Direct the Outside Operator to reset the T&TV when conditions allow 			

Examiners: Operators: Initial Conditions: The plant is at 95%. RCS boron concentration is at 1308 ppm, conditions. B Train equipment in service. ECCS accumulator #3 pressure is low. C B in PTL. Turnover: I	Facility: VOGTLE	Scenario No.: 2	Op-Test
Initial Conditions: The plant is at 95%. RCS boron concentration is at 1308 ppm, conditions. B Train equipment in service. ECCS accumulator #3 pressure is low. C B in PTL. Turnover:	Examiners:	Operators:	
 Plant Startup is in progress. Plant Startup is in progress. Rx power is 95%. 1PV-0456 is in the shut position due to seat leakage. 1HV-8000B is shut to comply with Technical Specification 3.4.11 Condition ECCS accumulator #3 pressure is low due to a minor leak. After assum shift repressurize the accumulator using SOP 13105-1. CCW train B pumps in PTL, clearance has just been released. Function scheduled approxiamtely 2 hours from now. The last shift entered AOP 18009-C due to a 20 GPD tube leak on Stean generator #1. All actions of Section "B" have been completed with the of the radiation monitors which still need to be reset. In addition a tornado alert has been issued for Burke and Richmond Courthere are heavy thunderstorms occuring at this time. The severe weath checklist has been completed in the last hour. 	Initial Conditions: The plant conditions. B Train equipment B in PTL.	t is at 95%. RCS boron concentra nt in service. ECCS accumulator #	ation is at 1308 ppm, #3 pressure is low. C
 Plant Startup is in progress. Rx power is 95%. 	<u>Turnover:</u>		:
 2Rx power is 95%. 31PV-0456 is in the shut position due to seat leakage. 41HV-8000B is shut to comply with Technical Specification 3.4.11 Conditions. 5ECCS accumulator #3 pressure is low due to a minor leak. After assum shift repressurize the accumulator using SOP 13105-1. 6CCW train B pumps in PTL, clearance has just been released. Function scheduled approxiamtely 2 hours from now. 7The last shift entered AOP 18009-C due to a 20 GPD tube leak on Stean generator #1. All actions of Section "B" have been completed with the of the radiation monitors which still need to be reset. 8In addition a tornado alert has been issued for Burke and Richmond Courthere are heavy thunderstorms occuring at this time. The severe weath checklist has been completed in the last hour. 	1Plant Startup is in p	progress.	
 	2Rx power is 95%.		
 1HV-8000B is shut to comply with Technical Specification 3.4.11 Condition ECCS accumulator #3 pressure is low due to a minor leak. After assum shift repressurize the accumulator using SOP 13105-1. CCW train B pumps in PTL, clearance has just been released. Function scheduled approxiamtely 2 hours from now. The last shift entered AOP 18009-C due to a 20 GPD tube leak on Stean generator #1. All actions of Section "B" have been completed with the of the radiation monitors which still need to be reset. In addition a tornado alert has been issued for Burke and Richmond Cou There are heavy thunderstorms occuring at this time. The severe weath checklist has been completed in the last hour. 	31PV-0456 is in the	shut position due to seat leakage	
 ECCS accumulator #3 pressure is low due to a minor leak. After assum shift repressurize the accumulator using SOP 13105-1. CCW train B pumps in PTL, clearance has just been released. Function scheduled approxiamtely 2 hours from now. The last shift entered AOP 18009-C due to a 20 GPD tube leak on Stean generator #1. All actions of Section "B" have been completed with the of the radiation monitors which still need to be reset. In addition a tornado alert has been issued for Burke and Richmond Cou There are heavy thunderstorms occuring at this time. The severe weath checklist has been completed in the last hour. 	41HV-8000B is shut	t to comply with Technical Specific	ation 3.4.11 Conditio
 CCW train B pumps in PTL, clearance has just been released. Function scheduled approxiamtely 2 hours from now. The last shift entered AOP 18009-C due to a 20 GPD tube leak on Stean generator #1. All actions of Section "B" have been completed with the of the radiation monitors which still need to be reset. In addition a tornado alert has been issued for Burke and Richmond Cou There are heavy thunderstorms occuring at this time. The severe weath checklist has been completed in the last hour. 	5 ECCS accumulato shift repressurize	or #3 pressure is low due to a mino the accumulator using SOP 1310	or leak. After assumi 5-1.
 7The last shift entered AOP 18009-C due to a 20 GPD tube leak on Stean generator #1. All actions of Section "B" have been completed with the of the radiation monitors which still need to be reset. 8In addition a tornado alert has been issued for Burke and Richmond Cou There are heavy thunderstorms occuring at this time. The severe weath checklist has been completed in the last hour. 	6 CCW train B pump scheduled approx	ps in PTL, clearance has just beer kiamtely 2 hours from now.	n released. Function
 In addition a tornado alert has been issued for Burke and Richmond Cou There are heavy thunderstorms occuring at this time. The severe weath checklist has been completed in the last hour. 	7The last shift enter generator #1. All of the radiation mo	ed AOP 18009-C due to a 20 GPL actions of Section "B" have been onitors which still need to be reset.	D tube leak on Stean completed with the e
	8 In addition a torna There are heavy th checklist has been	do alert has been issued for Burke hunderstorms occuring at this time n completed in the last hour.	e and Richmond Cou e. The severe weath

Event No.	Malf. No.	Event Type*	Event Description
1		N-RO	Raise #3 accumulator pressure
2	PR-02A 100% PR-05 5%	RO-I	PRZR pressure channel fails high PORV-455A fails partially open on transient
3	FW14 0%	BOP-I	MFP discharge pressure fails low
4	CC01A O/R pmp5	BOP-C	Loss of CCW train B
5	CV07	RO-C	NCP trips
6	RP06A 15%	C-RO ALL-R	RCP #1 seal #1 failure (5.2 gpm) mgmt says S/D in 30 min SRO directs rapid power reduction per 18013-C
7	RP06a 100% RC05a 1.5% MS01 100% ES19B SI06a	M-ALL	RCP seal LOCA B train CVI failure SIP-1A fails to start PV-507C fails open (steam Dump) Stop scenario when 19012-C is entered
* (N)orr	nal, (R)ea	activity, (I)ne	strument, (C)omponent, (M)ajor, (P)RA, (L)ow Power

PREINSERTS:

Initial Conditions:

- _____ Reset to IC #___ (NRC #2 snap)
- Insure Information Board in Control Room is updated
- Shift sign in and reactivity breifing sheets provided
- RO & BOP Name plates on Panel D
- Check EOP's, AOP's, UOP's, SOP's used in the last scenario clear of red marks
- IPC is Mode 1
- Check Control Rod Group Step Counters
- _____ Unit 2 suppling the Aux Steam Header

Select to following QMCB positions:

- _____ 1PV-0456 in shut position with "Caution Tag"
- 1HV-8000B in shut position with "Caution Tag"
- Steam Seals System "<u>Caution Tag</u>" supplied from Aux Stm Hdr
- Hotwell Makeup Controller "<u>Caution Tag</u>" in manual at 50%
- All Controlling channels selected to channel #1
- _____ All Train "B" Equipment Running
- Align plant for operation with minor S/G tube leak per AOP-18009-C section "B"
- Ensure all QPCP and QHVC recorders running in auto

Insert simulator malfunctions:

- (Malfunction SG01e at 20%) 20 GPD tube leak on Steam Generator #1
- _____ (ES19B) CVI Train "B" failure
- (SI01C) at 100% until low pressure alarm then remove malfunction
- (SI06A) SI Pump "A" fails to automatically start on the SI signal

Simulator Overrides & Remote Functions:

- CCW pump #5 STOP
 Panel Drawings-AL-CCW-HS1856A-STOP
- ALB50 (CR HI/LO △P)
 Panel Drawings-HV1-ALB50-CR Hi/Lo Diff Press-OFF
- ALB20 (Turbine/Gen Trouble)
 Panel Drawings-B2-ALB20-E01-OFF
- ALB62 (Gen Gas Non Sys Alarm)
 Panel Drawings-QPLP2-ALB62-F02-OFF

Op-Test Event D	No.: <u>1</u> escription:	_ Scenario No.: <u>2</u> Event No.: <u>1</u> Page <u>3</u> of <u>9</u> Raise #3 ECCS accumulator Pressure
Time	Position	Applicant's Actions or Behavior
	RO	 SOP 13105-1 selected: OPEN ACCUM N2 ISO VLV 1HV8880. VERIFY pressures rising OPEN the ACCUM N2 SUPPLY/VENT VLV: Accumulator 3 1HV8875C and/or 1HV8875G When the Accumulators reach the desired pressure, CLOSE the valve opened in Step above When accumulators are at the desired pressure, CLOSE 1HV-8880

Operator Actions

Op-Test No.: 1 Scenario No.: 2 Event No.: 2 Page 3 of 9			
Event De	escription:	PRZR pressure PT-455 fails high and PORV 455A fails partially open	
Malfunct	ions: PR02	A @ 100%, PR05 @ 5%	
Remote	Function: P	R03 when requested to remove power from 1HV8000A	
Time	Position	Applicant's Actions or Behavior	
	RO	Immediate actions: Close Spray valves Close PORV-455A Energize PZR Heaters Master Controller placed in manual @ 25% Select 457/456 for control Return heaters, spray valves, and PORV, master controller to AUTO Select unaffected channel for panel recorder (457) Verify P-11 in proper state for plant conditions (1 hr LCO action) Observes dual indication for PORV-455A Shuts PORV Block Valve 1HV-8000A	
	SRO	 18001-C section C referenced Notifies duty manager of AOP entry Contacts maintenance to initiate repairs Refers to Tech Specs: LCO 3.3.1 Functional Unit 6 - Condition E Functional Unit 8a - Condition M Functional Unit 8b - Condition E LCO 3.3.2 Functional Unit 1d - Condition D Functional Unit 8b - Condition L LCO 3.4.11 Condition B Request SSS to remove power from 1HV-8000A 	

Op-Test No.: 1 Scenario No.: 2 Event No.: 3 Page 5 of 9

Event Description: MFP Discharge pressure indication (PT-508) fails low

Malfunction: FW14 @ 0% (set ramp time at 11 seconds)

Time	Position	Applicant's Actions or Behavior
	BOP	 Diagnose PT-508 failed low Take manual control of MFP master controller Match steam and feed flows on all 4 SGs Operate Main Feedwater Pump △P in manual
	SRO	 Reference 18016-C section A Notifies duty manager of AOP entry Contacts maintenance to initiate repairs Inform BOP of responsibilities regarding manual control of Main Feedwater Pump ΔP

Op-Test N	lo.: <u>1</u> Sc	enario No.: _ 2 _ Event No.: _ 4 _ Page_4 _ of _ 9 _
Event Des	scription: Loss	of CCW train B (pump 1 trips, pump 5 fails to start)
Malfunctio	on: CC01A	
Simulator	Operator CUE	: Report Back when dispatched to CCW Pump #1:
Time Calle Report bac	ed: .ck time:	
Control Bu	uilding SO and	Maintenance: Phase A,B,C (150 device) Overcurrent Flags are present and the 186 lockout is tripped for CCW Pump #1.
Auxiliary B	Building SO: th	at are no obvious problems noted locally at the CCW Pump #1
Simulator	Operator CUE	: Report Back when dispatched to CCW Pump #5:
Control Bu	uilding SO and	Maintenance: The Breaker to CCW Pump #5 appears to not be racked in completely and the racking mechanism may be damaged.
Time	Position	Applicant's Actions or Behavior
	BOP	Diagnose only CCW pump #3 is running Attempt manual start of pump #5 Stop CCW train A Place CCW train B in service Dispatch SO to place SFPC train B in service Dispatch SO to investigate CCW pumps/breakers
	SRO	Enters 18020-C Loss of CCW Notifies duty manager of AOP entry Contacts maintenance to initiate repairs Tech Spec: LCO 3.7.7 condition B (72 hour shutdown)

Op-Test No.: <u>1</u> 5	Scenario No.: <u>2</u> Event No.: <u>5</u> Page <u>6</u> of <u>9</u>
Event Description: NC	P Trips
Malfunction: CV07	
Simulator Operator CL	E: Report Back when dispatched to CCW Pump #1:
Time Called: Report back	- -
Auxiliary Building SO a	nd Maintenance: The NCP Pump appears to be OK. Maintaince suspects a faulty relay caused the problem.
Time Position	Applicant's Actions or Behavior
RO	 Isolate CVCS letdown Verify Charging Pump lineup OPEN 1-HV-8471A (1-HV-8471B) CCP-A(B) SUCTION OPEN 1-HV-8111A (1-HV-8111B) CCP-A(B) MINIFLOW, OPEN 1-HV-8110 CCP A & B COMMON MINIFLOW, CLOSE 1-HV-0190A (1-HV-0190B) CHARGING THROTTLE, OPEN 1-HV-8485A (1-HV-8485B) CCP-A(B) DISCHARGE ISOLATION, If starting CCP-B, OPEN 1-HV-8438 CCP DISCHARGE HEADER CROSS-CONNECT SET 1-HIC-182 for MAXIMUM Seal Flow (0% demand). ENSURE 1-FIC-0121 CHARGING FLOW in MAN and SET to minimum ENSURE 1-LI-0185 VCT level indicates between 30 and 80%. Start CCP 1A or 1B Raise charging to 80-90 GPM RCP seal injection flow 8-13 GPM/pump Initiate letdown pressure and ACCW temperature controllers in auto Dispatch SO to investigate NCP and preform CCP presart checks

Op-Test No.: 1 Scenario No.: 2 Event No.: 5 Page 6 of 9

Event Description: NCP Trips

Malfunction: CV07

Simulator Operator CUE: Report Back when dispatched to CCW Pump #1:

Time Called: _____ Report back _____

Auxiliary Building SO and Maintenance: The NCP Pump appears to be OK. Maintaince suspects a faulty relay caused the problem.

Time	Position	Applicant's Actions or Behavior
	SRO	 Enters 18007-C "Section B" Have RO isolate CVCS letdown flow Check ACCW System in service Check indication that NCP did not trip due to gas binding Direct starting of CCP (A or B) Dispatches Operator and maintenance to investigate problem Notifies duty manager of AOP entry Has SSS initiate work order (Note Only INFO LCOs for this failure)

Op-Test No.: 1 Scenario No.: 2 Event No.: 6 Page 6 of 9

Event Description: RCP #1 seal #1 failure (5.2 gpm)

Malfunction: RP06A @ ramp slowly @ 15% (watch indication)

Cue: Duty Manager instructs USS to shutdown unit in next 30 minutes and secure RCP #1 when contacted by USS about problem. Load Dispatcher will be notified by duty manager

Time	Position	Applicant's Actions or Behavior
	RO	 <u>Seal Failure:</u> Diagnose RCP seal failure (Controlled leakage hi/lo flow alarm) SOP 13003-1 RCP operation with seal abnomality Use figures 1&2 to determine RCP must be stopped in 8 hours 18013-C Actions:
		 Insert Control control rods/borate as necessary Energize all Pressurizer Heaters Tave/Tref within 3 degrees Maintain Reactor Power and Turbine Power matched Maintain Pressurizer Level & pressure in normal control band
:	BOP	 Reduce turbine load Maintain S/G in normal control band
	SRO	 <u>Seal Failure:</u> Using 13003-1 confirm decision tree Seal injection > 8 gpm & <130 deg F Seal leakoff outside normal ops band (figure 2) Seal leakoff <5.5 gpm & above min required Shutdown RCP w/i 8 hours
		 <u>18013-C Actions:</u> Enters 18013-C for rapid down power Notify chemistry >15% power change in 1 hour

Op-Test	: No.: <u>1</u> So	enario No.: <u>2</u> Event No.: <u>6</u> Page <u>6</u> of <u>9</u>
Event D	escription: <i>RCP</i>	seal LOCA (300 gpm)
Malfunc	tion: (1) RP06 (2) RC05 (3) MS01	A 100% "RCP #1 seal failure" 5A @ 1.5% "Hot Leg Break at 450 GPM" I @ 100% " Steam Dump Valve 1PV-507C fails fully open"
Time	Position	Applicant's Actions or Behavior
	RO/BOP	 Diagnose leak increasing Increases charging flow to maintain PZR level Manually trips reactor Manual SI <u>Actions:</u> (19000-C) Verify Rx Trip (RO) Verify turbine trip. (BOP) Verify power to AC emergency busses.(BOP) Check if SI Actuated. (RO) Verify Feedwater isolation. (BOP) Verify Feedwater isolation. (BOP) Verify Containment isolation Phase A actuated. (RO) Verify AFW Pumps running. (BOP) SG blowdown isolated (BOP) TDAFW pump running. (BOP) Verify ECCS pumps running on each Train. (RO) Verify 2 CCW pumps running on each Train. (RO) Verify containment ventilation isolation (CVI). (RO) Check if MSIV should be isolated (RO/BOP) Check ontainment spray not required. (RO) Verify ECCS flows. (RO) Verify ECCS flows. (RO) Verify ECCS alignment on MLBs. (RO) Verify RCS temperatures. (Should find 1PV-507C failed open and actuate MSLI)(RO/BOP)

Event De Malfuncti	escription: <i>RCP</i> on: (1) RP06 (2) RC05 (3) MS0	<i>seal LOCA (300 gpm)</i> 5A 100% "RCP #1 seal failure" 5A @ 1.5% "Hot Leg Break at 450 GPM" 1 @ 100% " Steam Dump Valve 1PV-507C fails fully open"		
Time	Position	Applicant's Actions or Behavior		
	SRO	 Directs RO to maintain PZR level Directs RO to manually trip reactor and intiate manual SI Enters 19000-C, Reactor trip/SI Insures all immediate actions are performed per 19000-C. Directs operator actions per the 19000-C direction. Ensures proper communication between crewmembers. Diagnose Primary LOCA Enter 19010-C, Response to LOCA Transistion to 19012-C Post LOCA cooldown/depressurization 		
Appendix D		Scenario Outline		Form ES-D-1
---	---	---	---------------------------------	---
Facility:	VOGTLE	Scenario No.:	2	Op-Test No.: <u>1</u>
Examiners:		Operators:		
<u>Initial Conc</u> conditions. B in PTL.	<u>litions:</u> The plant i B Train equipment	is at 95%. RCS boron conc t in service. ECCS accumula	entration is ator #3 pre	at 1308 ppm, BOL ssure is low. CCW train
<u>Turnover:</u>				
1P	lant Startup is in pr	rogress.		
2R	x power is 95%.			
31	PV-0456 is in the s	hut position due to seat leal	kage.	
4 1	HV-8000B is shut t	o comply with Technical Sp	ecification	3.4.11 Condition "A".
5E	ECCS accumulator shift repressurize the termination of terminatio	#3 pressure is low due to a ne accumulator using SOP ⁻	minor leak 13105-1.	. After assuming the
60	CCW train B pumps	s in PTL, clearance has just amtely 2 hours from now.	been relea	ased. Functional testing
7T g o	he last shift entere enerator #1. All a f the radiation mor	d AOP 18009-C due to a 20 actions of Section "B" have I hitors which still need to be r	GPD tube been comp reset.	e leak on Steam leted with the exception
8l T	n addition a tornad here are heavy thu hecklist has been	o alert has been issued for understorms occuring at this completed in the last hour.	Burke and time. The	Richmond Counties. Severe weather
,				

Event No.	Malf. No.	Event Type*	Event Description	
1		N-RO	Raise #3 accumulator pressure	
2	PR-02A 100% PR-05 5%	RO-I	PRZR pressure channel fails high PORV-455A fails partially open on transient	
3	FW14 0%	BOP-I	MFP discharge pressure fails low	
4	CC01A O/R pmp5	BOP-C	Loss of CCW train B	
5	CV07	RO-C	NCP trips	
6	RP06A 15%	C-RO ALL-R	RCP #1 seal #1 failure (5.2 gpm) mgmt says S/D in 30 min SRO directs rapid power reduction per 18013-C	
7	RP06a 100% RC05a 1.5% MS01 100% ES19B SI06a	M-ALL	RCP seal LOCA B train CVI failure SIP-1A fails to start PV-507C fails open (steam Dump) Stop scenario when 19012-C is entered	
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor, (P)RA, (L)ow Power				

PREINSERTS:

Initial Conditions:

- _____ Reset to IC #__ (NRC #2 snap)
- Insure Information Board in Control Room is updated
- Shift sign in and reactivity breifing sheets provided
- _____ RO & BOP Name plates on Panel D
- Check EOP's, AOP's, UOP's, SOP's used in the last scenario clear of red marks
- IPC is Mode 1
- Check Control Rod Group Step Counters
- Unit 2 suppling the Aux Steam Header

Select to following QMCB positions:

- 1PV-0456 in shut position with "Caution Tag"
- 1HV-8000B in shut position with "Caution Tag"
- Steam Seals System "<u>Caution Tag</u>" supplied from Aux Stm Hdr
- Hotwell Makeup Controller "Caution Tag" in manual at 50%
- All Controlling channels selected to channel #1
- _____ All Train "B" Equipment Running
- Align plant for operation with minor S/G tube leak per AOP-18009-C section "B"
- Ensure all QPCP and QHVC recorders running in auto

Insert simulator malfunctions:

- (Malfunction SG01e at 20%) 20 GPD tube leak on Steam Generator #1
- _____ (ES19B) CVI Train "B" failure
- (SI01C) at 100% until low pressure alarm then remove malfunction
- (SI06A) SI Pump "A" fails to automatically start on the SI signal

Simulator Overrides & Remote Functions:

- _____ CCW pump #5 STOP Panel Drawings-AL-CCW-HS1856A-STOP
- ALB50 (CR HI/LO △P)
 Panel Drawings-HV1-ALB50-CR Hi/Lo Diff Press-OFF
- ALB20 (Turbine/Gen Trouble)
 Panel Drawings-B2-ALB20-E01-OFF
- ALB62 (Gen Gas Non Sys Alarm)
 Panel Drawings-QPLP2-ALB62-F02-OFF

Op-Test No.: 1 Scenario No.: 2 Event No.: 1 Page 3 of 9 Event Description: Raise #3 ECCS accumulator Pressure			
Time	Position	Applicant's Actions or Behavior	
	RO	 SOP 13105-1 selected: OPEN ACCUM N2 ISO VLV 1HV8880. VERIFY pressures rising OPEN the ACCUM N2 SUPPLY/VENT VLV: Accumulator 3 1HV8875C and/or 1HV8875G When the Accumulators reach the desired pressure, CLOSE the valve opened in Step above When accumulators are at the desired pressure, CLOSE 1HV-8880 	

,

•

Appendix D

Operator Actions

Form ES-D-2

Op-Test	Op-Test No.: 1 Scenario No.: 2 Event No.: 2 Page 3 of 9				
Event De	Event Description: PRZR pressure PT-455 fails high and PORV 455A fails partially open				
Malfunctions: PR02A @ 100%, PR05 @ 5%					
Remote	Remote Function: PR03 when requested to remove power from 1HV8000A				
Time	Position	Applicant's Actions or Behavior			
	RO	Immediate actions: • Close Spray valves • Close PORV-455A • Energize PZR Heaters Master Controller placed in manual @ 25% Select 457/456 for control Return heaters, spray valves, and PORV, master controller to AUTO Select unaffected channel for panel recorder (457) Verify P-11 in proper state for plant conditions (1 hr LCO action) Observes dual indication for PORV-455A Shuts PORV Block Valve 1HV-8000A			
	SRO	 18001-C section C referenced Notifies duty manager of AOP entry Contacts maintenance to initiate repairs Refers to Tech Specs: LCO 3.3.1 Functional Unit 6 - Condition E Functional Unit 8a - Condition M Functional Unit 8b - Condition M Functional Unit 8b - Condition E LCO 3.3.2 Functional Unit 1d - Condition D Functional Unit 8b - Condition L LCO 3.4.11 Condition B Request SSS to remove power from 1HV-8000A 			

Op-Test No.: 1 Scenario No.: 2 Event No.: 3 Page 5 of 9

Event Description: MFP Discharge pressure indication (PT-508) fails low

Malfunction: FW14 @ 0% (set ramp time at 11 seconds)

Time	Position	Applicant's Actions or Behavior
	BOP	 Diagnose PT-508 failed low Take manual control of MFP master controller Match steam and feed flows on all 4 SGs Operate Main Feedwater Pump △P in manual
	SRO	 Reference 18016-C section A Notifies duty manager of AOP entry Contacts maintenance to initiate repairs Inform BOP of responsibilities regarding manual control of Main Feedwater Pump ΔP

Op-Test No.: _	_ <u>1_</u> Sc	enario No.: 2 Event No.: 4 Page 4 of 9			
Event Descript	Event Description: Loss of CCW train B (pump 1 trips, pump 5 fails to start)				
Malfunction: C	C01A				
Simulator Operator CUE: Report Back when dispatched to CCW Pump #1:					
Report back tin	ne:				
Control Building SO and Maintenance: Phase A,B,C (150 device) Overcurrent Flags are present and the 186 lockout is tripped for CCW Pump #1.					
Auxiliary Buildi	ng SO: th	at are no obvious problems noted locally at the CCW Pump #1			
Simulator Ope	rator CUE	: Report Back when dispatched to CCW Pump #5:			
Control Building SO and Maintenance: The Breaker to CCW Pump #5 appears to not be racked in completely and the racking mechanism may be damaged.					
Time Po	osition	Applicant's Actions or Behavior			
E	BOP	Diagnose only CCW pump #3 is running Attempt manual start of pump #5 Stop CCW train A Place CCW train B in service Dispatch SO to place SFPC train B in service Dispatch SO to investigate CCW pumps/breakers			
5	SRO	Enters 18020-C Loss of CCW Notifies duty manager of AOP entry Contacts maintenance to initiate repairs Tech Spec: LCO 3.7.7 condition B (72 hour shutdown)			

Appendix D	Ap	pen	dix	D
------------	----	-----	-----	---

Op-Test No.: 1 Scenario No.: 2 Event No.: 5 Page 6 of 9			
Event Description: NCP Trips			
Malfunction: CV	07		
Simulator Operator CUE: Report Back when dispatched to CCW Pump #1:			
Time Called: Report back			
Auxiliary Building SO and Maintenance: The NCP Pump appears to be OK. Maintaince suspects a faulty relay caused the problem.			
Time Positic	n Applicant's Actions or Behavior		
RO	 Isolate CVCS letdown Verify Charging Pump lineup OPEN 1-HV-8471A (1-HV-8471B) CCP-A(B) SUCTION OPEN 1-HV-8111A (1-HV-8111B) CCP-A(B) MINIFLOW, OPEN 1-HV-8110 CCP A & B COMMON MINIFLOW, CLOSE 1-HV-0190A (1-HV-0190B) CHARGING THROTTLE, OPEN 1-HV-8485A (1-HV-8485B) CCP-A(B) DISCHARGE ISOLATION, If starting CCP-B, OPEN 1-HV-8438 CCP DISCHARGE HEADER CROSS-CONNECT SET 1-HIC-182 for MAXIMUM Seal Flow (0% demand). ENSURE 1-FIC-0121 CHARGING FLOW in MAN and SET to minimum ENSURE 1-LI-0185 VCT level indicates between 30 and 80%. Start CCP 1A or 1B Raise charging to 80-90 GPM RCP seal injection flow 8-13 GPM/pump Initiate letdown pressure and ACCW temperature controllers in auto Dispatch SO to investigate NCP and preform CCP presart checks 		

Op-Test	No.: <u>1</u> Sc	enario No.: <u>2</u> Event No.: <u>5</u> Page <u>6</u> of <u>9</u>				
Event Description: NCP Trips						
Malfuncti	Malfunction: CV07					
Simulato	r Operator CUE	: Report Back when dispatched to CCW Pump #1:				
Time Cal Report ba	Time Called: Report back					
Auxiliary	Auxiliary Building SO and Maintenance: The NCP Pump appears to be OK. Maintaince suspects a faulty relay caused the problem.					
Time	Position	Applicant's Actions or Behavior				
	SRO	 Enters 18007-C "Section B" Have RO isolate CVCS letdown flow Check ACCW System in service Check indication that NCP did not trip due to gas binding Direct starting of CCP (A or B) Dispatches Operator and maintenance to investigate problem Notifies duty manager of AOP entry Has SSS initiate work order (Note Only INFO LCOs for this failure) 				

Op-Test No.: 1 Scenario No.: 2 Event No.: 6 Page 6 of 9

Event Description: RCP #1 seal #1 failure (5.2 gpm)

Malfunction: RP06A @ ramp slowly @ 15% (watch indication)

Cue: Duty Manager instructs USS to shutdown unit in next 30 minutes and secure RCP #1 when contacted by USS about problem. Load Dispatcher will be notified by duty manager

Time	Position	Applicant's Actions or Behavior
	RO	 <u>Seal Failure:</u> Diagnose RCP seal failure (Controlled leakage hi/lo flow alarm) SOP 13003-1 RCP operation with seal abnomality Use figures 1&2 to determine RCP must be stopped in 8 hours
		 <u>18013-C Actions:</u> Insert Control control rods/borate as necessary Energize all Pressurizer Heaters Tave/Tref within 3 degrees Maintain Reactor Power and Turbine Power matched Maintain Pressurizer Level & pressure in normal control band
	BOP	 Reduce turbine load Maintain S/G in normal control band
	SRO	 <u>Seal Failure:</u> Using 13003-1 confirm decision tree Seal injection > 8 gpm & <130 deg F Seal leakoff outside normal ops band (figure 2) Seal leakoff <5.5 gpm & above min required Shutdown RCP w/i 8 hours
		 <u>18013-C Actions:</u> Enters 18013-C for rapid down power Notify chemistry >15% power change in 1 hour

Appendix D

Form ES-D-2

Op-Test No.: <u>1</u> Scenario No.: <u>2</u> Event No.: <u>6</u> Page <u>6</u> of <u>9</u>			
Event De	Event Description: <i>RCP seal LOCA (300 gpm)</i>		
Malfunction: (1) RP06A 100% "RCP #1 seal failure" (2) RC05A @ 1.5% "Hot Leg Break at 450 GPM" (3) MS01 @ 100% " Steam Dump Valve 1PV-507C fails fully open"			
Time	Position	Applicant's Actions or Behavior	
	RO/BOP	 Diagnose leak increasing Increases charging flow to maintain PZR level Manually trips reactor Manual SI <u>Actions:</u> (19000-C) Verify Rx Trip (RO) Verify turbine trip. (BOP) Verify power to AC emergency busses.(BOP) Check if SI Actuated. (RO) Verify Feedwater isolation. (BOP) Verify MLB indications ECCS equipment aligning for injection phase. (RO) Verify AFW Pumps running. (BOP) SG blowdown isolated (BOP) TDAFW pump running. (BOP) Verify ECCS pumps running: CCP, SI, RHR. (Manually starts SI Pump "A") (RO) Verify 2 CCW pumps running on each Train. (RO) Verify containment ventilation isolation (CVI). (RO) Check if MSIV should be isolated (RO/BOP) Check containment spray not required. (RO) Verify ECCS flows. (RO) Verify ECCS alignment on MLBs. (RO) Verify RCS temperatures. (Should find 1PV-507C failed open and actuate MSLI)(RO/BOP) 	

Op-Test	Op-Test No.: <u>1</u> Scenario No.: <u>2</u> Event No.: <u>6</u> Page <u>6</u> of <u>9</u>				
Event De	Event Description: RCP seal LOCA (300 gpm)				
Malfunction: (1) RP06A 100% "RCP #1 seal failure" (2) RC05A @ 1.5% "Hot Leg Break at 450 GPM" (3) MS01 @ 100% " Steam Dump Valve 1PV-507C fails fully open"					
Time	Position	Applicant's Actions or Behavior			
	SRO	 Directs RO to maintain PZR level Directs RO to manually trip reactor and intiate manual SI Enters 19000-C, Reactor trip/SI Insures all immediate actions are performed per 19000-C. Directs operator actions per the 19000-C direction. Ensures proper communication between crewmembers. Diagnose Primary LOCA Enter 19010-C, Response to LOCA Transistion to 19012-C Post LOCA cooldown/depressurization 			

	······································	Scenario Outline	Form ES
Facility:	VOGTLE	Scenario No.: 3	Op-Test No.: _1
Examiners:		Operators:	
Initial Cond conditions.	l <u>itions:</u> The plant is Shutdown in progr	s at 95%. RCS boron concentration require	is at 1194 ppm, BOL ment.
Shint Turno	ver:		
1Pl	ant Shutdown is in	progress.	
2R	x power is 95%.		
3Tr fc d	ain "A" MDAFW Po or 48 hours and not ue to parts unavail	ump is OOS due to mechanical seal t expected to return to service within ability, LCO has been written.	failure. It has been OO the remaining LCO time
4Al p H tr tr	so affecting AFW i ressure side of 1-1 leader from S/G #1 ne TDAFW Pump f ne valve. The man hut to allow mainte	is a severe packing leak tahe has oc 301-U4-051, a chemical cleaning iso I to the TDAFW Pump. As a result, from S/G #1 is tagged shut and powe ual upstream isolation valve, 1- 1304 enace to repack the valve.	curred on the high blation valve on the Stea 1HV-3009, steam supply er has been removed fro 4-U4-005 ,is also tagged
5A	s a result of this wo 7.5 Condition "C" c	ork, Unit 1 is in a 6 hour shutdown re due to 2 inoperable AFW Trains.	quirement per Tech. Sp
6A	ir Compressor #2 i:	s tagged out for moter replacement.	
7P	lant Management h	nas directed Unit 1 be in Mode 3 with	nin the next 3.5 hours.
8T	he System Operato	or has been notified of the pending p	ower reduction.
9T p	he SS has directed er chimistry depart	I you to have the RO increase CVCS tment request.	letdown flow to 120 GF
10T g o	he last shift entered enerator #1. All a f the radiation mon	d AOP 18009-C due to a 20 GPD tul ctions of Section "B" have been con hitors which still need to be reset.	be leak on Steam npleted with the exception

Event No.	Malf. No.	Event Type*	Event Description
1		RO-N	Increase CVCS letdown flow to 120 GPM per chemistry request (SS direction during shift turnover)
2		RO-R	Decrease power to Mode 3
3	OR	BOP-C	Air Compressor #1 Trips
4	CV13 CV01	RO-C	VCT level transmitter 1LT-112 fails low, with auto M/U failure
5	FW02b 0%	BOP-I	Controlling feedwater flow channel fails low on S/G #2 (1FT-520)
6	PR02a 100%	RO-I	Controlling Pressurizer pressure channel fails high (1Pl 455)
7	SG01a 50%	ALL-M	500 GPM S/G #1 tube rupture

,

PREINSERTS:

Initial Conditions:

- _____ Reset to IC #15 (Snap for NRC #3) Snap #_____
- Insure Information Board in Control Room is updated
- _____ Shift sign in and reactivity breifing sheets provided
- RO & BOP Name plates on Panel D
- Check EOP's, AOP's, UOP's, SOP's used in the last scenario clear of red marks
- _____ IPC is Mode 1
- _____ Check Control Rod Group Step Counters
- Unit 2 suppling the Aux Steam Header

Select to following QMCB positions:

- All Controlling channels selected to channel #1
- ______ Align plant for operation with minor S/G tube leak per AOP-18009-C section "B"
- Ensure all QPCP and QHVC recorders running in auto
- Place Clearance Tag on AFW Train "A" Pump (PTL Position) (Use Panel Drawings to override the Pump to stop)
- Place Clearance Tag on AFW Train "A" Discharge valves: Place in local control and override valves shut (Remote Function for AFW)
- Place Clearance Tag on Air Compressor #2 (Stop position)
 Panel Drawing-AL-NSW-HS9383-stop(Also turn off RED/AMBER/GREEN light indication for A/C #2.
- Place Clearance Tag on TDAFW Pump steam supply isolation Valve 1HV-3009

Insert simulator Malfunctions:

- (Malfunction SG01e at 20%) 20 GPD tube leak on Steam Generator #1
 malfunction
- (ES01) Failure of the Automatic Reactor Trip
- (CV01) VCT automatic makeup failure
- (AF05B) MDAFW Pump "B" fails to automatically start

Simulator Overrides & Remote Functions:

- Reactor Trip Handswitch on "C" to CLOSE position
 Panel Drawings-C-NIM-HS40007-CLOSE
- Air Compressor #4 Handswitch to Stop
 Panel Drawings-A1-NSW-HS9381-STOP
- Override 1HV-3009 shut and remove light inditcation
 Panel Drawings-B1-AFW-HS3009-CLOSE (Use Panel Drawings to turn off
 RED & GREEN light indication)
- Override Train "A" AFW Pump to off position and remove power from
 Handswitch light for Clearance
- Override discharge Valves for Train "A" AFW Pump to shut position Remote Function (AF20, AF18 in LOCAL ; AF19, AF21 to 0%) Panel Drawings-A2-ALB04-F03-OFF (F04-OFF)
- ALB50 (CR HI/LO △P)
 Panel Drawings-HV1-ALB50-CR Hi/Lo Diff Press-OFF
- ALB20 (Turbine/Gen Trouble)
 Panel Drawings-B2-ALB20-E01-OFF
- ALB62 (Gen Gas Non Sys Alarm)
 Panel Drawings-QPLP2-ALB62-F02-OFF

Op-Test Event D	No.: <u>1</u> escription:	Scenario No.: <u>3</u> Event No.: <u>1</u> Page <u>3</u> of <u>9</u> Increase CVCS letdown flow to 120 GPM
Time	Position	Applicant's Actions or Behavior
	RO-N	 <u>Actions:</u> SOP-13006-1 Section 4.2.4 Raise charging flow to between 120-130 GPM Main RCP seal injection flow between 8-13 GPM Place 1-PIC-0131 in manual and lower pressure between 100-120 psig Open 45 GPM orifice valve Adjust 1-PTC-0131 to between 360-380 psig Return system to automatic

Op-Test Event De	Op-Test No.: 1 Scenario No.: 3 Event No.: 2 Page 3 of 9 Event Description: Decrease Reactor Power (Mode 3 in 3.5 hours)				
Time	Position	Applicant's Actions or Behavior			
	SRO	 <u>Actions:</u> Gives crew briefing on the power decrease Directs Operators to increase power (Mode3 in 3.5 hours) Refers to UOP 12004-C, Power Operation 			
	RO	Actions: • Commences boration • Maintains rods above insertion limits • Maintains Tave within 2 deg Tref • Maintains AFD within target band			
	BOP	Actions: Loads Turbine per SOP. 			

Op-Test No.: <u>1</u> Scenario No.: <u>3</u> Event No.: <u>3</u> Page <u>3</u> of <u>9</u>					
Event De	Event Description: Air Compressor #1 Trips (Air Compressor #4 fails to automatically start)				
Malfunction/Override: Trigger the following: 1. Panel Drawings-A1-NSW-HS19338-STOP 2. Panel Drawings-A1-NSW-A/C #1 RED light OFF 3. Panel Drawings-A1-NSW-A/C #1 GREEN light ON 4. Panel Drawings-A1-NSW-A/C #1 AMBER light ON 5. Panel Drawings-??????????for alarm on 1NB03					
Time	Position	Applicant's Actions or Behavior			
	SRO	Actions: • Enters AOP-18028-C Secton "A" • Directs RO to Start Air Compressor #4 • Dispatch Operator & Maintenance to investigate • Have SSS write Work Order and make notifications			
	BOP	Actions: • Trend air pressure on IPC • Starts Air Compressor #4 • Dispatch Operator to investigate problem			

Op-Test	No.: <u>1</u>	Scenario No.: <u>3</u> Event No.: <u>4</u> Page <u>3</u> of <u>9</u>
Event Description:		VCT Level transmitter 1LT-112 fails low (Automatic VCT makeup should have initiated with this problem however to function will not operate. The RO should identify this problem and inform the USS.
Malfunct	ion: Chec	k (CV01) active then insert (CV13)
Time	Position	Applicant's Actions or Behavior
	SRO	 <u>Actions:</u> Enters AOP-18007-C Secton "C" Dispatch Operator & Maintenance to investigate Have SSS write Work Orders for 1LT-112 & Automatic makeup failures, and make notifications Provide direction to RO (BOP) on VCT status during briefing
	RO	 <u>Actions:</u> Identify that 1LT-112 failure Verify VCT level using alternate indication (IPC) Identify that automatic makup should have been initiated by the failure. Determine that manual VCT makeup will be required until system is repaired.

Op-Test No.: 1 Scenario No.: 3 Event No.: 5 Page 3 of 9 Event Description: Controlling Feedwater Flow channel fails low on S/G #2 (1FT-520) Malfunction: FW02b at 0% Time Position Applicant's Actions or Behavior SRO Actions: • Enters AOP-18001-C Section "G" Directs BOP to control S/G #2 flow in manual • Have SSS notify Maintenance to investigate Have SSS write Work Order and make notifications • BOP Actions: Determine failure of 1LT-520 (controlling channel) • Immediate actions: Take manual control of S/G #2 MFRV and MFP control level ٠ between 60-70% Select non affected controlling channel ٠ Return system to automatic •

Op-Test No.: 1 Scenario No.: 3 Event No.: 6 Page 3 of 9 Event Description: Controlling Pressurizer pressure channel fails high. Malfunction: PR02a at 100%				
Time	Time Position Applicant's Actions or Behavior			
	SRO	Actions: Enters 18001-C section "C" Notifies duty manager of AOP entry Contacts maintenance to initiate repairs Refers to Tech Specs: • LCO 3.3.1 Functional Unit 6 - Condition E Functional Unit 8a - Condition M Functional Unit 8b - Condition E • LCO 3.3.2 Functional Unit 1d - Condition D Functional Unit 8b - Condition L • LCO 3.4.11 Condition B • Request SSS to remove power from 1HV-8000A		
	RO	 <u>Actions:</u> Immediate actions: Close Spray valves Close PORV-455A Energize PZR Heaters Master Controller placed in manual @ 25% Select 457/456 for control Return heaters, spray valves, and PORV, master controller to AUTO Select unaffected channel for panel recorder Verify P-11 in proper state for plant condtions (1 hr LCO action) 		

Op-Test No.: 1 Scenario No.: 3 Event No.: 7 Page 3 of 9 Event Description: 500 GPM Tube Rupture On S/G #1 Molfunction: SC01a @ 50%				
Time	Position	Applicant's Actions or Behavior		
	SRO	 Actions: Identifies from indications of high radiation on secondary and lowering Pressurizer level & Pressure that a S/G tube rupture is in progress Directs operator actions to maintain Pressurizer level & pressure Directs operator the manually trip the Unit One Reactor due to the decreasing Pressurizer Level & pressure Enters 19000-C. Insures all immediate actions are performed per 19000-C. Directs operator actions per the 19000-C direction. Ensures proper communication between crewmembers. Transitions to 19030-C due to secondary High Radiation OR uncontrolled level rise on S/G #1. Directs the isolation of S/G #1 per 19030-C Directs the maximum rate cooldown per 19030-C 		
	RO/BOP	 <u>Actions:</u> (19000-C) Identifies from indications of high radiation on secondary and lowering Pressurizer level & Pressure that a S/G tube rupture is in progress Increases Charging (start additional charging pump if time permits) to maintain Pressurizer level and pressure. Actuates manual Reactor Trip (NOTE: QMCB panel "C" Handswitch will not function and the RO will be required to us Panel "A" Handswitch) (RO) Verify Rx Trip (RO) Verify power to AC emergency busses. (BOP) Check if SI Actuated. (RO) Verify Feedwater isolation. (BOP) Verify MLB indications for both trains of ECCS equipment aligning for injection phase. (RO) Verify containment isolation Phase A actuated. (RO) MDAFW Pumps running. (NOTE: operator must manually start MDAFW Pump "B") (BOP) SG blowdown isolated (BOP) 		

Op-Test No.: 1 Scenario No.: 3 Event No.: 7 Page 3 of 9 Event Description: 500 GPM Tube Rupture On S/G #1 Malfunction: SG01a @ 50% Time Position Applicant's Actions or Behavior TDAFW pump running. (BOP) ٠ Verify ECCS pumps running: CCPs, SI, RHR. (RO) ٠ Verify 2 CCW pumps running on each train. (RO) ٠ Verify 2 NSCW pumps running on each train. (RO) • Verify containment ventilation isolation (CVI). (RO) • Check if MSLIVs should be isolated. (RO/BOP) . Check containment spray not required. (RO) • Verify DG running. (BOP) • Verify ECCS flows. (RO) • Verify total AFW flow greater than 570 GPM. (BOP) ٠ Verify ECCS alignment on MLBs. (RO) • Verify RCS temperatures. (RO/BOP) • Identify ruptured S/G on uncontrolled level rise or secondary high • radiation (BOP) Isolates all flow to S/G #1 when identified and level is >10% NR • (BOP) Isolates S/G #1 per USS direction in 19030-C • Performs maximum rate cooldown of S/G #1 to target Core exit . temperature

Appendix D		Scenario Outline		Form ES-D-1
Facility:	VOGTLE	Scenario No.:	4	Op-Test No.: <u>1</u>
Examiners:		Operators:		
Initial Cond conditions.	<u>itions:</u> The plant is al B Train equipment in	t 95%. RCS boron con service.	centration is	at 1308 ppm, BOL
<u>Turnover:</u>				
1Pla	ant Startup is in progr	ess.		
2R>	cpower is 95%.			
31F	V-0456 is in the shut	position due to seat lea	akage.	
41⊦	IV-8000B is shut to c	omply with Technical S	pecification	3.4.11 Condition "A".
5 E ra	CCS Accumulator #2 ise the accumulator	level is low due to a mi level per SOP-13105-C	nor leak. A	fter assuming the shift
6Tr ge o	ne last shift entered A enerator #1. All action f the radiation monito	OP 18009-C due to a 2 ons of Section "B" have ors which still need to be	0 GPD tube been comp e reset.	e leak on Steam Deted with the exception
7 lr T cł	addition a tornado al here are heavy thund hecklist has been con	lert has been issued for erstorms occuring at th npleted in the last hour.	r Burke and is time. The	Richmond Counties. e severe weather
	,,,			

.

Event No.	Malf. No.	Event Type*	Event Description	
1		RO-N	Raise #2 accumulator level	
2		RO-R	Increase power to 98%	
3	CV12	RO-I	VCT level transmitter 1LT-185 fails high	
4	RC10c 100%	RO-I	Loop #3 NR Tavg fails high (TE-431B)	
5	SG02h 100%	BOP-C	Controlling S/G #4 level transmitter (1LT-549) fails high	
6	MS03b 100%	BOP-C	ARV #2 (1PV-3010) fails open due to controlling pressure transmitter failure	
7	GE01 EL02, 03 EL01a 15Sec/ TD MS04c 100% SY01A, B, D, E, G, H, J, K, M	M-ALL	 Loss of offsite power DG 1B trips after starting Faulted S/G #3 (IRC) 	
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor, (P)RA, (L)ow Power				

PREINSERTS:

Initial Conditions:

- _____ Reset to IC #__ (NRC #4 snap)
- Insure Information Board in Control Room is updated
- Shift sign in and reactivity breifing sheets provided
- BO & BOP Name plates on Panel D
- Check EOP's, AOP's, UOP's, SOP's used in the last scenario clear of red
 marks
- IPC is Mode 1
- Check Control Rod Group Step Counters
- Unit 2 suppling the Aux Steam Header

Select to following QMCB positions:

- _____ 1PV-0456 in shut position with "Caution Tag"
- 1HV-8000B in shut position with "<u>Caution Tag</u>"
- All Controlling channels selected to channel #1
- _____ All Train "B" Equipment Running
- Align plant for operation with minor S/G tube leak per AOP-18009-C section "B"
- Ensure all QPCP and QHVC recorders running in auto

Insert simulator malfunctions:

- (Malfunction SG01e at 20%) 20 GPD tube leak on Steam Generator #1
- _____ SI02B at 100% until low level is received for accumulator #2 alarm then remove malfunction

Simulator Overrides & Remote Functions:

- ALB50 (CR HI/LO △P)
 Panel Drawings-HV1-ALB50-CR Hi/Lo Diff Press-OFF
- ALB20 (Turbine/Gen Trouble)
 Panel Drawings-B2-ALB20-E01-OFF
- _____ ALB62 (Gen Gas Non Sys Alarm)
 Panel Drawings-QPLP2-ALB62-F02-OFF

Op-Test No.: 1 Scenario No.: 4 Event No.: 1 Page 3 of 9 Event Description: Raise #3 ECCS accumulator Level					
Time	Position	Applicant's Actions or Behavior			
	RO	Actions: SOP 13105-1 Secton 4.2.1 selected: Check miniflow path for SI pump aligned Start SI pump Open 1HV-8888 Open 1HV-8871 Open 1HV-8878B Monitor Accum #2 level When desired level is reached close valves			

Op-Test Event De	Op-Test No.: <u>1</u> Scenario No.: <u>4</u> Event No.: <u>2</u> Page <u>3</u> of <u>9</u> Event Description: Increase Reactor Power to 98%				
Time	Position	Applicant's Actions or Behavior			
	SRO	 <u>Actions:</u> Gives crew briefing on the power increase Directs Operators to increase power to 98% Refers to UOP 12004-C, Power Operation 			
	RO	Actions: • Commences dilution • Maintains rods above insertion limits • Maintains Tave within 2 deg Tref • Maintains AFD within target band			
	BOP	Actions: Loads Turbine per SOP. 			

٠.

Event D	escription:	VCT level transmitter 1LT-185 fails high. Result in letdown how being diverted to the RHUT. VCT level will lower to the automatic makeup setpoint of 30% if not noticed be the operators.			
Malfunction: CV12					
Time	Position	Applicant's Actions or Behavior			
	SRO	 <u>Actions:</u> Directs operator to place 1-LV-0112A to the VCT position Directs operator to Monitor VCT level using 1-LT-0112 (IPC) Alerts operator that the automatic swap-over on low VCT level is functional. Caution the operators of the possible loss of suction to the CCP'. Have Maintenance Work order written. 			
	RO	 <u>Actions:</u> Identify failed VCT level channel (1-LT-185) Trend 1-LT-115 on the IPC computer. Place 1-LV-0112A to the VCT position. Be aware of the possible loss of suction potential to the CCP's. 			

Op-Test No.: <u>1</u> Scenario No.: <u>4</u> Event No.: <u>4</u> Page <u>3</u> of <u>9</u> Event Description: Loop #3 NR temperature instrument fails high. Control rods would move in if controls were in automatic, however with power ramp in progress they should be in manual control.							
Time	Position	Applicant's Actions or Behavior					
	SRO	 <u>Actions:</u> Enters AOP 18001-C Secton "B" Has operator place rod control in manual (should be there) Have operator verify Tavg is on program Defeat failed channel Notify Operations duty manager. Have Maintenance Work order written. Refer to Technical Specifications. 3.3.1 Function 6 Condition E 3.3.1 Function 7 Condition E 3.3.2 Function 5b Condition I 					
	RO	 <u>Actions:</u> Identify the failed channel is Loop #3 Insure control rods in manual control (immediate action) Adjust Tavg to Tref if required Place Tavg defeat switches (1TS-412T & 1TS-411F) to Loop #3 position 					

Op-Test No.: 1 Scenario No.: 4 Event No.: 5 Page 3 of 9 Event Description: Controlling S/G #4 level transmitter (1LT-549) fails high. Results in the Loop #4 MFRV going in the shut direction to lower feedwater flow. Malfunction: SG02D @ 100%					
Time	Position	Applicant's Actions or Behavior			
	SRO	 Actions: Enters AOP 18001-C Secton "E" Has operator control S/G #4 MFRV in manual to restore level between 60-70% Have operator select unaffected controlling channel Directs operator to restore system to automatic when conditions have stablized. Notify Operations duty manager. Have Maintenance Work order written. Refer to Technical Specifications. 3.3.1 Function 13 Condition E 3.3.2 Function 5c Condition I 3.3.3 Info LCO 			
	BOP	 <u>Actions:</u> Identify the failed channel is Loop #4 (1LT-549) Place MFRV on Loop #4 in manual control and control level between 60-70% Select an unaffected controlling channel Restore system to automatic when conditions allow 			

.....

Op-Test No.: 1 Scenario No.: 4 Event No.: 6 Page 3 of 9 Event Description: ARV on Loop #2 (1PV-3010) fails open due to controlling transmitter failing high. The operate should identify the condition when the alarm is received on high tailpipe temperature and Reactor Power is observed to be increasing with Main Turbine Load lowering. Malfunction: MS03b @ 100% Applicant's Actions or Behavior Position Time SRO Actions: May enters AOP 18008-C for secondary leakage Alert operator keep Reactor Power below 100% by all indications • Directs operator that manually shut 1PV-3010 (using 1PIC-3110) • Notify Operations duty manager. • Have Maintenance Work order written. • Refer to Technical Specifications. • 3.3.4 (Info only) 3.3.4 (info only) ٠ Actions: BOP Identify the failed open ARV on Loop #2 Keep Reactor Power below 100% by all indications Place 1PIC-3010 in manual control and lower output to 0%, closing • the ARV
Op-Test No.: <u>1</u> Scenario No.: <u>4</u> Event No.: <u>7</u> Page <u>3</u> of <u>9</u>		
Event Description:		Loss of offsite power, Reactor will automatically trip, D/G 1A will trip during load sequencing followed by a major secondary fault in Containment on S/G #3.
Malfunction: List::		
		 GE01 (Mian Generator Trip) EL02, EL03 (Loss of RAT's) (SY01A,B,D,E,G,H,J,K,M) (PCB's tripping in the high voltage switchyard) MS04c @ 100% (S/G #3 faulted IRC) EL01A @ 15 second time delay (D/G 1A Trip on OS)
Time	Position	Applicant's Actions or Behavior
	SRO	 <u>Actions:</u> Identifies Automatic Reactor Trip Enters 19000-C Reconizes the loss of 1BA03 Insures all immediate actions are performed per 19000-C. Directs operator actions per the 19000-C direction. Ensures proper communication between crewmembers. Transitions to 19020-C due to S/G #3 low pressure Directs the operator in isolating S/G #3 in 19020-C Transitions to either 19001-C or 19010-C depending on conditions at the time When time permits should dispatch personnel to 1BA03 and switchyard.
	RO/BOP	 <u>Actions:</u> (19000-C) Verify Rx Trip (RO) Verify turbine trip. (BOP) Verify power to AC emergency busses. (alert the operating crew on the loss of power to 1BA03)(BOP) Check if SI Actuated. (RO) Verify Feedwater isolation. (BOP) Verify MLB indications "A" Train ECCS equipment aligning for injection phase. (RO) Verify containment isolation Phase A actuated. (RO) Train "A" MDAFW Pump running. (BOP) SG blowdown isolated (BOP) TDAFW pump running. (BOP)

Op-Test No.: <u>1</u>		Scenario No.: <u>4</u> Event No.: <u>7</u> Page <u>3</u> of <u>9</u>
Event Description:		Loss of offsite power, Reactor will automatically trip, D/G 1A will trip during load sequencing followed by a major secondary fault in Containment on S/G #3.
Malfunction: List::		
		 GE01 (Mian Generator Trip) EL02, EL03 (Loss of RAT's) (SY01A,B,D,E,G,H,J,K,M) (PCB's tripping in the high voltage switchyard) MS04c @ 100% (S/G #3 faulted IRC) EL01A @ 15 second time delay (D/G 1A Trip on OS)
Time	Position	Applicant's Actions or Behavior
		 Verify ECCS pumps running: CCP, SI, RHR. (RO) Verify 2 CCW pumps running on "A" Train. (RO) Verify 2 NSCW pumps running on."A" Train. (RO) Verify containment ventilation isolation (CVI). (RO) Check if MSLIVs should be isolated. (BOP should recognize that S/G #3 is faulted and isolate all AFW flow to that S/G) (RO/BOP) Check containment spray not required. (RO) Verify DG Train "A" running. (BOP) Verify ECCS flows. (RO) Verify total AFW flow greater than 570 GPM. (BOP) Verify ECCS alignment on (Train "A") MLBs. (RO) Verify RCS temperatures. (RO/BOP) Isolate S/G #3 in 19020-C per USS direction (BOP)