

NOVEMBER 26, & DECEMBER 2 - 13, 2002

- 1. Administrative Questions/JPMs
- 2. In-plant JPMs
- 3. Control Room JPMs (simulator JPMs)
- 4. Administrative Topics Outline ES-301-1
- Control Room Systems and Facility Walk-Through Test Outline ES-301-2

5,

ES-301

and the second second

Administrative Topics Outline

Form ES-301-1 (R8, S1)

Facilit Exami	y: <u>Vogtle</u> nation Level (circle	one): RO	Date of Examination: <u>12/02/02</u> Operating Test Number: <u>DRAFT</u>		
ے ۲	dministrative opic/Subject Description	Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions			
A.1	CONDUCT OF OPERATIONS	Calculate QPTR (LO-JP-14915-001)			
	CONDUCT OF OPERATIONS	Calculate Boron neede	ed for Stuck Rod		
A.2	EQUIPMENT CONTROL	Review Tagout for ma	ntenance		
A.3	RADIATION CONTROL	Given a Survey Map, (Emergency	Calculate Stay Time for Entry in an		
A.4	EMERGENCY PLAN	Make Emergency Noti (RQ-JP-91002-002)	ications with Failure of the ENN		

ES-301

Administrative Topics Outline

Form ES-301-1 (R8, S1)

Facility Examin	Facility: Vogtle Date of Examination: 12/02/02 Examination Level (circle one): ISRO/ USRO Operating Test Number: DRAFT					
Administrative Topic/Subject Description		Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Questions				
A.1	CONDUCT OF OPERATIONS	Calculate Shutdown Margin				
	CONDUCT OF OPERATIONS	Calculate Boron needed for Stuck Rod				
A.2	EQUIPMENT CONTROL	Review Tagout for Maintenance				
A.3 RADIATION CONTROL		Question Topic - License Requirements for Conducting a Waste Release with Inoperable Instrumentation and Administrative Controls Ensuring Requirements Met. Question Topic - Selection Process for Individuals Performing Emergency Entries into Radiation Fields Resulting in Exceeding Permissible Exposure Limits.				
A.4	EMERGENCY PLAN	Perform an Emergency Action Level Classification and Recommend Protective Actions				



This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	The unit is at 100% power.
Assigned Task:	The USS has directed you to "Perform a QPTR Calculation using 14915, Special Conditions Surveillance Logs."

Task Standard: Quadrant Power Tilt Ratio calculated.

JPM INFORMATION

5									
	OPERATOR'S NAME:								
	EVALUATION DATE:	//							
	JPM TITLE:	Calculate Quad	rant Pov	ver Tilt	Ratio				
	REVISION:	1 <u>2</u> March-₹	3, 1998 ⊆	October	10, 2000	<u>)</u>			
	COMPLETION TIME:	8 minutes <i>This JPM</i>	is to be	used f	or Initial	Licens	e Exam Only		
	Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 17007 015000A104	RO:	3.5	SRO:	3.7			
I									
	Evaluation Method	[] Performed		[] Si	mulated		····		
	Evaluation Location	[] Simulator		[] Co	ontrol Ro	om	[] Unit 1	[] Unit 2	
/	Performance Time:	minutes							
	OVERALL JPM EVAL	UATION	[] SA	TISFA	CTORY		[] UNSATIS	FACTORY	
	Examiner Comments:								
	Examiner's Signature:								

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 14915-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to examinee during performance of this JPM. This JPM provides data for two different conclusions (QPTR> or< 1.02).

- 1. 14915, Special Conditions Surveillance Logs
 - 2. Plant Technical Data Book
- SIMULATOR SETUP:

REQUIRED ITEMS:

Reset to IC19 Freeze simulator

The simulator should remain in FREEZE during the performance of this JPM.

Setup time: 3 minutes

This JPM is based on Unit 1 Cycle 8<u>Current Cycle</u>. The Unit 1 PTDB Normalization Factors should be used to calculate the QPTR. To ensure examination consistency, once the examinee demonstrates the ability to determine detector current output, the attachment provided should be used to calculate the QPTR.

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: The unit is at 100% power.

1.

2.

Assigned Task: The USS has directed you to "Perform a QPTR Calculation using 14915, Special Conditions Surveillance Logs."

TASK STANDARD: Quadrant Power Tilt Ratio calculated.

JPM STEPS

START TIME:

;

STEP 1	
CRITICA	AL (+)
SAT 🗆.	le UNSAT ⊡e
F ^	Record Detector Current Values Note: The examiner must review the "Instructions to Examiner" section on page 4 of this JPM prior to administration. The examinee must demonstrate the ability to determine detector current output in order to consider this step SAT.
240	Upper detector currents recorded
80 4	Lower detector currents recorded
STEP 2 CRITICA SAT	AL (♦) ໄຮ UNSAT ⊡ຮ
۲ ۲	Determine QPTR Note: If this JPM is being PERFORMED, ensure the Unit 1 PTDB Normalization Factors are used. The attachment should be provided to the examinee for performance of this step.
• D.«	 Upper detector currents normalized (see note above)
80 •	 Average upper detector current calculated
80 4	 Upper detector QPTR determined to be < 1.02
80.	 Lower detector currents normalized (see note above)
<u>⊳</u> □•	 Average lower detector current calculated
80 4	 Lower detector QPTR determined to be > 1.02
L	
STEP 3 SAT	IS UNSAT DS
F	Report to USS
80.	Lower detector QPTR is > 1.02
STOP TI	ME:

Field Notes

NI C	hannel	Detector	Current	
	N41	А	424 mA	
	N42	Α	380 mA	.) 0
	N43	Α	450 mA	NEwmbers
	N44	А	415 mA	P.
<u>.</u>	N41	В	445 mA	
	N42	В	414 mA	
	N43	В	463 mA	
	N44	В	435 mA	

, **`**

.



Energy to Serve Your World"

PLANT VOGTLE

NRC-JP-19001

Calculate Boron Addition Following Reactor Trip With 3 Stuck Control Rods

> October 04,2002 Rev #0

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions: Given the Following Conditions/Events on Unit 1:
 Automatic Reactor Trip due to Main Turbine Trip EOL RCS Boron Concentration is at 200 ppm BAST Boron Concentration is 7100 ppm RCS is at 2235 psig and 557 degrees F.
On step 1 of 19000-C the following conditions are observed:
 Reactor Trip Breakers are open Power Range NI's indicate 0%
 DRPI indicates that 3 rod failed to fully insert
 The RO actuates both the QMCB Reactor Trip Handswitches and announces the Reactor Tripped
 The Operating Crew has entered 19001-C to stablize the plant
 On Step 3 on 19001-C the USS checks all "FULLY INSERTED"
Assigned Task: How many gallons of boric acid must be added to the RCS under the stated conditions?

Task Standard: Boron addition Calculated.

	<u> </u>					
OPERATOR'S NAME:						
EVALUATION DATE: _	//					
JPM TITLE Calculate Boron Addition Following Reactor Trip With 3 Stuck Control Rods						
REVISION: 0	Date: October 0	4, 2002				
COMPLETION TIME: 15	i minutes					
Application: R	o					
Evaluation Method	[] Perform	ed	[] S	imulated		
Evaluation Location	[] Simulate	or	[] Control Room	[] Unit 1	[] Unit 2	
Performance Time:	minutes					
OVERALL JPM EVALUA	TION	[] \$	ATISFACTORY	[] UNSATI	SFACTORY	
Examiner Comments:						
Examinar'a Signatura						
LAIniner & Signature.						

INSTRUCTIONS TO EXAMINER

This JPM is based on latest revision of 19001-C. If this revision is no longer current, verify this JPM is in accord with the latest procedural revision. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable.

REQUIRED ITEMS:

- 1. Calculator
- 2. PTDB (Plant Technical Data Book)
- 3. 19001-C

Direction To Operator:

Initial Conditions: Given the Following Conditions/Events on Unit 1:

Automatic Reactor Trip due to Main Turbine Trip

- EOL
- RCS Boron Concentration is at 200 ppm
- BAST Boron Concentration is 7100 ppm
- RCS is at 2235 psig and 557 degrees F.

On step 1 of 19000-C the following conditions are observed:

- Reactor Trip Breakers are open
- Power Range NI's indicate 0%
- DRPI indicates that 3 rod failed to fully insert
- The RO actuates both the QMCB Reactor Trip Handswitches and announces the Reactor Tripped
- The Operating Crew has entered 19001-C to stablize the plant
- On Step 3 on 19001-C the USS checks all "FULLY INSERTED"

Assigned Task: How many gallons of boric acid must be added to the RCS under the stated conditions?

Task Standard: Boron addition Calculated.

STEP	1	
CRITI		
SAT	⊡≤ UNSAT ⊡≤	
Boro	n Addition to the RCS calculated	
20	◆ 4252 (+ or – 50) gallons of boric acid added to the RCS	

STOP TIME: ______

Field Notes

Calculation:

`~___

. المسينية الم (154 ppm) X (3 Rods) = 462 ppm

RCS Boron Concentration = 61346 X Ln (7100 - 200 / 7100 - 662) = 4252 gallons of Boric Acid



This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:

- Unit 1 is at 100% Reactor Power on 10/04/02
- A planned outage for Containment Spray Pump Train "A" to replace the pump seals is to be installed on 10/05/02
- The scope of the work requires that the motor be electrically isolated and the pump drained.
- NSCW cooling water to the pump is NOT required to be tagged as part of the boundary
- The LCO has been written and will be entered when the clearance is authorized by the USS

Assigned Task: Verify clearance hold points for Containment Spray Pump Train "A" are correct.

OPERATOR'S NAME:								
EVALUATION DATE://								
JPM TITLE: Review Clearance for Containment Spray Pump Train "A" REVISION: 0 Date: October 04, 2002 COMPLETION TIME: 30 minutes								
Application: RO/SRC)							
Evaluation Method [] Performed [] Si	mulated						
Evaluation Location [] Simulator [] Control Room	[] Unit 1 [] Unit 2						
Performance Time:m	inutes							
OVERALL JPM EVALUATION	[] SATISFACTORY	[] UNSATISFACTORY						
Examiner Comments:								
Examiner's Signature:								

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest revision of 00304-C. If this revision is no longer current, verify this JPM is in accord with the latest procedural revision. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable.

REQUIRED ITEMS:

1. Current revision of 00304-C

Direction To Operator:

Initial Conditions:

- Unit 1 is at 100% Reactor Power on 10/04/02
- A planned outage for Containment Spray Pump Train "A" to replace the pump seals is to be installed on 10/05/02
- The scope of the work requires that the motor be electrically isolated and the pump drained.
- NSCW cooling water to the pump is NOT required to be tagged as part of the boundary
- The LCO has been written and will be entered when the clearance is authorized by the USS

Assigned Task: Verify clearance hold points for Containment Spray Pump Train "A" are correct.

START TIME: _____

STEP	1	<u></u>					
CRIT	'ICAL (+)						
SAT	SAT De UNSAT De						
Containment Spray Pump Train "A" clearance review							
20	➤□ ◆ Errors on clearance identified.						

STOP TIME: _____

Field Notes

.

CLEARANCE SHEET

. Clearance # 10210011		Equipment Number: 1-1206-P6-001	
Equipment Description: CONTAINM	ENT SPRAY PUMP TRAIN "	۵"	
Reason For Clearance (include WO N Replace pump seals (1-02-111)	ło.):		
	Additio	nal WOs:	
Requested by: Al Sweat	Extension: 3963		Beeper: 111

Requires LCO:	Locked Valves:		Fire P	rotection In s 🖾 No	paired:	IV Requ Yes	ilred:	
Prepared by: Al Sweat	Date:	10/04/02	Revie	wed by:			Date:	
Authorized by:			Date:			Time:		
Installed by:	· · · · · · · · · · · · · · · · · · ·		Date:		•	Time:		
Verified by:	····		Date:			Time:		
		SUBC	EARANCE	S		•		
NAME Printed in first space Signature in second space					GROUNE REMOVE RELEAS	DING DEVIC D AND SUE ED BY:	ES VERIFIE	D CE
PRINT AND SIGNATURE	WORK DOC	EXT.	DATE	TIME	SIGN	ATURE	DATE	TIME
1.								
2.								
3.								
4.								
5.				1				

COMMENTS:

NSCW cooling line not required to be tagged out for this work.

Front

Clearan	Clearance # 10210011 Prepared by:			L SWEAT					
EQUI 1-120	EQUIPMENT TO BE CLEARED AND TAGGED 1-1206-P6-001			TAGS TO BE REMOVED AND EQUIPMENT RETURNED TO SERVICE AS SPECIFIED					
TAG #	EQUIPMENT#	TAGGED POSITIO	INIT -	IV INIT	RESTORE	RESTORE POSITION	INIT		
01	1HS-10940	PTL							
Conta	ainment Spray Train "A" QMCB Control Han	dswitch							
02	1AA02-15	Disconne	ect						
Supp	Supply Breaker to Containment Spray Train "A" Pump								
03	2HS-9003A	CL/Norm	al					· · · · ·	
Pump	Discharge Isolation Motor Operated Valve	from Conta	ainment Su	mp					
04	1HS-9001A	CL/AUTO							
Pump	Discharge isolation Motor Operated Valve					·			
05	1HS-9017A	CL/Norm	al						
Pum;	Discharge Isolation Motor Operated Valve	from RWS	T						
06	1ABD-30	OFF							
1HS-	9003A feeder breaker								
07	1ABD-48	OFF							
1HS-90	01A feeder breaker								
08	1ABD-41	OFF							
1HS-	9017A feeder breaker								
09	1ABD30W-K2	OPEN							
Alarn	n relay								
10	1ABD48W-K2	OPEN							
Alarn	n Relay								
11	1ABD41W-K2	OPEN							
Alarn	n Relay								
12	1AYE1-34	OFF							
1-120	06-P6-001 Motor Space Heater								
13	1HV-9003A	Closed					<u> </u>		
Pum	p Discharge Isolation Motor Operated Valve	from Cont	ainment Su	mp Handw	heel	<u> </u>			

Clearan	ce # 10210011		Prepare	d by: Al	Sweat				
EQUI 1-120	PMENT TO BE CLEARED AND TAGGED 6-P6-001				TAGS TO TO SERVI	BE REMOVE CE AS SPEC	D AND EQUIP IFIED	MENT RE	TURNED
TAG #	EQUIPMENT #	TAC	GED	INIT	IV INIT	RESTORE	RESTORE	INIT	IV INIT
14	1HV-9001A	Clo	sed						
Pump	Discharge Isolation Motor Operated Valve	Hand	wheel						
15	1HV-9017A	Ĉlo	sed						
Pump	Discharge Isolation Motor Operated Valve f	rom	RWST H	iandwhe	el				
16	1-1206-U4-115	Clo	sed						
1HV-	9003A bypass line isolation valve					(1		
17	1-120 6 -U4-034	Clo	sed						
Spra	y eductor manual isolation valve (Normally L	ocke	d Close	d)					
18	1-1206-U4-109	Ор	en						
Cont	ainment Spray Train "A" Pump casing drain		·			·			,
19	1-1206-U4-112	Ор	en						
Cont	ainment Spray Train "A" Pump suction line c	drain							
20	1-1206-X4-108	Un Op	cap/ en						
Cont	ainment Spray Train "A" Pump Discharge lin	ne ve	nt			. <u></u>			
21	1-1206-U4-108	Uni Op	flange/ en						
Cont	ainment Spray Train "A" Pump casing vent					<u> </u>			
									<u> </u>
		<u> </u>	···	·r		. <u></u>	·		<u> </u>
	·	r <u> </u>		<u></u>		7	1	T	<u> </u>
						1	<u> </u>		
	I			<u></u>	1			1	
					. 1		l	1	
		<u> </u>		<u> </u>]	<u> </u>		
					<u> </u>	II	I		.l

Clearance #	Prepared by:
10210011	AI Sweat

TECH SPEC #	LCO #	SI #	
3.6.6	1-02-111		P&ID
01010			MECH
			ELEM
,			ELEC
<u>,</u>			CONN

ADDITIONAL WOS

1		
		1
	1	1

REFERENCES:

CLEARANCE REMOVAL:		· · · ·
Authorized by:	Date:	Time:
Removed by:	Date:	Time:
Verified by:	Date:	Time:

Extended Active Clearance Quarterly Audits:

DATE	INITIAL	DATE	INITIAL
	······		······································

DATE	INITIAL

DATE	INITIAL

٦

CLEARANCE SHEET

Clearance # 10210011	Equipment Nu 1-1206-P6-001	umber: 1
Equipment Description: CONTAINM	ENT SPRAY PUMP TRAIN "A"	
Reason For Clearance (Include WO N Replace pump seals	ło.):	
	Additional WOs:	
Requested by: Al Sweat	Extension: 3963	Beeper: 111

Requires LCO:	Locked Valves:		Fire Pi	rotection Im	palred:	IV Requ	aired:	
Prepared by:	Date:		Review	wed by:			Date:	
Authorized by:			Date:			Time:		
Installed by:			Date:			Time:		
Verified by:			Date:			Time:		
		SUBCI	EARANCES	<u> </u>	•			
NAME Printed in first space Signature in second space					GROUND REMOVE RELEASE	ING DEVIC D AND SUE D BY:	ES VERIFIE BCLEARAN	D CE
PRINT AND SIGNATURE	WORK DOC	EXT.	DATE	TIME	SIGN	ATURE	DATE	TIME
1.	-							
2								
3.						, <u>.</u>		
4.								
5.	1							

COMMENTS:

NSCW cooling line not required to be tagged out for this work.

Front

Clearan	ce # 10210011	Prepare	d by: AL	SWEAT				
EQUI	PMENT TO BE CLEARED AND TAGGED 6-P6-001	<u>+</u> _		TAGS TO TO SERVI	BE REMOVE	D AND EQUIP	MENT RE	TURNED
TAG #	EQUIPMENT #	TAGGED POSITION	INIT		RESTORE	RESTORE	INIT	IV INIT
01	1HS-10940	PTL						
Conta	ainment Spray Train "A" QMCB Control Han	iswitch						
02	1AA02-14)	Disconnect						
Supp	ly Breaker to Containment Spray Train "A" F	ump				· · · · · · · · · · · · · · · · · · ·		
03	1HS-9003A (2HS-9003A)	CL/Normal						
Pump	Discharge Isolation Motor Operated Valve	rom Contain	ment Su	mp				
04	1HS-9001A	CL/AUTO						
Pump	Discharge Isolation Motor Operated Valve							
05	1HS-9017A	CL/Normal						
Pumj	Pump Discharge Isolation Motor Operated Valve from RWST							
06	1ABD-30	OFF						
1HS-	9003A feeder breaker							
07	1ABD-48	OFF						
1HS-90	01A feeder breaker						<u>,</u>	
08	1ABD-41	OFF						
1HS-	9017A feeder breaker						<u> </u>	
09	1ABD30W-K2	OPEN						
Alarn	n relay							
10	2ABD48W-K2	OPEN						
Alarr	n relay							
11	1ABD41W-K2	OPEN						
Alarr	n relay							
12	1AYE1-34	OFF						
1-120	06-P6-001 Motor Space Heater	·						.
13	1HV-9003A	Closed						
Pum	p Discharge Isolation Motor Operated Valve	from Contair	nment Su	mp Handw	rheel			

.

Cleara	Clearance # 10210011 Prepared by: Al Sweat							
EQ	JIPMENT TO BE CLEARED AND TAGGED			TAGS TO TO SERVI	BE REMOVE	D AND EQUIP FIED	MENT RE	TURNED
TAG	EQUIPMENT #	TAGGED POSITION	INIT	IV INIT	RESTORE	RESTORE POSITION	INIT	IV INIT
14	1HV-9001A	Closed						
Pur	np Discharge Isolation Motor Operated Valve H	iandwheel			<u> </u>			
15	1HV-9017A	Closed						
Pur	np Discharge Isolation Motor Operated Valve fr	om RWST H	landwhee) 				
16	1-1206-U4-115	Closed						
18	7-9003A bypass line isolation valve					. <u></u>	<u> </u>	
17	(1-1206-U4-006)	Closed						
Co	ntainment Spray Train "A" test line to RWST (N	ormally Loc	ked Close	ed)				
18	1-1206-U4-034	Closed						
Spi	ay eductor manual isolation valve (Normally Lo	ocked Close	d)					
19	1-1206-U4-109	OPEN						
Co	ntainment Spray Train "A" Pump casing drain (Normally Lo	cked Clo	sed)				
20	1-1206-U4-112	Open						
Co	ntainment Spray Train "A" Pump suction line d	rain						
21	1-1206-X4-108	Uncap/ Open						
Co	ntainment Spray Train "A" Pump Discharge line	e vent						
22	1-120 6 -U4-108	Unflange/ Open						
Co	ntainment Spray Train "A" Pump casing vent							

Clearance #	Prepared by:
10210011	AI Sweat

LCO #	SI #		
		P&ID	
		MECH	
		ELEM	
		ELEC	
		CONN	
		LCO # SI #	LCO # SI # P&ID MECH ELEM ELEC CONN

ADDITIONAL WOS

,		

REFERENCES:

٦

CLEARANCE REMOVAL:		
Authorized by:	Date:	Time:
Removed by:	Date:	Time:
Verified by:	Date:	Time:

Extended Active Clearance Quarterly Audits:

	DATE	INITIAL	DATE	INITIAL	DATE
· · · · · · · · · · · · · · · · ·	 				
	 	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·		



Energy to Serve Your World"

PLANT VOGTLE

NRC-JP-00920

CALCULATE WORKER DOSE USING SURVEY MAPS

October 04,2002 Rev #0 This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

You will be given info Standard. Please ens allowed access to an	ormation describing the Initial Conditions, Assigned Task, and the Task sure you understand the assigned task before beginning. You will be y item normally used to perform this task.
INITIAL CONDITIONS:	
• Unit 1 in MODE 5	for refueling outage.
The Operating Crosses	ew has entered 18019-C "Loss of RHR" Section "B"
The Auxiliary Bui Recirculation to F	Iding System Operator has been dispatched to shut 1-1205-U4-027 "RHR ?WST isolation Valve"
Assigned Task:	Given that Auxiliary Building System Operator is required to:
	 Remain in the area for 15 minutes to shut 1-1205-U4-027 enter the area receiving 10 mrem TEDE dose exit the area receiving 10 mrem TEDE dose
	Using the Radiological Information Survey Map provided calculate the "TOTAL" dose the Auxiliary Building System Operator has received following the task ("including" the dose received during entry and exiting the Train "A" RHR Pump Room).
TASK STANDARD:	Auxiliary Building System Operator TOTAL TEDE DOSE CALCULATED.

OPERATOR'S NAME:		
EVALUATION DATE://		
JPM TITLE: CALCULATE WORKER DOSE	USING SURVEY MAPS	
COMPLETION TIME: 20 minutes		
Application: RO/SRO		
Task Number:		
K/A Number:		
Evaluation Method [] Performed	[] Simulated	
Evaluation Location [] Simulator	[] Control Room	[] Unit 1 [] Unit 2
Performance Time:minutes		
OVERALL JPM EVALUATION	[] SATISFACTORY	[] UNSATISFACTORY
Examiner Comments:		
Examiner's Signature:		

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS:

- Unit 1 in MODE 5 for refueling outage.
- The Operating Crew has entered 18019-C "Loss of RHR" Section "B"
- The Auxiliary Building System Operator has been dispatched to shut 1-1205-U4-027 "RHR Recirculation to RWST isolation Valve"

Assigned Task:

Given that Auxiliary Building System Operator is required to:

- Remain in the area for 15 minutes to shut 1-1205-U4-027
- enter the area receiving 10 mrem TEDE dose
- exit the area receiving 10 mrem TEDE dose

Using the Radiological Information Survey Map provided calculate the "TOTAL" dose the Auxiliary Building System Operator has received following the task ("including" the dose received during entry and exiting the Train "A" RHR Pump Room).

TASK STANDARD: Auxiliary Building System Operator TOTAL TEDE DOSE CALCULATED.

START TIME: _____

STEP 1

.

 $\sum_{i=1}^{n} e^{i i i i}$

SAT De UNSAT De (300 mrem/hr) (1hr/60min) (15 min) = 75 mrem + 20 mrem = <u>95 mrem</u>

Stop Time _____

Field Notes



Energy to Serve Your World[™]

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC-JP-14005

CALCULATE SHUTDOWN MARGIN -- FOLLOWING PLANT TRIP

Revision 0

November 14, 2002

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions: Reactor tri 557 degree	pped from 100% power, the unit is currently in mode 3 at as F.
The reactor shutdown	2 hours ago
Power history prior to trip	100% for 200 days
Cycle Burnup	10,500 MWD/MTU
Boron Concentration	1000 ppm
Rod Height	All Rods on Bottom $\sqrt{2^{1/2}}$
Axial Offset Correction	0 pcm
RCP(s) running	All 4 are in service
Assigned Task: The USS h current co and Samar	as directed you to calculate the shutdown margin for the nditons using 14005-1. You should take credit for Xenon ium present in the core.

Task Standard: Shutdown margin calculated.(Current)

OPERATOR'S NAME:
EVALUATION DATE://
JPM TITLE: CALCULATE SHUTDOWN MARGIN – FOLLOWING PLANT TRIP
REVISION: 06 November 14, 2000
COMPLETION TIME: 30 minutes
Application: SRO
Evaluation Method [] Performed [] Simulated

Evaluation Location	[] Simulator	[] Control Room	[] Unit 1	[]

Performance Time: _____minutes

OVERALL JPM EVALUATION	[] SATISFACTORY	[] UNSATISFACTORY
------------------------	-----------------	-------------------

Examiner Comments:

Examiner's Signature: _____
This JPM is based on the latest rev of 14005-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

- 1. 14005, Shutdown Margin and Keff Calculations
- 2. Plant Technical Data Book (Unit 1)

SIMULATOR SETUP: Performance of this JPM does not require the simulator.

This JPM is based on Unit 1 Cycle 11 data.

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions: Reactor tripped from 100% power, the unit is currently in mode 3 at 557 degrees F.

•	The reactor shutdown	2 hours ago
•	Power history prior to trip	100% for 200 days
•	Cycle Burnup	10,500 MWD/MTU
•	Boron Concentration	1000 ppm
•	Rod Height	All Rods on Bottom
•	Axial Offset Correction	0 pcm
•	RCP(s) running	All 4 are in service
A	ssigned Task: The USS h	as directed you to calculate the s

Assigned Task: The USS has directed you to calculate the shutdown margin for the current conditons using 14005-1. You should take credit for Xenon and Samarium present in the core.

Task Standard: Shutdown margin calculated.(Current)

START TIME: _____

STEP 1 CRITICAL (♦) SAT □ ≤ UNSAT □ ≤

Select appropriate Data Sheet

Data Sheet 2 selected
Current conditions recorded

STEP 2 SAT ⊡⊯

ສ UNSAT ⊡ສ

Determine reactivity values using PTDB

E.1 8835 pcm
E.2 1085 ppm
E.3 9530 pcm
E.4 0.88164
E.5 4117 pcm
E.6 1019 pcm
E.7 5136 pcm
E.8 4528 pcm
E.9 1112 pcm
E.10 0 pcm
E.11 0 pcm
E.12 3833 pcm

STEP 3 CRITICAL (♦) SAT □ ∞ UNSAT □ ∞

Determine Shutdown Margin

Note: Interpolation and rounding may result in values slightly different from those provided.

B□ + E. 13 Shutdown Margin of 3.83 (+ or - 0.1) % calculated



STOP TIME: _____

Field Notes



Energy to Serve Your World[™]

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC-JP-91001

CLASSIFY AN EMERGENCY EVENT -- SITE AREA

Revision 0

October 04, 2002

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

 The Operating Crew has entered 19231-C "LOSS OF SECONDARY HEAT SINK" following a Reactor Trip The RCS is currently in Feed & Bleed with the following conditions: Core Exits TC's 511 degrees F. and lowering Hot leg temperatures 502 degrees and lowering RCP's are stopped Pressurizer level is 100% The Crew is preparing to feed Steam Generator #3 with Condensate Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering nast events, and their impact on the current plant conditions". 	Initial Conditions:	The following is the sequence of events as they occurred on Unit 1:		
 The RCS is currently in Feed & Bleed with the following conditions: Core Exits TC's 511 degrees F. and lowering Hot leg temperatures 502 degrees and lowering RCP's are stopped Pressurizer level is 100% The Crew is preparing to feed Steam Generator #3 with Condensate Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering nast events, and their impact on the current plant conditions". 	1. The Operating (Reactor Trip	Crew has entered 19231-C "LOSS OF SECONDARY HEAT SINK" following a		
Core Exits TC's 511 degrees F. and lowering Hot leg temperatures 502 degrees and lowering RCP's are stopped Pressurizer level is 100% 3. The Crew is preparing to feed Steam Generator #3 with Condensate Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering past events, and their impact on the current plant conditions".	2. The RCS is curr	ently in Feed & Bleed with the following conditions:		
Hot leg temperatures 502 degrees and lowering RCP's are stopped Pressurizer level is 100% 3. The Crew is preparing to feed Steam Generator #3 with Condensate Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering nast events, and their impact on the current plant conditions".	Core Exits T	C's 511 degrees F. and lowering		
RCP's are stopped Pressurizer level is 100% 3. The Crew is preparing to feed Steam Generator #3 with Condensate Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering past events, and their impact on the current plant conditions".	Hot leg tem	peratures 502 degrees and lowering		
Pressurizer level is 100% 3. The Crew is preparing to feed Steam Generator #3 with Condensate Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering past events, and their impact on the current plant conditions".	RCP's are s	topped		
 3. The Crew is preparing to feed Steam Generator #3 with Condensate Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering nast events, and their impact on the current plant conditions". 	Pressurizer	Pressurizer level is 100%		
Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering past events, and their impact on the current plant conditions".	3. The Crew is pre	paring to feed Steam Generator #3 with Condensate		
Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering past events, and their impact on the current plant conditions".				
classification level based on events which are in progress, considering nast events, and their impact on the current plant conditions".	Assigned Task:	You have been directed to "Determine the HIGHEST emergency		
paor overhei, and then impaor of the carrent plant contaiters :		classification level based on events which are in progress, considering past events, and their impact on the current plant conditions".		

Task Standard:

Emergency event classified.

OPERATOR'S NA	ME:			
EVALUATION DA	TE://			
JPM TITLE:	Classify an Emer	gency Event – SITE AREA		
REVISION:	0			
COMPLETION TI	ME:11 minutes			
Application:	SRO ONLY			
Evaluation Metho	d [] Performed	[] Simulated		
Evaluation Locat	ion [] Simulator	[] Control Room	[] Unit 1	[] Unit 2
Performance Tim	e:minutes			
OVERALL JPM E	VALUATION	[] SATISFACTORY	[] UNSAT	SFACTORY
Examiner Comm	ents:			

This JPM is based on the latest rev of 91001-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS: 1. 91001-C, Emergency Classification and Implementing Instructions

SIMULATOR SETUP: None

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions: The following is the sequence of events as they occurred on Unit 1:

- 3. The Operating Crew has entered 19231-C "LOSS OF SECONDARY HEAT SINK" following a Reactor Trip
- 4. The RCS is currently in Feed & Bleed with the following conditions: Core Exits TC's 511 degrees F. and lowering Hot leg temperatures 502 degrees and lowering RCP's are stopped Pressurizer level is 100%
- 3. The Crew is preparing to feed Steam Generator #3 with Condensate

Assigned Task: You have been directed to "Determine the HIGHEST emergency classification level based on events which are in progress, considering past events, and their impact on the current plant conditions".

TASK STANDARD: Emergency event classified.

START TIME: _____

. مرجع میں ا STEP 1 CRITICAL (♦) SAT □ ∞ UNSAT □ ∞

Classify the event

B ● Plant conditions evaluated

➢□ ♦ Emergency event classified as a SITE AREA

STOP TIME: _____

Field Notes



Energy to Serve Your World™

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC-JP-91305

IMPLEMENT OFFSITE PROTECTIVE ACTION RECOMMENDATIONS - PAR 1

Revision 0

October 04,2002

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	 Given the following Conditions/Events on Unit 1: Reactor Trip following a Tornado striking the switchyard results in the loss Both RATs and the SAT D/G 1B was tagged out prior to the event SAT is also damaged during the event D/G 1A starts then trips due failure of the shaft driven lube oil pump (Maintenance estimates 5 hours to repair) RCS temperature @ 557 degrees F. Emergency Director has declared a General Emergency When direction is at 098 degrees
Assigned Task:	Based on the information given, determine the required Offsite Protective Action Recommendation(s).

 Task Standard:
 Offsite Protective Action Recommendation(s) correctly identified.

	OPERATOR'S NAME:
	EVALUATION DATE://
	JPM TITLE: Implement Offsite Protective Action Recommendations - PAR 1
	REVISION: 0 October 04,2002
	COMPLETION TIME: 11 minutes
	Application: SRO Only
	Evaluation Method [] Performed [] Simulated
	Evaluation Location [] Simulator [] Control Room [] Unit 1 [] Unit 2
/	Performance Time:minutes
	OVERALL JPM EVALUATION [] SATISFACTORY [] UNSATISFACTORY
	Examiner Comments:
	Examiner's Signature:

This JPM is based on the latest rev of 91305-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS: 1. Procedure 91305-C, Protective Action Guidelines

SIMULATOR SETUP: Simulator not required for JPM performance

DIRECTIONS TO OPERATOR			
You will be given in Standard. Please en allowed access to a	You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.		
INITIAL CONDITIONS:	 Given the following Conditions/Events on Unit 1: Reactor Trip following a Tornado striking the switchyard results in the loss Both RATs and the SAT D/G 1B was tagged out prior to the event SAT is also damaged during the event D/G 1A starts then trips due failure of the shaft driven lube oil pump (Maintenance estimates 5 hours to repair) RCS temperature @ 557 degrees F. Emergency Director has declared a General Emergency When direction is at 098 degrees 		
Assigned Task:	Should A	given, determine the required Offsite Protective %).	
TASK STANDARD:	0.	ecommendation(s) correctly identified.	

START TIME: _____

STEP 1 CRITICAL (♦) SAT □ ∞ UNSAT □ ∞

Determine correct Protective Action Recommendations

Note: Initial Emergency Classification is a seperate JPM therefore classification is not required and provided in the individual scenarios. In addition, notification forms are not required to be completed for performance of this JPM.

PAR 1:

B□ ◆ Evacuate zones A, C-5, D-5, E-5, F-5, SRS to 2 Miles

Shelter remainder of 10 mile EPZ

STOP TIME: _____

Field Notes



Energy to Serve Your World[™]

PLANT VOGTLE

NRC-JP-ODCM

LIQUID RELEASE WITH 1RE-0018 INOPERABLE

> October 04,2002 Rev #0

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS:

- Unit 1 is at 100% Reactor Power
- The Auxiliary Building System Operator has just completed processing WMT #9 for release.
- 1RE-0018 was declared INOPERABLE on the last shift.

Assigned Task: Under what conditions can this tank be released?

OPERATOR'S NAME: _____

EVALUATION DATE: ___/___/

JPM TITLE: LIQUID RELEASE WITH 1RE-0018 INOPERABLE

COMPLETION TIME: 20 minutes

INSTRUCTIONS TO EXAMINER

Evaluation Method [] Performed Evaluation Location [] Simulator Performance Time:minutes	[] Simulated [] Control Room	[] Unit 1 [] Unit 2
OVERALL JPM EVALUATION	[] SATISFACTORY	[] UNSATISFACTORY
Examiner Comments:		
Examiner's Signature:		

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS:

- Unit 1 is at 100% Reactor Power
- The Auxiliary Building System Operator has just completed processing WMT #9 for release.
- 1RE-0018 was declared INOPERABLE on the last shift.

Assigned Task: Under what conditions can this tank be released?

START TIME: _____

STEP 1

SAT De UNSAT De (1) At least Two independent samples are analyzed (2) At least two technically qualified members of the facility staff independently verify the discharge line valving and the release rate calculations.

Stop Time _____

Field Notes



Energy to Serve Your World"

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC-JP-91305

EMERGENCY EXPOSURE GUIDELINES SRO ONLY

> October 04,2002 Rev 0

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Given the following Conditions/Events on Unit 1: Initial Conditions: Major fuel damage occurred from a loose part in the RCS • SGTR on S/G #1 A General Emergency has been declared 1PV-3000. Loop #1 ARV has failed open HP has estimated that in the time it will take for a person to access Assigned Task: the area and manually isolate the failed open ARV, they would receive 45 Rem (TEDE). As the Emergency Director which of the following worker(s) would vou select for the task? 1. 21 year old declared pregnant female, who is fully aware of the risks. 2. 45 year old male volunteer, who's lifetime exposure is 31 Rem, 27 Rem of which is classified as emergency exposure from a previous event. 3. 23 Fear old female volunteer, who has been briefed on the task and fully aware of the risks. $4^{\eta/50}$ year old male, non-volunteer, who has been briefed on the task and fully aware 49 of the risks. $\sqrt{5}$ 5. At year old male volunteer, who due to experience could complete the task in the Aleast amount of time and has only received 4 Rem emergency exposure during this ²⁰event. DETERMINE WHICH WORKER(S) THE EMERGENCY DIRECTOR SHOULD SELECT TO Task Standard: PERFORM THE TASK.

JPM INFORMATION

π.			_
	OPERATOR'S NAME	:	
	EVALUATION DATE:	://	
	JPM TITLE:	EMERGENCY EXPOSURE GUIDELINES	
	COMPLETION TIME:	: 15 minutes	
	Application:	SRO	
	Evaluation Method	() Performed () Simulated	
	Evaluation Location	() Simulator () Control Room () Unit 1 () Unit 2	
/	Performance Time:	minutes	
	OVERALL JPM EVALU	JATION () SATISFACTORY () UNSATISFACTORY	
	Examiner Comment	's:	
/	Examiner's Signature	e:	-

JPM INFORMATION

.

	DIRECTIONS TO OPERATOR
Initial Conditions:	Given the following Conditions/Events on Unit 1:
 Major fuel dam SGTR on S/G #1 A General Emer 1PV-3000, Loop 	age occurred from a loose part in the RCS rgency has been declared #1 ARV has failed open
Assigned Task:	HP has estimated that in the time it will take for a person to access the area and manually isolate the failed open ARV, they would receive 45 Rem (TEDE).
	As the Emergency Director which of the following worker(s) would you select for the tast?
 21 year old ded 45 year old ma classified as en 23 year old fen the risks. 50 year old ma of the risks. 40 year old ma least amount of event. 	clared pregnant female, who is fully aware of the risks. le volunteer, who's lifetime exposure is 31 Rem, 27 Rem of which is nergency exposure from a previous event. hale volunteer, who has been briefed on the task and fully aware of le, non-volunteer, who has been briefed on the task and fully aware le volunteer, who due to experience could complete the task in the f time and has only received 4 Rem emergency exposure during this
<u>Task Standard</u> :	DETERMINE WHICH WORKER(S) THE EMERGENCY DIRECTOR SHOULD SELECT TO PERFORM THE TASK.

JPM STEPS

START TIME: _____

н.,...,

`~ ...~

STEP 1	
CRITICA	L (+)
SAT 🗆 🧃	s UNSAT ⊡.∞
Worker :	selected for task
≥□ ♦	23 year old female volunteer, who has been briefed on the task and the risks.

Stop Time _____

Field Notes

_

[
	SOUTHERN A COMPANY Energy to Serve Your World ^{**}
	PLANT VOGTLE
	CONTROL ROOM OPERATOR
	JOB PERFORMANCE MEASURE
	RQ-JP-40101-002-01B <u>91002-002</u>
	MAKE EMERGENCY NOTIFICATIONS WITH FAILURE OF THE ENN
	Revision 1 2
	August 16, 1996December 12, 2000
	Written By : George GunnM. C. Henry Date: 0812/1612/962000
	Approved By : Leon RayXXXXXXXR. D. Brigdon Date: 08 <u>12</u> /16 <u>xx/96200901/16/2001</u>
	08 <u>12</u> /16 <u>xx</u> /96 <u>200001/16/2001</u>

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

(S) This is a Time Critical JPM (S)

Initial Conditions:	An emergency has been declared and the Shift Superintendent has assumed the duties of the Emergency Director.
Assigned Task:	The Emergency Director has directed you to "Perform the duties of the ENN Communicator".

Task Standard:	Communications established, and the Emergency Notification form transmitted, to all State and Local authorities.

JPM	INFO	RMA	TION
-----	------	-----	------

OPERATOR'S NAME:	
EVALUATION DATE:	//
JPM TITLE:	Make Emergency Notifications with Failure of the ENN
REVISION:	12 August 16, 1996December 12, 2000
COMPLETION TIME:	15 minutes TIME CRITICAL (B)
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO / SRO 40003 194001A1.16 RO: 3.1 SRO: 4.4 11
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room
Performance Time:	minutes
OVERALL JPM EVAL	UATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 91002-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:	1. 2.	Proce VEGP	dure 91002-C, Emergency Notifications, Checklist 2 Emergency Response Telephone Directory
SIMULATOR SETUP:		Simula	ator not required for JPM performance
Notes to Exami	ner:	(1)	Checklist 2, Sheet 2, Emergency Notification, should be completed with the exception of Steps 3, 4, and 6 prior to the start of this JPM. Step 1.A, THIS IS A DRILL, should always be recorded.
		(2)	Step 3 of the Emergency Notification form must be completed within 15 minutes of the time documented in Step 6.A. The start time of this JPM should be the time recorded in Step 6.A.
		(3)	Ensure the ENN telephone jack in the rear of the ENN telephone has the "Simulator" cord installed.

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

This is a TIME CRITICAL JPM

INITIAL CONDITIONS: An emergency has been declared and the Shift Superintendent has assumed the duties of the Emergency Director.

Assigned Task: The Emergency Director has directed you to "Perform the duties of the ENN Communicator".

TASK STANDARD:Communications established and the Emergency Notification form transmitted to all
State and Local authorities.

JPM STEPS

START TIME:	 TIME	CRITICAL	٢
-			

STEP	
CRIT	CAL (+)
SAT	
	Initiate roll call
	Note: The Emergency Response Telephone Directory, or the dial code card, should be consulted as needed for required
	ENN dial codes. The dial code, **, should be used initially to ring ALL required agencies.
	-
==	
26	Burke County notified (1)
280	GEMA notified
	Aiken County notified
	Sh5 notifed Allondala County patified
	Alteridate County Formed State of South Carolina notified
	Barnwell County (2)
	. (1) When requested, provide cue that each emergency center hailed has responded.
	(2) Do not respond when Barnwell County is hailed from Comlabs Phone.
L	
STEP	2
CRIT	ICAL (+)
SAT	Des UNSAT Des
	Netify Bornwell County
	Note: For initial notifications the 24 hour warning point commercial telephone line should be notified.
=	
`∞□	Commercial telephone line (803) 541-1161
20	Barnwell County directed to respond to EINN (1)
CUES	; (d)
haan	(1) It performed correctly when proper number identified, provide the due that Barriwell County has
Deen	responded to ENN."
L	
STEP	23
SAT	or unsat or state of the state
	Transmit fascimile Note: On the Eav machine in the Simulator, the pushbutton labelled "Simulator TrainingNOTIFY/Training)" should be depressed
to simu	late
purpose	es, the "Simulator NOTIFY <u>(</u> Training)" pushbutton should be used to trnasmit the fax.
	- Place message feed down in transmit trav
	Frace message race down in transmituray Frace Eax in AUTO REC.mode
	Ensure Single Button Dial selected
	• "NOTIFY(Training)" pushbutton depressed

CRITIC SAT	:AL (+) ി <i>ട</i>	UNSAT Des	
	Comm Note:	unicate notification via ENN Examiner should arbitrarily pick a number between 1 and 100 and verify that the authentication codeword is correctly identified by examinee.	
28.	• Line	s 1 & 2 transmitted	
20	♦ Exa	ninee's name provided in Line 2, "Reported By"	
20	♦ Line	3, Transmittal time & date completed (1)	
السايعج	• Con	troi Room confirmation phone number transmitted	
CUES:	(1)	After completion of Emergency Notification form line 3, provide the following cue, "The State of South Carolina request that you authenticate number"	

Message authentication

>>□ ◆ Authentication codeword correctly provided.

STEP CRITI SAT	P6 ICAL (♦) □ ∞ UNSAT □ ∞	
	Transmit classification data	
	 Emergency Classification 	
Ъ	 Emergency declaration time and date 	
20	Emergency description	

JPM STEPS

STEP CRIT SAT	P7 TCAL(♦) □∞ UNSAT ⊡∞
	Transmit current plant radiological conditions
20 20 20 20 20 20 20	 Plant condition Emergency rad release status Current meteorological data Recommended protective actions ED approval,time, & date
STEF SAT	P 8 □ ∞ UNSAT □ ∞ Notify ED • Initial Emergency Notification completed

Field Notes:

1 ÷

~

.

Control Room Systems and Facility Walk-Through Test Outline

Facility: Vogtle Da Exam Level (circle one): RO / SRO(I) / SRO(U) Da	te of Examination Operating Te	: <u>12/02/02</u> st No.: <u>DRAF</u>
B.1 Control Room Systems		
System / JPM Title	Type Code*	Safety Function
a. Transferring From RAT A (1NXRA) to SAT Using 4160V AC Cross-tie Breaker in Mode 6 with UAT back feed available. Only two of the three phases can be verified at 4160 V. JPM should stop at step 4.2.2.13.i Malfunction is placed in between step 4.2.2.13.b and 4.2.2.13.h	A, S, N, L	6
Could not simulate		1
Replace: D/G emergency start with subsequent loss of NSCW, Manual Trip of D/G		
b. Respond to Loss of NSCW :: (RQ-JP-18021-001) One pump fails and backup fails to start. JPM should go through the end of step 6 and then be stopped.	A, S, M	8 6
One action in CR		
Replace : Failure of Auto Containment Spray start, manual initiation and partial lineup		
c. Start a Reactor Coolant Pump (RQ-JP-13003-001) After Start High Vibration requires pump to be stopped.	A, S, M, L	4P
d. Collapse PRZR Bubble and Cooldown PRZR (LO-JP-120006-001) Alternate path - Step D4.3.11.c Ensure all PRZR heaters on. One bank of PRZR heaters will not come on, this will	A, S, N	3
require the dispatch of an operator to operate the heaters.		2
letdown		
e. Initiate RCS Boration using BTRS (LO-JP-13010-001) We did not have this in our bank	D, S	1
f. Control PRZR Level and SG Level from Remote Shutdown Panel (RQ-JP-18038-003)	S, L, D	2
can not simulate		3
Replace:Control Przr PRESS and S/G LEVEL from remote shutdown panel		
g. (1) Transfer ECCS Pumps to Cold Leg Recirculation (RQ-JP-19013-001) This is for the Upgrades ONLY	D, S, L	4P
g. (2)Reduce Containment pressure following a spurious CVI (LO-JP- 13125-001)	D, S	5 8
B.2 Facility Walk-Through		

Papla

b. Locally Establish Condensate Flow Perstep 8 e of EB-H.1, including starting one Condensate Feed pump Locally.	D	4S
(RQ-JP-19321-006)		
TDAFW control w/o DC power		
c. Locally Isolate RCP Seals	D, R	4P

.

P8 201



Energy to Serve Your World™

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC-JP-19100-001

VERIFY PROPER DG OPERATION ON LOSS OF ALL AC POWER

Revision 0

10/24/02

This information describes the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the task before beginning. You will be allowed access to any item normally used to perform this task.

Initial Conditions:	A loss of all AC power condition has occurred, Power has been restored to 1BA03 from RAT-1B. All 1E pump handswitches other than NSCW are in the PTL position as required by EOP 19100-C. Emergency repairs to DG-1A have just been completed and the diesel is ready to be locally started.
Assigned Task:	The USS has directed you to "Verify proper DG-1A operation"

Task Standard: DG-1A operation verified

PERATOR'S NAME:				
EVALUATION DATE:	//			
IPM TITLE:	Verify Proper D	G-1A operation		
REVISION:	0			
COMPLETION TIME:	6 minutes			
	This JPM to b	e used for Initial Licensed O	perator Exam Only.	
Evaluation Method	[] Performed	[] Simulated		
Evaluation Location	[] Simulator	[] Control Room	[] Unit 1 [] Unit	2
Performance Time:	minutes			
OVERALL JPM EVALUATION		[] SATISFACTORY	[] UNSATISFACTOR	r
Examiner Comments:		· · · · · · · · · · · · · · · · · · ·		

INSTRUCTIONS TO EXAMINER

This JPM is based on the latest rev of 19251-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS: 1. 17035-1

1.

SIMULATOR SETUP:

Reset to IC 14

- 2. Place DG-1A in local control
- 2. Insert malfunctions EL02, DG12, EL01B
- 3. Manually trip the reactor
- 4. Place all 1E pumps (except NSCW) in PTL
- 6. Acknowledge alarms and freeze simulation
- 7. Emergency start DG-1A at start of JPM by going to remote
- 8. Override ALB035B06 (High lube oil filter D/P) to on after NSCW operation verified
- 9. Override ALB035B01 (Lo pressure), and then B02 (Lo Pressure Trip) to on after student references appropriate ARP

Setup time: 10 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: A loss of all AC power conditon has occurred, power has been restored to 1BA03 from RAT-1B. All 1E pump handswitches other than NSCW are in the PTL position as required by EOP 19100-C. Emergency repairs to DG-1A have just been completed and the diesel is ready to be locally started.

Assigned Task: The USS has directed you to "Verify proper EDG-1A operation."

TASK STANDARD: DG-1A operation verified

4
START TIME: _____

STEP	1
SAT	⊡e UNSAT ⊡e
	Verify proper DG-1A startup Note:
жП жП	 Emergency start annunicator verified (ALB35F10) DG-1A at 4160 Vac and 60 Hz DQ-1A subset breaker alegan subseting by (1AA02, 10)
<u>в</u> П	DG-1A output breaker closes automatically (1AA02-19)
SAT	Def UNSAT Def Verify proper load sequencing Note: After NSCW pumps are running with discharge valves open insert trigger for lube oil alarms.
8 9 8 9 8 9 8 9 9 9 9 9 9 9 9 9 9 9 9 9	 NSCW pumps 1 & 3 start and discharge valves fully open after 45 second time delay Acknowledge DG-1A lube oil alarms and refence procedure 17035-1 Note that DG-1A should have tripped when ALB035 B02 Alarmed (1) Emergency stop DG-1A using both emergency stop pushbuttons Verify DG-1A output breaker (1AA02-19) opens and engine stops
CUES	: (1) If requested: "System Operator at DG-1A reports lube oil pressure reading 17 psig and lowering"

STEP SAT	`4 □ø	UNSAT	D es	
	Report	t to USS		
<u>م</u> ط	• DG-1	A had to b	e tripped due to loss of lube oil pressure	

STOP TIME: _____



· ·

2

Initial Conditions:	A large break LOCA has occurred. After transitioning to 19010, the USS has determined that an ORANGE PATH exists for Containment due to high containment pressure.
Assigned Task:	The USS has directed you to "Verify proper Containment Spray operation beginning with step 3 of 19251."

7

 Task Standard:
 Containment spray flow initiated.

Б

OPERATOR'S NAME:					
EVALUATION DATE:	//				
JPM TITLE:	Manually Initiat	e Containment S	pray		
REVISION:	<u>078</u> July 7,	1999 <u>October 5,</u>	<u>2000</u>		
COMPLETION TIME:	6 minutes				
	This JPM-to-b	e used for Initia	I Licensed Op	erator Exam Or	nly.
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 15003 026000A203	- RO: - 4.1	SRO:4.4		
					· · · · · · · · · · · · · · · · · · ·
Evaluation Method	[] Performed	[] Sin	nulated		
Evaluation Location	[] Simulator	[] Co	ntrol Room	[] Unit 1	[] Unit 2
Performance Time:	minutes				
OVERALL JPM EVALU	JATION	[] SATISFAC	TORY	[] UNSATIS	SFACTORY
Examiner Comments:					
	·				
Examiner's Signature: _					

This JPM is based on the latest rev of 19251-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "@..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:	1.	19251, Response to High Containtment Pressure
SIMULATOR SETUP:	1.	Reset to IC 14
	2.	Override HS-40059 to RESET.
	3.	Insert malfunction CS01A & CS01B (CS pumps auto start fails)
	3.	Insert malfunction ES13 (Auto CS Failure Train A)
	4.	Insert malfunction ES14 (Manual CS Failure Train A)
	5.	Insert malfunction RC03 (Large LOCA)
	6.	Freeze when ORANGE Path on Cnmt exist
		Setup time: 5 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS:	A large break LOCA has occurred. After transitioning to 19010, the USS has determined that an ORANGE PATH exists for Containment due to high containment pressure.
ASSIGNED TASK:	The USS has directed you to "Verify proper Containment Spray operation beginning with step 3 of 19251."
TASK STANDARD:	Containment spray flow initiated.

START TIME: _____

STEP 1 CRITICAL (+)

SAT De UNSAT De

Manually Actuate Containment Spray

Note: One pair of handswitches must be positioned simultaneously to actuate containment spray.

Solution > Check Containment pressure > 21.5 psig

Check Containment Spray not actuated

→ HS-40010 and HS-40011 (HS-40004 and HS-40005) in ACTUATE

STEP 2 CRITICAL (+)

SAT DE UNSAT DE

Verify Containment Spray Pumps running

Note: CS Pumps A <u>& B</u> must be manually started.

- B → + CS Pump B RUNNING
- Solution State State

CUES:

©... Indicate the green lights are lit for CS Pump A, HV-9001A , and HV-8994A.

STEP 3

CRITICAL (♦) SAT □ ≤ UNSAT □ ≤

Check Containment Spray Alignment

Note: Train A components will require manual alignment.

B□ • Check RWST level > 10%

- Verify RWST supply HV-9017A and HV-9017B OPEN
- ♦ Spray isolations HV-9001A and HV-9001B OPEN
- Spray isolation HV-9001B_OPEN

STEP 4 SAT ⊡∞ UNSAT ⊡∞

Report to USS

• Containment Spray operation has been initiated

STOP TIME: ___



Energy to Serve Your World"

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC-JP-13003-001

START A REACTOR COOLANT PUMP

Revision 0

10/25/02

Initial Conditions:	A plant startup is in progress with the unit in Mode 4. Per UOP 12001, RCPs 1 and 4 have been started. The standby alignment has been verified for RCP 3 and an operator has performed a visual inspection. SGBD has been in service for 3 hours and the temperature is stable. Adequate SD Margin has been verified.
Assigned Task:	The USS has directed you to "Start RCP 3 using 13003."

Task Standard:

Б

Reactor Coolant Pump started.

EVALUATION DATE:	//			
JPM TITLE:	Start a Reactor Coo	lant Pump		
REVISION:	0			
COMPLETION TIME:	15 minutes			
· · · · · · · · · · · · · · · · · · ·		·····		
Evaluation Method	[] Performed	[] Simulated	······································	
Evaluation Location	[] Simulator	[] Control Room	[] Unit 1	[] Unit 2
Performance Time:	minutes			
	UATION []	SATISFACTORY	[] UNSATIS	SFACTORY
Examiner Comments:				
Evaminar's Signature:				

This JPM is based on the latest rev of 13003-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

1. 13003, Reactor Coolant Pump Operation

SIMULATOR SETUP:

- Reset to IC3 (BOL Mode 4)
- 2. Verify open both breakers for RCP 3. (Do not start lift pump)
 - 3. Verify SGBD for all 4 SGs
 - 4. Establish stable plant conditions
 - 5. Set ALB08E04 & F04 on a trigger to turn on
 - 6. Activate trigger 10 seconds after RCP is started
 - 7. Ack/Reset alarms
 - 8. Freeze simulator

Setup time: 4 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS: A plant startup is in progress with the unit in Mode 4. Per UOP 12001, RCPs 1 and 4 have been started. The standby alignment has been verified for RCP 3 and an operator has performed a visual inspection. SGBD has been in service for 3 hours and the temperature is stable. Adequate SD Margin has been verified.

ASSIGNED TASK: The USS has directed you to "Start RCP 3 using 13003."

 TASK STANDARD:
 Reactor Coolant Pump started.

1.

START TIME:					
STEP SAT	1 🛛 జ	UNSAT Des			
	Verify	proper ∆T for pump start			
ايخ ايخ	VeriRec	ify secondary water temperature ≤ 10°F above RCS loop Tcold ord value in Unit Control Log <i>(1)</i>			
CUES:		(1) Once value determined okay, state "The USS will record the ∆T value in the Unit Control Log."			
STEP CRITIC SAT	2 CAL (✦ □ଛ Start f) UNSAT ⊡ <i>⊭</i> the oil lift pump			
<u>م</u> ت م	♦ RCI ● Oil p	P 3 oil lift pump running permissive light lit			
STEP SAT SEQ 1	3 ⊡∕≤	UNSAT De			
	Estab	lish RCP starting conditions			
80 80 80 80 80 80	 Verif Seal Seal Seal VCT The 	y visual inspection (1) injection flow 8 to 13 gpm leakoff flow determined to be w/in normal operating range $\Delta P > 200 \text{ psid}$ pressure > 18 psig following annunciators windows dark: RCP Standpipe Hi & Lo level alarms (ALB08) RCP Upper & Lower Oil Rsvr Hi/Lo level alarms (ALB11) ACCW Cir Lo Flow Cir Oulet Hi Temp & Therm Barrier Hi Flow alarms (ALB04)			
20	• RCS	pressure and temperature within acceptable region of 12001, Fig 1			
CUES:	(1)	When requested: "Local inspection and hand rotation is complete."			
	©	Indicate RCS pressure is 335 psig and temperature is 330° F; Seal injection flow is 9 gpm; Seal leakoff flow is 0.5 gpm; Seal Δ P is 300 psid; VCT pressure is 35 psig; the (identified)			

Seal leakoff flow is 0.5 gpm annunciator window is dark

		JPM STEPS
STEP SAT	4 🛛 జ	UNSAT Dø
	Verify	vibration alarms clear
24	• The f	ollowing annunciators dark: RCP Frame and Shaft Vibration Alert (ALB-08) RCP Frame and Shaft Hi Vibration (ALB-08)
CUES:	©	"The (identified) annunciator window is dark".
STEP CRITI SEQ 2 SAT	5 CAL (+) 2 (critica □∞	l steps) UNSAT ⊡∞
	Start t	he RCP
80 80 80 80	 SGB Oil li Ensu HS-0 HS-0 	D temperatures < 10°F above RCS temperature <i>(1)</i> ft pump running > 2 minutes ure CNMT personnel clear of RCP before starting 0497A placed in START 0497B placed in START
CUES:	: (1)	If required, Indicate SGBD temperatures (IPC) \approx 212°F".
	©	If SG metal (skin) temperatures are requested, "SG skin temperatures are all \approx 210°F."
STEP SAT	°6 ⊡∉ Stop F	UNSAT 🗆 🖉
&□ 	• RCP • RCP	3 running > 1 minute 3 oil lift pump stopped

STEP CRITI(SAT	97 CAL (♦) □∞	UNSAT De
	Verify Note:	improper RCP operation and stop RCP Guidance in both 13003-1 and 17008-1 window F04 require that the RCP be stopped on high vibration
 مد	Adjus	st charging as necessary to control Pressurizer level.
20	• The f	ollowing paramters observed:
		RCS pressure normal
		RCS loop flow normal
		RCP Vibration alarms (ALBUSEU4 & ALBUSEU4) (Intrinsided
		BCP seal injection flows 8 to 13 gpm
		RCP seal leakoff flows determined to be w/in normal operating range
		RCP seal $\Delta P > 200 \text{ psid}$
20	♦ Stop	RCP 3 by placing either HS-0497A or HS-0497B placed in STOP
4000	<u>.</u>	
CUES	5:	
(1)	Whon	requested the Control Building SQ reports "BCP #3 shaft vibration at 22 mils and increasing"
(7)	wwnen	requested the Control Dunding CC reports from the Shart fibration at 22 miles and the control of the

STE SAT	Р8 Пе	UNSAT De	
	Repo	port to USS	
20	• RC	CP #3 was started and had to be stopped due to high vribration	
STO	P TIME:	Ξ	

STOP TIME: _____



Energy to Serve Your World™

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

NRC-JP-17006-001

Spurious CIA Response

Revision 0

10/24/02

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.				
Initial Conditions:	A SPURIOUS CIA ACTUATION OCURRED WHILE I&C PERSONNEL WERE TAKING VOLTAGE MEASUREMENTS IN THE SSPS CABINENTS WITH THE UNIT AT 100% POWER. ALL MEASURING EQUIPMENT HAS BEEN DISCONNECTED AND SSPS CABINET DOORS CLOSED.			
Assigned Task:	Restore systems to normal operations using ARP 17006-1 E06			

Task Standard: Systems restored to normal at power operation

/

2

OPERATOR'S NAME:	
EVALUATION DATE:	<u> </u>
JPM TITLE: REVISION: COMPLETION TIME:	Spurious CIA Response 0 15 minutes
F	
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EVAL	UATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	

This JPM is based on the latest rev of 17006-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS: 1. 17006-1

SIMULATOR SETUP:

- 1. Reset to IC14 (MOL 100%)
- 2. Initiate a manual CIA
- 3. Set charging flow to 85 gpm in manual with \approx 9 gpm seal injection flow
- 4. Ensure LV-459,460 closed, HV-8149A,B,C, closed and HV-8152,8160, and 15214 closed
- 5. Ack/Reset alarms
- 6. Freeze simulator

Setup time: 7 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.

INITIAL CONDITIONS: A SPURIOUS CIA ACTUATION OCCURRED WHILE I&C PERSONNEL WERE TAKING VOLTAGE MEASUREMENTS IN THE SSPS CABINENTS WITH THE UNIT AT 100% POWER. ALL MEASURING EQUIPMENT HAS BEEN DISCONNECTED AND SSPS CABINET DOORS CLOSED.

Assigned Task: Restore systems to normal operations using ARP 17006-1 E06

TASK STANDARD: Systems restored to normal at power operation

START TIME: __

STEP CRIT SAT	P1 ICAL (♦) □ ∞ UNSAT □ ∞
	Restore Instrument Air to Containment
80 80	 RESET Phase A by placing both 1-HS-40120 and 1-HS-40122 to RESET position OPEN Instrument Air to containment 1-HV-9378 using both 1-HS-9378A and 1-HS-9378B
STEP CRIT SAT	2 ICAL (♦) □ ∞ UNSAT □ ∞ Establish normal system alignment
	 Section 4.4.2 of 13006 selected Verify orifice isolations HV-8149A, B, & C CLOSED Verify letdown isolations LV-459 and LV-460 CLOSED Verify Pressurizer Aux Spray Valve HV-8145 CLOSED CVCS HELB isolation HV-15214 OPEN Letdown isolations HV-8160 and HV-8152 OPEN Place pressure controller PIC-131 in MAN at 50% to 75% demand Place temperature controller TIC-0130 in MAN at 50% demand

CUES:

©	Provide indication that charging flow is 85 gpm and seal injection flows are 9 gpm.
©	Provide indication that PRZR level is 32%.

STEP 3 CRITICAL (+)

SAT DE UNSAT DE

Establish letdown flow

Note: Letdown pressure may be allowed to fluctuate temporarily while establishing letdown flow, but must be stabilized within the required band. Charging flow will have to be adjusted to ≥ desired letdown flow in order to stabilize letdown parameters.

- Sum ♦ Letdown isolations LV-459 and LV-460 OPEN
- A□ ♦ Orifice isolation HV-8149B or HV-8149C OPEN
- ► PIC-131 adjusted to attain 360 to 380 psig on PI-131A
- Record the letdown orifice that was placed in service in the Unit Control Log (1)

CUES:

(1) "The USS will ensure the RO makes a log entry about the letdown orifice placed in service."

STEP 3 SAT ⊡∞

🖌 UNSAT 🗋 🗷

Place letdown controllers in automatic

B□ • PIC-131 in AUTO

Letdown pressure 360 to 380 psig on PI-131A

► TIC-130 in AUTO

• Letdown temperature \leq 115 °F on TI-130

STEP 4

SAT ⊡க UNSAT ⊡க

Verify proper system operation

≥.□ ≥.□	• Rege • Main	en heat exchanger outlet (letdown) on TI-127 verified < 380 °F ntain PRZR level within 1% of program <i>(1)</i>
CUES:	(4)	
	(1)	"The RO will monitor and control PRZR level."

STEP 5 SAT ⊡∞ UN

೮ UNSAT ⊡∞

Complete System restorations

≥□ ≥□ ≥□ (1)	• OPE • RESI • COI	IN RCP Seal Return 1-HV-8100 and 1-HV-8112 using 1-HS-8100 and 1-HS-8112 TCVI by placing both 1-HS-40121 and 1-HS-40123 to RESET position MPLETE the applicable portions of 11886-1, "Recovery From ESF Actuations", for CIA and CVI
CUES:	(1)	"The common BOP will perfrom 11886-1"

.

STEP 6

SAT 🗆 🖉 🛛 UNSAT 🗖 🧟

Report to USS

• Systems Restored to normal operations following CIA

STOP TIME: _____

6			· · · · · · · · · · · · · · · · · · ·			
	SOUTHERN COMPANY Energy to Serve Your World [™]					
	PLANT V	OGTLE				
	CONTROL ROOM OPERATOR					
	JOB PERFORMANCE MEASURE					
	LO-JP-130	10- 001				
	INITIATE RCS BORATION USING BTRS					
i	Revisio	on 7				
	September	23, 2000				
	Written By : M. C. Henry	Date:	9/23/2000			
	Approved By : R. D. Brigdon	Date:	10/10/2000			

Initial Conditions:	The crew is preparing to reduce power to 75% to remove MFP B from service. BTRS demineralizers 4, 5, 6, and 7 have been equilibrated with the current RCS boron concentration. In addition, the extra RO has placed the BTRS system in standby alignment.
Assigned Task:	The USS has directed you to "Initiate boration of RCS using BTRS demineralizers 4, 5, 6, and 7".

Task Standard: RCS boration established using BTRS.

PERATOR'S NAME:	
EVALUATION DATE:	//
PM TITLE:	Initiate RCS Boration Using BTRS
REVISION:	7 September 23, 2000
COMPLETION TIME:	15 minutes
Application: Fask Number: K/A Number: 10CFR55.45 Ref.:	This JPM to be used for Initial Licensed Operator Exam OnlyRO/SRO09024004000SG013RO: 3.6SRO: 3.5
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EVAL	UATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	

This JPM is based on the latest rev of 13010-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during performance of this JPM.

REQUIRED ITEMS:

13010, Boron Thermal Regeneration System

SIMULATOR SETUP:

- 1. Reset to IC14
- 2. Perform 13010-1 section 4.1.2
- 3. Place BTRS Chiller in service per 13010-1 section 4.1.3, RF: CV24
- 4. Ack/Reset alarms
- 5. Freeze simulator

1.

Setup time: 10 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS:The crew is preparing to reduce power to 75% to remove MFP B from service. BTRS
demineralizers 4, 5, 6, and 7 have been equilibrated with the current RCS boron
concentration. In addition, the extra RO has placed the BTRS system in standby
alignment.Assigned Task:The USS has directed you to "Initiate boration of RCS using BTRS demineralizers 4, 5,
6, and 7".Task Standard:RCS boration established using BTRS.

START TIME: _____

STEP SAT	STEP 1 SAT 🛛 🖉 UNSAT 🗆 🕿				
	Establ	ish prestart alignment			
2&[] 2&[] 2&[]	• Verify • Place • BTR\$	/ standby alignment IAW section 4.1.2 <i>(1)</i> the BTRS Chiller in service IAW section 4.1.3 <i>(2)</i> S Demin outlet isolation valves open <i>(3) (4)</i>			
CUES:	(1) (2) (3) (4)	"The extra RO has performed section 4.1.2." "The ABO has placed the BTRS Chiller in service." If requested, "The USS desires that demins 4, 5, 6, and 7 be used to borate the RCS." "The ABO has opened 1-1208-U4-263, 262, 261, and 260. The SSS will ensure the IV is performed. The USS will ensure the DEMIN CONTROL LOG is updated."			
STEP CRITIC SAT	2 CAL (+) ದಿಸ Align E	UNSAT ロダ 3TRS System for Boration			
80 80 80 80 80 80 80 80	 BTR: BTR:<td>S Demin Isolation valve, HS-7010E open S Demin Isolation valve, HS-7010D open S Demin Isolation valve, HS-7010C open S Demin Isolation valve, HS-7010B open quested (1) 387 to 0% Borate position Ire HV-8115 remains open e TIC-381A in manual at 0% demand</td>	S Demin Isolation valve, HS-7010E open S Demin Isolation valve, HS-7010D open S Demin Isolation valve, HS-7010C open S Demin Isolation valve, HS-7010B open quested (1) 387 to 0% Borate position Ire HV-8115 remains open e TIC-381A in manual at 0% demand			
CUES:	(1) "TI	he extra RO will perform the IV."			

STEP 3 CRITICAL (♦) SAT □ ≤ UNSAT □ ≤

Initiate boration

- S□ ◆ Place HS-10351 in the BORATE position
- Verify white BORATE light lit (this will occur after auto system alignment is complete)
- ► Ensure HV-7054 is OPEN
- Science → Close HV-8115 by placing HS-8115 in AUTO
- Adjust TIC-381 to ≈ 140° and place controller in AUTO (adjust pot if required)
- Verify BTRS demin inlet @ 140° on TI-381 and return header @ 115° on TI-386.
- ► HIC-387 output lowered to initiate boration
- Boronometer indication of BTRS outlet concentration rising

STEP SAT	່4 ⊡ຮ UNS	AT De	
	Report to US	SS	
20	RCS boration	on initiated using BTRS	

STOP TIME: _____

			<u></u>
	SOUTHERN COMI	PANY	
	Energy to Serve Yo	ur World [™]	
	PLANT VOC	GTLE	
	CONTROL ROOM (OPERATOR	
	JOB PERFORMANC	E MEASUR	E
	RQ-JP-13509	-001	
	BYPASS CONTAINMENT HI-1 FOLLOW	ING A LOSS OF	HEAT SINK
	Revision 4	ŀ	
	September 10,	2001	
Written By	: M. C. Henry	Date:	9/10/2001
Approved By	: R. D. Brigdon	Date:	9/11/2001

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.						
Initial Conditions:	While responding to a Loss of Heat Sink on Unit, Containment pressure reached the Hi-1 setpoint. The crew is preparing to establish feedwater flow in accordance with step 6 of 19231-C.					
Assigned Task:	The USS has directed you to "Bypass Containment Hi-1 pressure channels PB936B and PB935B by initiating 13509-C."					

 Task Standard:
 Containment Hi-1 pressure bistables bypassed.

		·	
OPERATOR'S NAME:			
EVALUATION DATE:	//		
JPM TITLE:	Bypass Contair	ment Hi-1 Following a Loss of	Heat Sink
REVISION:	4 Septerr	nber 10, 2001	
COMPLETION TIME:	10 minutes		
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 37051 054000EA1.01 6	RO: 4.5 SRO: 4.5	
Evaluation Method	[] Performed	[] Simulated	
Evaluation Location	[] Simulator	[] Control Room	[] Unit 1 [] Unit 2
Performance Time:	minutes		
OVERALL JPM EVAL	UATION	[] SATISFACTORY	[] UNSATISFACTORY
Examiner Comments:			

This JPM is based on 13509-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

- 1. 2.
- 13509-C, BTI Panel Operation Two (2) BTI panel keys

COMPONENT LOCATION: Main Control Room

Note to Examiner: Permission from the USS must be obtained to open the Protection Cabinet doors. A BTI key may be obtained from the USS.

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.

While responding to a Loss of Heat Sink on Unit ____, Containment pressure reached INITIAL CONDITIONS: the Hi-1 setpoint. The crew is preparing to establish feedwater flow in accordance with step 6 of 19231-C. The USS has directed you to "Bypass Containment Hi-1 pressure channels ___ - PB936B ASSIGNED TASK: and - PB935B by initiating 13509-C."

Containment Hi-1 pressure bistables bypassed. TASK STANDARD:

JPM STEPS

START TIME: _____

STEP 1 SAT ⊡∡	UNSAT De
Verify Note:	initial conditions Permission from the appropriate USS will be required to open the Protection Cabinet doors to access the BTI panels Discussion of the requirements to obtain 2 BTI panel keys will satisfy performance of the step.
Image: Second secon	cklist 2 & 3 bistables circled (13509-C) in BTI Enable keys <i>(reference above note)</i> y all bypass switches on selected panel positioned in NORMAL y circuit breaker is ON y red power available LED illuminated
STEP 2 CRITICAL (♦) SAT □∞	UNSAT De
Bypas	s NSSS Channel II Hi-1 bistable, 936B
>>.□ + BTI >>.□ + Keyl >>.□ + Verif >>.□ + PB9 >>.□ + Verif >>.□ + Verif	Enable Key inserted into keylock ock switch positioned to BYPASS ENABLE & Verify LED illuminates iy ALB05B02 illuminated 36B BTI switch #34 positioned to BYPASS iy 936B LED illuminated iy TSLB extinguished
STEP 3 CRITICAL (♦) SAT □∠ Bypas	UNSAT ⊡∞ s NSSS Channel III Hi-1 bistable, 935B
Image: Second state • Verify Image: Second state • Verify Image: Second state • Verify Image: Second state • BTI Image: Second state • BTI Image: Second state • Keyl Image: Second state • Verify	y all bypass switches on selected panel positioned in normal y circuit breaker is ON y red power available LED illuminated Enable Key inserted into keylock ock switch positioned to BYPASS ENABLE & Verify LED illuminates y ALB05C02 illuminated 35B BTI switch #34 positioned to BYPASS y 935B LED illuminated

• Verify TSLB extinguished

STEF SAT	°4 Пе	UNSAT	0e		 	
	Report	to USS				
20	Conta	ainment Hi	-1 Channels 936 and 935 a	are bypassed	 	

STOP TIME: _____



Energy to Serve Your World™

PLANT VOGTLE

CONTROL ROOM OPERATOR

JOB PERFORMANCE MEASURE

RQ-JP-60328-001-0118038-003

CONTROL PRZR PRESSURE AND SG LEVEL FROM REMOTE SHUTDOWN PANELS

Revision 1416

July 4, 1997August 15, 2001

Written By : George GunnM. C. Henry Date: 7/04/978/15/2001

Approved By : Leon Ray xxxxxxxR. D. Brigdon Date: 7/04xx/97998/2/19998x/16xx/2001

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.						
Initial Conditions:	Unit control room has been evacuated due to fire. You have responded to Shutdown Panel PRZR pressure is 2200 psig and lowering. SG WR levels are $\approx 60\%$ and lowering.					
Assigned Task:	The USS has directed you to "Restore PRZR pressure and SG level using 18038, steps 11 and 12 <u>."-</u>					

Task Standard:	PRZR pressure and SG level controlled within the allowed control band
	from the remote shutdown panels.

r								
OPERATOR'S NAME:	<u> </u>							
EVALUATION DATE:	//							;
JPM TITLE:	Control PRZR	Pressure	and SG	level Fro	m Rer	note Shutdowr	Panels	
REVISION:	1 4 <u>16</u> July 4,	1997 <u>Au</u>	gust 15, 2	<u>:001</u>				
COMPLETION TIME:	5 - <u>10 minutes</u>							
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 60010 000068EG12 4, 6, 12	RO:	3.8	SRO:	4.0			
Evaluation Method	[] Performed		[] Simu	ulated				
Evaluation Location	[] Simulator		[] Cont	rol Room	I	[] Unit 1	[] Unit 2	
Performance Time:	minutes							
OVERALL JPM EVALU	JATION	[] SA	TISFACT	ORY		[] UNSATIS	SFACTORY	
Examiner Comments:								
Examiner's Signature:					_			

This JPM is based on the latest rev of 18038-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:	1.	18038-1/2, Operation From Remote Shutdown Panels
	2.	PSDA(B) room key

COMPONENT LOCATION: PSDA(B) Rooms, Control Building, Level A

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.

 INITIAL CONDITIONS:
 Unit_____ control room has been evacuated due to fire. You have responded to Shutdown Panel_____. PRZR pressure is 2200 psig and lowering. SG WR levels are ≈ 60% and lowering.

 Assigned Task:
 The USS has directed you to "Restore PRZR pressure and SG level using 18038, steps 11 and 12.".

 TASK STANDARD:
 PRZR pressure and SG level controlled within the allowed control band from the remote shutdown panels.
JPM STEPS

START TIME:

STEP 1	
CRITICAL	ł

SAT 🗆 🔊 UNSAT 🗆 🔊

Control PRZR pressure

Note: All controls would have been transferred to Local at step 7. The operator should demonstrate knowledge of pressure control by expressing the need to operate sprays/heaters to stabilize pressure between 2220 and 2260 psig.

- 20 ♦ PORV PV-455A(456A) closed (1)
- 2 [PSDA only] Sprays PV-455B and PV-455C closed
- Backup heater HS-10469B(10470B) in ON 20
- 20 Heaters and Sprays operated to maintain PRZR pressure between 2220 and 2260 psig (2)

CUES:

- (1) Provide indication that PRZR pressure is 2200 psig and lowering slowly. (2)
 - Provide indication that PRZR pressure is 2220 psig and rising slowly (see 2nd-note above)

STEP 2 **CRITICAL (+)**

SAT De UNSAT De

Control Steam Generator level

The operator should demonstrate knowledge of level control by expressing the need to adjust AFW flow to stabilize SG Note: WR levels between 65% and 7570%.

- MDAFW pump A(B) running (1) 20
- ♦ Flow control FV-5137 and FV-5139(FV-5134 and FV-5132) throttled open \Box
- 20 Miniflow FV-5155(5154) verified open
- >⊛□ • AFW flow verified (2)
- 20 • FCVs operated to maintain SG WR levels between 65% and 75% (3)

CUES:

- (1) Provide indication that WR levels are 60% on SG 1(2) and 59% on SG 4(3) and both are slowly lowering".
 - Provide indication that AFW flow is 175 gpm to SG 1(2) and 190 gpm to SG 4(3) (2)
- (3) Provide indication that WR SG Levels are slowly rising".

STEF SAT	°3 □≪	UNSAT	⊡ <i>e</i> s		
	Rep	ort to USS			
				······································	
20	• PRZR pressure and SG level being maintained				
STOF	TIME:				



Initial Conditions:	During a pressure relief operation, a spurious CVI was actuated while I&C was troubleshooting a faulty slave relay. The testing has been terminated and the CVI signal has been reset.
Assigned Task:	The USS has verified the existing Gaseous Release Permit is still valid and has directed you to "Initiate containment pressure relief".

 Task Standard:
 Containment pressure reduced to zero and pressure relief terminated.

OPERATOR'S NAME:					
EVALUATION DATE:	//				
JPM TITLE:	Reduce Contai	nment Pressure F	Following CVI	I	
REVISION:	10 <u>11</u> March	2, 1998<u>October 5</u>	<u>, 2000</u>		
COMPLETION TIME:	8 minutes	<u>This JP</u> This JPM not t	<u>M to be use</u> o be used fo	<u>d for</u> Initial Licen: ⊭ r Annual Requal 	se Exam Only Exam
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 29006 029000A103	RO: 3.0	SRO: 3.(3	
Evaluation Method	[] Performed	[] Sim	ulated		
Evaluation Location	[] Simulator	[] Con	trol Room	[] Unit 1	[] Unit 2
Performance Time:	minutes				
OVERALL JPM EVALI	JATION	[] SATISFACI	ORY	[] UNSATISF	FACTORY
Examiner Comments:					
Examiner's Signature: _					

This JPM is based on the latest rev of 13125-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

1. 13125, Containment Purge System **REQUIRED ITEMS:** 1. Reset to IC14 SIMULATOR SETUP: Place Mini-Purge supply fan in service per 13125 2. Remove Mini-Purge supply fan from service when Containment 3. pressure is ≈ 0.5 psig Ack/Reset alarms 4. Freeze simulator 5. Setup time: 10 minutes

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

INITIAL CONDITIONS:	During a pressure relief operation, a spurious CVI was actuated while I&C was troubleshooting a faulty slave relay. The testing has been terminated and the CVI signal has been reset.
ASSIGNED TASK:	The USS has verified the existing Gaseous Release Permit is still valid and has directed you to "Initiate containment pressure relief".
TASK STANDARD:	Containment pressure reduced to zero and pressure relief terminated.

JPM STEPS

START TIME: _____

STEP SAT	?1 ⊡ຮ UNSAT ⊡ຮ	
	Select procedure and section	
≥.□ ≫.च	•13125 section 4.4.1 selected (1) (2) • Containment Sumps monitored during release (3)	
CUES	 (1) If requested, "The USS does not desire to start additional containment coolers." (2) When requested, "The USS has obtained an updated gaseous release permit." (3) "The common RQ will monitor the Containment Normal-Sump trends." 	
STEP	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	
SEQ SAT	1 □≤ UNSAT □≤	
	Initiate containment pressure relief	
I ———	Or the improvement are source werified between 0.2 and 1.4 pairs	_

CUES:

(1) If requested, "The ABO reports that air is isolated to HV-2632B and the damper is open."
 (21) If requested, "The USS has logged the initiation of Cnmt pressure relief and notified Chemistry."

STEP 3 CRITICAL (♦) SEQ 2 SAT □ ∞ UNSAT □ ∞

Place containment mini-purge exhaust fan in service

_			
_			
~	-	_	
_		_	

Science → Containment pressure <+0.3 psig</p>

- Verify HV-2632B open (1)
- S□ ♦ Mini-purge exhaust fan running using HS-2631B
- B☐ <u>Place</u> HV-12592 in AUTO

CUES:

(1) If requested, "The ABO has verified HV-2632B is open."

JPM STEPS

STEP 4
CRITICAL (+)
SAT 🗆 🖉 UNSAT 🗆 🖉
Stop pressure relief
 Containment pressure -0.1 to +0.1 psig (1)
A□ ♦ Mini-purge exhaust fan STOPPED
Mini-purge exhaust damper HV-12592 CLOSED
Bestore air to HV-2632B (1)
CUES:
(1) If requested, "The ABO- <u>USS has restored air-to-HV-2632b and verifies that the damper is</u>
closedwill log the final containment pressure and stop time on the gaseous
release permit."
STEP 5
SAT 🗆 🖉 UNSAT 🗇 🦉
Document termination of containment pressure relief
S□ • Chemistry notified (1)
•The following valves verified CLOSED using Checklist 3
Preaccess purge inlet HV-2593
Mini-purge exhaust cntmt isolations HV-2628B and HV-2629B
Mini-purge supply cntmt isolations HV-2626B and HV-2627B
• Independent verification requested for Checklist 3 (42)
CUES:
(1) "The SSS will perform the IV The USS will notify Chemistry that the pressure relief is secured."
(2) "The EXTRA RO will perform the IV on checklist 3."
STEP 6
SAT 🗆 🖉 UNSAT 🗆 🔊
Report to USS

• Containment pressure relief completed

STOP TIME: _____



REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.				
Initial Conditions:	Unit control room has been evacuated due to fireAA02/BA03 is de-energized and the EDG is ready to locally start.			
Assigned Task:	The USS has directed you to "Locally start DGA/B and energize Unit Train 4160V and 480V buses with steps B1 through B13 of 18038, Attachment B."			

Task Standard: 1E switchgear locally energized.

OPERATOR'S NAME:				
EVALUATION DATE:	//			
JPM TITLE:	Locally Energiz	ze Train B Switchgear Follow	wing Local Diesel Start	
REVISION:				
COMPLETION TIME:	minutes			
<u> </u>				<u> </u>
Evaluation Method	[] Performed	[] Simulated		
Evaluation Location	[] Simulator	[] Control Room	[] Unit 1 [] U	Unit 2
Performance Time:	minutes	; 		
OVERALL JPM EVAL	UATION	[] SATISFACTORY	[] UNSATISFACTO	DRY
Examiner Comments:				

This JPM is based on the latest rev of 18038-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS: 1. 18038 Attachment B, Starting and Placing DG A(B) on a Dead Bus From Outside the Control Room 2. AA02(BA03) room key

COMPONENT LOCATION: EDG rooms & 1E 4160 VAC Switchgerar Rooms

DIRECTIONS TO OPERATOR				
You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.				
REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.				
INITIAL CONDITIONS:	Unit control room has been evacuated due to fireAA02/BA03 is de-energized and the EDG is ready to locally start.			
ASSIGNED TASK:	The USS has directed you to "Locally start DG A/B and energize Unit Train 4160V and 480V buses with steps B1 through B13 of 18038, Attachment B."			
TASK STANDARD:	1E switchgear locally energized.			

START TIME: ___

Control generator frequency at 60 Hz using [1/2-HS-4518A (4519A)]

STEP 1

CRITICAL (+) SEQ 1

SAT De UNSAT De

Align DG for Local Starting

- Sa□ Establish communications
- Reset lockout relays A, B, C if required
- Verify Local/Remote switch in local [1/2-HS4516 (4517)]
- UNIT 2 Train B only:
 - Place Fuel Oil Pump Transfer switches to local (2HS-9045A and 2HS-9046A) (located on back of MCC 2BBF)
- Verify Control power breakers on front of engine control panel are shut
- B Place Unit/Parallel switch in UNIT [1/2-HS-4414A(4452A)]

STEP 2 CRITICAL (+) SEQ 1

SAT 🗆 🔊 UNSAT 🗆 🖉

Locally Start DG

- B□ Alert people in EDG room of engine start
- ➢□ ◆ Depress manual start pushbotton [1/2-HS-4569A(4570A)]
- >>□ Red starting lamp energizes
- Red shtudown system active light energizes
- Starting air rolls engine → Starting air rolls engine
- Red running lamp energizes at 200 RPM
- ▶□ Blue ready to load lamp energizes at 400 RPM
- Generator field flashes and voltage stabilizes between 3750-4300 VAC
- Monitor DG jacket water temperatures < 200 degrees F (positions 21 & 22)
- Scontrol generator voltage at 4160 VAC using [1/2-HS-4488A (4494A)]
- ☆□ ◆ Control generator frequency at 60 Hz using [1/2-HS-4518A (4519A)]

STEP 3

CRITICAL (+) SEQ 1

SAT DE UNSAT DE

Open the normal incoming breaker

Breaker AA02-05 (BA03-01) transfer switch in LOCAL
Breaker AA02-05 (BA03-01) OPEN

STEP 4 CRITICAL (+) SEQ 2 SAT □ ∞ UNSAT □ ∞	
Energize bus from Diesel Generator	
 Breaker AA02-19 (BA03-19) transfer switch in LOCAL Breaker AA02-19 (BA03-19) CLOSED 	:
STEP 5 CRITICAL (♦) SAT □ ≠ UNSAT □ ≠ Energize 480V load centers	
 The following transfer switches in LOCAL and associated breakers CLOSED: AA02-10(BA03-06) AA02-20(BA03-04) AA02-21(BA03-09) AA02-22(BA03-18) 	
STEP 6 SAT ⊡జ UNSAT ⊡జ Report to USS	

>>□ • 4160V and 480V buses energized

STOP TIME: _____

	,						
SOUTHERN COMI							
Energy to Serve Yo	ur World [™]						
PLANT VOO	GTLE						
CONTROL ROOM C	OPERATOR						
JOB PERFORMANC	E MEASUR	E					
RQ-JP-18034-002							
 Turbine Driven AFW Pump Local Manu	ual Control w	ithout DC Power					
Revision 1							
August 27, 20	001						
Million Du M C Honny	Data	8/27/2001					
	Dale.	0/2//2001					
Approved By : R. D. Brigdon	Date:	9/11/2001					

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.						
Initial Conditions:	The plant just experienced a trip due to a lightning strike in the switchyard. This caused a lock out relay to actuate onAA02 and a fault onCD1. The MDAFW pump B is tagged out for maintenance.					
Assigned Task:	The USS, with SS approval, has directed you to "Locally start the Unit TDAFW pump using Attachment E of 18034"					

Task Standard:

TDAFW pump operating with proper recirculation flow or discharge pressure.

OPERATOR'S NAME:	
EVALUATION DATE:	//
JPM TITLE:	Turbine Driven AFW Pump Local Manual Control without DC Power
REVISION:	1 August 27, 2001
COMPLETION TIME:	10 minutes
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 20009 061000A204 RO: 3.4 SRO: 3.8 6, 12,
r	
Evaluation Method	[] Performed [] Simulated
Evaluation Location	[] Simulator [] Control Room [] Unit 1 [] Unit 2
Performance Time:	minutes
OVERALL JPM EVAL	UATION [] SATISFACTORY [] UNSATISFACTORY
Examiner Comments:	
Examiner's Signature:	
11	

This JPM is based on 18034-1. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS:

18034-1/2 Attachment E, TDAFW Pump Local w/o DC Power

COMPONENT LOCATION:

TDAFWP Room

1.

DIRECTIONS TO OPERATOR

You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.

REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.

INITIAL CONDITIONS:	The plant just experienced a trip due to a lightning strike in the switchyard. This caused a lock out relay to actuate onAA02 and a fault onCD1. The MDAFW pump B is tagged out for maintenance.
ASSIGNED TASK:	The USS, with SS approval, has directed you to "Locally start the Unit TDAFW pump using Attachment E of 18034"
TASK STANDARD:	TDAFW pump operating with proper recirculation flow or discharge pressure.

START TIME:

S	T	ΈP	1	
\sim	۸	72		

UNSAT 🗆 🔊 SAT Dø

Establish Communications with Control Room

• Establish communications with required control room via telephone, page, headset, or radio. <u>م</u>

STEP 2		
SAT 🖽 🖉	UNSAT	⊡ø

Verify steam supply valve shut

• Verify that ____-HV-5106 is CLOSED. (1) 20

CUES:

(1) If located and verified correctly, state "__-HV-5106 is in the position you see now."

STEP 3 UNSAT 🗆 🔊 SAT 🗖 🖉

Verify Trip and Throttle Valve open

• Verify that TDAFW Pump Trip & Throttle Valve is LATCHED. (1) \Box • Verify that TDAFW Pump Trip & Throttle Valve is OPEN. (2) 20

CUES:

(1) If located and verified correctly, state "Trip and Throttle Valve latching mechaninsm is in the position you see now."

(2) If located and verified correctly, state "Trip and Throttle Valve is in the position you see now."

STEP 4 UNSAT 🗖 🔊 SAT 🗖 🖉

Locate FI-15100 to allow monitoring TDAFW Pump performance

• Locate __-FI-15100 in TDAFW Pump room. 20

STEP	5		
CRITIC	CAL (♦)	
SAT] ø	UNSAT	Пø

Start TDAFW pump to supply feed flow to Steam Generators

☆□ ◆ Throttle OPEN TDAFW Pump Steam Supply __-HV-5106. (1)

► Observe _-FI-15100 and Adjust _-HV-5106 to attain 140gpm miniflow. (2) (3)

CUES:

- (1) If valve throttled open correctly, state "Steam flow can be heard due to opening __-HV-5106."
- (2) Give cues to determine the operators ability to control proper miniflow rate as required. As steam flow is increases, feedback an increase in miniflow flowrate. The operator should take actions to control at approximately 140 gpm.
- (3) If requested, give feedback that "Discharge pressure reads 1650 psig."

STEP 6 SAT பட UNSAT பட	
Report to USS	
• TDAFW pump is operating and in service per Attachment E of 18034	

STOP TIME: _____



REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.						
Initial Conditions:	The crew is responding to a loss of all AC power on Unit per 19100. Power has been lost for 12 minutes and is not expected to be restored in the near future.					
Assigned Task:	gned Task: The USS has directed you to "Locally close the following Unit valves:					
	 ACCW supply isolation ORC,HV-1979(AB-A), 					
	 RCP seal injection isolation valves ORC,HV- 8103A/B(AB-A), &HV-8103C/D(FHB-A), 					
	RCP seal return isolation ORC,HV-8100(AB-A)."					

Task Standard:

RCP seals locally isolated.

OPERATOR'S NAME:								
EVALUATION DATE:	//							
JPM TITLE:	Locally Isolate F	RCP sea	ls					
REVISION:	13 Septem	nbe <mark>r 10</mark> , :	2001					
COMPLETION TIME:	15 minutes							
Application: Task Number: K/A Number: 10CFR55.45 Ref.:	RO/SRO 37018 000055EG06 4, 6, 12	RO:	3.8	SRO:	4.1			
							`	
Evaluation Method	[] Performed		[] Sim	ulated				
Evaluation Location	[] Simulator		[] Con	trol Roon	n	[] Unit 1	[] Unit 2	
Performance Time:	minutes							
OVERALL JPM EVAL	UATION	[] SA	TISFACI	TORY		[] UNSATIS	FACTORY	
Examiner Comments:								
					¹ **,			
Examinar's Signature:								

L

This JPM is based on the latest rev of 19100-C. Verify this JPM is in accord with the latest procedural revision prior to use. Cues preceded by a "©..." are provided to enhance simulation of this JPM and should only be used when the simulator is unavailable. Cues designated by (#) are to be provided to the examinee during the performance of this JPM.

REQUIRED ITEMS: 1. RWP and associated dosimetry

2. Hearing Protection

COMPONENT LOCATION: UNIT 1

1979 (AB-A12); 8103A/B (AB-A09); 8103C/D (FHB-A10); and 8100 (AB-A09)

<u>UNIT_2</u>

1979 (AB-A105); 8103A/B (AB-A103); 8103C/D (FHB-A01); and 8100 (AB-A103)

DIRECTIONS TO OPERATOR							
You will be given information describing the Initial Conditions, Assigned Task, and the Task Standard. Please ensure you understand the assigned task before beginning. You will be allowed access to any item normally used to perform this task.							
F	REMEMBER: All steps required for this task are to be simulated. Plant equipment is not to be operated.						
INITIAL CONDITIONS:	The crew is responding to a loss of all AC power on Unit per 19100. Power has been lost for 12 minutes and is not expected to be restored in the near future.						
ASSIGNED TASK:	The USS has directed you to "Locally close the following Unit valves:						
	 ACCW supply isolation outside,HV-1979(AB-A), 						
	 RCP seal injection isolation valves,HV-8103A/B(AB-A), andHV-8103C/D(FHB-A), 						
	RCP seal return isolation outside,HV-8100(AB-A)."						
TASK STANDARD:	RCP seals locally isolated.						

START TIME: _____

STEP 1 CRITICAL (A)
Isolate ACCW Return from RCPs
 ACCW containment isolation HV-1979 located. ► HV-1979 CLOSED.
STEP 2 CRITICAL (♦) SAT □ ∞ UNSAT □ ∞
Isolate RCP seal injection Note: If these valves are inaccessible, the path of ingress should be to the closest point allowed by radiological conditions.
 RCP seal injections HV-8103A and B located. HV-8103A and B CLOSED. RCP seal injections HV-8103C and D located. HV-8103C and D CLOSED.
STEP 3 CRITICAL (+) SAT □ ∞ UNSAT □ ∞
Isolate RCP seal return Note: If this valve is inaccessible, the path of ingress should be to the closest point allowed by radiological conditions.
 Seal return HV-8100 located. HV-8100 CLOSED.
STEP 4 SAT De UNSAT De
Report to USS
Score and a second
STOP TIME: