

February 26, 2003

Mr. J. V. Parrish
Chief Executive Officer
Energy Northwest
P.O. Box 968 (Mail Drop 1023)
Richland, WA 99352-0968

SUBJECT: COLUMBIA GENERATING STATION - CORRECTION TO AMENDMENT
NO. 182 (TAC NO. MB6684)

Dear Mr. Parrish:

On January 9, 2003, the Commission issued Amendment No. 182 to Facility Operating License No. NPF-21 for the Columbia Generating Station. The amendment was in response to your application dated October 22, 2002.

The amendment revised the administrative section of the technical specifications in accordance with Technical Specification Task Force, Item 258, Revision 4, "Changes to Section 5.0, Administrative Controls."

By letter dated February 4, 2003, the NRC staff issued a correction letter that reissued the technical specifications due to a reproduction error. In the January 9, 2003, amendment and the February 4, 2003, correction letter, page 5.7-5 of the technical specifications was omitted. Enclosed is page 5.7-5. We apologize for any inconvenience this may have caused.

Sincerely,

/RA by Drew Holland for/

Brian Benney, Project Manager, Section
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Page 5.7-5

cc w/encl: See next page

February 26, 2003

Mr. J. V. Parrish
Chief Executive Officer
Energy Northwest
P.O. Box 968 (Mail Drop 1023)
Richland, WA 99352-0968

SUBJECT: COLUMBIA GENERATING STATION - CORRECTION TO AMENDMENT
NO. 182 (TAC NO. MB6684)

Dear Mr. Parrish:

On January 9, 2003, the Commission issued Amendment No. 182 to Facility Operating License No. NPF-21 for the Columbia Generating Station. The amendment was in response to your application dated October 22, 2002.

The amendment revised the administrative section of the technical specifications in accordance with Technical Specification Task Force, Item 258, Revision 4, "Changes to Section 5.0, Administrative Controls."

By letter dated February 4, 2003, the NRC staff issued a correction letter that reissued the technical specifications due to a reproduction error. In the January 9, 2003, amendment and the February 4, 2003, correction letter, page 5.7-5 of the technical specifications was omitted. Enclosed is page 5.7-5. We apologize for any inconvenience this may have caused.

Sincerely,

/RA by Drew Holland for/

Brian Benney, Project Manager, Section
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Page 5.7-5

cc w/encl: See next page

DISTRIBUTION:

PUBLIC
PDIV-2 Reading
RidsNrrDlpmLpdiv (WRuland)
RidsNrrDlpmLpdii (HBerkow)
RidsNrrPMBBenney
RidsNrrLAEPeyton
GHill (2)
RidsOgcRp
RidsAcrsAcnwMailCenter
RDennig (RidsNrrDrip)
WBeckner (NRR/DRIP/DROP)
WBJones, Region IV/DRP/RPB-E

ADAMS Accession No.: ML030570658

NRR-106

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	Drew Holland for BBenney	EPeyton	SDembek
DATE	2/26/03	2/26/03	2/26/03

DOCUMENT NAME: G:\PDIV-2\Wnp2_Columbia Generating\second correction letter.wpd
OFFICIAL RECORD COPY

Columbia Generating Station

cc:

Mr. Rodney L. Webring (Mail Drop PE04)
Vice President, Nuclear Generation
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Mr. Albert E. Mouncer (Mail Drop PE01)
Vice President, Corporate Services/
General Counsel/CFO
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Chairman
Energy Facility Site Evaluation Council
P.O. Box 43172
Olympia, WA 98504-3172

Mr. D. W. Coleman (Mail Drop PE20)
Manager, Performance Assessment
and Regulatory Programs
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Ms. Christina Perino (Mail Drop PE20)
Manager, Licensing
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Chairman
Benton County Board of Commissioners
P.O. Box 190
Prosser, WA 99350-0190

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 69
Richland, WA 99352-0069

Mr. Dale Atkinson (Mail Drop PE08)
Vice President, Technical Services
Energy Northwest
P.O. Box 968
Richland, WA 99352-0968

Thomas C. Poindexter, Esq.
Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Mr. Bob Nichols
Executive Policy Division
Office of the Governor
P.O. Box 43113
Olympia, WA 98504-3113

Ms. Lynn Albin
Washington State Department of Health
P.O. Box 7827
Olympia, WA 98504-7827

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation), but less than 500 rads/hour (at 1 meter from the radiation source or from any surface penetrated by the radiation) (continued)

- f. Such individual areas that are within a larger area where no enclosure exists for purpose of locking and where no enclosure can reasonably be constructed around the individual area need not be controlled by a locked door or gate, nor continuously guarded, but shall be barricaded, conspicuously posted, and a clearly visible flashing light shall be activated at the area as a warning device.