

February 27, 2003

Mr. Jay K. Thayer
Site Vice President - Vermont Yankee
Entergy Nuclear Vermont Yankee, LLC
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

SUBJECT: VERMONT YANKEE NUCLEAR POWER STATION - ISSUANCE OF
AMENDMENT RE: GENERIC POSITION TITLES AND OTHER
ADMINISTRATIVE CHANGES (TAC NO. MB6925)

Dear Mr. Thayer:

The Commission has issued the enclosed Amendment No. 214 to Facility Operating License DPR-28 for the Vermont Yankee Nuclear Power Station, in response to your application dated December 10, 2002, as supplemented on January 20, 2003.

The amendment changes the diesel fuel specification to a more current revision in Technical Specification (TS) 4.10.C. The change also makes administrative revisions to reflect generic position titles in TS 6.0, correct page numbers and titles in the Table of Contents, and to delete the General Table of Contents. Bases pages were also revised to reflect the fuel specification revision as well as to make administrative changes to provide clarity and correct a misspelling.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

Robert M. Pulsifer, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures: 1. Amendment No. 214 to
License No. DPR-28
2. Safety Evaluation

cc w/encls: See next page

Vermont Yankee Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. David R. Lewis
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, DC 20037-1128

Ms. Christine S. Salembier, Commissioner
Vermont Department of Public Service
112 State Street
Montpelier, VT 05620-2601

Mr. Michael H. Dworkin, Chairman
Public Service Board
State of Vermont
112 State Street
Montpelier, VT 05620-2701

Chairman, Board of Selectmen
Town of Vernon
P.O. Box 116
Vernon, VT 05354-0116

Mr. Michael Hamer
Operating Experience Coordinator
Entergy Nuclear Vermont Yankee, LLC
P.O. Box 250
Governor Hunt Road
Vernon, VT 05354

G. Dana Bisbee, Esq.
Deputy Attorney General
33 Capitol Street
Concord, NH 03301-6937

Chief, Safety Unit
Office of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Ms. Deborah B. Katz
Box 83
Shelburne Falls, MA 01370

Mr. Raymond N. McCandless
Vermont Department of Health
Division of Occupational
and Radiological Health
108 Cherry Street
Burlington, VT 05402

Mr. Gautam Sen
Manager, Licensing
Entergy Nuclear Vermont Yankee, LLC
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Resident Inspector
Vermont Yankee Nuclear Power Station
U. S. Nuclear Regulatory Commission
P.O. Box 176
Vernon, VT 05354

Director, Massachusetts Emergency
Management Agency
ATTN: James Muckerheide
400 Worcester Rd.
Framingham, MA 01702-5399

Jonathan M. Block, Esq.
Main Street
P.O. Box 566
Putney, VT 05346-0566

Mr. Michael R. Kansler
Sr. Vice President and Chief Operating
Officer
Entergy Nuclear Operations, Inc.
Mail Stop 12A
440 Hamilton Ave.
White Plains, NY 10601

Mr. John J. Kelly
Director, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 1060

February 27, 2003

Mr. Jay K. Thayer
Site Vice President - Vermont Yankee
Entergy Nuclear Vermont Yankee, LLC
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

SUBJECT: VERMONT YANKEE NUCLEAR POWER STATION - ISSUANCE OF
AMENDMENT RE: GENERIC POSITION TITLES AND OTHER
ADMINISTRATIVE CHANGES (TAC NO. MB6925)

Dear Mr. Thayer:

The Commission has issued the enclosed Amendment No. 214 to Facility Operating License DPR-28 for the Vermont Yankee Nuclear Power Station, in response to your application dated December 10, 2002, as supplemented on January 20, 2003.

The amendment changes the diesel fuel specification to a more current revision in Technical Specification (TS) 4.10.C. The change also makes administrative revisions to reflect generic position titles in TS 6.0, correct page numbers and titles in the Table of Contents, and to delete the General Table of Contents. Bases pages were also revised to reflect the fuel specification revision as well as to make administrative changes to provide clarity and correct a misspelling.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

Robert M. Pulsifer, Project Manager, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures: 1. Amendment No. 214 to
License No. DPR-28
2. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION:

PUBLIC J. Clifford OGC ACRS Tech Branch
PDI-2 R/F R. Pulsifer G. Hill (2) J. Bobiak, RI C. Anderson, RI
S. Richards C. Raynor W. Beckner F. Arner, RI

Accession Number: Letter: ML030570728, Text Spec: ML , Package: ML

OFFICE	PDI-2/PM	PDI-2/LA	OGC	PDI-2/SC
NAME	RPulsifer	CRaynor	SUttal	JClifford
DATE	02/24/03	02/24/03	2/24/03	2/26/03

OFFICIAL RECORD COPY

ENERGY NUCLEAR VERMONT YANKEE, LLC
AND ENERGY NUCLEAR OPERATIONS, INC.
DOCKET NO. 50-271
VERMONT YANKEE NUCLEAR POWER STATION
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 214
License No. DPR-28

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (the licensees) dated December 10, 2002, as supplemented on January 20, 2003, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-28 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 214, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

James W. Clifford, Chief, Section 2
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: February 27, 2003

ATTACHMENT TO LICENSE AMENDMENT NO. 214

FACILITY OPERATING LICENSE NO. DPR-28

DOCKET NO. 50-271

Replace the following page(s) of the Appendix A Technical Specifications with the attached revised page(s). The revised page(s) are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
i	i
ii	ii
iii	iii
iv	iv
v	---
111b	111b
163	163
218	218
223	223
255	255
256	256
257	257
258	258
264	264

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 214 TO FACILITY OPERATING LICENSE NO. DPR-28

ENTERGY NUCLEAR VERMONT YANKEE, LLC
AND ENTERGY NUCLEAR OPERATIONS, INC.
VERMONT YANKEE NUCLEAR POWER STATION

DOCKET NO. 50-271

1.0 INTRODUCTION

By letter dated December 10, 2002, as supplemented on January 20, 2003, Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. (the licensees) submitted a request to amend the Vermont Yankee Nuclear Power Station Technical Specifications (TSs). The proposed amendment would revise the TSs to change the diesel fuel specification to a more current revision in TS 4.10.C. The amendment would also make administrative revisions to reflect generic position titles in TS 6.0, correct page numbers and titles in the Table of Contents, and to delete the General Table of Contents. Bases pages were also revised to reflect the fuel specification revision as well as to make administrative changes to provide clarity and correct a misspelling. The January 20, 2003, supplement did not expand the scope of the original Federal Register notice.

2.0 REGULATORY EVALUATION

The staff finds that the licensee in Attachment 1 of its submittal identified the applicable regulatory requirements for revising the plant specific personnel titles. The regulatory requirements for which the staff based its acceptance are ANSI N18.1-1971 or Regulatory Guide 1.8, "Qualification and Training of Personnel for Nuclear Power Plants." In addition the staff used Regulatory Guide 1.137, "Fuel Oil Systems for Standby Diesel Generators" in the review of the diesel fuel oil specification change.

3.0 TECHNICAL EVALUATION

3.1 Position Title Changes

The licensee proposes to change the position titles in the TS to generic titles as provided in ANSI N18.1-1971 or Regulatory Guide 1.8 instead of plant specific personnel titles. This change will make titles consistent with other Entergy Nuclear Operations, Inc. facilities. This change does not change any requirements, qualifications, or responsibilities of the individuals in these positions, and is strictly an administrative change. The plant specific titles will be

identified in licensee-controlled documents such as the Technical Requirements Manual and the Quality Assurance Manual. The following are the proposed changes:

- 3.1.A The term "Plant Manager" is changed to "plant manager" in TS Sections 6.1.A and B, 6.2.A.2, and 6.7.B.1.b.
- 3.1.B The term "Shift Supervisor" is changed to "shift supervisor" in TS Sections 6.1.C and 6.5.B.
- 3.1.C The term "operations superintendent" is changed to "operations manager" and the term "assistant operations superintendent" is changed to "assistant operations manager" in TS Section 6.2.B.7.
- 3.1.D In TS Section 6.2.B.8, the term "the Shift Engineer" is changed to "a shift engineer" and the term "Shift Supervisor (SS)" is changed to "shift supervisor."
- 3.1.E The term "Shift Engineer" in TS Section 6.2.C is changed to "shift engineer."
- 3.1.F In TS Sections 6.5.A.3 and 6.5.B, the term "Radiation Protection Manager" is changed to "radiation protection manager."
- 3.1.G In TS Section 6.2.A.3, change the text, "corporate executive with direct responsibility for the plant" to "site vice president."
- 3.1.H In order to delineate where the plant-specific titles will be discussed, the licensee proposes to add the following statement to TS Section 6.2.A.1. "The plant-specific titles of those personnel fulfilling the responsibilities of the positions delineated in these Technical Specifications shall be documented in the Technical Requirements Manual."

The changes involving the generic position titles and the location of the specific plant position delineation meet the intent of ANSI N18.1-1971 or Regulatory Guide 1.8 and are, therefore, acceptable.

3.2 Diesel Generator Fuel Oil

The current TS Surveillance Requirement 4.10.C requires that once a month the diesel fuel oil be sampled for quality and that it meets applicable limits on Table I of ASTM D975-68. The licensee proposes to use the more current revision of this specification, specifically ASTM D975-02. This revision provides more information and guidance than the 1968 standard. TS 4.10.C will be changed from ASTM D975-68 to ASTM D975-02. Changing this revision does not affect the safe operation of the diesels or affect the safety analysis and remains within the guidelines of NUREG 1.137. This change is acceptable because the more current revision provides up-to-date guidance and information regarding diesel fuel oil testing and meets the requirements of the applicable ASTM standard.

3.3 Administrative Changes

Several administrative changes are being made to provide clarity and consistency between the Table of Contents and the text of the TS. These changes reflect TS Section titles, page numbers, spelling, and deletion of the general table of contents.

3.3.A Page i, "Table of Contents General" (TOCG) is being deleted from the current TS because it provides no additional information than that provided by the revised Table of Contents (TOC). The TOCG was incomplete and unnecessary. Line item 1.0, "Definitions" and Sections 6.1 thru 6.7 from the TOCG are being relocated to the TOC for completeness. The relocation of Sections 1.0 and 6.1 thru 6.7 from the TOCG and the deletion of the TOCG is acceptable because the TOCG was incomplete and is redundant to the revised TOC. With the deletion of the TOCG, all subsequent pages ii through v will be renumbered i through iv.

3.3.B Proposed page i

1. Current TS page ii will be renumbered i and the text "(Continued)" will be deleted with the deletion of TOCG discussed in 3.3.A which will make this page the first page of this section.
2. The title of line item 3.2.D of the TOC is being changed to reflect the correct title of Section 3.2.D in the TS which reads, "Off-Gas System Isolation."
3. The title of line item 3.2.F of the TOC is being changed to reflect the correct title of Section 3.2.F in the TS which reads, "Mechanical Vacuum Pump Isolation Instrumentation."
4. The page number for Section 3.2.G in the TOC is being changed from page 35 to 36 and the page number for Sections 3.2.I, J, and K are being changed from page 36 to 37. Sections 3.2.G, I, J, and K were moved in Amendment No. 212, dated September 18, 2002, and the TOC was not changed at that time to reflect those changes.

The changes to page i are acceptable because they are administrative changes that accommodate the change in 3.3.A, actual TS titles, and a previous amendment.

3.3.C Proposed page ii

1. The title of line item 3.4.C of the TOC is being changed to reflect the correct title of section 3.4.C in the TS which reads, "Standby Liquid Control System Tank - Borated Solution."
2. The title of line item 3.6.E of the TOC is being changed to reflect the correct title of Section 3.6.E in the TS which reads, "Structural Integrity and Operating Testing."
3. The title of line item 3.7.B of the TOC is being changed to reflect the correct title of Section 3.7.B in the TS which reads, "Standby Gas Treatment System."

4. The page number for Section 3.6.C in the TOC is being changed from page 119 to 118; the page number for Section 3.6, "Bases," from page 139 to 138, and the page number for Section 3.7.D was changed from page 156 to 158. Sections 3.6.C, 3.6 Bases, and 3.7.D were moved in Amendment No. 190, dated July 18, 2000, Amendment No. 203, dated May 4, 2001, and Amendment No. 197, dated March 23, 2001, respectively. The TOC was not changed at the time these amendments were issued to reflect those changes.

The changes to page ii are acceptable because they are administrative changes that accommodate actual TS titles and previous TS amendments.

3.3.D Proposed page iii

1. The number 4.9 under the column Surveillance for line item Section 3.9 in the TOC is being deleted because Sections 3.9 and 4.9 had been deleted in Amendment No. 193, dated August 24, 2000.
2. The title of Section 3.11.A of the TOC is being changed to reflect the correct title of Section 3.11.A which reads, "Average Planar Linear Heat Generation Rate (APLHGR)."
3. The title of Section 3.11.B of the TOC is being changed to reflect the correct title of Section 3.11.B which reads, "Linear Heat Generation Rate (LHGR)."
4. The title of Section 3.11.C of the TOC is being changed to reflect the correct title of Section 3.11.C which reads, "Minimum Critical Power Ratio."

The changes to page iii are acceptable because they are administrative changes that accommodate actual TS titles in the TSs and a change from a previous amendment.

3.3.E The misspelling of the word "reactor" has been corrected on Bases page 111b for Section 3.5.G. This is an administrative change and the staff has no objection to this change.

3.3.F The text "1000 psig" was changed to "normal operating pressure" in the Bases for Section 3.7.A to provide clarity and correctness of the basis for the pressure suppression chamber water volume. The staff has no objection to this change.

3.3.G In TS Section 6.2.4, there was an extra tab at the beginning of the paragraph that was removed to provide consistency with the format of the TS. This is acceptable because it is administrative in nature.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Vermont State official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The amendment also changes recordkeeping, reporting, or administrative procedures or requirements. The NRC staff has determined that the amendment involves no significant increase in amounts, and no significant change in the types of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (68 FR 2802). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9) and (10). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Robert Pulsifer

Date: February 27, 2003