

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of $\leq L_a$, 0.25 percent by weight of the containment air per 24 hours at P_a , 12.0 psig, and
- b. A combined leakage rate of $\leq 0.60 L_a$ for all penetrations and valves subject to Types B and C tests when pressurized to P_a .

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding $0.75 L_a$, or (b) with the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding $0.60 L_a$, restore the overall integrated leakage rate to $\leq 0.75 L_a$ and the combined leakage rate for all penetrations and valves subject to Types B and C tests to $\leq 0.60 L_a$ prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 Perform leakage rate testing in accordance with 10 CFR 50 Appendix J Option B, except as modified by NRC-approved exemptions, and Regulatory Guide 1.163, dated September 1995. See Notes 1 and 2.

- a. Each containment air lock shall be verified to be in compliance with the requirements of Specification 3.6.1.3.
- b. The provisions of Specification 4.0.2 are not applicable.

Notes:

- 1 A one-time exception to the requirement to perform post-modification Type A testing is allowed for the steam generators and associated piping, as components of the containment barrier. For this case, ASME Section XI leak testing will be used to verify the leak tightness of the repaired or modified portions of the containment barrier. Entry into MODES 3 and 4 following the extended outage that commenced in 1997 may be made to perform this testing.
- 2 The Type A testing frequency specified in NEI 94-01, Revision 0, Paragraph 9.2.3, as "...at least once per 10 years based on acceptable performance history" is modified to be "...at least once per 15 years based on acceptable performance history." This change applies only to the interval following the Type A test performed in October 1992.

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

- 3.6.1.2 Containment leakage rates shall be limited to:
- a. An overall integrated leakage rate of $\leq L_a$, 0.25 percent by weight of the containment air per 24 hours at P_a , 12 psig, and
 - b. A combined leakage rate of $\leq 0.60 L_a$ for all penetrations and valves subject to Types B and C tests when pressurized to P_a .

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding $0.75 L_a$, or (b) with the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding $0.60 L_a$, restore the overall integrated leakage rate to $\leq 0.75 L_a$ and the combined leakage rate for all penetrations and valves subject to Types B and C tests to $\leq 0.60 L_a$ prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

- 4.6.1.2 Perform leakage rate testing in accordance with 10 CFR 50 Appendix J Option B, except as modified by NRC-approved exemptions, and Regulatory Guide 1.163, dated September 1995. See Note 1.
- a. Each containment air lock shall be verified to be in compliance with the requirements of Specification 3.6.1.3.
 - b. The provisions of Specification 4.0.2 are not applicable.

Notes:

- 1 The Type A testing frequency specified in NEI 94-01, Revision 0, Paragraph 9.2.3, as "...at least once per 10 years based on acceptable performance history" is modified to be "...at least once per 15 years based on acceptable performance history." This change applies only to the interval following the Type A test performed in May 1992.