

February 28, 2003

Mr. P. E. Katz, Vice President
Calvert Cliffs Nuclear Power Plant, Inc.
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 -
REQUEST FOR ADDITIONAL INFORMATION REGARDING INTERIM
INSPECTION REQUIREMENTS FOR REACTOR PRESSURE VESSEL HEAD
(TAC NOS. MB7752 AND MB7753)

Dear Mr. Katz:

By letter dated February 18, 2003, you responded to the Nuclear Regulatory Commission (NRC) Order dated February 11, 2003, regarding interim inspection requirements for reactor pressure vessel head. In reviewing that submittal, the NRC staff raised three groups of questions which were transmitted to your staff by a publicly available e-mail (Accession No. ML030570009). On February 26, 2003, the NRC staff held a conference call with your staff to discuss those questions and agreed that only the first group of questions (reproduced below) needed to be formally conveyed.

What is the justification that coverage up to 0.75 inches above the weld will provide an adequate level of quality and safety? In other words, provide justification that increasing the scope of inspection to 2 inches above the J-groove will not provide an increase in quality and safety. Are there residual stress data that indicates that 0.75 inches is a sufficient level above the weld, or is there any other basis that demonstrates an acceptable level of quality and safety for the restricted inspections?

Your staff indicated that you can respond on or before March 15, 2003.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate 1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

cc: See next page

Mr. P. E. Katz, Vice President
Calvert Cliffs Nuclear Power Plant, Inc.
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

February 28, 2003

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 -
REQUEST FOR ADDITIONAL INFORMATION REGARDING INTERIM
INSPECTION REQUIREMENTS FOR REACTOR PRESSURE VESSEL HEAD
(TAC NOS. MB7752 AND MB7753)

Dear Mr. Katz:

By letter dated February 18, 2003, you responded to the Nuclear Regulatory Commission (NRC) Order dated February 11, 2003, regarding interim inspection requirements for reactor pressure vessel head. In reviewing that submittal, the NRC staff raised three groups of questions which were transmitted to your staff by a publicly available e-mail (Accession No. ML030570009). On February 26, 2003, the NRC staff held a conference call with your staff to discuss those questions and agreed that only the first group of questions (reproduced below) needed to be formally conveyed.

What is the justification that coverage up to 0.75 inches above the weld will provide an adequate level of quality and safety? In other words, provide justification that increasing the scope of inspection to 2 inches above the J-groove will not provide an increase in quality and safety. Are there residual stress data that indicates that 0.75 inches is a sufficient level above the weld, or is there any other basis that demonstrates an acceptable level of quality and safety for the restricted inspections?

Your staff indicated that you can respond on or before March 15, 2003.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate 1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

cc: See next page

DISTRIBUTION:

PUBLIC	PDI-1 R/F	DSkay	BPlatchek, RGN -1	RLaufer
OGC	ACRS	AHiser	BFu	SBloom

Accession Number: **ML030590023**

OFFICE	PDI-1/PM	PDI-1/LA	EMCB	EMCB/SC	PDI-1/SC
NAME	PTam	SLittle	WKoo for AHiser	WKoo for TChan	PTam for RLaufer
DATE	2/27/03	2/27/03	2/27/03	2/27/03	2/28/03

OFFICIAL RECORD COPY

Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2

cc:

President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, MD 20678

Kristen A. Burger, Esquire
Maryland People's Counsel
6 St. Paul Centre
Suite 2102
Baltimore, MD 21202-1631

James Petro, Esquire
Counsel
Constellation Power Source
111 Market Street
Baltimore, MD 21202

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P.O. Box 33111
Baltimore, MD 21218

Jay E. Silberg, Esquire
Shaw, Pittman, Potts, and Trowbridge
2300 N Street, NW
Washington, DC 20037

Mr. Loren F. Donatell
NRC Technical Training Center
5700 Brainerd Road
Chattanooga, TN 37411-4017

Mark Geckle
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

Resident Inspector
U.S. Nuclear Regulatory
Commission
P.O. Box 287
St. Leonard, MD 20685

Mr. Richard I. McLean, Manager
Nuclear Programs
Power Plant Research Program
Maryland Dept. of Natural Resources
Tawes State Office Building, B3
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406