

March 5, 2003

MEMORANDUM TO: File

FROM: Jack N. Donohew, Senior Project Manager, Section 2 /RA/
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: TELECONFERENCE ON RELIEF REQUEST NO. I2R-23 FOR
WOLF CREEK GENERATING STATION (TAC NO. MB4077)

In its letter dated February 12, 2002 (ET 02-0001), Wolf Creek Nuclear Operating Corporation (the licensee) submitted Relief Request (RR) I2R-23, which requested approval for the use of an alternative to the requirements of Section XI, inservice inspection program, of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (i.e, the Code).

On February 11, 2003, a teleconference with the licensee was held to clarify staff questions regarding the ultrasonic volumetric coverage obtained by the licensee, as noted in RR I2R-23, for the Steam Generator A Nozzle-to-Shell Weld EBB01 A-11-W.

In the teleconference, the staff inquired if the licensee obtained 100% examination volume from one side with its 60 degree perpendicular scan, but only took credit for 50% of the exam. The licensee informed the staff that it only credited 50% of the examination because the examination was performed from one side of the weld only and that the configuration of the subject nozzle-to-shell component prevented the examiner from performing the examination from both sides of the weld.

The staff also requested the licensee to clarify the reasons for the 0% volumetric examination coverage for the 45 and 60 degree parallel scans and the 0 degree scan. The licensee informed the staff that due to the configuration of the subject nozzle-to-shell component, they experienced lift off of the transducer and could not obtain the required Code coverage.

Docket No. 50-482

March 5, 2003

MEMORANDUM TO: Docket File

FROM: Jack N. Donohew, Senior Project Manager, Section 2 /RA/
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

SUBJECT: TELECONFERENCE ON RELIEF REQUEST NO. I2R-23 FOR
WOLF CREEK GENERATING STATION (TAC NO. MB4077)

In its letter dated February 12, 2002 (ET 02-0001), Wolf Creek Nuclear Operating Corporation (the licensee) submitted Relief Request (RR) I2R-23, which requested approval for the use of an alternative to the requirements of Section XI, inservice inspection program, of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (i.e, the Code).

On February 11, 2003, a teleconference with the licensee was held to clarify staff questions regarding the ultrasonic volumetric coverage obtained by the licensee, as noted in RR I2R-23, for the Steam Generator A Nozzle-to-Shell Weld EBB01 A-11-W.

In the teleconference, the staff inquired if the licensee obtained 100% examination volume from one side with its 60 degree perpendicular scan, but only took credit for 50% of the exam. The licensee informed the staff that it only credited 50% of the examination because the examination was performed from one side of the weld only and that the configuration of the subject nozzle-to-shell component prevented the examiner from performing the examination from both sides of the weld.

The staff also requested the licensee to clarify the reasons for the 0% volumetric examination coverage for the 45 and 60 degree parallel scans and the 0 degree scan. The licensee informed the staff that due to the configuration of the subject nozzle-to-shell component, they experienced lift off of the transducer and could not obtain the required Code coverage.

Docket No. 50-482

DISTRIBUTION:

PUBLIC

PDIV-2 Reading

RidsDlpmLpdiv (HBerkow)

RidsNrrPMJDonohew

RidsNrrLAEPeyton

TMcLellan (NRR/DE/EMCB)

ADAMS Accession No.: ML030640016

NRR-106

OFFICE	PDIV-2/PM	PDIV-2/LA	EMCB	PDIV-2/SC
NAME	JDonohew	EPeyton	TMcLellan	RGramm for SDembek
DATE	2/28/03	2/28/03	3/03/03	3/4/03

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML030640016.wpd

OFFICIAL RECORD COPY