

Mail Envelope Properties (3E491EF3.D6F : 21 : 21114)

Subject: Fwd: RAI for Cooper TS Amentment
Creation Date: 2/11/03 11:04AM
From: David Jaffe

Created By: DHJ@nrc.gov

Recipients	Action	Date & Time
NPPD.Com	Transferred	02/11/03 11:04AM
CIBlaire (<u>CIBlaire@NPPD.Com</u>)		

Post Office	Delivered	Route
		NPPD.Com

Files	Size	Date & Time
Mail MESSAGE	468	02/11/03 11:04AM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: No
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened

From: David Jaffe
To: CIBlaire@NPPD.Com
Date: 2/11/03 11:04AM
Subject: Fwd: RAI for Cooper TS Amentment

Please call me. Thanks

From: Tai Huang
To: David Jaffe
Date: 2/11/03 10:38AM
Subject: RAI for Cooper TS Amentment

CC: RXC

MEMORANDUM FOR: David H. Jaffe, Project Manager
Project Directorate IV-1
Division of Licensing Project Management

FROM: Ralph Caruso, Chief
BWR Systems and Nuclear Performance Section
Reactor Systems Branch
Division of Systems Safety and Analysis

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION RELATED TO
COOPER LICENSE AMENDMENT FOR SAFETY LIMITS
MINIMUM CRITICAL POWER RATIO (TAC NO. MB6816)

Plant Name: Cooper Nuclear Station
Utility: Nebraska Public Power District
TAC No(s): MB6816
Docket No(s): 50-298
Operating License: DPR-46
Project Directorate: Project Directorate IV-1
Project Manager: David Jaffe
Review Branch: SRXB/DSSA
Review Status: Incomplete

By letter dated November 15, 2002, Nebraska Public Power District made application to amend the Technical Specifications (TS) of the Cooper Nuclear Station. The proposed change includes revising the safety limit minimum critical power ratio (SLMCPR) value in TS 2.1.1.2. The Reactor Systems Branch has reviewed the licensee's amendment request and prepared the attached request for additional information. Please transmit to the licensee.

Attachment:
AS stated

cc:
G. Holahan
J. Zwolinsky

Contact: T. Huang, SRXB/DSSA
415-2867

ATTACHMENT 1

REQUEST FOR ADDITIONAL INFORMATION
RELATING TO AMENDMENT NO. TO LICENSE NO. DPR-46
NEBRASKA PUBLIC POWER DISTRICT
COOPER NUCLEAR STATION
DOCKET NO. 50-298

The staff has reviewed the Technical Specifications amendment request dated November 15, 2002, and identified question to be clarified by the licensee in relation to the information stated in Enclosure 2 of the submittal.

1. Describe detailed core design process including approved methods used, based on a plant/cycle specific parameters, to model the unfavorable bias for those bundle that are top-peaked power shape through the entire cycle operation. Also, provide a Table to show net adjustment to SLMCPR for both dual loop operation and single loop operation including BOC, MOC and EOC if applicable.