

From: Thomas Alexion
To: SBENNE2@entergy.com
Date: 2/21/03 8:25AM
Subject: POWER UPRATE STARTUP TESTING REPORT SUPPLEMENT

Steve,

See the attached questions.

Tom

REQUEST FOR ADDITIONAL INFORMATION
POWER UPRATE STARTUP TESTING REPORT SUPPLEMENT
ARKANSAS NUCLEAR ONE, UNIT 2

The following questions are related to the report mentioned above, dated January 31, 2003:

1. Please clarify what is meant by secondary side differential pressure. Is it the difference between the steam generator inlet pressure (feedwater) and the outlet pressure (steam pressure)?
2. Please discuss the cause for the higher than anticipated differential pressure. Provide any test data supporting your assessment.
3. Please discuss the implications of these higher than anticipated differential pressures. Discuss all analyses that may be potentially affected by these results (e.g., because the pressure drop across the steam generator (or secondary side pressure) is used in the analyses, or because the analyses uses methods/codes similar to those used in determining the "projected" pressure drop). Please provide the results of any re-analyses performed.

Mail Envelope Properties (3E5628E6.D05 : 0 : 20628)

Subject: POWER UPRATE STARTUP TESTING REPORT SUPPLEMENT
Creation Date: 2/21/03 8:25AM
From: Thomas Alexion

Created By: TWA@nrc.gov

Recipients	Action	Date & Time
entergy.com	Transferred	02/21/03 08:26AM
SBENNE2 (<u>SBENNE2@entergy.com</u>)		

Post Office	Delivered	Route
		entergy.com

Files	Size	Date & Time
ANO2StartupRpt.wpd	2725	02/21/03 08:20AM
MESSAGE	667	02/21/03 08:25AM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened