

From: "BENNETT, STEVE A" <SBENNE2@entergy.com>
To: Tom Alexion <twalex@nrc.gov>
Date: 2/21/03 2:03PM

Tom,
I had to save it with a different file name to get it to save it.

steve

CC: "MEATHEANY, DANIEL J" <DMEATHE@entergy.com>

**Request for Additional Information
Request to Modify Steam Generator (SG) Tube Inspection Frequency
Arkansas Nuclear One, Unit 2 (ANO-2)**

NRC RAI 1.

The licensee located and removed a loose part approximately 12 inches above the cold leg tubesheet in the "B" SG. Were any loose parts left in service? If so, summarize the basis, including any analysis performed, for the conclusion that these loose parts will not cause unacceptable wear before the next scheduled inspection (2R17)?

ANO Response

There were no other loose parts identified. A 100 % bobbin inspection was performed in both generators. The only loose part identified was the one mentioned above which was removed. Visual inspections were also performed in both generators along the annulus and the tube lanes. No other foreign material was identified.

NRC RAI 2

Table 1 of the November 22, 2002, letter indicates that 271 special interest inspections were conducted. Please describe the results of these inspections. (The staff assumes that some of the results in Table 2 arose from the special interest inspections; however, a one-to-one comparison cannot be made.)

ANO Response

Upon review of the database, it was determined that the numbers specified in Table 1 were incorrect in Entergy's November 22, 2002 submittal [The information was improperly transcribed from the preservice inspection and what was significantly higher than the actual 2R15 data]. There were no tests performed that resulted in confirmed indications other than those associated with the loose part and wear at the AVB. The actual special interest inspections requested in RAI- 2 are properly detailed below in the replacement Table 1. Instead of "special interest", the more appropriate subject would be bobbin I-Codes, which could result in degradation based on confirmation with the plus point.

**Table 1
2R15 Eddy Current (ECT) Inspection Scope**

ECT Examination Type	Inspections Conducted		% Scope
	A	B	
Bobbin-	10637	10636 ^{Note 1}	100
U-bend Plus Point 1&2	181	181	100
Bobbin I-Codes (Total)	15	11	
Non-Quantifiable Indication (NQI)	9	5	
Distorted Support Indication (DSI)	2	0	
Distorted Freespan Indication (DFI)	4	6	

Note 1 One tube was plugged during fabrication due to an equipment failure. An inconel-690 welded plug was installed in both ends of the tube.

NRC RAI 3

The licensee indicates that SGs such as those at DC Cook, Farley, and South Texas have not experienced large amounts of wear. The licensee also indicates that these SGs are similar in design to the ANO-2 SGs.

- a. Provide details explaining the similarities and differences between the ANO-2 SGs and the SGs at the referenced plants.

ANO Response:

The new DC Cook 2, Farley 1 & 2, South Texas 1 and ANO- 2 steam generators are all Westinghouse designed. All contain Alloy 690 TT tubing with true U-bends and anti-vibration bars for support in the upper bundle. The original ANO-2 generators were CE designed with square bends and 3/4th inch diameter Alloy 600 mill annealed tubes. All plants were hydraulically expanded full depth in the tubesheet. The following is a summary of the plant information:

<u>Plant</u>	<u>Model</u>	<u>Tube Material</u>	<u>Tube Dimension</u>	<u>Support plate</u>	<u>Support Material</u>
Cook2	W54F	690TT	0.875 x 0.050	Broached	SS405
Farley1	W54F	690TT	0.875 x 0.050	Broached	SS405
Farley2	W54F	690TT	0.875 x 0.050	Broached	SS405
S Texas	WD94	690TT	0.687 x 0.040	Broached	SS508
ANO2	WD109	690TT	0.687 x 0.040	Broached	SS405

- b. What process is in place to gain relevant industry operating experience that may affect the operational assessment of ANO-2 during the proposed extended inspection interval?

Response:

All of the plants mentioned above are members of the EPRI Technical Advisory Group (TAG). The TAG meets about 3 times a year where industry relevant information is discussed. Additionally, ANO's industry events department tracks and communicates relevant information to the appropriate departments.

Mail Envelope Properties (3E5677D9.28D : 8 : 653)

Subject:
Creation Date: 2/21/03 2:01PM
From: "BENNETT, STEVE A" <SBENNE2@entergy.com>
Created By: SBENNE2@entergy.com

Recipients

nrc.gov
owf4_po.OWFN_DO
TWA (Thomas Alexion)

entergy.com
DMEATHE CC (MEATHEANY, DANIEL J)

Post Office

owf4_po.OWFN_DO

Route

nrc.gov
entergy.com

Files	Size	Date & Time
MESSAGE	80	02/21/03 02:01PM
Part.001	628	
2A0303XX draft.doc	45568	
Mime.822	64737	

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard