

March 10, 2003

Mr. John L. Skolds, President  
and Chief Nuclear Officer  
Exelon Nuclear  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-E  
Kennett Square, PA 19348

SUBJECT: LIMERICK GENERATING STATION, UNIT 2 - RE: DRAFT SAFETY  
EVALUATION FOR PROPOSED REVISION TO TECHNICAL  
SPECIFICATIONS SAFETY LIMIT MINIMUM CRITICAL POWER RATIO FOR  
CYCLE 8 OPERATION (TAC NO. MB6884)

Dear Mr. Skolds:

The Nuclear Regulatory Commission staff has reviewed the application from Limerick Generating Station, Unit 2 (LGS) dated November 21, 2002, as supplemented by letter dated February 25, 2003. The proposed amendment would revise the Technical Specifications for the safety limit for the minimum critical power ratio from its current value of 1.09 to 1.07 for two recirculation-loop operation, and from 1.11 to 1.09 for single recirculation-loop operation.

Enclosed is a draft safety evaluation (SE) for LGS. This draft SE is being withheld from public disclosure at this time because it may contain proprietary information.

We are providing this draft SE for the purpose of identifying if it contains any proprietary information pursuant to Section 2.790 of Title 10 of the *Code of Federal Regulations*. Please provide any comments that you may have on the enclosed draft SE with regard to the inclusion of proprietary information by March 13, 2003. Should a situation occur that prevents you from meeting that date, please contact Scott Wall of my staff at (301) 415-2855.

Sincerely,

**/RA/**

James W. Clifford, Chief, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-353

Enclosure: Draft Safety Evaluation (Licensee only)

cc w/o encl: See next page

Limerick Generating Station, Units 1 & 2

cc:

Vice President, General Counsel and  
Secretary  
Exelon Generation Company, LLC  
300 Exelon Way  
Kennett Square, PA 19348

Manager Licensing-Limerick and Peach  
Bottom  
Exelon Generation Company, LLC  
Nuclear Group Headquarters  
Correspondence Control  
P.O. Box 160  
Kennett Square, PA 19348

Site Vice President  
Limerick Generating Station  
Exelon Generation Company, LLC  
P.O. Box 2300  
Sanatoga, PA 19464

Plant Manager  
Limerick Generating Station  
Exelon Generation Company, LLC  
P.O. Box 2300  
Sanatoga, PA 19464

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Limerick Generating Station  
P.O. Box 596  
Pottstown, PA 19464

Chairman  
Board of Supervisors  
of Limerick Township  
646 West Ridge Pike  
Linfield, PA 19468

Chief-Division of Nuclear Safety  
PA Dept. of Environmental Resources  
P.O. Box 8469  
Harrisburg, PA 17105-8469

Library  
U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Vice President, Licensing and Regulatory  
Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Director-Licensing  
Mid-Atlantic Regional Operating Group  
Exelon Generation Company, LLC  
Nuclear Group Headquarters  
Correspondence Control  
P. O. Box 160  
Kennett Square, PA 19348

Correspondence Control Desk  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 1-N-1  
Kennett Square, PA 19348

Chief Operating Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Senior Vice President, Nuclear Services  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Limerick Generating Station, Units 1 & 2

cc:

Vice President, Mid-Atlantic Operations Support  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-N  
Kennett Square, PA 19348

Senior Vice President  
Mid-Atlantic Regional Operating Group  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-N  
Kennett Square, PA 19348

Regulatory Assurance Manager  
Limerick Generating Station  
Exelon Generation Company, LLC  
P.O. Box 2300  
Sanatoga, PA 19464

March 10, 2003

Mr. John L. Skolds, President  
and Chief Nuclear Officer  
Exelon Nuclear  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-E  
Kennett Square, PA 19348

SUBJECT: LIMERICK GENERATING STATION, UNIT 2 - RE: DRAFT SAFETY  
EVALUATION FOR PROPOSED REVISION TO TECHNICAL  
SPECIFICATIONS SAFETY LIMIT MINIMUM CRITICAL POWER RATIO FOR  
CYCLE 8 OPERATION (TAC NO. MB6884)

Dear Mr. Skolds:

The Nuclear Regulatory Commission staff has reviewed the application from Limerick Generating Station, Unit 2 (LGS) dated November 21, 2002, as supplemented by letter dated February 25, 2003. The proposed amendment would revise the Technical Specifications for the safety limit for the minimum critical power ratio from its current value of 1.09 to 1.07 for two recirculation-loop operation, and from 1.11 to 1.09 for single recirculation-loop operation.

Enclosed is a draft safety evaluation (SE) for LGS. This draft SE is being withheld from public disclosure at this time because it may contain proprietary information.

We are providing this draft SE for the purpose of identifying if it contains any proprietary information pursuant to Section 2.790 of Title 10 of the *Code of Federal Regulations*. Please provide any comments that you may have on the enclosed draft SE with regard to the inclusion of proprietary information by March 13, 2003. Should a situation occur that prevents you from meeting that date, please contact Scott Wall of my staff at (301) 415-2855.

Sincerely,

**/RA/**

James W. Clifford, Chief, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-353

Enclosure: Draft Safety Evaluation (Licensee only)

cc w/o encl: See next page

**DISTRIBUTION:**

PUBLIC PDI-2 R/F JClifford SWall MO'Brien  
RCaruso THuang RDennig RWeisman BPlatchek, RI

ACCESSION NO. ML030690619

OFFICE	PD1-2/PM	PD1-2/LA	PDI-2/SC
NAME	SWall	SLittle for MO'Brien	JBoska for JClifford
DATE	3/10/03	3/10/03	3-10-03

**Official Record Copy**