

3.6 CONTAINMENT SYSTEMS

3.6.1.1 Primary Containment-Operating

LCO 3.6.1.1 Primary containment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

-----NOTE-----  
Applicable Conditions and Required Actions are not required to be entered for the Inclined Fuel Transfer System (IFTS) penetration for up to 20 hours per 12 month period when the IFTS blind flange is unbolted.  
-----

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Primary containment inoperable.	A.1 Restore primary containment to OPERABLE status.	1 hour
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.6.1.3.4 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. Only required to be met in MODES 1, 2, and 3.</li> <li>2. Valves and blind flanges in high radiation areas may be verified by use of administrative means.</li> <li>3. Not required to be met for PCIVs that are open under administrative controls.</li> <li>4. Not required to be met for the Inclined Fuel Transfer System (IFTS) penetration when the associated primary containment blind flange is removed, provided that the Fuel Handling Building Fuel Transfer Pool water level is maintained <math>\geq 40'</math>, the upper containment pool water level is <math>\geq 22</math> ft 9 inches above the reactor pressure vessel flange and the suppression pool water level is maintained at <math>\geq 17</math> ft 11.7 inches, the fuel transfer and storage pool supply isolation valve is closed, the upper pool IFTS gate is installed, and the IFTS transfer tube drain valve remains closed. The IFTS transfer tube drain valve may be opened under administrative controls. Removal of the IFTS blind flange shall not exceed 60 days per cycle while in MODES 1, 2, or 3.</li> </ol> <p>-----</p> <p>Verify each primary containment isolation manual valve and blind flange that is located inside primary containment, drywell, or steam tunnel and is required to be closed during accident conditions is closed.</p>	<p>Prior to entering MODE 2 or 3 from MODE 4, if not performed within the previous 92 days</p>

(continued)