

RULEMAKING ISSUE NEGATIVE CONSENT

May 15, 2003

SECY-03-0078

FOR: The Commissioners

FROM: William D. Travers
Executive Director for Operations

SUBJECT: NRC STAFF-SPONSORED RULEMAKING - CODES AND STANDARDS
(10 CFR 50.55a)

PURPOSE:

To obtain Commission approval to proceed with rulemaking to amend Title 10 of the *Code of Federal Regulations* Section 50.55a (10 CFR 50.55a), "Codes and Standards," to incorporate by reference the 2001 Edition and 2002 Addenda of the American Society of Mechanical Engineers (ASME) Code in accordance with the attached rulemaking plan.

To obtain Commission approval to conduct subsequent rulemakings to update 10 CFR 50.55a approximately every 2 to 3 years without Commission approval in accordance with the attached rulemaking plan.

BACKGROUND:

The ASME *Boiler and Pressure Vessel Code* (BPV Code) and *Code for Operation and Maintenance of Nuclear Power Plants* (OM Code) have been revised on a continuing basis over the years to provide updated provisions for design, construction, and inservice inspection of pressure boundary components and testing of pumps and valves in nuclear power plants. Typically, the subsequent editions and addenda of the ASME Code contain many new and revised Code provisions. Some new and revised Code provisions have increased requirements and others have decreased requirements, but overall, the staff considers the evolution of the ASME Code to result in a net improvement in the measures for constructing and inspecting components and testing pumps and valves. New editions of the ASME BPV and OM Codes are issued every 3 years. Addenda to the editions are issued yearly except in years when a new edition is issued. Section 50.55a was most recently updated on September 26, 2002

CONTACT: Steve Tingen, NRR/DE/EMEB
(301) 415-1280

(67 FR 60520), to incorporate by reference the 1998 Edition of the ASME BPV and OM Codes, up to and including the 2000 Addenda.

DISCUSSION:

The staff requests approval to initiate rulemaking to amend Nuclear Regulatory Commission (NRC) regulations in 10 CFR 50.55a to incorporate by reference the following: (1) the 2001 Edition and 2002 Addenda of Section III, Division 1, "Rules for Construction of Nuclear Power Plant Components," of the ASME BPV Code; (2) the 2001 Edition and 2002 Addenda of Section XI, Division 1, "Rules for Inservice Inspection of Nuclear Power Plant Components," of the ASME BPV Code; and (3) the 2001 Edition and 2002 Addenda of the ASME OM Code.

The ASME BPV Code and the ASME OM Code that will be incorporated by reference will provide updated rules for the construction of light-water-cooled nuclear power plant components and for the inservice inspection and inservice testing of those components. Approval of the proposed amendment would permit the use of the most recent methods for construction, inservice inspection, and inservice testing of nuclear power plant components. Timely endorsement of the most recent edition and addenda of the ASME Code may reduce the number of relief requests by licensees, thereby increasing efficiency and effectiveness and reducing unnecessary burden while maintaining safety. Timely NRC endorsement of more recent ASME Code editions and addenda should also increase public confidence. Therefore, the NRC staff requests authorization to initiate the proposed rulemaking. The plan for proceeding with the rulemaking to amend 10 CFR 50.55a is provided in the attachment.

In addition, nuclear power plant licensees have expressed concern that the NRC process for reviewing and approving new editions and addenda of the ASME Code is slow, and therefore, licensees have the additional burden of submitting relief requests to use editions and addenda of the Code not yet approved. The Commission has also expressed concern regarding the timeliness of NRC review and approval of new editions and addenda of the ASME Code. Although the previous rulemaking that updated 10 CFR 50.55a was timely, in other cases a number of years have passed between updates. The staff believes further efficiencies can be gained through relatively minor changes in NRC's rulemaking procedure without affecting the minimum procedural requirements that Federal agencies are required to follow when promulgating rules.

To improve the timeliness of NRC review and approval of new editions and addenda of the ASME Code, the staff proposes to conduct rulemakings to keep current the ASME Code editions and addenda incorporated by reference in 10 CFR 50.55a at approximately 2 to 3 year intervals in accordance with the attached rulemaking plan. The 2 to 3 year interval is based on a typical schedule for a rulemaking requiring a proposed rule, public comment period, and final rule. The attached rulemaking plan will be used for rulemakings that are routine in nature and do not involve new policy issues. Since these rulemakings will not pertain to any significant questions of policy, they will be authorized in accordance with the authority delegated to the NRC's Executive Director for Operations. To further expedite the issuance of subsequent rulemakings that are routine in nature, the staff proposes to conduct subsequent rulemakings in accordance with the attached rulemaking plan. This action will eliminate the need to obtain Commission approval of each individual rulemaking plan for subsequent rulemakings.

RESOURCES:

The staff estimates resources of approximately 1.5 full-time equivalent positions on an annual basis to review new ASME Code editions and addenda and to conduct periodic rulemakings. These resource estimates are within current budget plans.

COORDINATION:

The Office of the General Counsel has no legal objection to this rulemaking plan. The Office of the Chief Financial Officer has reviewed the rulemaking plan for resource implications and has no objections to it.

RECOMMENDATION:

The staff recommends that the Commission approve the plan to proceed with the rulemaking to amend 10 CFR 50.55a to incorporate by reference the 2001 Edition and 2002 Addenda of the ASME BPV and OM Codes as described in the attached rulemaking plan.

It is also recommended that the Commission approve the staff's recommendation to conduct subsequent routine 10 CFR 50.55a updates to keep current the ASME Code editions and addenda incorporated by reference at 2 to 3 year intervals in accordance with the attached rulemaking plan without the need for future Commission approval.

Staff requests action within 10 days. Action will not be taken until the staff requirements memorandum is received. We consider this action to be within the delegated authority of the Executive Director for Operations.

/RA/

William D. Travers
Executive Director
for Operations

Attachment: As Stated

RESOURCES:

The staff estimates resources of approximately 1.5 full-time equivalent positions on an annual basis to review new ASME Code editions and addenda and to conduct periodic rulemakings. These resource estimates are within current budget plans.

COORDINATION:

The Office of the General Counsel has no legal objection to this rulemaking plan. The Office of the Chief Financial Officer has reviewed the rulemaking plan for resource implications and has no objections to it.

RECOMMENDATION:

The staff recommends that the Commission approve the plan to proceed with the rulemaking to amend 10 CFR 50.55a to incorporate by reference the 2001 Edition and 2002 Addenda of the ASME BPV and OM Codes as described in the attached rulemaking plan.

It is also recommended that the Commission approve the staff's recommendation to conduct subsequent routine 10 CFR 50.55a updates to keep current the ASME Code editions and addenda incorporated by reference at 2 to 3 year intervals in accordance with the attached rulemaking plan without the need for future Commission approval.

Staff requests action within 10 days. Action will not be taken until the staff requirements memorandum is received. We consider this action to be within the delegated authority of the Executive Director for Operations.

/RA/

William D. Travers
Executive Director
for Operations

Attachment: As Stated
ADAMS ACCESSION NO.:ML 030700408

*See Previous Concurrences

OFFICE	DE:EMEB	E	DE:EMEB		EMEB: BC	E	Tech. Editor		DE:DD	
NAME	STingen*		DTerao*		Elmbro*		PKleene*		WDean*	
DATE	03/10/03		03/10/03		03/11/03		3/18/03		3 /21/03	
OFFICE	DE:D		DRIP:RPRP		PMAS		RES		OGC	
NAME	RBarrett*		CGrimes*		MCase*		AThadani*		STreby*	
DATE	3 /25 /03		4 /23/03		4/3/03		4/17 /03		4/7/03	
OFFICE	CFO		ADM		OE		OSP		ADIP:AD	
NAME	JFunches*		MLesar*		FCongel*		PLohaus*		RBorchardt*	
DATE	4/3/03		3 /31/03		4/15/03		4 /17/03		4 / 29 /03	
OFFICE	ADT:AD		NRR:D		EDO					
NAME	BSheron*		SCollins*		WTravers					
DATE	4/29/03		5/01/03		5/15/03					

Rulemaking Plan
CODES AND STANDARDS

10 CFR Part 50.55a

Regulatory Requirements

The American Society of Mechanical Engineers (ASME) develops and publishes the *Boiler and Pressure Vessel Code* (BPV Code), which contains requirements for construction and inservice inspection (ISI) of nuclear power plant components, and the *Code for Operation and Maintenance of Nuclear Power Plants* (OM Code), which contains requirements for inservice testing (IST) of pumps and valves. New editions of the ASME Code are issued every 3 years. Addenda to the editions are issued annually except in years when a new edition is issued. The ASME Code is a national consensus standard developed by participants with broad and varied interests. All interested parties participate in the development of this standard.

The National Technology Transfer and Advancement Act of 1995, Pub. L. 104-113, requires agencies to use technical standards that are developed or adopted by voluntary consensus standards bodies unless the use of such a standard is inconsistent with applicable law or is otherwise impractical. It has been the policy of the Commission to periodically update § 50.55a to Title 10 of the *Code of Federal Regulations* (10 CFR 50.55a) to keep current the ASME Code editions and addenda incorporated by reference. Section 50.55a was most recently updated on September 26, 2002 (67 FR 60520) to incorporate by reference the 1998 Edition of the ASME BPV and OM Codes, up to and including the 2000 Addenda.

New applicants for a nuclear power plant submitting an application for a construction permit under 10 CFR Part 50 or a design certification under 10 CFR Part 52 are required to use the most recent edition and addenda of Section III, Division 1, of the ASME BPV Code incorporated by reference in 10 CFR 50.55a for the design and construction of the reactor coolant pressure boundary and Quality Group B and C components. Licensees of currently operating nuclear power plants may voluntarily update their construction Code of Record for any system or component to a later edition and addenda of Section III, Division 1, of the ASME BPV Code incorporated by reference in 10 CFR 50.55a at any time.

New applicants for a nuclear power plant submitting an application for an operating license under 10 CFR Part 50 or a combined operating license under 10 CFR Part 52 are required to use the most recent edition and addenda of Section XI, Division 1, of the ASME BPV Code incorporated by reference in 10 CFR 50.55a for the preservice inspection and ISI of nuclear power plant components. Licensees of currently operating nuclear power plants are required to use the most recent edition and addenda Section XI, Division 1, of the ASME BPV Code incorporated by reference in 10 CFR 50.55a when performing the required 120-month update of their ISI programs.

New applicants for a nuclear power plant submitting an application for an operating license under 10 CFR Part 50 or a combined operating license under 10 CFR Part 52 are required to use the most recent edition and addenda of the ASME OM Code incorporated by reference in

10 CFR 50.55a for the IST of nuclear power plant pumps and valves. Licensees of currently operating nuclear power plants are required to use the most recent edition and addenda of the ASME OM Code incorporated by reference in 10 CFR 50.55a when performing the required 120-month update of their IST programs.

Regulatory Options

The staff will conduct routine 10 CFR 50.55a updates that incorporate by reference newer editions and addenda of Section III, Division 1, and Section XI, Division 1, of the ASME BPV Code and the ASME OM Code at approximately 2 to 3 year intervals. The NRC's longstanding policy has been to update 10 CFR 50.55a to keep current the ASME Code editions and addenda incorporated by reference. This is codified in 10 CFR 50.55a, which requires licensees to revise their ISI and IST programs every 120 months to the latest edition and addenda of Section XI of the ASME BPV Code and the ASME OM Code incorporated by reference into 10 CFR 50.55a that are in effect 12 months prior to the start of a new 120-month ISI and IST interval. Thus, when the NRC endorses a more recent version of the Code, it is implementing this longstanding policy and requirement.

Rulemaking plans normally identify several regulatory options with respect to how to accomplish the desired rulemaking and best meet the agency's performance goals of maintaining safety, increasing public confidence, reducing unnecessary regulatory burden, and making NRC activities and decisions more effective, efficient, and realistic. However, regulatory options are not addressed in this rulemaking plan because the Commission's staff requirements memorandum dated April 13, 2000, directed the staff to follow the NRC's longstanding policy of updating 10 CFR 50.55a to incorporate by reference newer editions and addenda to the ASME BPV and OM Codes. If, in the future, the staff determines that it is not appropriate to conduct routine 10 CFR 50.55a updates, the staff will submit a rulemaking plan with regulatory options to the Commission for its consideration.

Impact on Licensees

The ASME Code has been revised on a continuing basis over the years to provide updated provisions for the design, construction, and ISI of pressure boundary components and the testing of pumps and valves in nuclear power plants. Typically, the subsequent editions and addenda of the ASME Code contain many new and revised Code provisions. Some new and revised Code provisions have increased requirements and others have decreased requirements, but overall, the staff considers the evolution of the ASME Code to result in a net improvement in the provisions for constructing and inspecting components and testing pumps and valves.

The costs for licensees to update their ISI and IST programs to more recent editions and addenda of the ASME Code are difficult to quantify; neither the NRC staff nor ASME performs detailed quantified cost/benefit analyses of the individual changes to the ASME Code, and industry cost estimates have not always been consistent. For example, when commenting on the *Federal Register* notice dated April 27, 1999 (64 FR 22580), the Nuclear Energy Institute estimated that it may cost a licensee up to \$1.5 million every 10 years to update ISI and IST programs, to revise procedures, and to train personnel. However, estimates from ASME indicated that the costs were significantly lower (\$200,000 to \$300,000 every 10 years). The staff notes that, in some instances, implementing a new edition of the ASME Code can result in cost savings that offset the implementation costs. For example, more recent editions of the

ASME Code permit the use of new, more cost-effective methods for construction, ISI, and IST.

Benefits

The proposed amendment is expected to maintain the overall protection of public health and safety while updating the rules to be consistent with the latest methods for construction, ISI, and IST specified by the ASME Code. Timely endorsement of newer ASME Code editions and addenda will likely reduce the number of licensee requests to use alternative Code requirements and requests for relief from Code requirements pursuant to 10 CFR 50.55a(a)(3), (f)(5), and (g)(5), thereby improving both NRC staff and licensees' efficiency and effectiveness and reducing unnecessary regulatory burden. The proposed amendment should also increase public confidence as a result of the use of the most up-to-date technologies and methods for design, construction, ISI, and IST of nuclear power plants components.

Office of the General Counsel (OGC) Legal Analysis

The proposed rule would amend 10 CFR 50.55a to endorse newer editions of Section III of the ASME BPV Code, Section XI of the ASME BPV Code, and the ASME OM Code on a continuing basis. The Section III requirements would apply to the construction of new nuclear power plants, while the requirements in Section XI and in the OM Code would apply to ISI and IST of currently operating nuclear power plants. Consistent with existing requirements, licensees would be required to revise their ISI and IST programs at the end of their current 120-month interval to the ASME Code edition and addenda incorporated by reference 12 months prior to the start of the next 120-month interval. At this time, OGC has not identified any legal objections to this rulemaking.

The staff will continue to obtain approval for incorporation by reference of the relevant editions and addenda of the ASME BPV and OM Codes from the Office of the Federal Register as required by 1 CFR Part 51. The Commission's proposal to endorse an industry consensus standard is consistent with the intent of the National Technology Transfer and Advancement Act of 1995. Nonetheless, in accordance with the law and Office of Management and Budget (OMB) Circular A-119, the Statement of Considerations must contain a statement requesting public comment regarding whether there are other national or international consensus standards that could be endorsed as an option to the ASME BPV and OM Codes.

OGC does not believe that the proposed rule will constitute a backfit as defined in 10 CFR 50.109(a)(1). OGC believes that the correct basis for this determination is the same as the basis for previous rulemakings updating 10 CFR 50.55a (67 FR 60520 and 64 FR 51370), namely, that the 120-month updating requirement is a longstanding part of the Commission's regulatory regime and that licensees understood this when they received their operating licenses. Despite this determination, OGC notes that nuclear power plant licensees disagreed with this rationale in their comments on previous 10 CFR 50.55a update rulemakings.

Category of Rule

Rulemakings that incorporate by reference later editions and addenda of the ASME Code are not considered "major rules" because they will not cause a major increase in costs for licensees to update and implement ISI and IST programs, the proposed rule's annual effect on the economy will be less than \$100 million, and these rulemakings will not have a significant adverse effect on licensees' ability to compete with foreign-based utilities. The effect of these

OGC Contact: Geary Mizuno, Senior Attorney

Contractual Assistance: None expected

Schedule

Proposed Rule to EDO The proposed rule to incorporate by reference the 2001 Edition and 2002 Addenda will be submitted to the EDO approximately 6 months after Commission approval of the rulemaking plan. All subsequent proposed rules will be submitted to the EDO every 2 to 3 years.

Publish Proposed Rule 1.5 months later

Final Rule to EDO Approximately 16 months after proposed rule is published in the *Federal Register*

Publish Final Rule 1.5 months later