

5.5 Programs and Manuals

---

5.5.1 Offsite Dose Calculation Manual (ODCM) (continued)

shall indicate the date (i.e., month and year) the change was implemented.

5.5.2 Primary Coolant Sources Outside Containment

This program provides controls to minimize leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to levels as low as practicable. The systems include the Core Spray, High Pressure Coolant Injection, Low Pressure Coolant Injection, Isolation Condenser, Shutdown Cooling, Reactor Water Cleanup, process sampling (until such time as a modification eliminates the PASS penetration as a potential leakage path), containment monitoring, and Standby Gas Treatment. The program shall include the following:

- a. Preventive maintenance and periodic visual inspection requirements; and
- b. Integrated leak test requirements for each system at 24 month intervals.

The provisions of SR 3.0.2 are applicable to the 24 month Frequency for performing integrated system leak test activities.

5.5.3 Deleted.

---

(continued)