

# **Nuclear Fuel Update**

## **Palo Verde Nuclear Generating Station**

**March 12, 2003**  
**Meeting with US NRC**

1



## **Review of 2002**

- ◆ **May 2002 Meeting with NRR**
- ◆ **Review of Unit 2 Cycle 11**
- ◆ **CENTS Implementation**
- ◆ **Clad Performance Strategy**
- ◆ **CEA Investigation**
- ◆ **Dry Cask Storage Update**

2



## Agenda Today

- ◆ Reactivity Management
- ◆ CENTS & RSG/Power Uprate
- ◆ Fuel Performance
- ◆ CPC Replacement
- ◆ CEA Replacement
- ◆ Dry Cask Storage Update

3



## Reactivity Management

- ◆ Overview of INPO AFI
- ◆ Palo Verde Actions
- ◆ Results

4



## Overview

- ◆ INPO Identified
- ◆ 2001 Plant Evaluation
  - Reactivity Management AFI
    - REACTOR ENGINEERING
    - OPERATIONS

5



## Palo Verde Actions

- ◆ NFM/Operations/Training Interface
- ◆ Operations Single Point of Contact
- ◆ Xenon Program
- ◆ Maneuvering Box
- ◆ Procedure Enhancement
- ◆ Training

6



## Results

- ◆ **NO REACTIVITY EVENTS**
- ◆ **Standardized Game Plans**
- ◆ **Improved Inter-Departmental Relationships**
- ◆ **Improved Tools**

7



## CENTS, RSG, U2 Uprate

- ◆ **CENTS Implementation Status**
- ◆ **U2 Power Uprate Submittal**

8



## **CENTS Implementation Status**

- ◆ **GL 83-11 S1 Process for 3876 MW**
- ◆ **U1, U2 Complete - U3 April 2003**
- ◆ **SABD Revision 20% Complete**
- ◆ **Two Events Await U2 SER**
  - **SGTR + LOP + SF**
  - **Long Term FWLB (PSV Operability)**

9



## **U2 RSG & Power Uprate**

- ◆ **Draft SER 3/31 -- Final SER 6/30**
- ◆ **SABD Supplement In Progress**
- ◆ **U2C12 Reload Safety Analyses Begun**
- ◆ **Actively Participating in Development of SG Startup Test Program**

10



## Fuel Performance

- ◆ **Integrated Fuel Clad Strategy:**
  - Advanced Clad Alloys
  - Primary Chemistry
  - CRUD/Oxide Software
  - Low Duty Core Designs
- ◆ **Long Range Fuel Inspection Plan**

11



## Advanced Clad Alloys

- ◆ **Westinghouse Decision: Low Tin Zirlo**
  - Alloy A LTA in U3C10 (Spring 2003)
- ◆ **First Batches of Standard Zirlo & Columbia Fuel Rod**
  - U2C11, U1C11 (2002)
  - U3C11 In April 2003
- ◆ **Fuel Handling Accident Rod Pressure**

12



## Primary Chemistry

- ◆ Additional RCS Cleaning at EOC Shutdown
- ◆ Early Lithium Injection During Startups
- ◆ Elevated-Coordinated Lithium Strategy
  - Currently 7.1 pH
  - Hold Until Inconel Corrosion Issue Resolved

13



## CRUD/Oxide Software

- ◆ Steaming Rate in Core Design Tools
  - Screen Patterns Against U3C9 Benchmark
- ◆ APS CRUD/Oxide Model
  - Nodal Level/High Duty Ass'y Rod Level
- ◆ Vendor Fuel Duty Model
  - Safety Grade Oxide and FDI Calculations

14



## Low Duty Core Designs

- ◆ Increase Feed Batch Size
  - 104 vs 96 Assemblies
- ◆ Minimal Feed-Face-Feed
  - U1C10 Visuals of P1M316
- ◆ U2 Uprate Corrosion Strategy
  - Zirlo Clad
  - Re-design Lattice Pattern

15



## Re-Designed Lattice

- ◆ Current Lattice
  - 2 Enrichments
  - 12 High Enrichment Rods on Each Face
- ◆ New Lattice
  - 3 Enrichments
  - Same Assembly Average Enrichment
  - All Peripheral Rods Low Enrichment
- ◆ Extensive Design Review

16





## Long Range Fuel Inspection Plan

- ◆ Unit 2, Beginning Fall 2003
- ◆ Zirlo Oxidation (R11, R12, R13)
- ◆ Lithium 3.5 PPM (R11, R12)
- ◆ New Lattice (R12, R13)
- ◆ Assembly Bow (R11)
- ◆ Higher Burnup Leakers

17



## CPC Replacement

- ◆ Overview of Changes
- ◆ Licensing Schedule

18



## **CPC Replacement Overview**

- ◆ **Upgrade to Modern Hardware**
  - 8 CEA Calculators
- ◆ **Concurrent Software Language Change**
- ◆ **Preserve Original Functionality & Timing**
- ◆ **First Installation - Fall 2003 Outage**

19



## **CPC Replacement Licensing**

- ◆ **SER on Westinghouse Common-Q**
- ◆ **Schedule for Formal RAI on PVNGS**
- ◆ **U2C12 Reload Engineering**
  - No Impact to Safety & Uncertainty Analyses
- ◆ **PVNGS Supports Joint Meeting**

20



## CEA Replacement

- ◆ Review CEA History
- ◆ Determination of New, Conservative Lifetime
- ◆ Design of New Replacement CEAs
- ◆ Replacement of PLCEAs

21



## Review of CEA History

- ◆ CEA Finger Failures Observed - 2001
  - Cracks in High Fluence CEA Tips
  - Root Cause - IASCC, Inadequate Testing
  - U2/U3 With Small Pellet Less Severe
- ◆ All Full Length CEAs Replaced
  - Replaced by Design with Smallest Pellet
- ◆ Lifetime Software Abandoned

22



## Determination of New Lifetime

- ◆ Investigating Various Options
- ◆ Monitoring YGN Inspections
- ◆ Inconel IASCC Threshold
- ◆ Vendor Has Adjusted Software

23



## Design of New CEAs

- ◆ Now: Unique Feltmetal Design
- ◆ Want: Industry Standard AgInCd Tips
- ◆ Tip Region Extended 4 Inches
- ◆ Hollow AgInCd Slugs

24



## Replacement of PLCEAs

- ◆ **Original Equipment**
  - Part Length, Part Strength
  - Not Subject to Same Failure Mode
  - Reviewing Design Bases
- ◆ **Replacements**
  - Full Length, Part Strength
  - Transparent to Safety Analysis
  - Tech Spec Change Required

25



## Dry Cask Storage Update

26



# Dry Cask Storage Update

- ◆ **Current status Unit 2**
  - Loaded 24 assemblies in first canister March 3
  - Shield lid welded March 6
  - Completed first vacuum drying period March 8
  - March 10 will start 2nd vacuum drying period
- ◆ **Capturing lessons learned from first loading**



# Fuel Loading Schedule

- ◆ Complete first canister loading in March, 2003
- ◆ Time out for Unit 3 Refueling outage, ends early May, 2003
- ◆ Complete Unit 2 campaign in June
- ◆ Load 5 casks in Unit 1 later in 2003
- ◆ Plan to load 10 casks per year



# UMS Amendment 3

## ◆ Palo Verde benefits

- Extended vacuum drying times
- Action statements won't require submersion of Transfer Cask and Canister for cooling
- Increased seismic limit
- Increased PWR fuel enrichment limit

## ◆ Anticipate issuance early May 2003

