

April 8, 2003

MEMORANDUM TO: Marsha Gamberoni, Deputy Director  
New Reactor Licensing Project Office  
Office of Nuclear Reactor Regulation

FROM: Joseph Colaccino, Senior Project Manager */RA/*  
New Reactor Licensing Project Office  
Office of Nuclear Reactor Regulation

SUBJECT: FEBRUARY 25, 2003, TELEPHONE CONFERENCE CALL SUMMARY

On Tuesday, February 25, 2003, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss NRC Request for Additional Information (RAI) Number 251.021. Westinghouse submitted a response to this RAI on November 26, 2002 (ADAMS Accession No. ML023360097). A list of call participants is included in Attachment 1. Attachment 2 contains NRC staff comments regarding the subject RAI that was sent to Mr. Michael Corletti of Westinghouse via electronic mail on February 14, 2003. These comments were used to facilitate discussions during the telephone conference call.

Following is a brief summary of the discussions regarding the identified RAIs (see comments in Attachment 2):

RAI 251.021

Westinghouse will review the reactor coolant pump (RCP) flywheel critical flaw size calculations to ensure that the comparison with the AP600 applies. The RAI response in this area will be revised and the design control document (DCD) will also be revised if necessary.

Westinghouse will clarify the RAI response to indicate that the increased energy from the RCP flywheel postulated fragments will not penetrate the pump casing, i.e., the reactor coolant pressure boundary.

Westinghouse will revise the RAI response to state that the RCP flywheel enclosure is not a pressure boundary structure, the Code is being used as guidance in this phase of the design, and that the plan is to perform a weld analysis when the design of the pump is completed. Westinghouse will provide an expanded explanation of why "it is expected that the AP1000 flywheel enclosure weld stresses will also meet the ASME Code limits" during revolutions at normal and design speeds. The DCD and WCAP-15994-P will be revised to reflect this information.

Docket No. 52-006

Attachment: As stated

April 8, 2003

MEMORANDUM TO: Marsha Gamberoni, Deputy Director  
New Reactor Licensing Project Office  
Office of Nuclear Reactor Regulation

FROM: Joseph Colaccino, Senior Project Manager /RA/  
New Reactor Licensing Project Office  
Office of Nuclear Reactor Regulation

SUBJECT: FEBRUARY 25, 2003, TELEPHONE CONFERENCE CALL SUMMARY

On Tuesday, February 25, 2003, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss NRC Request for Additional Information (RAI) Number 251.021. Westinghouse submitted a response to this RAI on November 26, 2002 (ADAMS Accession No. ML023360097). A list of call participants is included in Attachment 1. Attachment 2 contains NRC staff comments regarding the subject RAI that was sent to Mr. Michael Corletti of Westinghouse via electronic mail on February 14, 2003. These comments were used to facilitate discussions during the telephone conference call.

Following is a brief summary of the discussions regarding the identified RAIs (see comments in Attachment 2):

RAI 251.021

Westinghouse will review the reactor coolant pump (RCP) flywheel critical flaw size calculations to ensure that the comparison with the AP600 applies. The RAI response in this area will be revised and the design control document (DCD) will also be revised if necessary.

Westinghouse will clarify the RAI response to indicate that the increased energy from the RCP flywheel postulated fragments will not penetrate the pump casing, i.e., the reactor coolant pressure boundary.

Westinghouse will revise the RAI response to state that the RCP flywheel enclosure is not a pressure boundary structure, the Code is being used as guidance in this phase of the design, and that the plan is to perform a weld analysis when the design of the pump is completed. Westinghouse will provide an expanded explanation of why "it is expected that the AP1000 flywheel enclosure weld stresses will also meet the ASME Code limits" during revolutions at normal and design speeds. The DCD and WCAP-15994-P will be revised to reflect this information.

Docket No. 52-006

Attachment: As stated

Distribution:

Hard Copy

NRLPO R/F

JColaccino

JLyons

MGamberoni

E-mail

PUBLIC

R. Borchardt

J. Williams

J. Medoff

E. Sullivan

H. Walker

J. Segala

J. Colaccino

J. Starefos

J. Moore, OGC

R. Weisman, OGC

ACCESSION NUMBER: ML030710713 \*See previous concurrence

OFFICE	NRLPO/PM	SPSB/SC*	NRLPO/DD
NAME	JColaccino:cn	ESullivan	MGamberoni-JMS3 for:
DATE	04/7/03	03/28/03	04/8/03

OFFICIAL RECORD COPY

FEBRUARY 25, 2003  
TELEPHONE CONFERENCE CALLS SUMMARY  
LIST OF PARTICIPANTS

Nuclear Regulatory Commission

Joseph Colaccino  
Ted Sullivan  
Jim Medoff

Westinghouse

Mike Corletti  
Dale Wiseman  
Ed Cummins

NUCLEAR REGULATORY COMMISSION STAFF  
COMMENTS THAT WERE SENT TO WESTINGHOUSE TO FACILITATE  
DISCUSSIONS OF REQUESTS FOR ADDITIONAL INFORMATION (RAI) RESPONSES  
FOR CALL HELD ON FEBRUARY 25, 2003

Chapter 5.4.1.3.6.3 Reactor Coolant Pump Flywheel Integrity

251.021

In the AP600 review, RAIs 251.2 through 251.23 pertain to reactor coolant pump (RCP) flywheel integrity. In addition, WCAPs-13734 and 13735, "Structural Analysis Summary for the AP600 Reactor Coolant Pump Flywheel," were submitted as supplemental information for the revised response to question 251.11. Confirm that these responses and the WCAPs are applicable to the AP1000 application as it pertains to RCP flywheel integrity. Should aspects of these responses or reports not be applicable, provide updated information to address the AP600 RAIs as applicable to the AP1000 RCP flywheel integrity. (Section 5.4.1)

Note: AP600 RAIs 251.2 through 251.23 were issued by the NRC on October 1, 1992 (NUDOCS Accession No. 9210090123). Westinghouse provided its responses to these RAIs in letters dated January 14 May 24 and May 28, 1993 (NUDOCS Accession Nos. 9301250260, 9306020387, and 9306020220, respectively).

A comparison of the Westinghouse responses to AP600 RAI 251.3, as given for the AP1000 and the AP600 designs, indicates that the limiting critical flaw size for the AP1000 RCP flywheel design is about one-half of the limiting critical flaw size that was previously reported for the AP600 RCP flywheel design. However, Westinghouse Proprietary Class 2 Topical Report WCAP-15994-P, [Joe-provide title of WCAP] Revision 0, indicates that the critical flaw size for the AP1000 and the AP600 designs are virtually the same. This appears as an inconsistency in the design certification. The applicant needs to clarify what the actual critical flaw sizes are for both the AP1000 and the AP600 flywheel designs.

In response to AP600 RAI 251.8, the applicant's response for the AP1000 flywheel design is virtually the same as that for the AP600 flywheel design, with the exception that the response for the AP1000 increases the kinetic energy for flywheel fragments that could potentially impact the RCP structure from 10 percent of the tensile energy-absorbing capability in the AP600 RCP structure to 15 percent of the tensile energy-absorbing capability in the AP1000 RCP structure. However, there is some confusion in the wording of the final paragraph of the applicant's AP1000 response to AP600 RAI 251.8 as to whether potential flywheel fragments will penetrate the flywheel enclosure or not, and whether they could impact the surrounding RCP structure. The staff needs to discuss this with Westinghouse.

In response to AP600 RAIs 251.17 and 251.19, the applicant discusses the relationship of the structural integrity of the RCP flywheel enclosures to the revolution of the flywheels at normal and design operating speeds. In this case, the applicant's responses for the AP1000 are virtually the same as the previous AP600 design

responses to the RAIs. However, in the AP1000 responses to these AP600 RAIs, the applicant has a statement that the flywheel impact on the enclosure was assessed for a postulated rupture of the AP600 flywheel under normal and design revolution speeds and that the impact on the AP600 enclosure welds was within acceptable American Society of Mechanical Engineers (ASME) limits. The applicant then concludes that since the AP1000 flywheel design is similar to that for the AP600 flywheels, "it is expected that the AP1000 flywheel enclosure weld stresses will also meet the ASME Code limits" during revolutions of the AP1000 flywheel at normal speeds (as addressed in the AP1000 response to AP600 RAI 251.17) and design speeds (as addressed in the AP1000 response to AP600 RAI 251.19). The applicant needs to state whether this is based solely on engineering judgement or whether the applicant actually did the corresponding analyses at normal speed and design speed for the AP1000 design. If it is based solely on engineering judgement, the staff will have to determine whether engineering judgement is an acceptable basis for making this determination. These structural integrity assessments are critical to the staff's acceptance that the RCP flywheel enclosures will preclude the flywheels or portions of them from reaching the RCP structures following a postulated rupture of the flywheel under normal and design revolution speeds, as well as for acceptance that ASME Section XI inservice inspections will not be necessary for the AP 1000 flywheels.

AP 1000

cc:

Mr. W. Edward Cummins  
AP600 and AP1000 Projects  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355

Mr. H. A. Sepp  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230

Lynn Connor  
Doc-Search Associates  
2211 SW 1<sup>ST</sup> Ave - #1502  
Portland, OR 97201

Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott, LLC  
600 Grant Street 44<sup>th</sup> Floor  
Pittsburgh, PA 15219

Mr. Ed Rodwell, Manager  
Advanced Nuclear Plants' Systems  
Electric Power Research Institute  
3412 Hillview Avenue  
Palo Alto, CA 94304-1395

Charles Brinkman, Director  
Washington Operations  
Westinghouse Electric Company  
12300 Twinbrook Parkway, Suite 330  
Rockville, MD 20852

Mr. R. Simard  
Nuclear Energy Institute  
1776 I Street NW  
Suite 400  
Washington, DC 20006

Mr. Thomas P. Miller  
U.S. Department of Energy  
Headquarters - Germantown  
19901 Germantown Road  
Germantown, MD 20874-1290

Mr. David Lochbaum  
Nuclear Safety Engineer  
Union of Concerned Scientists  
1707 H Street NW, Suite 600  
Washington, DC 20006-3919

Mr. Paul Gunter  
Nuclear Information & Resource Service  
1424 16th Street, NW., Suite 404  
Washington, DC 20036

Mr. Tom Clements  
6703 Guide Avenue  
Takoma Park, MD 20912

Mr. James Riccio  
Greenpeace  
702 H Street, NW, Suite 300  
Washington, DC 20001

Mr. James F. Mallay, Director  
Regulatory Affairs  
FRAMATOME, ANP  
3315 Old Forest Road  
Lynchburg, VA 24501

Mr. Ed Wallace, General Manager  
Project Management  
Lake Buena Vista Bldg., 3<sup>rd</sup> Floor  
1267 Gordon Hood Avenue  
Centurion 0046  
Republic of South Africa  
PO Box 9396 Centurion 0046

Mr. Vince Langman  
Licensing Manager  
Atomic Energy of Canada Limited  
2251 Speakman Drive  
Mississauga, Ontario  
Canada L5K 1B2

Mr. Gary Wright, Manager  
Office of Nuclear Facility Safety  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive  
Springfield, IL 62704

Dr. Gail H. Marcus  
U.S. Department of Energy  
Room 5A-143  
1000 Independence Ave., SW  
Washington, DC 20585

Mr. Edwin Lyman  
Nuclear Control Institute  
1000 Connecticut Avenue, NW  
Suite 410  
Washington, DC 20036

Mr. Jack W. Roe  
SCIENTECH, INC.  
910 Clopper Road  
Gaithersburg, MD 20878

Patricia Campbell  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005

Mr. David Ritter  
Research Associate on Nuclear Energy  
Public Citizens Critical Mass Energy  
and Environmental Program  
215 Pennsylvania Avenue, SE  
Washington, DC 20003

Mr. Michael M. Corletti  
Passive Plant Projects & Development  
AP600 & AP1000 Projects  
Westinghouse Electric Company  
P. O. Box 355  
Pittsburgh, PA 15230-0355