UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 1 of 3

<u>FACILI</u>	<u>TY</u> : QUAD CITI	ES	<u>SCENARIO NO</u> : 1	OP-TEST NO: 1	
EXAMINERS:			OPERATORS:		
			<u></u>	· · · · · · · · · · · · · · · · · · ·	
INITIAI and 1B	<u>CONDITIONS</u> :	~ 41% pow Compresso	ver, 1B Service Water Pump, 1B EHC OOS, IRM #12 bypassed. Power as	pump, 1D RHR pump cension in progress.	
TURNO The fol pump a IAW Q QNE d progres	<u>TURNOVER</u> : ~ 365 MWe and 41% power on the 50% FCL. Rod step 53 is partially withdrawn. The following equipment is out of service: 1B Service Water Pump, 1B EHC pump, 1D RHR pump and 1B Instrument Air Compressor OOS, IRM #12 bypassed. Plant startup in progress IAW QCGP 1-1, step F.9.t. transitioning to QCGP 3-1 step F.3.g. Place the A FWRV in service. QNE directions are to increase power with recircs to ~ 65 MLBM/hr core flow. Inerting in progress per QCOP 1600-20 step F.16.				
Event No.	Malfunction Number	Event Type*	Event Descriptior	ı	
1	FW08b	I – R, S	B FWRV lockup		
2	N/A	N – B, S	Place A FWRV in service and transf	er to 3-element control	
3	N/A	R – R, S	Increase power using recirc pumps		
4	SW11b	C – B, S	TBCCW pump trip		
5	RP04b	C – B, S	Trip of RPS-B		
6	RD04r	C – R, S	Rod drift out		
7	TU12/RD13	M – All	Turbine Trip with Hydraulic ATWS (I	PSA identified event)	
8	TC05a	C – All	Trip of 1A EHC Pump		

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (S)– SRO/US (R) – RO (B) – BOP/ANSO

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 2 of 3

Facility: Quad Cities Scenario No: 1 Op-Test No: 1 Summary: The crew will take the shift at \sim 41% power. The B FWRV will lockup, requiring reset. (Instrument – RO, SRO) When Feedwater flow is approximately 4.5 MLBM/hr the BOP will place the 2nd FWRV in service. (Normal Evolution – BOP, SRO) The RO will increase reactor power using Recirc pumps. (Reactivity Manipulation - RO, SRO) The A TBCCW pump will trip, requiring manual start of the B TBCCW pump. (Component – BOP, SRO) Next a loss of "B" RPS will occur, requiring restoration of power and resetting of isolations and equipment. (Instrument, TS – BOP, SRO) A rod will drift out of the core, requiring it to be manually inserted, scrammed and isolated. (Component, TS - RO, SRO) The turbine will trip, rods will not insert -Hydraulic ATWS, requiring entry into QGA 101. (Major – All) Approximately 2 minutes after the Turbine trips, the 1A EHC pump will trip, requiring pressure control to be transferred to the ADS valves. The scenario is complete when the crew has inserted control rods IAW QCOP 0300-28 and are controlling RPV water level and pressure IAW QGA 100.

CT #1 - During an ATWS with conditions met to perform power/level control, TERMINATE AND PREVENT INJECTION, with the exception of boron, CRD and RCIC into the RPV until conditions are met to re-establish injection. (BWROG RPV- 6.3 PWR/LVL TERM/PREVENT)

CT #2 - When conditions are met to re-establish injection, use available injection systems to MAINTAIN RPV water level above the Minimum Steam Cooling RPV Water Level (-166"). (BWROG RPV-6.4 ATWS PWR/LVL RESTORE RPV LVL)

CT #3 (Contingent on water level) - With a reactor scram required, reactor not shutdown, and conditions for ADS blowdown are met, INHIBIT ADS to prevent an uncontrolled RPV depressurization, to prevent causing a significant power excursion. (BWROG RPV-6.2 ATWS PWR/LVL INHIBIT ADS)

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 3 of 3

Simulator setup:

- 1. Load IC-91 from the zip disk and reset the simulator to IC-91: rst 91
- 2. Take the following equipment OOS: **1B Service Water Pump in PTL**

1B Instrument Air Compressor in PTL

1D RHR Pump in PTL

1B EHC Pump in PTL

- 3. Bypass IRM 12 and place Eq. Status tag on IRM joystick.
- 4. Verify hydraulic block (rd13a and b) of the Scram Discharge Volume at 99% ramped to 100% in 3 seconds via trigger.
- 5. Verify control rods at step 53 1st 4 rods (C-11, C-5, N-11, N-5) at position 24, the others at target in.
- 6. Adjust recircs to ~ 51 MLBM/hr core flow. (This is ~ 30% speed demand).
- 7. Verify the 2nd RFP started IAW QCOP 3200-03 and verify condensate pump amps in band. If necessary, adjust 3401.
- 8. Verify CAMS started for Drywell sampling on the 901-56 panel.
- 9. Verify the 1A FWRV in Sequence Manual at the left computer screen and ensure 1B FWRV is the primary. (D-1).
- 10. Verify Drywell inerting in progress in accordance with QCOP 1600-20 step F.16. Hang equipment status tag on 1A DW/Torus purge fan.
- 11. Verify the RWM is setup correctly.
- 12. Verify all procedures, QGAs, and meter faces, are erased.
- 13. Clear old SER and alarm screens.
- 14. Run new OD-20.
- 15. Write on white board the following:

Tech Spec 3.5.1 Condition A 1D RHR Pump OOS Day 1 of 30 Tech Spec 3.6.2.5 Condition A, Drywell Oxygen Concentration High, Hour 8 of 24 Tech Spec 3.6.3.1 Condition A, Drywell Torus Delta P Low, Hour 8 of 24

16. Place placard for RBCCW ¹/₂ lined up to U1 by the RBCCW pumps.

17. Verify trigger 4 set to delete malfunction fw08b when reset pushbutton is depressed.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 4 of 3

LIST OF POTENTIAL PROCEDURES

QCGP 1-1, QCGP 3-1 QCGP 4-1 QCOP 0202-03 0250-02 0300-28 0600-02 0600-18 5750-19 7000-01 QCOA/QOA 0300-04, 0300-11, 0600-01, 3800-03, 7000-01 QOA 912-1, C-2, D-2 QCAN 901-5, A-3, A-12, H-8 QGAs HARD CARDS METER FACES

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 5 of 3

Crew Turnover:

Unit 1 is at approximately 365 MWe and 41% power on the 50% FCL. Rod step 53 is partially withdrawn.

Unit 2 is operating at 97% power on the 97% Flow Control Line.

The following equipment is out of service:

1B Service Water Pump due to a ground in the motor windings.

1B EHC pump due to a failure of the autostart feature.

1D RHR pump due to a failure of the trip coil. Tech Spec 3.5.1, condition A.1 entered, Day 1 of 30.

Drywell inerting in progress IAW QCOP 1600-20 step F.16., Tech Spec 3.6.2.5 and 3.6.3.1 Condition A, Hour 8 of 24.

1B Instrument Air Compressor due to a seal water failure.

IRM #12 bypassed due to erratic operation and is INOP.

Alarm 901-5 B-3, Rod Worth Minimizer, Block alarms sporadically and is being investigated.

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip, alarms sporadically and is being investigated.

Plant startup in progress IAW QCGP 1-1, step F.9.t. transitioning to QCGP 3-1 step F.3.g.(4). Your directions for the shift are to place 1A Feedwater Reg Valve in service and continue power ascension. QNE directions are to increase power with recircs to ~ 65 MLBM/hr core flow.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 6 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: 1B FWRV lockup

1

Initiation: Shortly after the crew takes the shift and when directed by the lead examiner, lockup the 1B FWRV using malfunction FW08b (**imf fw08b**).

Time	Position	Applicant's Actions or Behavior
	RO	Reports annunciator 901-5 H-8, 1B FW ACTUATOR TROUBLE, is alarming and addresses the annunciator procedure and enters QCOA 0600-01, Feedwater Regulator Lockup.
		Monitors Rx Water level.
!		Depresses 1B VLV RESET pushbutton and holds for at least 5 seconds.
SIM OP		Verify malfunction fw08b automatically clears when the 1B FWRV reset pushbutton is depressed (trigger 4). While the RESET pushbutton is depressed, delete the locked FWRV malfunction. (dmf fw08b)
		Reports 1B FWRV reset.
		Verifies Rx Water level is approximately the same as the Master Controller
		the Operator workstation (OWS).
		Monitors Rx Water Level.
		Directs Instrument Maintenance investigate FWRV lockup.
SIM OP		As the IM sent to investigate, wait approximately 5 minutes and report that you found a loose lead on 1B FWRV and have tightened it.
ļ	BOP	Monitors Balance of Plant parameters.
		Assist RO as requested by SRO/RO
	SRO	Directs the RO to investigate the anuunciator and enters QCOA 0600-01, Feedwater Regulator Lockup.
		Sets scram criteria of 11 and 44 inches.
		If asked, authorizes placing FWRV in Auto.
		Ensures Instrument Maintenance is contacted.
T		

Termination: The 1B FWRV lockup has been investigated and reset.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 7 of 3

EVENT/POSITION EVALUATION

Event No.(s): 2

Description: Place the A FWRV in service.

Initiation: Feedwater flow is approximately 4.5 MLBM/hr.

Time	Position	Applicant's Actions or Behavior
	SRO	Directs A FWRV placed in service IAW QCOP 0600-02, Placing Main Feedwater Regulator On-Line of Off-Line and/or QCOP 0600-18, Main Feedwater Regulator Operation.
	BOP	Refers to QCOP 0600-02 and/or QCOP 0600-18.
		Verifies A FWRV is in sequence manual on the OWS screen.
		Verifies B FWRV is on-line in AUTO.
		Verifies A FWRV is in "remote-manual" and is closed.
		If desired, balances positions of FWRVs.
		Place A FWRV in "Auto".
		Verifies A and B FWRVs are balanced.
		Verifies Reactor Water level being maintained.
		Places FWLC in 3-element control IAW QCOP 0600-12, Feedwater Level 3- Element Control Operation by depressing the 3-element control pushbutton on the master controller.
	RO	Monitors Rx Water level and 901-5 panel parameters.

Termination: The A FWRV is in service.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 8 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Power ascension.

3

Initiation: The crew is turned over to raise reactor power with recirc pumps.

Time	Position	Applicant's Actions or Behavior	
	US	Authorizes power increase. Gives pre-job brief. (Brief may have been done prior to the crew assuming the shift.)	
		Supervises and monitors the power ascension.	
	RO	Monitors 901-5 panel parameters.	
		Increases recirc pump speed using individual controllers.	
	BOP	Monitors Balance of Plant parameters.	
		Provides peer-check for the RO when performing reactivity manipulations.	
		Increases load set IAW QCGP 3-1, Reactor Power Operations, maintaining	
		10% above generator output.	
Termina	Termination: As determined by Lead Evaluator or core flow reaches ~ 65 MLBM/hr.		

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 9 of 3

EVENT/POSITION EVALUATION

Event No.(s): 4

Description: 1A TBCCW Pump Trip

Initiation: Sim Op trips 1A TBCCW pump by inserting malfunction SW11a (**imf sw11a**) when the power ascension is started or when directed by the lead examiner.

Time	Position	Applicant's Actions or Behavior	
	BOP	Reports annunciators 912-1 C-2, TURB BLDG CLG WATER PUMP TRIP and D-2, TURB BLDG COOLING WATER LOW PRESS, are alarming and addresses the annunciator procedures.	
		Determines that 1A TBCCW pump has tripped.	
		Starts 1B TBCCW pump.	
		Dispatches an operator to MCC 15-1 to check for breaker trip or thermal overload condition and sends an operator to the pump to check for an abnormal condition.	
SIM OP		As the operator sent to 15-1, wait ~ 3 minutes and report 1A TBCCW pump thermal overloads are tripped. As the operator sent to investigate the pump, report 1B TBCCW pump is running normal and 1A TBCCW pump feels hot.	
	SRO	Directs the BOP to investigate the annunciators.	
		If asked, authorizes the start of 1B TBCCW pump.	
		Ensures Mechanical Maintenance is contacted.	
		May refer to QCOA 3800-03, Total Failure of the TBCCW System.	
	RO	Monitors plant parameters.	
Termina	Termination: 1B TBCCW pump is running and the failure of 1A TBCCW pump is being investigated.		

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 10 of 3

EVENT/POSITION EVALUATION

Event No.(s): 5

Description: Trip of RPS B

Initiation: When the load increase is complete or when directed by the lead examiner, trip RPS B using malfunction RP04b (**imf rp04b**).

Time	Position	Applicant's Actions or Behavior
	RO	Reports "B" RPS ¹ / ₂ scram and an apparent loss of RPS "B"
		Monitors plant parameters.
	SRO	Directs BOP to perform QOA 7000-01, RPS Bus Failure.
		Directs RPS "B" placed on alternate power.
		Contacts Electrical Maintenance to investigate.
		Refers to TS 3.3.8.2 and determines that he has 72 hours to remove EPAs from service.
	BOP	If the RO does not report a loss of RPS "B", the BOP does.
		Refers to QOA 7000-01, RPS Bus Failure.
		Dispatches an operator to the Aux Electric Room to investigate.
		Verifies Rx Bldg Vents auto-isolate and SBGT auto-starts.
		Verifies Group 2 and 3 valve closures.
SIM OP		After ~ 3 minutes, report that RPS "B" EPAs are tripped and will not reset. 1B RPS MG Set tripped.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 11 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Trip of RPS B (Continued)

5

Initiation: When the load increase is complete or when directed by the lead examiner, trip RPS B using malfunction RP04b (**imf rp04b**).

Time	Position	Applicant's Actions or Behavior	
	BOP	Directs the NLO to place RPS "B" on alternate power.	
		Ensures Electrical Maintenance is contacted.	
SIM OP		After ~ 1 minute, places RPS "B" on alternate power using remote function RP03r (mrf rp03r alt).	
	BOP/RO	Resets the Group 2 and 3 isolations.	
		Resets the Group 1 isolation.	
		Resets the ½ scram.	
	BOP	Restores Primary Containment vent system to normal.	
		Opens AO 4720 or AO 4721.	
		Reset Rx Building Floor Drain and Equipment Drain Tank Pumps.	
		Resets ARMs, APRMs and RBM.	
		Resets Rx Bldg Vents and Shutdowns SBGT.	
		Resets CR Vents.	
		Opens RWCU isolation valves and restarts RWCU.	
		Resets Gp 2 ISOL RESET VLV 1001-29 pushbuttons on both loops of RHR	
		Gives outboard MSIVs an open signal.	
		Resets HPCI Logic.	
SIM OP		If asked, as the EM, report to the CR and report DC solenoid cable currents are between 45 and 65 ma in the 901-3 panel.	

Termination: At a minimum, the cause has been investigated, RPS B is on alternate power and the $\frac{1}{2}$ scram and $\frac{1}{2}$ isolations have been reset.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 12 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Control rod drifts out

6

Initiation: When the minimum actions for restoring RPS B are complete and directed by the lead examiner, cause control rod 34-27 to drift out using malfunction RD04r. (**imf rd04r3427**).

Time	Position	Applicant's Actions or Behavior
	RO	Reports alarm 901-5 A-3, Rod Drift and control rod 34-27 (J-7) drifting out of the core.
		Refers to the annunciator procedure and QCOA 0300-11, Control Rod Drift.
		Selects control rod 34-27 (J-7) and drives to position 00.
		Reports control rod 34-27 (J-7) will not latch and drives to position 00.
	BOP	Refers to the annunciator procedure and QCOA 0300-11, Control Rod Drift.
		Places individual control rod Scram Test Switch for control rod 34-27 (J-7) to the scram position at panel 901-16.
		Contacts a QNE
		Contacts NLO to close 1-305-105, CRD EXH VLV for control rod 34-27 (J-7).
SIM OP		When directed to close 1-305-105 for control rod 34-27 (J-7), wait ~ 3 minutes and modify remote function RD06r (mrf rd06r3427r inop) and delete malfunction RD04r (dmf rd04r3427).
	SRO	Directs RO/BOP to address annunciator 901-5 A-3, Rod Drift and QCOA 0300-11, Control Rod Drift.
		Refers to Tech Spec 3.1.3.C and declares control rod 34-27 (J-7) inop. Fully inserts control rod within 3 hours and disarms within 4 hours.
		Directs control rod 34-27 (J-7) taken OOS.
Terminat	tion: When	the drifting control rod has been inserted, scrammed and directed to be taken

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 13 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Trip of the Main Turbine with ATWS

7

Initiation: When the actions for the drifting control rod have been completed or when directed by the lead examiner, trip the main turbine on high bearing vibration using malfunction TU02L ramped to to 50 % over 5 minutes. (**imf tu02L 50 5:**).

Time	Position	Applicant's Actions or Behavior	
	RO	Notes by annunciator 901-5 A-12, CHANNEL A/B STOP VLVS CLOSE TRIP, that the Main Turbine has tripped and the Rx failed to scram.	
		Inserts a manual scram and places the Mode Switch to SHUTDOWN.	
		Reports rods did not insert.	
		Initiates ARI	
		Runs recirc pumps to minimum speed.	
		Bypasses the RWM or selects power reduction mode, selects the cram rods and drives them to position 00.	
		Directs the 1-301-25 valve closed, if necessary.	
SIM OP		If requested, wait ~ 3 minutes and close the unit 1-301-25 valve using remote function RD04r (mrf rd04r close) and report valve closed to the RO.	
	SRO	Directs Rx scrammed on rising bearing vibration.	
		Enters QGA 100, RPV Control due to failure to scram.	
		Transitions from QGA 100, RPV Control to QGA 101, RPV Control ATWS) due to rods being out.	
		Directs ADS inhibited.	
		Directs Core Spray Pumps placed in PTL.	
	BOP	Reports annunciator 901-7 D-2, TURB GEN BRG HI VIBRATION, and refers to the annunciator procedure.	
		Reports bearing #12 vibration is rising.	
		Inhibits ADS.	
		Places Core Spray Pumps in PTL.	
Termina	Fermination: Taking actions for the ATWS		

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 14 of 3

EVENT/POSITION EVALUATION

Event No	Event No.(s): 8		
Descript	ion: Hydrau	ulic ATWS with subsequent trip of 1A EHC pump.	
Initiation	: Turbine Tr	ip	
Time	Position	Applicant's Actions or Behavior	
	SRO	Determines Main Steam Lines are open and directs the ANSO to perform QCOP 0250-02, Bypassing MSIV Group 1 Isolation Signal From Low Low Reactor Water Level.	
SIM OP		If requested, wait ~ 2 minutes, perform QCOP 0250-02, Bypassing MSIV Group 1 Isolation Signal From Low Low Reactor Water Level using remote function QG09r (mrf qg09r activate) and report completion to the ANSO.	
		Determines Rx power > 3% and RPV water level > -35 inches.	
		Directs termination and prevention of injection with exception of Boron, CRD and RCIC.	
		Directs RO to report when RPV water level reaches -35 inches.	
		Directs a level band of -35 to -166 inches.	
		Directs Mode Switch placed in SHUTDOWN.	
		Directs ARI initiated.	
		Directs recirc pumps run to minimum.	
		Directs recirc pumps tripped once minimum speed is reached.	
		Directs the RO to perform QCOP 0300-28, Alternate Control Rod Insertion.	
		Directs pressure controlled on the bypass valves.	
SIM OP		When plant conditions are stable or when directed by the Lead Examiner, trip the A EHC pump using malfunction TC05A (imf tc05a).	
		When bypass valves close, directs reactor pressure maintained 800-1000 psig.	
		When all rods are inserted, exit QGA 101, RPV Control (ATWS) and enters QGA 100, RPV Control. Enters QGA 200, Promary Containment Control if condition is reached.	

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 15 of 3

EVENT/POSITION EVALUATION

Event No.(s): 8					
Descript	Description: Hydraulic ATWS with subsequent trip of 1A EHC pump.				
Initiation	Initiation: Turbine Trip				
Time	Position Applicant's Actions or Behavior				
	RO	Drives control rods to position 00, spiraling out from the center of the core.			
		Terminates and prevents feedwater injection by placing FWRVs in manual, closing and closing the FWRV isolation valves. Directs the ANSO to trip HPCI and shutdown the SSMP if running.			
		Bypass SDV high level scram and attempts scram reset.			
		Directs jumpers installed to bypass reactor scram.			
SIM OP		If requested, wait ~ 2 minutes and bypass reactor scrams using remote function QG08r (mrf qg08r activate) and report completion to the RO.			
		Resets Rx Scram.			
		Directs ARI fuses removed if level < -59 inches.			
SIM OP		Delete malfunction rd13a and b when scram is reset and ARI fuses are removed, if necessary.			
SIM OP		If requested, wait ~2 minutes and remove ARI fuses using remote function QG14r (mrf qg14r activate) and report completion to the RO.			
		Inserts a reactor scram and reports all rods inserted.			
	RO/BOP	Maintains Rx water level -35 to -166 inches using feedwater.			
	BOP	Performs/directs performed QCOP 0250-02, Bypassing MSIV Group 1 Isolation Signal From Low Low Reactor Water Level.			
		Trips recirc pumps.			
		Reports Bypass valves controlling pressure.			
		I rip latches HPCI. Starts Torus Cooling			
		Reports closure of Bypass Valves and cycles ADS valves to maintain reactor			
		pressure 800-1000 psig.			
Termination: The scenario is complete when all control rods are inserted and the crew is controlling RPV water level and pressure IAW QGA 100, RPV Control or at the discretion of the lead examiner.					

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 16 of 3

<u>-</u> <u>FACILITY</u> : QUAD CITIES		ES	SCENARIO NO: 2 OP-TEST NO: 1	
EXAMINERS:			OPERATORS:	
INITIA Servic Instrur Consta <u>TURN</u> Pump, Compi Day 2	INITIAL CONDITIONS: IC-21, 97% Power, The following equipment is out of service: 1B Service Water Pump, 1B EHC pump, 1D RHR pump, 1B Stator Cooling Pump and 1B Instrument Air Compressor OOS, IRM #12 bypassed. Currently Holding Power Constant. <u>TURNOVER</u> : 912 MWe. The following equipment is out of service: 1B Service Water Pump, 1B EHC pump, 1D RHR pump, 1B Stator Cooling Pump and 1B Instrument Air Compressor OOS, IRM #12 bypassed. Currently Holding Power Constant. TS 3.5.1.A.1			
Event No.	Malfunction Number	Event Type*	Event Description	
1	N/A	N – B, S	SSMP Valve Timing (QCOS 2900-03) (Note: for crew A due to intermittent simulator fidelity problem on channel A reactor water level, received low low level causing a ½ scram signal. Problem cleared, allowed to reset ½ scram and continued with scenario.)	
2	NM08/ RP02	I – R, S	APRM failure with failure of automatic ½ scram. (Note: for all crews, due to the level instrument fidelity problem, changed APRM failure from channel B to channel A, just in case level instrument problem occurred	
3	SW01	C – B, S	Service Water Pump Trip.	
4	RD03	C – R, S	Rod drift in 1 notch.	
5	ior dihs110021c close	I – B, S	RHR Pump inadvertent start	
6	MC08	R – R, S	Main Condenser air in leakage that requires a power reduction. (PSA identified event)	
7	RR10A	M - All	Recirc suction line rupture.	
8	imf fw17abcd HP01	M – All	Loss of all cond pumps and failure of HPCI leads to RPV Blowdown at TAF and low pressure system injection. (PSA identified event)	

 * (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (S)– SRO/US

- (R) RO

(B) – BOP/ANSO

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 17 of 3

Facility: Quad Cities

Scenario No: 2

Op-Test No: 1

 <u>Summary</u>: The crew will take the shift at 100% power and perform QCOS 2900-03 -SSMP Valve Timing Surveillance. (Normal – BOP, SRO) An APRM will fail upscale with a failure of the automatic ½ scram, requiring a manual ½ scram and bypassing of the failed APRM. (Instrument, TS – RO, SRO) A Service Water pump will trip, requiring a standby pump to be manually started. (Component – BOP, SRO) A control rod will drift in from 48 to 46, requiring it to be withdrawn back to 48. (Component – RO, SRO) An RHR pump will inadvertently start, requiring it to be manually tripped and Tech Specs to be addressed. (Instrument, TS - ANSO, SRO) Air in-leakage will develop in the Main Condenser Boot due to a rupture, requiring power reduction and a reactor scram. (Component, Reactivity – NSO, SRO) A Recirc Suction line will rupture along with a loss of all cond pumps and a failure of HPCI, which will result in level reaching TAF and RPV blowdown. (Major – ALL) The scenario ends when the crew has performed an RPV Blowdown and reestablished core cooling with low pressure systems.

CT #1 - When Torus pressure exceeds 5 psig, INITIATE drywell sprays, while in the safe region of the drywell spray initiation limit (DSIL). (BWROG PC-5.1 INIT DW SPRAY)

CT #2 - With Reactor pressure greater than shutoff head of the Low pressure system(s) before RPV water level drops to -166", INITIATE emergency depressurization. (BWROG RPV-1.1 LOSS HP INJ E/D TAF)

CT #3 - Action is taken to restore RPV water level above TAF, by OPERATING available low pressure system(s) when RPV pressure decreases below the shut off head of the low pressure system(s). (BWROG RPV-1.2 LOSS HP IND RESTORE RPV LVL).

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 18 of 3

Simulator setup:

- 18. Load IC-93 from the zip drive and reset the simulator to IC-93: rst 93
- 19. Take the following equipment OOS:
- 1B Service Water Pump in PTL

1B Instrument Air Compressor in PTL

1D RHR Pump in PTL

1B Stator Water Cooling pump in PTL

1B EHC Pump in PTL

20. Bypass IRM 12

21. Insert the following malfunctions:

- a. Fail HPCI to autostart using malfunction HP11. (imf HP11)
- b. Trip 1A Core Spray pump using malfunction CS01A. (imf CS01a)
- c. Fail 1B Core Spray pump injection valve closed using malfunction CS07B. (imf cs07b)
- d. Assign event rdsdrposrwm(151).eq.45 to trigger #1. (trg 1 rdsdrposrwm(151).eq.45) (dmf rd03r5015 (1))
- 22. Assign event hpciturbinespeed>0.5 to trigger #3 and inset malfunction HP01 to trip the HPCI turbine one minute after it starts.
 (trg 3 hpciturbinespeed>0.5)
 (imf hp01 (3) 60)
- 6. Verify the RWM is setup correctly.
- 7. Verify all procedures, QGAs, and meter faces, are erased.
- 8. Clear old SER and alarm screens.
- 9. Run new OD-20.
- 10. Write on white board the following:

Tech Spec 3.5.1 Condition A 1D RHR Pump OOS Day 2 of 30

11. Place placard for RBCCW ¹/₂ lined up to U1 by the RBCCW pumps.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 19 of 3

LIST OF POTENTIAL PROCEDURES

QCGP 4-1 QCOP 0300-16, 0500-03, 0700-03, 0700-04, 3300-05, 4100-03 QCOS 2900-03 QCOA/QOA 0201-01 0300-04, 0300-11, 0700-03, 1000-04, 3300-02, 3800-03, 3900-01 QCAN 901-3 A-5, A-6, A-15 QCAN 901-5, A-3, A-6, A-15, B-11, C-3, D-13, H-1 QCAN 901-6, F-11 QCAN 901-7 H-3 QCAN 901-54 B-6, C-7 QCAN 912-1 A-3 T.S 3.3.1.1 TRM 3.3.a, 3.6.a QCAP 200-10 ATT. Q and others HARD CARDS QGAs METER FACES

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 20 of 3

Crew Turnover:

Unit 1 is at approximately 912 MWe and 97% power on the 97% FCL.

Unit 2 is at approximately 912 MWe and 97% power on the 97% FCL.

The following equipment is out of service:

1B Service Water Pump due to a ground in the motor windings.

1B EHC pump due to a failure of the autostart feature.

1B Stator Water Cooling pump due to overheating.

1D RHR pump due to a failure of the trip coil. Tech Spec 3.5.1, condition A.1 entered, Day 2 of 30.

1B Instrument Air Compressor due to a seal water failure.

IRM #12 bypassed due to erratic operation.

Alarm 901-5 B-3, Rod Worth Minimizer, Block alarms sporadically and is being investigated.

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip, alarms sporadically and is being investigated.

Instructions for the shift are to hold load and perform QCOS 2900-03, Safe Shutdown Makeup System Power Operated Valve Test, as soon as you take the shift.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 21 of 3

EVENT/POSITION EVALUATION

Event No.(s): 1			
Descript	Description: SSMP Valve Timing (QCOS 2900-03)		
Initiation	: Crew is d	irected to perform during shift turnover.	
Time	Position	Applicant's Actions or Behavior	
	SRO	Directs QCOS 2900-03, Safe Shutdown Makeup System Power Operated Valve Test performed and performs pre-job brief.	
	RO	Monitors plant parameters.	
	BOP	Opens and times open MO ¹ / ₂ -2901-7.	
		Records time.	
		Verifies MO ¹ / ₂ -2901-7 opening time meets IST Ctiteria.	
		Closes and times close MO 1/2-2901-7.	
		Records time.	
		Verifies MO ¹ / ₂ -2901-7 closing time meets IST Criteria.	
		Opens and times open MO 1-2901-8.	
		Records time.	
		Verifies MO 1-2901-08 opening time meets IST Ctiteria.	
		Closes MO 1-2901-8.	
		Opens and times open MO 2-2901-8.	
		Records time.	
		Verifies MO 2-2901-08 opening time meets IST Ctiteria.	
		Closes MU 2-2901-8.	
		As the NLO report that step H.3 of QCOS 2900-03.	
		Verifies all Acceptance Criteria verification steps are complete	
		Signs for completing the surveillance	
	SRO	Approves the surveillance.	
Termination: QCOS 2900-03 is complete.			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 22 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: APRM failure with failure of automatic ¹/₂ scram.

2

When QCOS 2900-03 is complete or when directed by the lead examiner, fail the "A" channel of RPS to scram using malfunction RP02 A and C (imf rp02a; imf rp02c) and then fail APRM #1 upscale using malfunction NM08a at 100% severity (imf nm08a 100). [Note: changed from APRM #5 to #1]

Time	Position	Applicant's Actions or Behavior
	RO	Reports annunciators 901-5 A-6, APRM UPSCALE/HIGH, B-11 CHANNEL
		A/B NEUTRON MONITOR, and C-12 CHANNEL 1-3 APRM HI-HI OR INOP,
		and refers to the procedures.
		Reports APRM #1 indicates upscale.
		Verifies rod block occurred.
		Reports failure of ½ scram on RPS "A".
		Inserts ½ scram on RPS "A".
	BOP/RO	Refers to QCOA 0700-03, Loss of neutron Flux Indication.
	RO	Stops all reactivity changes and holds power constant.
	BOP/RO	Refers to QCOP 0700-04, Average Power Range Monitoring System
		Operation (APRM).
	RO	Bypasses APRM #1 and verifies the white bypass light comes on.
		If desired, bypasses the associated OPRM per QCOP 0700-10, Oscillation
		Power Range Monitoring (OPRM) Operation.
	SRO	Directs ¹ / ₂ scram inserted on RPS "A".
		Refers to QCOA 0700-03, Loss of neutron Flux Indication.
		Directs reactivity changes stopped and power held constant.
		Refers to QCOP 0700-04, Average Power Range Monitoring System
		Operation (APRM) and Tech specs 3.3.1.1 and TRM 3.3.a.
		Determines minimum number of APRM channels still available.
		Directs APRM #1 bypassed.
NOTE		The crew may or may not choose to reset the $\frac{1}{2}$ scram since this is not a
		required channel.
	BOP	Checks for abnormally high LPRM indication.
		Monitors plant parameters.
		Contacts QNE and Instrument Maintenance.
SIM OP		If asked, as the QNE, it is not desired to bypass OPRMs 1 and 3.

Termination: APRM 1 has been bypassed.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 23 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Service Water Pump Trip.

3

Initiation: When APRM 1 has been bypassed and the ½ scram is reset or when directed by the lead examiner, trip the 2B Service Water pump using malfunction SW01e. (**imf sw01e**)

Time	Position	Applicant's Actions or Behavior	
	BOP	Reports 2B Service Water Pump tripped.	
		Refers to annunciator procedures QOA 912-1 A-3 SERVICE WATER PUMP TRIP, B-3 SERVICE WATER LOW PRESSURE, and C-3 FIRE PROTECT SERVICE WATER LOW PRESSURE.	
		Reports fire trouble alarm is alarming and ask U2 what is causing the alarm.	
SIM OP		Acknowledges fire trouble alarm using bat fire (bat fire).	
		Starts 2A Service Water Pump. Verifies adequate Service Water System pressure.	
		Dispatches an operator to investigate 2B Service Water Pump and breaker.	
SIM OP		As the NLO sent to investigate 2B Service Water pump trip, wait ~ 5 minutes and report 2B Service Water tripped due to overcurrent. If asked, report fire trouble alarm is due to fire diesel auto-start on low service water pressure.	
		Reports Fire Pumps auto-started.	
		Directs NLO to secure the Fire Diesels per QCOP 4100-03, Diesel Fire Pump Operation.	
	D O	Manitara plant parametera	
	RU		
	SRO	Directs start of 2A Service Water Pump.	
		Refers to QCOA 3900-01, Service Water System Failure.	
Termination: A standby Service Water pump has been started and the tripped pump is being investigated.			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 24 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Control Rod drift in 1 notch.

4

Initiation: When a standby Service Water pump has been started and the tripped pump is being investigated or when directed by the lead examiner, cause control rod 50-15 (N-4) to drift in 1 notch by inserting malfunction RD03 (**imf rd03r5015**) and deleting malfunction RD03 when control rod 50-15 (N-4) reaches position 45. (**dmf rd03r5015**)

Time	Position	Applicant's Actions or Behavior	
	RO	Reports alarm 901-5 A-3, Rod Drift and control rod 50-15 (N-4) drifted in one	
		notch to position 46.	
		Refers to the annunciator procedure and QCOA 0300-04, Mispositioned	
		Control Rod and QCOA 0300-11, Control Rod Drift.	
		Stops all control rod movements and reactor recirculation flow changes.	
		Verifies blue scram light is not lit.	
		Verifies alarm 901-5 A-1 is not up.	
		Verifies Drive water pressure is 260-350 psid and cooling water pressure is \sim	
		15 psid.	
		Selects control rod 50-15 (N-4) and moves to position 48.	
	BOP	Refers to the annunciator procedure and QCOA 0300-04, Mispositioned	
		Control Rod and QCOA 0300-11, Control Rod Drift.	
		Verifies instrument air pressure at 912-1, PI 1-340-20 is > 60 psig.	
		Dispatches an NLO to verify AO 1-305-127 (Scram Outlet Valve) discharge	
		line is not hot.	
SIM OP		As the NLO/Field Supervisor sent to check the scram outlet valve	
		discharge line, wait ~3 minutes and report the discharge line is cool to	
		the touch. Also report that you found the instrument air supply line to	
		the scram inlet valve leaking at a fitting and you were able to tighten the	
		fitting.	
		Contacts a QNE	
	SRO	Directs RO/BOP to address annunciator 901-5 A-3, Rod Drift and QCOA	
		0300-04, Mispositioned Control Rod and QCOA 0300-11, Control Rod Drift.	
		Refers to Tech Spec 3.1.6 and determines 8 hours to return control rod 50-15	
		(N-4) to 48 or insert and declare inop.	
		Directs control rod 50-15 (N-4) returned to position 48.	
Terminati	on: Control	rod 50-15 (N-4) has been returned to position 48.	

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 25 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: RHR Pump inadvertent start.

5

Initiation: When control rod 50-15 (N-4) has been returned to position 48 or when directed by the lead examiner, cause an inadvertent start of the 1C RHR pump using override dihs110021c close. **(ior dihs110021c close)** When 1C RHR pump is taken to PTL, delete the override. **(dor dihs110021c)**

Time	Position	Applicant's Actions or Behavior	
	BOP	Reports 1C RHR pump auto start and refers to annunciators 901-3 A-5,	
		CNMT SPRAY A or B Low Flow, A-6, RHR Pump Running and C-15, Auto	
		Blowdown Interlock Core spray/RHR.	
		Verifies MO 1-1001-18B (RHR Min Flow Valve) is open.	
		Determines a spurious pump start.	
		Places 1C RHR pump in PTL.	
		Directs NLO to 1C RHR Pump breaker.	
		Notify IMs, EMs, Engineering, and SOS.	
SIM OP		As the NLO sent to investigate 1C RHR pump breaker, wait ~ 3 minutes	
		and report no apparent reason for the inadvertent start.	
	SRO	Directs 1C RHR pump placed in PTL.	
		Refers to Tech Spec 3.5.1.B and determines Unit 1 has entered a 7 day time	
		clock. Also in Tech Spec 3.6.2.3 and 3.6.2.4 and TRM 3.6.a, cond A.	
	RO	Monitors plant parameters.	

Termination: 1C RHR pump is taken to PTL and is being investigated.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 26 of 3

EVENT/POSITION EVALUATION

Event No.(s):

6

Description: Main Condenser air in leakage that requires a power reduction.

Initiation: When 1C RHR pump is taken to PTL and is being investigated or when directed by the lead examiner, insert an air leak in the Main Condenser using malfunction MC08. (**imf mc08 50 20**:)

Time	Position	Applicant's Actions or Behavior	
	BOP/RO	Reports annunciator 900-54 C-7, Normal Process Flow Hi/Lo.	
		Checks charcoal adsorber DP and bypasses if > alarm setpoint (900-54 B-6).	
		Reports alarm 901-7 H-3 up, notes decreasing condenser vacuum on the	
		901-7 panel and refers to QCOA 3300-02, Loss of Condenser Vacuum.	
		Checks for closure of off-gas or SJAE suction valves.	
		Verifies Steam seal pressure normal.	
		Verifies Circ Water system operating normal.	
		Verifies condenser hotwell level normal.	
		Verifies condenser vacuum breaker is closed and has a water seal.	
		Dispatches operators to look for vacuum leaks.	
SIM OP		As the NLO dispatched to look for vacuum leaks, wait ~ 10 minutes and	
		report that the main condenser boot has an irrepairable rupture in it.	
		Verifies Rx pressure maintained < 1060 psig, commences a cooldown with	
		AUS Valves.	
		Verifies main Turbine tripped.	
		Verifies Group 2 and 3 isolations.	
	RO	Reduces recirc flow as necessary to maintain condenser vacuum \leq 5",	
		maintaining core flow <u>></u> 49 MLBM/hr.	
		Bypasses the RWM and inserts CRAM rods to position 00.	
		Inserts a Rx scram when vacuum cannot be maintained above 23.5".	
		Places Mode Switch in Shutdown.	
		Verifies all rods in.	
		Maintains RPV water level 0-48".	

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 27 of 3

Event No.(s):

6

Description: Main Condenser air in leakage that requires a power reduction. (continued)

Initiation: When 1C RHR pump is taken to PTL and is being investigated or when directed by the lead examiner, insert an air leak in the Main Condenser using malfunction MC08. (**imf mc08 50 20**:)

Refers to QCOA 3300-02, Loss of Condenser Vacuum.
Sets scram criteria of 23.5" vacuum. (6.5" Backpressure)
Directs RO to perform QCGP 2-3, Reactor scram.
If RPV water level reaches 0", enters QGA 100, RPV Control.
Directs BOP to verify 0" isolations.
Directs RO to maintain RPV water level 0-48".
Directs BOP to maintain RPV pressure < 1060 and commence a cooldown with ADS values, not to exceed 100 degrees E/br

Termination: The reactor is scrammed due to an inability to maintain main condenser vacuum.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 28 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Recirc suction line rupture.

7

Initiation: When the reactor has been scrammed due to low Main Condenser vacuum or when directed by the lead examiner, rupture the "A" Recirc loop suction line using malfunction RR10a at a severity of 0.5% ramped over 20 minutes. **(imf rr10a 0.5 20:)**

Time Position	Applicant's Actions or Behavior	
BOP Reports annunciator 90	1-3 A-16, PRIMARY CONTAINMENT HIGH	
PRESSURE and refers	to the annunciator procedure.	
BOP/RO Reports Dywell pressur	e is 1.55 and rising.	
BOP/RO Refers to QCOA 0201-0	01, INCREASING DRYWELL PRESSURE.	
BOP/RO Investigates cause of ris	sing Drywell pressure.	
BOP/RO Announces evacuation	Announces evacuation of Rx Building.	
BOP Starts 7 th Drywell Coole	Starts 7 th Drywell Cooler.	
BOP/RO Reports 2.5 psig in Dry	Reports 2.5 psig in Drywell.	
SRO Refers to QCOA 0201-0	01, INCREASING DRYWELL PRESSURE.	
Directs BOP/RO to inve	Directs BOP/RO to investigate cause of rising Drywell pressure.	
Directs evacuation of R	Directs evacuation of Rx Building.	
Enters QGA 100, RPV	Control and QGA 200, Primary Containment Control	
when Drywell pressure	reaches 2.5 psig.	

Termination: The scenario ends when the crew has performed an RPV Blowdown and reestablished core cooling with low pressure systems.



UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 29 of 3

EVENT/POSITION EVALUATION

Event No.(s):

8

Description: Loss of all RFPs and failure of HPCI leads to RPV Blowdown at TAF and low pressure system injection.

Initiation: When Drywell pressure reaches 2.5 psig, cause a loss of condensate pumps by inserting a loss of all condensate pumps using malfunction imf fw17 abcd. (imf fw17a) (imf fw17b) (imf fw17c) (imf fw17d)

Time	Position	Applicant's Actions or Behavior	
	RO	Reports all Feedwater pumps tripped.	
		Reports level every 20 inch drop.	
		Starts 2nd CRD pump.	
		Injects SBLC.	
		Reports level at -142".	
	BOP	Verifies EGDs and Low Pressure ECCS auto start, Group 2 and 3 isolations.	
		Reports HPCI failed to start, starts manually. After ~ 1 minute, HPCI trips.	
		Trip latches HPCI and sends an NLO to investigate.	
SIM OP		~ 1 minute after HPCI is started, trip HPCI using malfunction HP01. (imf HP01) Verify trigger 3 goes true 1 minute after HPCI reaches 3000	
		rom.	
SIM OP		As the NLO sent to investigate HPCI, wait ~ 5 minutes and report that the	
		HPCI Overspeed Linkage is broken. Mech Maint is investigating.	
	BOP/RO	Reports containment parameters.	
		Starts Torus sprays.	
		Reports 5 psig in Torus and reports Drywell pressure and temperature.	
		Starts Drywell sprays	
	BOP/RO	Starts/verifies RCIC starts for injection.	
	BOP/RO	Starts SSMP for injection to Unit 1.	
	BOP	Inhibits ADS.	
		Reports Torus level above 5 feet.	
		Diverts all ECCS flow to the core. Secures all containment sprays/cooling flow.	
		Opens all 5 ADS valves and leaves switches in MAN.	
		Verifies and reports all 5 ADS valves open.	
		When Rx pressure < 325 psig, verifies all LP ECCS systems inject.	
	BOP/RO	Maintains RPV water level 0-48 inches.	
SIM OP		When all injection has been attempted and with concurrence from the	
		Lead Examiner, increase the leak size to .6 modifying malfunction rr10a	
		(mmf rr10a .6 1:).	
Termina	tion: The sce	enario ends when the crew has performed an RPV Blowdown and reestablished	
core coo	ing with low	pressure systems.	

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 30 of 3

EVENT/POSITION EVALUATION

Event No.(s):

8

Description: Loss of all RFPs and failure of HPCI leads to RPV Blowdown at TAF and low pressure system injection. (Continued)

Initiation: When Drywell pressure reaches 2.5 psig, cause a loss of condensate pumps by inserting a loss of all condensate pumps using malfunction imf fw17 abcd. (imf fw17a) (imf fw17b) (imf fw17c) (imf fw17d)

Time	Position	Applicant's Actions or Behavior
	SRO	Directs actions of QGA 100, RPV Control and QGA 200, Primary Containment
		Control.
		Verifies rx scrammed and all rods in.
		Directs BOP to verify isolations and auto starts for 2.5 psig in Drywell.
		Directs level maintained with RCIC, HPCI, SSMP, CRD.
		Directs Torus sprays started and directs Torus pressure reported when 5 psig.
		Directs Drywell pressure and temperature reported.
		Verifies Recirc pumps and Drywell coolers off.
		Directs Drywell Sprays started.
		Directs use of Alternate injection systems, SBLC,
		Directs ADS inhibited.
		Determines 2 or more systems available per Detail F.
		When level reaches –142", determines a Detail F subsystem is lined up with a
		pump running.
		Determines any injection source is lined up with a pump running.
		Enters QGA 500-01, RPV Blowdown prior to –166".
		Determines Torus level above 5 feet.
		Directs all ECCS flow diverted to the Core.
		Directs all 5 ADS valves opened and the switches left in MAN.
		Directs RPV water level restored to 0-48 inches.

Termination: The scenario ends when the crew has performed an RPV Blowdown and reestablished core cooling with low pressure systems.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 31 of 3

FACILITY: QUAD CITIES			SCENARIO NO: 3 OP-TEST NO: 1				
EXAMI	EXAMINERS:OPERATORS:						
<u>INITIAL CONDITIONS</u> : ~3% Power, Reactor Start-Up In Progress, Mode Switch In Startup/Hot-Standby. The following equipment is out of service: 1B Service Water Pump, 1B Stator Cooling Pump and 1B Instrument Air Compressor OOS, IRM #12 bypassed. <u>TURNOVER</u> : Reactor Startup In Progress IAW QCGP 1-1 Step F.6. ad and ae. RWCU reject is ready to be secured and continue pulling rods for startup. The following equipment is out of service: 1B Service Water Pump, 1B Stator Cooling Pump and 1B Instrument Air Compressor OOS, IRM #12 bypassed.							
Event No.	Malfunction Number	Event Type*	Event Description				
1	N/A	N – B, S	Secure RWCU reject				
2	N/A	R – R, S	Pull rods to increase power				
3	RD07	C – R, S	CRD Pump trip				
4	NM05	I – R, S	IRM failure				
5	SW06/SW07	C – All	Loss of RBCCW/Trip of Recirc Pumps				
6	RP05	M – All	Reactor Scram with inadvertent Group 1.				
7	RD14/CR02	M – All	SDV Volume Rupture/Fuel Failure/QGA 300 RPV Blowdown				
8	HV01	С – В, Ѕ	Failure of Reactor Building Vents to isolate on Reactor Building Ventilation high rads.				

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (S)– SRO/US (R) – RO (B) – BOP/ANSO

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 32 of 3

Facility: Quad Cities

Scenario No: 3

Op-Test No: 1

Summary:

The crew will take the shift with the plant at ~ 3% power and secure RWCU reject blowdown. (Normal – BOP, SRO) The RO will then pull rods to increase power. (Reactivity – RO, SRO) A CRD pump will trip, requiring the standby CRD pump to be started. (Component – RO, SRO) An IRM will fail while the NSO is pulling rods, requiring a ½ scram to be inserted. (Instrument, TS – RO, SRO) A total loss of RBCCW will occur, requiring the Recirc pumps to be tripped (Component – All) and a Rx scram to be inserted. When the scram is inserted, an inadvertent Group 1 isolation will occur. (Major – All) A fuel failure and Scram Discharge Volume rupture that cannot be isolated will occur on the Rx Scram that leads to an RPV Blowdown on 2 areas above max safe rads. (Major – All) A Reactor Building Ventilation High High Rad alarm will come in with a failure of the RB Vents to isolate, requiring them to be manually isolated. (Instrument, TS – BOP, SRO)The scenario will be complete when the crew has completed the RPV blowdown and isolated Reactor Building Vents or at the discresion of the lead examiner.

CT #1 - The crew will recognize a failure of the Reactor Building Vents to isolate and manually isolate them using the control switch on the 912-1 Pnl.

CT #2 - The crew will recognize a trip of both recirc pumps and insert a manual reactor scram.

- With a primary system discharging into the secondary containment and area radiation/temperature/water levels exceed maximum safe levels in more than one area of the same parameter, INITIATE an emergency depressurization. (BWROG SC-1.2 LOCA SC E/D)

Simulator setup:

23. Load IC-81 from the zip drive and reset the simulator to IC-81: rst 81

24. Insert control rods until rod step 17 is at target in.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 33 of 3

25. Take the following equipment OOS:

1B Service Water Pump in PTL

1B Instrument Air Compressor in PTL

1B Stator Water Cooling pump in PTL

26. Bypass IRM 12

- 27. Insert the following malfunctions:
 - a. Fail the Reactor Building Vents to isolate using malfunction HV01. (imf hv01)
 - b. Verify, BUT DO NOT INSERT, batch file loct0102a contains the following: imf rd14a 100 10: ior dihs10590303 norm imf cr02 10 8: imf rm0106 (none 4:) 40 10: imf rm0108 (none 4:) 40 10: imf rm0109 (none 4:) 40 10: imf rm0111 40 10: imf rm0112 40 10: imf rm0113 40 10:
 - c. Assign trigger 2 to its default: trg 2 E2 and then assign a Group 1 isolation to occur when RPS B is deenergized using malfunction RP05. (imf rp05a(2); imf rp05b(2); imf rp05c(2); imf rp05d(2))
 - d. Bypass IRM 12.
- 28. Ensure RWM is setup correctly.
- 7. Verify the Rod Sequence Sheets are clean or replace if necessary.
- 8. Verify all procedures, QGAs, and meter faces, are erased.
- 9. Clear old SER and alarm screens.
- 10. Run new OD-20.
- 11. Place placard for RBCCW ¹/₂ lined up to U1 by the RBCCW pumps.
- 12. Establish RWCU reject flow at 80% open (Open the RWCU 78 valve and open the FCV to 80%).

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 34 of 3

LIST OF POTENTIAL PROCEDURES

QCGP 4-1 QCOP 0500-03, 0700-02, 0700-04, 1200-07, 1800-01 QCOS 1700-05 QCOA/QOA 0202-05, 0300-01, 0700-03, 5750-07, 7500-01 QCAN 901-3, A-1, A-3, G-3 QCAN 901-4, C-18, D-12, F-12, G-3, G-7, H-12 QCAN 901-5, A-2, A-4, A-5, B-2, B-11, C-10, E-2, F-2 T.S 3.1.5 T.S 3.3.1.1 T.S 3.3.6.2 T.S 3.3.7.1 QGAs HARD CARDS METER FACES

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 35 of 3

Crew Turnover:

Unit 1 is at approximately 3% power with a Rx startup in progress. The reactor is critical, 1 Bypass valve open, Containment is deinerted. Ready to pull rod step 17. Currently in QCGP 1-1, step F.6, ad and ae

Unit 2 is at approximately 912 MWe and 97% power on the 97% FCL.

The following equipment is out of service:

1B Service Water Pump due to a ground in the motor windings.

1B Stator Water Cooling pump due to overheating.

1B Instrument Air Compressor due to a seal water failure.

IRM #12 bypassed due to erratic operation. Maintenance and testing is complete. Shift Manager is reviewing paperwork for return to operation.

Alarm 901-5 B-3, Rod Worth Minimizer, Block alarms sporadically and is being investigated.

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip, alarms sporadically and is being investigated.

Instructions for the shift are to secure RWCU reject and continue the startup by pulling control rods in preparation for placing the Mode Switch in RUN

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 36 of 3

EVENT/POSITION EVALUATION						
Event No.(s): 1						
Description: Secure RWCU reject						
Initiation: The crew is directed to secure RWCU reject during shift turnover.						
Time	Position	Applicant's Actions or Behavior				
	SRO	Directs RWCU reject secured.				
	RO	Monitors plant parameters.				
	BOP	Secures RWCU reject per QCOP 1200-07, RWCU System Coolant Rejection. Closes FCV 1-1239, CU REJECT FCV				
		Verifies reject flow indicates 0.				
		Open MO 1-1201-80, RETURN ISOL VLV as necessary to maintain RWCU pump discharge pressure 100 to 200 psig greater than reactor pressure.				
Termination: RWCU reject is secured.						
Page 37 of 3

EVENT/POSITION EVALUATION				
Event No	(s) : 2			
Descript	ion: Increas	se power by pulling control rods.		
Initiation	: RWCU reje	ect is secured and the US orders power ascension.		
Time	Position Applicant's Actions or Behavior			
	SRO	Directs rod pulls to continue startup.		
		Conducts pre-job brief. (May have been done prior to crew taking shift).		
	BOP	Monitors Balance of plant parameters.		
RO Refers to QCGP 4-1, Control Rod Movements and Control Rod Sec		Refers to QCGP 4-1, Control Rod Movements and Control Rod Sequence.		
		Verifies rods in step 16 are at target out.		
		Selects the desired control rod.		
	Verifies the selection of the proper control rod, its present position and bound on the RWM.			
Communicates to QIV "Ready to move rod xx-yy from position to		Communicates to QIV "Ready to move rod xx-yy from position to		
	QIV Rod xx-yy is selected, understanding moving xx-yy from position to			
	RO	That's correct.		
		Performs another self check.		
		Moves control rod to desired position.		
		When all rods in the step are at target out, verifies with the QIV that each		
		control rod is at its desired position.		
		Fills out the rod sequence sheet.		
	Repeats for subsequent steps as necessary.			
Terminat	tion: When a	a discernable increase has been noted or as directed by the lead examiner		

Page 38 of 3

EVENT/POSITION EVALUATION					
Event No	ɔ.(s): 3				
Descript	ion: CRD pu	ump trip			
Initiation: When directed by the lead examiner, trip the "A" CRD pump using malfunction RD07a. (imf rd07a)					
Time	Position	osition Applicant's Actions or Behavior			
	RO	Reports annunciators 901-5 A-2, CRD PUMP TRIP and F-2, CRD			
		Verifies closed MO 1-301-28, 18 PMP DISCH VI V for 18 CRD nump			
		Starts 1B CRD nump			
		Verifies Steady-state current < 34 amps on 1-302-1B.			
	Throttles MO 1-301-2B discharge valve to maintain 1400-1500 psig.				
		Closes MO 1-301-2A, discharge valve on the tripped pump.			
		Dispatches an NLO to check operation of the running pump and investigate the tripped pump.			
		Directs an NLO to close 1-301-254A (Min flow valve) for the tripped pump and open 1-301-254B (Min flow valve) for the running pump			
SIM OP		As the NLO sent to the CRD pumps, report 1B CRD pump post start			
		checks are sat, 1-301-254B is open, 1-301-254A is closed and 1A CRD			
		pump tripped on overcurrent.			
	BOP/RO	Refers to QCOA 0300-01, Control Rod Drive Pump Failure.			
	BOP	Monitors plant parameters.			
	000	D. C. J. COOA 2000 04. Os stasl Ded Drive Duran Feilure			
	SRU	Refers to QCOA 0300-01, Control Rod Drive Pump Failure.			
		Directs start of starioby GRD pump.			
		pressure > 900 psig, directs charging header pressure restored within 20			
Termination: "B" CRD pump has been started and CRD system parameters are returned to normal.					

Page 39 of 3

-					
EVENT/POSITION EVALUATION					
Event No	Event No.(s): 4				
Description: IRM failure					
Initiation using ma	: When rod Ifunction NM	pulls are complete or directed by the Lead Examiner, fail irm 11 downscale 05a at 0% severity. (imf nm05a 0)			
Time	Position	Applicant's Actions or Behavior			
	RO	Reports annunciator 901-5 C-5, IRM DOWNSCALE and refers to the annunciator procedure.			
		Reports IRM #11 indicates downscale.			
		Verifies rod block occurred.			
		May insert ½ scram on RPS channel "A".			
SIM OP		As the Shift Manager, if asked about the status of IRM 12 or notified that the start-up was stopped, report that IRM 12 has been cleared for operation.			
		Returns IRM 12 to operation. Bypasses IRM 11 and resets ½ scram, if inserted.			
	BOP/RO	Refers to QCOA 0700-03, Loss of neutron flux Indication.			
	RO	Stops all reactivity changes and holds power constant.			
	BOP/RO	Refers to QCOP 0700-02, Intermediate Range Monitor Operation (IRM).			
	SRO	Refers to QCOA 0700-03, Loss of neutron flux Indication.			
		Directs reactivity changes stopped and power held constant.			
		Refers to QCOP 0700-02, Intermediate Range Monitor Operation (IRM) and			
		Tech specs 3.3.1.1.			
		Determines minimum number of IRM channels NOT available.			
		May direct a ½ scram inserted on RPS channel "A"			
		Directs IRM 12 return to operation. IRM 11 bypassed and ½ scram reset, if inserted.			
	BOP	Monitors plant parameters.			
		Contacts QNE and Instrument Maintenance.			
Terminat	tion: IRM 11	is bypassed and the $\frac{1}{2}$ scram is reset if it was inserted.			

Page 40 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Loss of RBCCW

5

Initiation: When "B" CRD pump has been started and CRD system parameters are returned/being returned to normal or when directed by the lead examiner, simulate a leak in the RBCCW system by reducing the capacity of the 1B and ½ C RBCCW pumps using malfunction SW07 to 85% reduced capacity over 5 minutes. (**imf sw07b 85 5:**) (**imf sw07c 85 5:**). When directed by Lead Examiner, override annunciator 912-1, F-1 on to simulate RBCCW expansion tank low level. (**imf ano9121f1 on) After 2 minutes**, override annunciator 9014c18 on to simulate Rx Building Floor Drain Sump High Level. (**imf ano9014c18 on**)

After 3 minutes, trip the "A" RBCCW pump using malfunction SW06a. (imf sw06a)

Time	Position	Applicant's Actions or Behavior		
	BOP	Reports annunciator 912-1 D-1 RBCCW Low Pressure and refers to the proc.		
		Checks PI 1-3740-4, DISCH HDR PRESS and determines Unit 1 RBCCW		
		discharge press is 40 psig and dropping.		
		Directs an NLO to line up the 1/2 RBCCW pump to Unit 1 and investigate		
		RBCCW low pressure on unit 1.		
SIM OP		As the NLO sent to RBCCW, wait ~ 4-6 minutes and report an RBCCW		
		leak on the suction piping for the RBCCW pumps. If asked, you cannot		
		isolate it.		
		Refers to QCOA 3700-01, RBCCW Low Pressure.		
	BOP/RO	Monitors Recirc pump seal cooling temp and flow.		
SIM OP		When the crew is monitoring recirc seal temps, trip the "A" RBCCW		
		pump using malfunction SW06. (imf sw06a)		
		Reports annunciators 901-4 G-3 and G-7, Recirc pump A and B Seal Cooling		
		Water low flow and refers to the procedure.		
		Directs NLO to remove RWCU Filter Demins from service and stops the		
		RWCU pumps.		
	BOP	Closes MO 1-3701, U-1 RBCCW HDR ISOL.		
		Reports annunciator 912-1 C-1, RBCCW pump trip and reports a trip of 1A		
		RBCCW pump trip and RBCCW discharge pressure ~ 20 psig and dropping.		
	RO	Monitors plant parameters.		
		Inserts a Rx Scram.		
	RO/BOP	Trips the recirc pumps and refers to QCOA 0202-05, Reactor Recirc Pump		
		Trip – Both pumps.		
SIM OP		When actions for low RBCCW flow are completed, trip 1B RBCCW pump		
		using malfunction sw06b (imf sw06b).		
NOTES:				

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 41 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Loss of RBCCW (continued)

5

Initiation: When "B" CRD pump has been started and CRD system parameters are returned/being returned to normal or when directed by the lead examiner, simulate a leak in the RBCCW system by reducing the capacity of the 1B and ½ C RBCCW pumps using malfunction SW07 to 85% reduced capacity over 5 minutes. (**imf sw07b 85 5:**) (**imf sw07c 85 5:**). When directed by Lead Examiner, override annunciator 912-1, F-1 on to simulate RBCCW expansion tank low level. (**imf ano9121f1 on) After 2 minutes**, override annunciator 9014c18 on to simulate Rx Building Floor Drain Sump High Level. (**imf ano9014c18 on**)

After 3 minutes, trip the "A" RBCCW pump using malfunction SW06a. (imf sw06a))

	SRO	Refers to QCOA 3700-01, RBCCW Low Pressure.
		Directs seal temps and flow monitored.
		Directs RWCU stopped and MO 1-3701 closed.
		Directs Rx scrammed.
		Directs Recirc pumps tripped and refers to QCOA 0202-05, Reactor Recirc
		Pump Trip – Both pumps.
— · · ·	D (

Termination: Reactor Recirc pumps are tripped.

Page 42 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Reactor Scram with Inadvertent Group 1 Isolation

Initiation: Failure of RBCCW/Trip of Recirc Pumps

6

Time	Position	Applicant's Actions or Behavior			
	RO	Depresses Scram pushbuttons.			
		Places Mode Switch in Shutdown.			
		Verifies and reports all rods in.			
		Maintains RPV water level 0-48".			
	BOP/RO	Maintains RPV pressure < 1060 psig.			
	RO	Verifies SRMs/IRMs insert.			
		Verifies Main Turbine tripped.			
		Verifies alarm 901-8 H-9, EXCITER FIELD BRKR OPEN is lit.			
	SRO	Directs Rx scrammed and QCGP 2-3, Reactor Scram entered.			
		Directs RPV water level maintained 0-48".			
		Directs RPV pressure maintained < 1060 psig and RPV cooldown < 100			
		degrees F/hr.			
		Directs QCOA 0202-05, Reactor Recirc Pump Trip – Both pumps.			
	BOP/RO	Reports all MSIVs closed.			
	BOP	Performs RPV cooldown at < 100 degrees F/hr.			
	BOP/RO	Refers to QCOA 0202-05, Reactor Recirc Pump Trip – Both pumps.			
Termina	Termination: Mode Switch in SHUTDOWN and RPV water level being controlled.				

Page 43 of 3

EVENT/POSITION EVALUATION

Event No.(s):

7

Description: SDV Rupture/Fuel Failure/QGA 300 RPV Blowdown

Initiation: When the reactor scram is inserted, insert batch file loct0102a to simulate a SDV rupture, a fuel failure and a failure of the scram reset switch. (bat loct0102a) (imf rm02k 100 5:) (imf rm02l 100 5:)

Time	Position	Applicant's Actions or Behavior		
	BOP	Reports annunciator 901-3 A-1 Rx BDG Hi Rad and refers to the ann. Proc.		
		Reports alarming area in the Rx BLDG to the SRO.		
		Evacuates affected areas.		
		Dispatches an operator and Rad Protection to investigate.		
		Directs RP to set up access control.		
SIM OP		As the operator sent to investigate hi rads, wait ~ 3 minutes and report a		
		lot of steam and water in the vicinity of the North SDV.		
		Refers to QCOA 0201-05, Primary System Leaks (Slow Leaks) Outside		
		Primary Containment and QCOA 1800-01, Area High Radiation.		
		Monitors and reports rad levels.		
		Reports torus level > 5 feet.		
		Opens all 5 ADS valves and leaves switches in MAN.		
		Verifies and reports all 5 ADS valves open.		
	RO	Attempts to isolate the leak by resetting the Rx scram IAW QCOP 0500-03,		
		Resetting Scrams.		
		Reports the scram will not reset.		
	SRO	Enters QGA 300, Secondary Containment Control.		
		Directs Unit 1 DGCWP started.		
SIM OP		As the NLO directed to start the U-1 DGCWP, wait ~ 3 minutes and start		
		the pump using remote function SW 10. (mrf sw10r RUN)		
0114 0.0		Directs Rx BLDG Basement water levels checked.		
SIM OP		As the NLO sent to check RX Bidg water levels, wait ~ 5 minutes and		
		Preport that access is not allowed to the RX Bidg Basement.		
		Directs scram reset if not allempted.		
		cannot be isolated and one area > Max Safe, onters OCA 100, PPV Control		
		$\frac{1}{100} \text{ be isolated and one area > Max Sale, enters QGA 100, RFV Control.}$		
		Determines Terus level above 5 feet		
		Directs all ECCS flow diverted to the Core		
		Directs all 5 ADS valves enabled and the switches left in MAN		
	· -·			
Terminat	tion: The sce	enario will be complete when the crew has completed the RPV blowdown.		
NOTES:				

Page 44 of 3

Event No.(s):

8

Description: Reactor Building Vents fail to isolate when Reactor Building Ventilation High - High Radiation alarms.

Initiation: Reactor Building Ventilation High-High Radiation alarms..

Time	Position	Applicant's Actions or Behavior	
	BOP	Reports annunciators 901-3 G-3 and H-3, RX BLDG VENT CHANNEL A/B HI	
		HI RADIATION and refers to the annunciator procedure.	
		Verifies Reactor Building Vents and Control Room Vents isolate and Standby	
		Gas Treatment Starts	
		Notes failure of Unit 1 Reactor Building Vents to isolate and manually isolates	
		indies failure of ornit i Reactor Dunuing vents to isolate and manually isolates.	
		Reports failure of Reactor Building Vent isolation to the US.	
		Contacts maintenance to investigate the failure of Reactor Building Vents to	
		isolate.	
	US	Directs Unit 1 Reactor Building Vents isolated	
	00		
	RU	Monitors plant parameters.	

Termination: Reactor Building Vents are isolated.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 45 of 3

Facility: Quad Cities Scenario No: 4 Op-Test No: 1				
Examiners:			Operators:	
		<u> </u>		<u></u>
Initial C SBGT (Conditions: ~ 700 running for mont	0 MWe, 75% hly surveilla	% power, 1A RHR Loop and ance.	I 1B Service Water Pump OOS. B
<u>Turnover</u> : The following equipment is out of service: 1A RHR loop and 1B Service Water Pump. B SBGT is running for the monthly surveillance per QCOS 7500-05 and is ready to be shutdown per step H.2.p.				
Event No.	Malfunction Number	Event Type*	Event Description	
1	N/A	N – B, S	Shutdown SBGT	
2	RR01	R – R, S	Insert Control Rods to exit drive motor breaker trip.	the instability region due to recirc
3	RD02	C – R, S	Stuck control rod.	
4	EG05	C – B, S	Stator Cooling Pump Trip start.	with failure of the Standby to auto
5	AD01	I – B, S	ADS valve fails open due	to setpoint drift – Rx scram
6	RP02/RP03	I – R, S	Control rods fail to insert o (PSA identified event)	n manual scram – initiate ARI.
7	MS05/RP05	M – All	Steamline break in Drywel	I with a Group I.
8	lor zdish11001S 17(B)1 Bat DWCLRTRIP	M – All	Failure of Drywell Sprays a blowdown and flooding. (F	and Cooling leads to RPV 'SA identified event)

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor (S)– SRO/US (R) – RO (B) – BOP/ANSO

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 46 of 3

Facility: Quad Cities Scenario No: 4 Op-Test No: 1 Summary: The crew will take the shift with SBGT running. The surveillance is complete and needs to be shutdown. (Normal – BOP, SRO) After this, a Recirc Pump drive motor breaker will trip, requiring the RO to insert cram rods. (Reactivity manipulation, TS – RO, SRO) While inserting cram rods, one of the rods will stick, requiring drive water pressure to be raised in order to drive it. (Component, - RO, SRO) When they have inserted cram rods/exited the instability region, the running Stator Water Cooling Pump will trip and the standby will fail to auto start, requiring it to be manually started. (Component - BOP, SRO). An ADS valve will fail open and will not close when attempted manually, (Instrument, TS – BOP, SRO) requiring a manual scram to be inserted. When the manual scram pushbuttons are depressed, no rod movement will occur, requiring initiation of ARI to insert the rods. (Instrument – RO, SRO) After the rods are inserted, a steamline break will occur in the Drywell with an inadvertent Group 1 isolation. Coupled with a failure of Drywell Sprays and Cooling, this will lead to an RPV Blowdown and RPV Flooding. (Major – All) The scenario will be completed when the crew has identified the requirements to determine the Main Steam Lines are flooded.

CT #1 - Crew will recognize instabilities region has been entered and insert control rods to exit instabilities.

CT #2 - When Torus Pressure cannot be maintained below PSP curve and/or drywell temperature cannot be restored or held below 280°F, INITIATE emergency depressurization. below 280°F, INITIATE emergency depressurization.

CT #3 - When RPV level cannot be determined, INJECT into the RPV to maintain RPV flooded to the Main Steam Lines. (BWROG RPV-2.2 LOSS LVL INST MRPVFP)

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 47 of 3

Simulator setup:

- 29. Load IC-82 from the zip drive and reset the simulator to IC-82: rst 82
- 30. Take the following equipment OOS: **1B Service Water Pump in PTL**

1A RHR Loop 1A RHR Pump in PTL

1B RHR Pump in PTL

31. Insert batch file bat Arhroos_1.

Verify the following valves CLOSED, leave the hand switches in NEUTRAL and THEN open the valve breakers:

MO-1-1001-18A	(mrf rh17ar open)
MO-1-1001-19A	(mrf rh18ar open)
MO-1-1001- 23A	(mrf rh19ar open)
MO-1-1001-26A	(mrf rh20ar open)
MO-1-1001-28A	(mrf rh21ar open)
MO-1-1001-29A	(mrf rh22ar open)
MO-1-1001-34A	(mrf rh23ar open)
Verify the following valves	CLOSED and THEN override their lights off
MO-1-1001-43A	(ior lohs1100143a1 off)
MO-1-1001-43B	(ior lohs1100143b1 off)
MO-1-1001-7A	(ior lohs110017a1 off)
MO-1-1001-7B	(ior lohs110017b1 off)
MO-1-1001-19A	(ior lohs1100119a1 off)
Verify the "A" RHR Pump disc	charge pressure gauge downscale.
(ior aopi110402a 0)	
Verify the RHR DISCH HDR	PRESS HI/LO alarm on the 901-3 panel ON.
(imf ano9013c8 on)	

- 32. Insert the following malfunctions:
 - e. Fail B channel of RPS and ATWS to scram using malfunction RP02 B & D and RP03 A,B.

(imf rp02b; imf rp02d; imf rp03a; imf rp03b)

- b. Fail the "B" Stator Water Cooling pump to autostart by overriding it off. (ior dihs15300scpb trip)
- c. Fail the "B" RHR Loop S-17 switch by overriding it off. (ior dihs11001s17b off)
- d. Assign trigger 15 to DWCLRATRP. (trg 15 DWCLRATRP)
- e. Cause the DW Coolers to trip when trigger 15 goes true by inserting batch file DWCLRTRP. (bat DWCLRTRP)
- f. Stick Control Rod 4211 fully out using malfunction rd02r at 100%. (imf rd02r4211 100)
- g. Assign trigger 1 to event **rdpdrivedelta.gt.350** and assign command **dmf rd02r4211** to trigger 1.
- h. Assign trigger 3 to event zdihs10287303a(1).and.zdihs10287303d(1).and. zdihs10287303e(1) and assign command mmf ms04c 12 1: to trigger 3.
- 5. Start the "B" train of SBGT IAW QCOS 7500-05 step H.2.c e.
- 6. Verify the RWM is setup correctly.
- 7. Verify the Rod Sequence sheets are clean or replace as necessary.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 48 of 3

- 8. Verify all procedures, QGAs, and meter faces, are erased.
- 9. Clear old SER and alarm screens.
- 10. Run new OD-20.
- 11. Write on white board the following:

Tech Spec 3.5.1 Condition A, 1A and 1B RHR Pump OOS Day 1 of 30 Tech Spec 3.5.1 Condition B, LPCI Subsystem A Inop Day 1 of 7 Tech Spec 3.5.1 Condition D, Both LPCI Subsystems Inop Day 1 of 3 Tech Spec 3.6.2.3. Condition A, A Loop RHR Suppression Pool Cooling Inop Day 1 of 7 Tech Spec 3.6.2.4. Condition A, A Loop RHR Suppression Pool Spray Inop Day 1 of 7 TRM 3.6.a. Condition A, A Loop RHR Drywell Spray Inop Day 1 of 7

12. Place placard for RBCCW ¹/₂ lined up to U1 by the RBCCW pumps.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 49 of 3

LIST OF POTENTIAL PROCEDURES

QCGP	1-1,	4-1							
QCOP	P 0202-07, 1600-13,		0202-13, 3500-05		0600-(02,	1000	-30,	1200-07,
QCOS	0202-0	09,	7500-0)5					
QCOA	QCOA 0201-01, 1700-04,		0202-0 5300-0)4,)1	0203-(D1,	0300	-02,	0400-02,
QCAN	912-5	B-6							
QCAN	901-3	A-16,	E-13,	E-14,	E-16				
QCAN	901-4	A-3,	A-9,	H-3					
QOA 9	01-7 A	-7,	B-10,	C-10					
POWE	R/FLO	w map							
T.S 3.1.3, T.S 3.4.1,		1 .1,	T.S 3.8	5.1,	T.S 3.0).3			
QCAP 0200-10									
QGAs									
HARD CARDS									
METER FACES									

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 50 of 3

Crew Turnover:

Unit 1 is at approximately 700 MWe and 76% power on the 92% FCL.

Unit 2 is at approximately 912 MWe and 97% power on the 97% FCL.

The following equipment is OOS:

1B Service Water Pump due to a ground in the motor windings. Electrical Maintenance is investigating.

1A RHR Loop is OOS for packing replacement on the 1-1001-66A valve.

Day 1 of 7, TS 3.5.1, Condition B, LPCI Subsystem A Inop.

Day 1 of 3, TS 3.5.1, Condition D, Both LPCI Subsystems Inop.

Day 1 of 30, TS 3.5.1, Condition A, RHR Pump Inop.

Day 1 of 7, TS 3.6.2.3, Condition A, A Loop RHR Suppression Pool Cooling Inop.

Day 1 of 7, TS 3.6.2.4, Condition A, A Loop RHR Suppression Pool Sprays Inop.

Day 1 of 7, TRM 3.6.a, Condition A, A Loop RHR Drywell Sprays Inop.

Alarm 901-5 B-3, Rod Worth Minimizer, Block alarms sporadically and is being investigated.

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip, alarms sporadically and is being investigated.

Instructions for the shift are to hold load.

QCOS 7500-05, SBGTS MONTHLY OPERABILITY TEST is complete through step H.2.o, has been running for 10 hours and is to be shutdown when you take the shift.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 51 of 3

		EVENT/POSITION EVALUATION
Event No	o.(s): 1	
Descript	ion: Shutde	own SBGT
Initiatior	: The crew	is directed during the shift turnover to shutdown SBGT.
Time	Position	Applicant's Actions or Behavior
	SRO	Directs "B" SBGT Train secured.
		Approves the surveillance.
	RO	Monitors plant parameters.
	BOP	Refers to QCOS 7500-05, SBGTS Monthly Operability Test.
		Places the "B" train 1/2 SBGTS TRAIN MODE SELECTOR SWITCH in B OFF.
		Announces alarm 912-5 B-6 SBGT trouble.
		Places ½ B SBGTS TRAIN MODE SELECTOR SWITCH to B PRIM.
		Records SBGT B run time and verifies > 10 hours.
		Verifies ¹ / ₂ - 7505B INLET DAMPER closed.
		Verifies ¹ / ₂ - 7504B TURB BLDG CLG AIR DMPR open.
		Verifies ¹ / ₂ - 7503B SBGTS AIR HTR off.
		Verifies ¹ / ₂ - 7506B ¹ / ₂ SBGTS FAN off.
		Verifies ¹ / ₂ - 7507B SBGTS FAN DISCH DMPR closed.
		Verifies all applicable SBGTS annunciators are cleared.
		Verifies ¹ / ₂ B SBGTS TRAIN MODE SELECTOR SWITCH in B PRIM.
		Verifies ¹ / ₂ A SBGTS TRAIN MODE SELECTOR SWITCH is in A STBY.
		Signs off surveillance performance.
Termina	tion: SBGT	shutdown per QCOS 7500-05.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 52 of 3

EVENT/POSITION EVALUATION

Event No.(s):

2

Description: Insert Control Rods to exit the instability region due to recirc drive motor breaker trip.

Initiation: When SBGT shutdown is complete per QCOS 7500-05 or when directed by the lead examiner, trip the "A" Recirc Pump Motor breaker using malfunction RR01a. (**imf rr01a**)

Time	Position	Applicant's Actions or Behavior
	BOP/RO	Reports annunciator 901-4 A-9, RECIRC SETS DRIVE MOTOR AUTO TRIP
	BOP	Refers to the annunciator procedure.
		Reports 1A Recirc MG tripped.
		Verifies "B" Recirc pump speed < 78% and motor current < 724 amps.
	BOP/RO	Refers to QCOA 0202-04, Reactor Recirc Pump Trip – Single Pump.
		Refers to QCOA 0400-02, Core Instabilities.
		Closes MO 1-202-5A and reopens after at least 5 minutes.
		Monitors loop delta-T and RPV bottom head temperature.
		Contacts QNE.
		Monitors Off-Gas rad levels and refers to QCOA 1700-04, Abnormal Off Gas
		Radiation.
		Performs QCOS 0202-09, Recirculation Single Loop Operation Outage Report.
	RO	Monitors for power oscillations.
		Bypasses the RWM.
		Continuously inserts all CRAM rods to position 00.
		Continues to insert control rods to target in until power has stopped increasing
		and FCL < 59.4%.
		Continues to monitor for power oscillations.
		Completes QCOP 0207-02, RWM Bypass Control to document bypassing the
		RWM if necessary.
	SRO	Directs the RO to monitor for power oscillations.
		Refers to QCOA 0202-04, Reactor Recirc Pump Trip – Single Pump
		Directs CRAM rods driven to position 00.
		Directs control rods inserted to target in until power has stopped increasing
		and FCL < 59.4%.
		Refers to QCOA 0400-02, Core Instabilities.
		Directs QCOS 0202-09, Recirculation Single Loop Operation Outage Report.
		performed.
		Refer to 15 3.4.1. and declares A Recirc Loop not in operation within 2 hours.
Termina	tion: Instabi	lity region is exited.

Page 53 of 3

		EVENT/POSITION EVALUATION			
Event No	Event No.(s): 3				
Descript	ion: Stuck	Control Rod			
Initiation (imf rd02	1: Control ro 2 r4211 100)	d 4211 will not insert when selected due to being stuck fully out.			
Time	Position	Applicant's Actions or Behavior			
	RO	Reports that rod 4211 is stuck at position 48			
		Refers to QCOA 0300-02, Control Rod Stuck.			
		Verifies no Control Rod Block or RWM Select Block exist and			
		Control Rod 4211 is selected.			
		Throttles MO 1-302-8, U-1 CRD DRIVE WTR PCV to increase drive water			
		pressure in 50 psid increments to a maximum of 400 psid.			
		Drives the Control Rod to position 00 after Drive Water pressure is > 350 psid.			
		Returns Drive water pressure to 260 – 350 psid.			
SIMOP		delete malfunction rd02r4211.			
	BOP	Monitors plant parameters and continues actions for a tripped Recirc pump.			
		Contacts QNE.			
	SRO	Refers to QCOA 0300-02, Control Rod Stuck.			
		Directs RO to investigate cause of stuck Control Rod.			
		May refer to TS 3.1.3. – Control Rod is not considered stuck for Bases 3.1.3-3.			
SIM OP		If asked as Ops Management, direct 1B RFP secured.			
Termina	tion: The st	uck control rod is driven to 00.			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 54 of 3

EVENT/POSITION EVALUATION

Event No.(s):

4

Description: Stator Cooling Pump Trip with failure of the Standby to auto start.

Initiation: When the stuck control rod is driven to 00 or when directed by the lead examiner, trip the "A" Stator Cooling Water Pump using malfunction EG05a. (**imf eg05a**)

Time	Position	Applicant's Actions or Behavior
	BOP/RO	Reports annunciator 901-7 B-10, STATOR COOLING PUMPS AUTO TRIP.
		Starts the 1B Stator Cooling Water pump.
SIM OP		When the 1B Stator Cooling Water Pump is given a start signal, delete
		override DIHS15300scpb. (dor dihs15300scpb)
		Refers to annunciator procedure.
		Dispatches an operator to check Stator Cooling Water parameters and the
		tripped Stator Cooling Water pump.
		Directs Electrical Maintenance to investigate failure of 1B Stator Cooling Water
		pump to auto start.
	RO	Monitors plant parameters.
	SRO	Refers to QCOA 5300-01, Loss of Stator Cooling.
		Directs 1B Stator Cooling Water pump started.

Termination: The "B" Stator Water Cooling pump has been manually started and the trip of the "A" Stator Water Cooling pump is being investigated.



Page 55 of 3

EVENT/POSITION EVALUATION

Event No.(s):

5

Description: ADS valve fails open due to setpoint drift – Rx scram

Initiation: Fail the A side or RPS to scram using malfunction rp02. **(imf rp02a; imf rp02c)** When the "B" Stator Cooling Water pump has been manually started and the trip of the "A" Stator Water Cooling pump is being investigated or when directed by the lead examiner, cause the "E" relief valve to spuriously open using malfunction AD01e at 0% severity and stick open using malfunction ad07e at 100% severity. **(imf ad01e 0) (imf ad07e 100)**

Time	Position	Applicant's Actions or Behavior
	BOP/RO	Reports annunciators 901-3 E-13, ELEC RELIEF VALVE 3C/3D/3E OPEN,
		E-14, ACOUSTIC MON SAFETY RLF VALVES OPEN, and E-16, VALVE
		LEAK DET SYS HIGH TEMP, and refers to the annunciator procedures.
		Determines "E" Relief Valve open by use of the Acoustic monitor.
		Places the Key Switch for "E" Relief Valve in OFF.
		Reports "E" Relief Valve did not close, attempts to close by cycling the Key Switch between MAN and AUTO.
		Scrams the reactor and enters QCOA 0203-01, Failure of a Relief Valve to Close or Reseat properly at SUBSEQUENT OPERATOR ACTIONS.
		Determines "E" Relief Valve solenoid can be deenergized with the keylock
		switch.
		Starts Torus cooling.
		Monitors torus temperature.
		Monitors Recirc loop temps, Reactor shell and flange temps and continues to attempt to close "E" Relief Valve.
	RO	Monitors plant parameters.
	SRO	Refers to QCOA 0203-01, Failure of a Relief Valve to Close or Reseat
		Directs the BOD to attempt to close "E" Pelief Valve
		Directs the BOF to allempt to close L. Keller valve.
		Difects the KO to filse it a Manual Reactor Sciam.

Termination: The crew has attempted to close "E" relief valve.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 56 of 3

EVENT/POSITION EVALUATION

Event No.(s):

6

Description: Control rods fail to insert on manual scram – initiate ARI.

Initiation: RO attempts manual Rx scram due to "E" relief valve sticking open.

Time	Position	Applicant's Actions or Behavior		
	RO	Inserts a manual reactor scram.		
		Places the Mode Switch in SHUTDOWN.		
		Reports no rod motion.		
		Manually initiates ARI.		
		Runs Recirc pumps to minimum.		
		Reports control rods are inserting.		
		Reports all Control Rods are inserted.		
	BOP	Monitors plant parameters.		
		Inhibits ADS.		
		Places Core Spray Pumps in PTL.		
	SRO	Enters QGA 100, RPV Control on failure to scram.		
		Determines rods are > 04 and the reactor will not stay shutdown per QNE.		
		Enters QGA 101, RPV Control (ATWS).		
		Directs ADS inhibited.		
		Directs Core Spray pumps placed in PTL.		
		Returns to QGA 100, RPV Control when all control rods are inserted.		
Termination: The RO has manually initiated ARI and all control rods are inserted.				

Page 57 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Steamline break in Drywell with a Group I.

Initiation: When the control rods are inserted, insert a steam line break in the Drywell using malfunction MS04c at 2% severity over 20 minutes (**imf ms04c 2 20:**) and insert an inadvertent Group 1 isolation using malfunction RP05.

(imf rp05a; imf rp05b; imf rp05c; imf rp05d)

7

Time	Position	Applicant's Actions or Behavior
	BOP/RO	Reports closure of MSIVs
	BOP/RO	Controls RPV pressure as directed by SRO
	BOP/RO	Reports annunciator 901-3 A-16, PRIMARY CONTAINMENT HIGH
		PRESSURE and refers to the annunciator procedure.
	BOP/RO	Reports Drywell pressure is 1.55 and rising.
	BOP/RO	Refers to QCOA 0201-01, INCREASING DRYWELL PRESSURE.
	BOP/RO	Investigates cause of rising Drywell pressure.
	BOP/RO	Announces evacuation of Rx Building.
	BOP	Starts 7 th Drywell Cooler.
	BOP/RO	Reports 2.5 psig in Drywell.
	BOP	Reports containment parameters.
		Attempts to start Torus sprays, reports Torus Sprays will not start and directs
		NLO to manually open the MO 1-1001-34B valve.
SIM OP		As the NLO sent to open the MO 1-1001-34B valve, wait 5 minutes and
		deenergize the MO 1-1001-34B valve breaker using remote function
		RH23br. (mrf rh23br open) Wait 10 more minutes and open the
		MO 1-1001-34B valve using remote function RH33br. (mrf rh33rb open)

Termination: The crew is taking actions in QGA 200 to address rising containment pressure and temperature.

Page 58 of 3

EVENT/POSITION EVALUATION

Event No.(s):

Description: Steamline break in Drywell with a Group I. (Continued)

Initiation: When the control rods are inserted, insert a steam line break in the Drywell using malfunction MS04c at 2% severity over 20 minutes (**imf ms04c 2 20:**) and insert an inadvertent Group 1 isolation using malfunction RP05.

(imf rp05a; imf rp05b; imf rp05c; imf rp05d)

7

Position	Applicant's Actions or Behavior	
SRO	Refers to QCOA 0201-01, INCREASING DRYWELL PRESSURE.	
	Directs BOP/RO to investigate cause of rising Drywell pressure.	
	Directs evacuation of Rx Building.	
	Enters QGA 200, Primary Containment Control and re-enters QGA 100, RPV	
	Control when Drywell pressure reaches 2.5 psig.	
	Directs BOP to verify isolations and auto starts for 2.5 psig in Drywell.	
	Directs level maintained 0-48 inches.	
	Directs Torus sprays started and directs Torus pressure reported when 5 psig.	
	Directs Torus sprays started locally.	
	Directs Drywell pressure and temperature reported.	
	Verifies Recirc pumps and Drywell coolers off.	
	Directs Drywell Sprays started.	
	Directs Drywell sprays started locally.	
	Establishes blowdown criteria for torus pressure and drywell temperature.	
	Directs containment vented per QCOP 1600-13, Post – Accident Venting of the	
	Primary Containment if necessary.	
	Position SRO	

Termination: The crew is taking actions in QGA 200 to address rising containment pressure and temperature.

Page 59 of 3

	EVENT/POSITION EVALUATION				
Event No	b.(s): 8				
Descript	ion: Failure o	of Drywell Sprays and Cooling leads to RPV blowdown and flooding.			
Initiation DWCLRT	: Verify that RP has gone	trg 15 goes active when the crew trips the "A" DW Cooler and that batch file e active, preventing the DW Coolers from being restarted.			
Time	Position	Applicant's Actions or Behavior			
	BOP	Reports 5 psig in Torus and reports Drywell pressure and temperature.			
		Attempts to start Drywell sprays, reports Drywell Sprays will not start and directs NLO to manually open the MO 1-1001-23B valve.			
SIM OP		As the NLO sent to open the MO 1-1001-23B valve, wait 5 minutes and deenergize the MO 1-1001-23B valve breaker using remote function RH20br. (mrf rh20br open) Wait 3 more minutes and report back that you cannot get the MO 1-1001-23b valve open due to the limitorque operator failing to engage.			
		Attempts to restart Drywell coolers, reports that Drywell coolers will not start.			
		Reports Torus pressure rise and drywell temp every 20 degree F rise.			
		Reports when blowdown criteria is met.			
		Reports Torus level above 5 feet.			
		Opens all 5 ADS valves and leaves switches in MAN.			
SIM OP		Verify trigger 3 goes true when all 5 ADS valves are open to modify malfunction ms04c to a 12% steam leak over 1 minute. (mmf ms04c 12 1:)			
		When Dy processing < 225 pairs verifies DHD and CS injection values open			
		Diverte ECCS flow as percentary to maintain RDV water level 0.48 inches			
	BOP/RO	Vents containment per QCOP 1600-13, Post – Accident Venting of the Primary Containment if necessary.			
		Verify AO 1-1601-23/24/60/61/62/63 closed.			
		If drywell or torus pressure is less than 25 psig, place the vent isolation signal bypass switch to torus, open the AO 1-1601-63 valve, and cycle the AO 1-1601-61 valve to control primary containment pressure.			
		If drywell or torus pressure is greater than 25 psig, place AO 1-1601-24 CIS OVERRIDE in the OVERRIDE position and hold for 1 second. Simultaneously place AO 1-1501-23 CIS OVERRIDE and AO 1-1601-60 CIS OVERRIDE in the OVERRIDE position and hold for 1 second.			
		Opens AO 1-1601-24, AO 1-1601-60, and cycles AO 1-1699-6 to control primary containment pressure.			
Terminat	Termination: The crew has identified the requirements to determine the Main Steam Lines are flooded.				

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 60 of 3

EVENT/POSITION EVALUATION

Event No.(s):

8

Description: Failure of Drywell Sprays and Cooling leads to RPV blowdown and flooding. (Continued)

Initiation: Verify that trg 15 goes active when the crew trips the "A" DW Cooler and that batch file DWCLRTRP has gone active, preventing the DW Coolers from being restarted.

Time	Position	Applicant's Actions or Behavior
	SRO	Enters QGA 500-01, RPV Blowdown.
		Determines Torus level above 5 feet.
		Directs all ECCS flow diverted to the Core.
		Directs all 5 ADS valves opened and the switches left in MAN.
		Directs RPV water level restored to 0-48 inches.
		Directs RO to monitor for saturation conditions.
		Declares RPV water level unknown.
		Enters QGA 500-4, RPV Flooding.
		Determines all rods in.
		Directs all 5 ADS valves opened.
		Determines 0 ADS valves open.
		Determines Feed Pump is available.
		Directs MSIVs, Main Steam Line Drains, RCIC and HPCI isolated.
		Directs injection to flood the RPV.
		Directs conditions monitored to meet flooding conditions.

Termination: The crew has identified the requirements to determine the Main Steam Lines are flooded.

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 61 of 3

EVENT/POSITION EVALUATION

Event No.(s):

8

Description: Failure of Drywell Sprays and Cooling leads to RPV blowdown and flooding. (Continued)

Initiation: Verify that trg 15 goes active when the crew trips the "A" DW Cooler and that batch file DWCLRTRP has gone active, preventing the DW Coolers from being restarted.

Time	Position	Applicant's Actions or Behavior					
	RO	Monitors for saturation conditions.					
		Reports saturation conditions met.					
SIM OP		When saturation conditions are met, insert batch file seqflash					
		(batseqflash5then6) to cause level instruments to fail upscale.					
		Reports all level instruments read upscale.					
		Reports Torus level >5 feet.					
		Reports 0 ADS valves open.					
		Reports Feed Pump is available.					
		Verifies MSIVs, Main Steam Line Drains, RCIC and HPCI isolated.					
		Injects to flood the RPV.					
		Monitors for flooding conditions met.					
Termina	Termination: The crew has identified the requirements to determine the Main Steam Lines are						

NOTES:

flooded.

[] Plant Status:

 MWe:
 365
 HWCS: on
 Zinc Inj: on
 SBLC: 14.563% 12/09/02

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 62 of 3

Mode Switch: RUN Mode: 1 System: Green OLR: Not Available

[] TS LCO's: Tech Spec 3.5.1, Condition A, Day 1 of 30 for 1D RHR Pump OOS

Tech Spec 3.6.2.5, Condition A, Hour 8 of 24 Drywell to Suppression Chamber Differential Pressure due to Containment inerting in progress.

Tech Spec 3.6.3.1, Condition A, Hour 8 of 24 Primary Containment Oxygen Concentration due to Containment inerting in progress.

[] ATR's:

None

[] Significant Alarms and the reason: At a minimum, this is to include alarms that are not expected:

Alarm 901-5 B-3, Rod Worth Minimizer Block Intermittent alarms and is being investigated.

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms and is being investigated.

[] Major Equipment OOS/Reason: At a minimum, include equipment OOS that causes an LCO:

1B Service Water Pump due to a ground in the motor windings.

1B EHC pump due to a failure of the autostart feature.

1D RHR pump due to a failure of the trip coil.

1B Instrument Air Compressor due to a seal water failure.

[] Operations / Evolutions in Progress:

Plant startup in progress IAW QCGP 1-1, step F.9.t. transitioning to QCGP 3-1 step F.3.g (4) Your directions for the shift are to place 1A Feedwater Reg Valve in service and continue power ascension. QNE directions are to increase power with recircs to ~ 65 MLBM/hr core flow IAW QCGP 3-2, Attachment A. (REMA).

Drywell inerting in progress IAW QCOP 1600-20 step F.16.

[] Special Instructions:

None

[] Off Normal:

IRM #12 bypassed due to erratic operation and is INOP.

[] Material Condition:Problem:WR#WO#Status (12/02/02)

Alarm 901-5 B-3, Rod Worth Minimizer, Block Intermittent alarms SWR# 3483

Working

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 63 of 3

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms SWR# 3759 Working

	Operational Status						
Rx. Mode: Mode 1					System Status: Green		
Holding @		Mwe					
Increasing to	920	Mwe @	150	MwE/hr	HWCS: ON	ZINC: ON	
Decreasing to		Mwe @		MwE/hr			
		Con	nmon	Panels co	ntrolled by UNIT ON	E	
				LCOs and C	outage Reports		
Tech Spec 3.5.1, 1D RHR Pump C	Conditi DOS	on A, Day	1 of 30	for			
Tech Spec 3.6.2. to Suppression C Containment iner	Tech Spec 3.6.2.5, Condition A, Hour 8 of 24 Drywell to Suppression Chamber Differential Pressure due to Containment inerting in progress.						
Tech Spec 3.6.3.1, Condition A, Hour 8 of 24 Primary Containment Oxygen Concentration due to Containment inerting in progress.				4 1			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 64 of 3

Significant Ala	Significant Alarms / Reasons					
Alarm 901-5 B-3, Rod Worth Minimizer Block Intermittent alarms and is being investigated. Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms and is being investigated.						
Major Equipmen	t OOS / Reasons					
1B Service Water Pump due to a ground in the motor windings.1B EHC pump due to a failure of the autostart feature.						
 1B EHC pump due to a failure of the autostart feature. 1D RHR pump due to a failure of the trip coil. 1B Instrument Air Compressor due to a seal water failure. 						

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 65 of 3

	Surveillances in Progress							
•	None							
	Evolutions Uncoming or in Prograss							
	Evolutions Opcoming or in Progress							
	Plant startup in progress IAW QCGP 1-1, step F.9.t. transitioning to QCGP 3-1 step F.3.g. (4). Your directions for the shift are to place 1A Feedwater Reg Valve in service and continue power ascension. QNE directions are to increase power with recircs to ~ 65 MLBM/hr core flow IAW QCGP 3-2, Attachment A. (REMA).							
•	Drywell inerting in progress IAW QCOP 1600-20 step F.16.							
	Upcoming Production Risk Activities							
No	ne							

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 66 of 3

	Special Instructions
None.	

Comments							
IRM #12 bypassed due to errat	ic operation and is INOP.						
• Unit 2 is operating at 97%	• Unit 2 is operating at 97% power on the 97% Flow Control Line.						
[] Plant Status	[] Plant Status:						

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 67 of 3

MWe:	912	HWCS:	on	Zinc Inj:	on	SBLC:	14.563% 12/09/02
Mode Switch:	RUN	Mode:	1	System:	Green	OLR:	Not Available

[] TS LCO's:

Tech Spec 3.5.1, Condition A, Day 2 of 30 for 1D RHR Pump OOS.

ATR's:

[]]

None

[] Significant Alarms and the reason: At a minimum, this is to include alarms that are not expected:

Alarm 901-5 B-3, Rod Worth Minimizer Block Intermittent alarms and is being investigated.

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms and is being investigated.

[] Major Equipment OOS/Reason: At a minimum, include equipment OOS that causes an LCO:

1B Service Water Pump due to a ground in the motor windings.

1B EHC pump due to a failure of the autostart feature.

1D RHR pump due to a failure of the trip coil.

1B Instrument Air Compressor due to a seal water failure.

1B Stator Water Cooling Pump due to overheating.

[] Operations / Evolutions in Progress:

Perform QCOS 2900-03, Safe Shutdown Makeup System Power Operated Valve Test as soon as you take the shift.

Hold load constant IAW QCGP 3-2, Attachment A. (REMA).

[] Special Instructions:

None

.

[] Off Normal:

IRM #12 bypassed due to erratic operation and is INOP.

[] Material Condition:Problem:WR#WO#Status (12/02/02)

Alarm 901-5 B-3, Rod Worth Minimizer, Block Intermittent alarms SWR# 3483 Working

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms SWR# 3759 Working

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 68 of 3

lace a check $\sqrt{}$ to indicate that checklist item meets specified criteria,unless otherwise indicated, OR include remarks explaining equip. status

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 69 of 3

Panel 901-3				
DW/Torus DP > 1.2 psid				
Torus Level in Normal Operating Band				
DW Air Temperature < 180°F				
B Core Spray Pump in Auto				
MO 1402-3B and 24B Open				
MO 1402-25B Closed				
C and D RHR Pumps in Auto				
C and D RHRSW Pumps in Auto				
MO 1001-7C 7D 16B 19B and 28B Open				
MO 1001-43C 43D and 29B Closed				
HPCI Controller in Auto @ 5600 gpm				
MO 2201 4 5 6 and 0 Onan				
MO 2301-4,5,6 and 9 Open				
A and B RHR Pumps in Auto				
A and B RHRSW Pumps in Auto				
MO 1001-7A,7B,16A,19A and 28A Open				
MO 1001-43A,43B and 29A Closed				
A Core Spray Pump in Auto				
MO 1402-3A and 24A Open				
MO 1402-25A Closed				
Auto Blowdown Inhibit in Normal				
Drywell Pressure Reset in Normal				
Relief Valves 3A,3B,3C,3D,3E in Auto				
TEST Panel Annunciators				
Panel 901-4				
RCIC Controller in Auto @ 400 gpm				
MO 1301-16.17.22 and 48 Open				
MO 1301-61.25.26 and 49 Closed				
Torus Temperature < 90°F				
Recirc Loop Flow Mismatch within TS limits.				
MO 202-6A and 6B closed				
MO 202-9A or 9B closed				
TEST Panel Annunciators				
Papel 001 5		ما		
List Dynamical Nuclear Instrumentation		V		
List Bypassed Nuclear Instrumentation				
Check Rod Step and compare to RWM				
RX water Level steady @ 30"				
MSL Flow indicators approximately equal				
TEST Panel Annunciators				
Panel 901-6				
RX Feed Pumps ON (Circle)	Α	В		С
RX Feed Pump Aux Oil pps in AUTO	Α	В		С
RX Feed Pump Aux Oil pps auto trip	Α	В		C
Condensate Pumps ON (Circle)	Α	В	С	D
CCST Level ≥ 10.5 feet				
TEST Panel Annunciators				
Comments:				

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 70 of 3

Panel 901-7			
Condenser Backpressure < 5" Hg			
Circulating Water Pumps ON (Circle)	Α	В	С
Pressure Regulator in Control	Α		В
PMG Power Malfunction light Extinguished			
Electrical Malfunction light Extinguished			
TEST Panel Annunciators			
Panel 901-8			
Unit 1 Diesel Generator C/S in AUTO			
¹ / ₂ Diesel Generator C/S in AUTO			
TEST Panel Annunciators			
Panel 901-74			
SBO DG 1 Mode switch in NORMAL		•	
Check alarm status (Touch Screen)			
TEST Panel Annunciator			
Panels 901-53 and 901-54		2	
HWCS Flow Rate		V	
W O2 on 1 2740 26 (OCOD 2700 6) 159/ 249/			
/0 02 011 1-2/40-20 (QCOP 2/00-0) 15%-24%			
TEST 001 54 Danal Annunsistara			
Converse of Events Decorder		1	
Sequence of Events Recorder		γ	
Demand an Alarm Summary			
Disable report matches QCOP 0900-02			
Panels 901-55			
H ₂ & O ₂ Monitor Inlet viv Select			
TEST Annunciators			
Panels 901-56			
H ₂ & O ₂ Monitor Inlet viv Select			
Opposite of 901-55 panel			
Back Panels			
One light on off-gas timer lit			
Status of Common Panels			
Unit in charge of Common Panels (circle)	1		2
Checklist and attach to this turney	1		2
Missellenseus offer turnever		_	
Iniscenaneous atter turnover			
Review Dally Orders			
Review New Standing Orders			
Review Interim Proceaures			
Review Temporary Alterations Log			
Review BRIO Outline			
Snitt I raining Notebook (NSO/Assist)		1	
OD 56 Options 1 and 2 alarms are valid			
OD 58 inserted values are correct			
U-1 and ½ Breathing Air > 1500 psig			
Verify A Model printer operating properly			
Verify recorders printing & inking properly			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 71 of 3

Performed By (Ur							
Reviewed By (As	Reviewed By (AssistNSO)						
ŀ	Reviewed By (1	Гетр Reli	ef)				
[] Plant Status:							
MWe:	912 DIDI	HWCS:	on	Zinc Inj:	on	SBLC:	14.563% 12/09/02
Mode Switch:	RUN	Mode:	1	System:	Green	OLK:	Not Available
Tech Spec 3.5.1, 0	Condition A, Day	y 2 of 30 for	r 1D RHR Pi	ump OOS.			
[] ATR's:							
None							
[] Significant Alar expected:	ms and the reas	son: Atan	ninimum, th	nis is to inclu	ude alarms that are	not	
Alarm 901	I-5 B-3, Rod	Worth M	linimizer	Block Int	termittent alarm	ns and is	5
being investigat	ed.						
Alarm 901-6 F-1	1, Main Turbine	RFP High	Level Trip I	ntermittent a	larms and is being in	vestigated.	
[] Major Equipn causes an LCO:	nent OOS/Re	eason: A	t a minimi	um, incluc	de equipment O	OS that	
1B Service W	ater Pump due to	o a ground i	in the motor	windings.			
1B EHC pum	p due to a failure	e of the auto	start feature				

- 1D RHR pump due to a failure of the trip coil.
- 1B Instrument Air Compressor due to a seal water failure.
- 1B Stator Water Cooling Pump due to overheating.
- [] Operations / Evolutions in Progress:

Perform QCOS 2900-03, Safe Shutdown Makeup System Power Operated Valve Test as soon as you take the shift.

Hold load constant IAW QCGP 3-2, Attachment A. (REMA).

[] Special Instructions:

None

•

[] Off Normal:

IRM #12 bypassed due to erratic operation and is INOP.

[] Material Condition: WO# Problem: Status **(12/02/02)**

WR#

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 72 of 3

Alarm 901-5 B-3, Rod Worth Minimizer, Block Intermittent alarms SWR# 3483 Working

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms SWR# 3759 Working

lace a check $\sqrt{}$ to indicate that checklist item meets specified criteria,unless otherwise indicated, OR include remarks explaining equip. status
UNIT 1 SUPERVISOR TURNOVER CHECKLIST

Page 73 of 3

Panel 901-3		1		
DW/Torus DP > 1.2 psid				
Torus Level in Normal Operating Band				
DW Air Temperature < 180°F				
B Core Spray Pump in Auto				
MO 1402-3B and 24B Open				
MO 1402-25B Closed				
C and D BHB Pumps in Auto				
C and D RHPSW Pumps in Auto				
MO 1001 7C 7D 16B 19B and 28B Open				
MO 1001-7C,7D,10D,19D and 20D Open				
HBCI Controller in Auto @ 5600 anm				
MO 2301-4,5,6 and 9 Open				
MO 2301-3,8,14,35 and 36 Closed				
A and B RHR Pumps in Auto				
A and B RHRSW Pumps in Auto				
MO 1001-7A,7B,16A,19A and 28A Open				
MO 1001-43A,43B and 29A Closed				
A Core Spray Pump in Auto				
MO 1402-3A and 24A Open				
MO 1402-25A Closed				
Auto Blowdown Inhibit in Normal				
Drywell Pressure Reset in Normal				
Relief Valves 3A,3B,3C,3D,3E in Auto				
TEST Panel Annunciators				
Panel 901-4		٦		
RCIC Controller in Auto @ 400 gpm				
MO 1301-16,17,22 and 48 Open				
MO 1301-61,25,26 and 49 Closed				
Torus Temperature < 90°F				
Recirc Loop Flow Mismatch within TS limits.				
MO 202-6A and 6B closed				
MO 202-9A or 9B closed				
TEST Panel Annunciators				
Panel 901-5		1		
List Bypassed Nuclear Instrumentation				
Check Rod Step and compare to RWM				
RX Water Level steady @ 30"				
MSL Flow indicators approximately equal				
TEST Panel Annunciators				
Panel 901-6		1		
PX Food Pumps ON (Circle)	٨	F	2	6
BY Food Bump Aux Oil and in AUTO	A 		, 2	0
RX Feed Fump Aux Oil pps in A010	A)	0
Condonsato Rumas ON (Circle)	A ^		<u>``</u>	
	A	D	C	U
TEOT Daniel Ammunication				
IESI Panel Annunciators				
Comments:				

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 74 of 3

		1	
Panel 901-7			
Condenser Backpressure < 5" Hg	_		_
Circulating Water Pumps ON (Circle)	Α	В	С
Pressure Regulator in Control	Α		В
PMG Power Malfunction light Extinguished			
Electrical Malfunction light Extinguished			
TEST Panel Annunciators			
Panel 901-8			
Unit 1 Diesel Generator C/S in AUTO			
1/2 Diesel Generator C/S in AUTO			
TEST Panel Annunciators			
Panel 901-74			
SBO DG 1 Mode switch in NORMAL			
Check alarm status (Touch Screen)			
TEST Panel Annunciator			
Panels 901-53 and 901-54		2	
		N	
9/ O2 on 1 2740 26 (OCOP 2700 6) 459/ 249/			
76 02 011 1-2740-20 (QCOF 2700-0) 15%-24%			
AQ 4 5409 ASP anon			
AU-1-5408-A&B open			
1EST 901-54 Panel Annunciators		1	
Sequence of Events Recorder			
Demand an Alarm Summary			
Disable report matches QCOP 0900-02			
Panels 901-55			
H ₂ & O ₂ Monitor Inlet vIv Select			
TEST Annunciators			
Panels 901-56			
H ₂ & O ₂ Monitor Inlet vIv Select			
Opposite of 901-55 panel			
TEST Annunciators			
Back Panels			
One light on off-gas timer lit			
Status of Common Panels			
Unit in charge of Common Panels (circle)			
IF Unit 1, THEN Perform Common Ranel	1		2
Checklist and attach to this turnover.			
Miscellaneous after turnover			
Review Daily Orders			
Review New Standing Orders			
Review Interim Procedures			
Review Temporary Alterations Log			
Review BRIO Outline			
Shift Training Notebook (NSO/Assist)		1	
OD 56 Options 1 and 2 alarms are valid			
OD 58 inserted values are correct			
U-1 and $\frac{1}{2}$ Breathing Air > 1500 psig			
Verify A Model printer operating properly			
Verify recorders printing & inking properly			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 75 of 3

Performed By (UnitNSO)_____

Reviewed By (AssistNSO)_____

Reviewed By (Temp Relief)_____

Operational Status						
Rx. Mode: Mode	1			System Status:	Green	
Holding @	912	Mwe				
Increasing to		Mwe @	MwE/hr	HWCS: ON	ZINC: ON	
Decreasing to		Mwe @	MwE/hr			
		Comn	non Panels cor	ntrolled by UNIT O	NE	
			LCOs and O	utage Reports		
Tech Spec 3.5.1, 1D RHR Pump (Conditi OOS	on A, Day 2 c	of 30 for			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 76 of 3

Significant Ala	rms / Reasons						
Alarm 901-5 B-3, Rod Worth Minimizer Block Intermittent alarms and is being investigated.							
	intent diding and is complified for a function						
Major Equipmen	t OOS / Reasons						
1B Service Water Pump due to a ground in the motor windings.							
1B EHC pump due to a failure of the autostart feature.							
1D RHR pump due to a failure of the trip coil.							
1B Instrument Air Compressor due to a seal water failure.1B Stator Water Cooling pump due to overheating.							

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 77 of 3

	Surveillances in Progress
•	None
	Evolutions Upcoming or in Progress
•	Instructions for the shift are to perform QCOS 2900-03, Safe Shutdown Makeup System Power Operated Valve Test, as soon as you take the shift.
	Hold load constant IAW QCGP 3-2. Attachment A (REMA).
•	
N	Upcoming Production Risk Activities
1001	

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 78 of 3

	Special Instructions
None.	

	Com	ments	
IRM #12 bypassed due to errat	tic operation and is INOP.		
• Unit 2 is operating at 97%	power on the 97% Flow Contro	ol Line.	
L			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 79 of 3

MWe:	0	HWCS:	off	Zinc Inj:	on	SBLC:	14.563% 12/09/02
Mode Switch:	STATUP/HO	T STANDB	Y	Mode:	2 System:	Green	OLR: Not Available

[] TS LCO's:

Tech Spec 3.3.1.1, Function 1, Condition A, for tracking only, for IRM 12 being bypassed.

[] **ATR's**:

None

[] Significant Alarms and the reason: At a minimum, this is to include alarms that are not expected:

Alarm 901-5 B-3, Rod Worth Minimizer Block Intermittent alarms and is being investigated.

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms and is being investigated.

[] Major Equipment OOS/Reason: At a minimum, include equipment OOS that causes an LCO:

1B Service Water Pump due to a ground in the motor windings.

1B Stator Water Cooling Pump due to overheating.

1B Instrument Air Compressor due to a seal water failure.

[] Operations / Evolutions in Progress:

Plant startup in progress IAW QCGP 1-1, step F.6.ad and ae.The unit is approximately 3% power with a reator startup in progress. The reactor is critical, one Bypass Valve open, Containment is deinerted, ready to pull rod step 17. Your directions for the shift are to secure RWCU reject flow and continue the startup by pulling control rods in preparation for placing the Mode Switch in RUN IAW QCGP 3-2, Attachment A. (REMA).

[] Special Instructions:

None

ſ

[] Off Normal:

IRM #12 bypassed due to erratic operation and is INOP. Maintenance and testing is complete. Shift Manager is

reviewing paperwork for return to operation.

]	Material Condition: WO#	Problem: Status (12/02/02)	WR#
	Alarm 901-5 B-3, Rod Worth Minimizer	, Block Intermittent alarms	SWR# 3483
	Alarm 901-6 F-11, Main Turbine/RFP H	igh Level Trip Intermittent a	larms
	SWR# 3759	Working	

Working

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 80 of 3

Place a check $\sqrt{}$ to indicate that checklist item meets specified criteria,unless otherwise indicated, OR include remarks explaining equip. status

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 81 of 3

	Г		1	
Panel 901-3		١		
DW/Torus DP > 1.2 psid				
Torus Level in Normal Operating Band				
DW Air Temperature < 180°F				
B Core Spray Pump in Auto				
MO 1402-3B and 24B Open				
MO 1402-25B Closed				
C and D RHR Pumps in Auto				
C and D RHRSW Pumps in Auto				
MO 1001-7C,7D,16B,19B and 28B Open				
MO 1001-43C,43D and 29B Closed				
HPCI Controller in Auto @ 5600 gpm				
MGU @ HSS				
MSC @ LSS				
MO 2301-4,5,6 and 9 Open				
MO 2301-3,8,14,35 and 36 Closed				
A and B RHR Pumps in Auto				
A and B RHRSW Pumps in Auto				
MO 1001-7A,7B,16A,19A and 28A Open				
MO 1001-43A.43B and 29A Closed				
A Core Spray Pump in Auto	<u> </u>			
MO 1402-3A and 24A Open				
MO 1402-25A Closed				
Auto Blowdown Inhibit in Normal				
Drywell Pressure Reset in Normal				
Relief Valves 3A 3B 3C 3D 3E in Auto				
TEST Panel Annunciators				
Panel 901-4		1	1	_
PCIC Controller in Auto @ 400 anm		N		
MO 1201 16 17 22 and 48 Open				
MO 1301-10,17,22 and 40 Open				
	<u> </u>			
Torus Temperature < 90°F				
Recirc Loop Flow Mismatch within 15 limits.				
MO 202-6A and 6B closed				
MU 202-9A or 9B closed				
TEST Panel Annunciators			,	
Panel 901-5		١		
List Bypassed Nuclear Instrumentation				
Check Rod Step and compare to RWM				
RX Water Level steady @ 30"				
MSL Flow indicators approximately equal				
TEST Panel Annunciators				
Panel 901-6		١		
RX Feed Pumps ON (Circle)	Α	E	3	С
RX Feed Pump Aux Oil pps in AUTO	Α	E	;	С
RX Feed Pump Aux Oil pps auto trip	Α	E	3	С
Condensate Pumps ON (Circle)	Α	В	С	D
CCST Level ≥ 10.5 feet				
TEST Panel Annunciators				
Comments:	L			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 82 of 3

		1	
Paner 901-7		V	
Condenser Backpressure < 5" Hg		_	
Circulating Water Pumps ON (Circle)	Α	В	<u> </u>
Pressure Regulator in Control	Α		В
PMG Power Malfunction light Extinguished			
Electrical Malfunction light Extinguished			
TEST Panel Annunciators			
Panel 901-8			
Unit 1 Diesel Generator C/S in AUTO			
1/2 Diesel Generator C/S in AUTO			
TEST Panel Annunciators			
Panel 901-74			
SBO DG 1 Mode switch in NORMAL			
Check alarm status (Touch Screen)			
TEST Panel Annunciator			
Panels 901-53 and 901-54			
HWCS Flow Rate			
% O2 on 1-2740-26 (QCOP 2700-6) 15%-24%			
TEST 901-53 Panel Annunciators			
AQ—1-5408-A&B open			
TEST 901-54 Panel Annunciators			
Sequence of Events Recorder		2	
Demand on Alarm Summary		N	
Demand an Alarm Summary			
Disable report matches QCOP 0900-02			
Panels 901-55			
H ₂ & O ₂ Monitor Inlet VIV Select			
TEST Annunciators			
Panels 901-56			
H ₂ & O ₂ Monitor Inlet VIV Select			
Opposite of 901-55 panel			
Back Panels			
Une light on off-gas timer lit		_	
Status of Common Panels			
Unit in charge of Common Panels (circle)			•
IF Unit 1, IHEN Perform Common Ranel	1		2
Checklist and attach to this turnover.			
Miscellaneous after turnover			
Review Dally Orders			
Review New Standing Orders			
Review Interim Procedures			
Review Temporary Alterations Log			
Review BRIO Outline			
Shift Training Notebook (NSO/Assist)		- 1	
OD 56 Options 1 and 2 alarms are valid			
OD 58 inserted values are correct			
U-1 and $\frac{1}{2}$ Breathing Air > 1500 psig			
Verify A Model printer operating properly			
Verify recorders printing & inking properly			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 83 of 3

Performed By (UnitNSO)_____

Reviewed By (AssistNSO)_____

Reviewed By (Temp Relief)_____

Operational Status						
Rx. Mode: Mode	2			System Status:	Green	
Holding @		Mwe				
Increasing to	920	Mwe @	MwE/hr	HWCS: OFF	ZINC: ON	
Decreasing to		Mwe @	MwE/hr			
		Com	mon Panels cor	ntrolled by UNIT ON	NE	
			LCOs and O	utage Reports		
LCOs and Outage Reports Tech Spec 3.3.1.1, Function 1, Condition A, for tracking only, for IRM 12 being bypassed.						

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 84 of 3

Significant Alarms / Reasons			
Alarm 901-5 B-3, Rod Worth Minimizer Block Intermittent alarms and is being investigated. Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms and is being investigated.			
Major Equipmen	t OOS / Reasons		
1B Service Water Pump due to a ground in the motor windings.1B Stator Water Cooling Pump due to overheating.1B Instrument Air Compressor due to a seal water failure.			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 85 of 3

	Surveillances in Progress				
•	None				
	Evolutions Upcoming or in Progress				
Evolutions Upcoming or in Progress Plant startup in progress IAW QCGP 1-1, step F.6.ad and ae.The unit is approximately 3% power with a reator startup in progress. The reactor is critical, one Bypass Valve open, Containment is deinerted, ready to pull rod step 17. Your directions for the shift are to secure RWCU reject flow and continue the startup by pulling control rods in preparation for placing the Mode Switch in RUN IAW QCGP 3-2, Attachment A. (REMA).					
No	Upcoming Production Risk Activities				
110	None				

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 86 of 3

	Special Instructions
None.	

Comments					
IRM #12 bypassed due to errat paperwork for return to operati	tic operation and is INOP. Main ion.	ntenance and testing is complete.	Shift Manager is reviewing		
• Unit 2 is operating at 97%	power on the 97% Flow Contro	ol Line.			

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 87 of 3

MWe:	700	HWCS:	on	Zinc Inj:	on	SBLC:	14.563% 12/09/02
Mode Switch:	RUN	Mode:	1	System:	Green	OLR:	Not Available

[] TS LCO's:

Tech Spec 3.5.1, Condition A, Day 1 of 30 for 1A and 1B RHR Pumps OOS.

Tech Spec 3.5.1, Condition B, Day 1 of 7 for LPCI A Subsystem INOP.

Tech Spec 3.5.1, Condition D, Day 1 of 3 for both LPCI Subsystems INOP.

Tech Spec 3.6.2.3. Condition A, Day 1 of 7, A Loop RHR Suppression Pool Cooling INOP.

Tech Spec 3.6.2.4. Condition A, Day 1 of 7, A Loop RHR Suppression Pool Spray INOP.

TRM 3.6.a. Condition A, Day 1 of 7, A Loop RHR Drywell Spray INOP.

[] ATR's:

None

[] Significant Alarms and the reason: At a minimum, this is to include alarms that are not expected:

Alarm 901-5 B-3, Rod Worth Minimizer Block Intermittent alarms and is being investigated.

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms and is being investigated.

[] Major Equipment OOS/Reason: At a minimum, include equipment OOS that causes an LCO:

1B Service Water Pump due to a ground in the motor windings.

1A RHR Loop is OOS for packing replacment on the 1-1001-66A Valve, 1A RHR Pump Discharge Valve.

[] Operations / Evolutions in Progress:

QCOS 7500-05, SBGTS MONTHLY OPERABILITY TEST is complete through step H.2.o, has been running for ten hours and is to be shutdown when you take the shift.

Hold load constant IAW QCGP 3-2, Attachment A. (REMA).

[] Special Instructions:

None

[] Off Normal:

None

[] Material Condition:Problem:WO#Status (12/02/02)

WR#

Alarm 901-5 B-3, Rod Worth Minimizer, Block Intermittent alarms SWR# 3483

Working

UNIT 1 SUPERVISOR TURNOVER CHECKLIST Page 88 of 3

Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms SWR# 3759 Working

	·				
	Operational Status				
Rx. Mode: Mode	1			System Status:	Green
Holding @	700	Mwe			
Increasing to		Mwe @	MwE/hr	HWCS: ON	ZINC: ON
Decreasing to		Mwe @	MwE/hr		
		Con	nmon Panels co	ntrolled by UNIT O	NE
			LCOs and (Dutage Reports	
Tech Spec 3.5.1, 1A and 1B RHR	Conditio Pumps (on A, Day 1 DOS.	of 30 for		
Tech Spec 3.5.1, Condition B, Day 1 of 7 for LPCI A Subsystem INOP.			l of 7 for LPCI A		
Tech Spec 3.5.1, Condition D, Day 1 of 3 for both LPCI Subsystems INOP.					
Tech Spec 3.6.2.3. Condition A, Day 1 of 7, A			ion A, Day 1 of		
Loop RHR Suppression Pool Cooling INOP.					
Tech Spec 3.6.2.4. Condition A, Day 1 of 7, A Loop RHR Suppression Pool Spray INOP.					
TRM 3.6.a. Condition A, Day 1 of 7, A Loop RHR Drywell Spray INOP.			', A Loop RHR		

		Page 89 of 91
Appendix D	1	Form ES-D-1

Significant Alarms / Reasons Alarm 901-5 B-3, Rod Worth Minimizer Block Intermittent alarms and is being investigated. Alarm 901-6 F-11, Main Turbine/RFP High Level Trip Intermittent alarms and is being investigated. Major Equipment OOS / Reasons 1B Service Water Pump due to a ground in the motor windings. 1A RHR Loop is OOS for packing replacment on the 1-1001-66A Valve, 1A RHR Pump Discharge Valve.

	Surveillance	es in Progress	
QCOS 7500-05, S H.2.o, has been r	BGTS MONTHLY OPER unning for ten hours an	ABILITY TEST is comp d is to be shutdown wh	lete through step en you take the shift.

Ap	pendix D
· • • • •	

Page 90 of 91 Form ES-D-1

Evolutions Upcoming or in Progress				
QCOS 7500-05, SBGTS MONTHLY OPERABILITY TEST is complete through step H.2.o, has been running for ten hours and is to be shutdown when you take the shift.				
Hold load constant IAW QCGP 3-2, Attachment A. (REMA).				
Uncoming Production Risk Activities				
Special Instructions				
None.				

Comments

1

		Page 91 of 91
Appendix D	1	Form ES-D-1

Unit 2 is operating at 97% power on the 97% Flow Control Line. •