

3.3 INSTRUMENTATION

3.3.8 Fuel Storage Building Emergency Ventilation System (FSBEVS) Actuation Instrumentation

LCO 3.3.8 FSBEVS manual and automatic actuation instrumentation shall be OPERABLE.

APPLICABILITY: During movement of recently irradiated fuel in the fuel storage building.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Manual or automatic FSBEVS actuation instrumentation inoperable.	A.1 Place FSBEVS in operation.	Immediately
	<u>OR</u> A.2 Suspend movement of recently irradiated fuel in the fuel storage building.	Immediately

3.7 PLANT SYSTEMS

3.7.13 Fuel Storage Building Emergency Ventilation System (FSBEVS)

LCO 3.7.13 FSBEVS shall be OPERABLE.

APPLICABILITY: During movement of recently irradiated fuel assemblies in the fuel storage building.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. FSBEVS inoperable.	A.1 Suspend movement of recently irradiated fuel assemblies in the fuel storage building.	Immediately

3.9 REFUELING OPERATIONS

3.9.3 Containment Penetrations

LCO 3.9.3

The containment penetrations shall be in the following status:

- a. The equipment hatch closed and held in place by at least four bolts or the equipment hatch opening is closed using an equipment hatch closure plate that may include a personnel access door that is capable of being closed;
- b. One door in each air lock is capable of being closed;
- c. Each penetration providing direct access from the containment atmosphere to the outside atmosphere either:
 1. closed by a manual or automatic isolation valve, a blind flange, or equivalent, or
 2. capable of being closed by OPERABLE Containment Purge Isolation System.

-----NOTE-----
Penetration flow path(s) providing direct access from the containment atmosphere to the outside atmosphere may be unisolated under administrative controls.

APPLICABILITY: During movement of recently irradiated fuel assemblies within containment.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more containment penetrations not in required status.	A.1 Suspend movement of recently irradiated fuel assemblies within containment	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.9.3.1	Verify each required containment penetration is in the required status.	7 days
SR 3.9.3.2	Verify each required containment purge system valve actuates to the isolation position on an actual or simulated actuation signal.	92 days