

COPY

OI 150

# HEATING THE CONDENSATE STORAGE TANKS

DOCUMENT TYPE: Technical

CLASSIFICATION: Safety Related

REVISION: 1

EFFECTIVE DATE: April 12, 2001

REVIEWER: Qualified Reviewer

APPROVAL AUTHORITY: Department Manager

PROCEDURE OWNER (title): Group Head

OWNER GROUP: Operations

Verified Current Copy:

*James E. Sullivan*  
Signature

*9/16/02*  
Date

*1050*  
Time

List pages used for Partial Performance

1-7, 20, 21  
\_\_\_\_\_  
\_\_\_\_\_

Controlling Work Document Numbers

\_\_\_\_\_  
\_\_\_\_\_ *A/235*  
\_\_\_\_\_

~~*A/235*~~

HEATING THE CONDENSATE STORAGE TANKS

INITIALS

**NOTE:** Due to Improved Technical Specifications (ITS) implementation, in order to allow use of this procedure prior to and after implementation, both the custom and improved Technical Specification information is shown, with the ITS information in Braces. Example: CTS info {ITS info}

1.0 PURPOSE

This procedure provides instruction for filling the Condensate Storage Tank, T-24A or T-24B from the opposite units Condensate Feedwater System or Waste Condensate System to provide approximately 42,000 gallons of water at a temperature of 95°F (80°F to 110°F) to fill the Steam Generator and Main Steam line.

2.0 PREREQUISITES

The IT-300/305 transfer hose (rated at greater than 2000 psig) is available for use.

3.0 PRECAUTIONS AND LIMITATIONS

3.1 Do **NOT** allow CST temperature to exceed 120 Degrees F during the fill with a final target temperature of approximately 110 degrees F.

3.2 Observe appropriate safety precautions when IT-300/305 transfer hose is pressurized. The temperature and pressure could be approximately 210°F and approximately 400 psig.

4.0 INITIAL CONDITIONS

4.1 Ensure greater than 13,000 gallons usable condensate volume in each CST if required by current plant conditions per CTS 15.3.4 {ITS 3.7.6}.

4.2 Permission to Perform Evolution

The conditions required by this evolution are consistent with required plant conditions including equipment operability. Permission is granted to perform this evolution.

DSS James E. Sullivan Time 1701 Date 9/16/02

HEATING THE CONDENSATE STORAGE TANKS

INITIALS

5.0 PROCEDURE

- NOTE:** If both Units are in Cold Shutdown {ITS MODE 5, 6, or defueled} then heat the CSTs using Waste Heating Returns per section 5.3 or 5.4 as applicable.
- NOTE:** Approximately 42,000 gallons of water will be needed to fill the Steam Generator and Main Steam line. This will require multiple filling of the target CST.
- NOTE:** Maintain a minimum of 13,000 gallons of water in the target CST to satisfy the on-line units technical specification for Auxiliary Feedwater source volume.
- NOTE:** It will be necessary to perform this procedure more than once to fill the SG and MS line and maintain the minimum CST TS required level.
- NOTE:** Each section of the procedure stands alone. Perform only the section(s) required.

5.1 Heat T-24A (South) CST to between 80 and 110 degrees F. using Unit 2 2A Feedwater Heater.

5.1.1 Record the As-Found position AND position the valves to the required position to Split the North and South CSTs.

<u>Valve</u>	<u>As Found</u>	<u>Required</u>	
AF-2 T-24A Mini Recirc Isolation	<u>LO</u>	OPEN	<u>RB</u>
AF-9 T-24B CST Recirc isolation	<u>LO</u>	SHUT	<u>RB</u>
AF-3 T-24A Service Outlet	<u>LO</u>	OPEN	<u>RB</u>
AF-8 T-24B Service Outlet	<u>LO</u>	OPEN	<u>RB</u>
AF-5 T-24A CST Outlet To Aux Feed Pumps	<u>LO</u>	OPEN	<u>RB</u>
AF-6 T-24B CST Outlet To Aux Feed Pumps	<u>LO</u>	SHUT	<u>RB</u>
AF-7A T-24B CST Inlet From Water Treatment	<u>O</u>	OPEN	<u>RB</u>
AF-4A T-24A CST Inlet From Water Treatment	<u>O</u>	SHUT	<u>RB</u>

HEATING THE CONDENSATE STORAGE TANKS


INITIALS

- 5.1.2 Install IT-300/305 transfer hose by:
- a. Connect one end of IT-300/305 transfer hose to 2CS-107C, HX-17A LP FWH 2A Outlet to HX-19A LP FWH 3A DRN.
  - b. Connect the other end of IT-300/305 transfer hose to AF-13, T-24A CST Drain.

JB  
JB

CAUTION

Feedwater outlet temperature is approximately 210 °F and approximately 400 psig. When the transfer hose between Unit 2 2A FW Heater and T-24A is used, AF-13 is to be opened before throttling open 2CS-107C and 2CS-107C is to be shut before shutting AF-13 to minimize the pressure on the transfer hose.



- 5.1.3 Hang Temporary Information tags containing the information in the Caution above on:
- a. AF-13, T-24A CST Drain.
  - b. 2CS-107C, HX-17A LP FWH 2A Outlet to HX-19A LP FWH 3A DRN.
- 5.1.4 Open AF-13, T-24A CST Drain.

JB  
JB  
JB

**NOTE:** 2CS-107C, HX-17A LP FWH 2A Outlet to HX-19A LP FWH 3A DRN, may be throttled open or closed to vary fill or rate of temperature change.

**NOTE:** Steps 5.1.5 and 5.1.6 or 5.1.7 may be performed concurrently.

- 5.1.5 Using the tool provided, throttle open 2CS-107C, HX-17A LP FWH 2A Outlet to HX-19A LP FWH 3A DRN AND check hose for leaks.

JB

HEATING THE CONDENSATE STORAGE TANKS

INITIALS

5.1.6 IF it is desired to cool T-24A (South) CST water volume, AND there is sufficient level in the T-24B (North) CST, THEN perform the following:  
(Otherwise mark this step as N/A)

a. Throttle open AF-6, T-24B CST Outlet To Aux Feed Pumps, to sluice water from T-24B to T-24A.

N/A RW

b. WHEN the CST water volume has cooled to 95 °F (80 °F-110 °F), THEN Close AF-6, T-24B CST Outlet To Aux Feed Pumps.

N/A RW

5.1.7 IF it is desired to cool T-24A (South) CST water volume, AND there is NOT sufficient level in the T-24B (North) CST, THEN perform the following:  
(Otherwise mark this step as N/A)

a. Open AF-4A, T-24A CST Inlet From Water Treatment.

N/A RW

b. WHEN the CST water volume has cooled to 95 °F (80 °F - 110 °F), THEN close AF-4A, T-24A CST Inlet From Water Treatment.

N/A RW

5.1.8 IF necessary to temporarily stop heating T-24A (South) CST water volume, THEN perform the following:  
(Otherwise mark this step as N/A)

*Shut off  
12" line*

a. Shut 2CS-107C, HX-17A LP FWH 2A Outlet to HX-19A LP FWH 3A DRN. ? 1330, 98°

β

b. WHEN heating T-24A (South) CST water volume is to be restarted, THEN go to step 5.1.10.

β

5.1.9 WHEN T-24A (South) CST level is at the level desired by Shift Management, AND temperature is at 95 °F (80 °F-110 °F), THEN shut 2CS-107C, HX-17A LP FWH 2A Outlet to HX-19A LP FWH 3A DRN.

*full*

β

HEATING THE CONDENSATE STORAGE TANKS

INITIALS

**NOTE:** It may be necessary to repeats steps that refill and reheat T-24A (South) CST as the Steam Generator(s) and Main Steam Line(s) are filled.

5.1.10 **IF** it is necessary to refill and reheat T-24A (South) CST, **THEN** repeat steps 5.1.5 through steps 5.1.9, **AND** document steps performed below. (Mark step not performed N/A).

AB

STEP NO.	1st PERFORMANCE	2nd PERFORMANCE
5.1.5	AB	AB
5.1.6	N/A	N/A
5.1.7	N/A	N/A
5.1.8	N/A	AB
5.1.9	AB	N/A

**NOTE:** Perform the next three steps without delay in case 2CS-107C, HX-17A LP FWH 2A Outlet To HX-19A LP FWH 3A DRN leaks by.

5.1.11 Using the tool provided, shut 2CS-107C, HX-17A LP FWH 2A Outlet To HX-19A LP FWH 3A DRN.

MMS

5.1.12 Shut AF-13, T-24A CST Drain.

IV

5.1.13 Remove IT-300/305 transfer hose from AF-13, T-24A CST Drain **AND** route to a floor drain.

MMS

5.1.14 Cap AF-13, T-24A CST Drain.

IV

5.1.15 Remove IT-300/305 transfer hose from 2CS-107C, HX-17A LP FWH 2A Outlet To HX-19A LP FWH 3A DRN **AND** drain hose into floor drain.

MMS

5.1.16 Cap 2CS-107C, HX-17A LP FWH 2A Outlet To HX-19A LP FWH 3A DRN.

MMS

IV

HEATING THE CONDENSATE STORAGE TANKS

INITIALS

- 5.1.17 Remove the Temporary Information tags hung during step 5.1.3 on AF-13, T-24A CST Drain AND 2CS-107C, HX-17A LP FWH 2A Outlet To HX-19A LP FWH 3A DRN.
- 5.1.18 Allow the IT-300/305 transfer hose to cool to approximately ambient temperature while continuing with the balance of this section.
- 5.1.19 Place the following valves to the original as-found position recorded in step 5.1.1 or as directed by the DSS.

①  
N/A mms

RH

		<u>As-found</u> <u>/DSS</u>	
AF-9	T-24B CST Recirc Isolation	<u>LO</u>	<u>B</u>
AF-2	T-24A Mini Recirc Isolation	<u>LO</u>	<u>B</u>
AF-3	T-24A Service Outlet	<u>LO</u>	<u>B</u>
AF-8	T-24B Service Outlet	<u>LO</u>	<u>B</u>
AF-6	T-24B CST Outlet To Aux Feed Pumps	<u>LO</u>	<u>B</u>
AF-5	T-24A CST Outlet To Aux Feed Pumps	<u>LO</u>	<u>B</u>
AF-7A	T-24B CST Inlet From Water Treatment	<u>0</u>	<u>B</u>
AF-4A	T-24A CST Inlet From Water Treatment	<u>0</u>	<u>B</u>

- 5.1.20 Provide Independent Verification of the Redlocked valves listed below.

<u>Valve</u>	<u>Required</u>	<u>IV</u>
AF-2 T-24A Mini Recirc Isolation	LO	<u>N/A</u>
AF-9 T-24B CST Recirc isolation	LO	<u>N/A</u>
AF-3 T-24A Service Outlet	LO	<u>N/A</u>
AF-8 T-24B Service Outlet	LO	<u>N/A</u>
AF-5 T-24A CST Outlet To Aux Feed Pumps	LO	<u>N/A</u>
AF-6 T-24B CST Outlet To Aux Feed Pumps	LO	<u>N/A</u>

- 5.1.21 Store the IT-300/305 transfer hose as designated by the DSS.

① N/A mms

HEATING THE CONDENSATE STORAGE TANKS

Remarks

① IT-300 will be performed later in outage  
leave hoses in place  
② steps reperfomed after draining the ACST  
RHay

Performed By

Bruce Tesurik Bruce Tesurik 8-5-02 1500 BT  
Performer (Print and Sign) Date Time Initials

JOHN BURISH John Burish 9/14/02 1215 JB  
Performer (Print and Sign) Date Time Initials

Bodis Bg 9-16-02 1730 B  
Performer (Print and Sign) Date Time Initials

M.D. Bosdech Michael D Bosdech 9-19-02 2230 MMB  
Performer (Print and Sign) Date Time Initials

Steve Johnson Steve Johnson 9-23-02 10145 SJ  
Performer (Print and Sign) Date Time Initials

RHastings RHay 9-23-21 0359 RH  
Performer (Print and Sign) Date Time Initials

Reviewed By

RHay RHastings 9-23-21 0359 RH  
Reviewer (Print and Sign) Date Time Initials



HEATING THE CONDENSATE STORAGE TANKS

6.0 REFERENCES

6.1 Technical Specifications:

- 15.3.4, Steam and Power Conversion System.
- {ITS: 3.7.6 Condensate Storage Tank (CST)} .

6.2 FSAR:

- Section 10.0, Steam and Power Conversion System.

6.3 P&IDs:

- M-217, Sheet 1, Auxiliary Feedwater System.
- M-202, Sheet 1, Condensate System.
- M-2202, Sheet 1, Condensate System.

6.4 Tank Level Book:

- Condensate Storage Tank (T-24 A/B).
- Calculation - N97-155, PBNPIC-42.

6.5 OM 5.4.4 Control of Posted Plant Information