

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
09/18/2002 00:14		Concerning shutdown safety U1 One required reactivity flow path has been physically walked down [Rode, Ryan - STA - Station Log - Mid Shift]
09/18/2002 02:30		Completed ORT-27 [Wandrie, Tom - MISC - Station Log - Mid Shift]
09/18/2002 03:38	WT Backwashed	NRC plant status and phone check completed SAT. [Higgins, Robert E. - DOS (Fire Brigade) - Station Log - Mid Shift]
09/18/2002 03:40	DSS Midnight Entry	Common: Received a report that a Phillips-Getschow employee working on Containment Fan Cooler replacement had experienced eye irritation After rinsing his eye out, the employee reported that the irritation had ceased. Employee's supervisor to follow-up, as appropriate. [Larson, Tom - OS (Fire Brigade) - Station Log - Mid Shift]
09/18/2002 03:55	DSS Midnight Entry	Common: Received a report of a hydraulic fluid leak from a Contractor-operated Rental Crane located outside the RCA near the Controlled Side Maintenance Shop Overhead Door. Approximately 1 to 2 gallons of hydraulic fluid had sprayed on the crane and the pavement in the vicinity of the crane. No hydraulic fluid entered any plant drainage system AOP-12A, Oil, Hazardous Material, and Radioactive Materials Spill, was referenced and it was determined entry into AOP-12A was not required Approximately 100# of Oil Dry was spread on the pavement near the crane to absorb the spilled fluid. The balance of the cleanup will be completed by the Contractor personnel. [Larson, Tom - OS (Fire Brigade) - Station Log - Mid Shift]
09/18/2002 04:33		Commence discharge of T-20C Gas Decay Tank per OP-9D. [Fischer, Terry - PAB (Fire Brigade) - Station Log - Mid Shift]
09/18/2002 05:25		Pumped 443 Gal. from U1 Facade Sump to WWES per OI-66. [Fischer, Terry - PAB (Fire Brigade) - Station Log - Mid Shift]
09/18/2002 05:55		Placed 'A' HUT on purification recirc [LaFountain, Ken - U1 TurbHall (Fire Brigade) - Station Log - Mid Shift]
09/18/2002 06:18		U-1, Completed Pre-ORT-35, Hot Leg Sample Line. [Raasch, Dean - MISC - Station Log - Mid Shift]
09/18/2002 06:23	NLOGS01	Merkes, Rick Assumed DSS Position from Harper, Ron, DSS. [Merkes, Rick - DSS - Station Log - Day Shift]
09/18/2002 06:26	NLOGS01	Robbins, Rick Assumed STA Position from Rode, Ryan, STA. [Robbins, Rick - STA - Station Log - Day Shift]
09/18/2002 06:31	NLOGS01	Wilson, Jim Assumed DOS (Fire Brigade) Position from Higgins, Robert E., DOS (Fire Brigade). [Wilson, Jim - DOS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 06:32	NLOGS01	Schleif, James Assumed OS (Fire Brigade) Position from Larson, Tom, OS (Fire Brigade). [Schleif, James - OS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 07:18	WT Backwashed	Commenced 1ICP 10.009, Fuel Manipulator Load Cell Refueling Calibration. [Schleif, James - MISC - Station Log - Mid Shift]
09/18/2002 07:25	NLOGS01	Lewis, Al Assumed Unit 2 CO Position from Kupsch, Loren, Unit 2 CO. [Lewis, Al - Unit 2 CO - Station Log - Day Shift]
09/18/2002 07:26	1RE-211/212 OOS	Control Room ING (RE-234 & 235) OOS for filter change. TS 3.5 CREFS Actuation Instrumentation is not met. Enter condition A for function 1.b RA is to place CREFS in emergency mode in 7 days. [Schleif, James - MISC - Station Log - Mid Shift]
09/18/2002 07:26	NLOGS01	Bunsh, John Assumed U2 TurbHall (Fire Brigade) Position. [Burish, John - U2 TurbHall (Fire Brigade) - Station Log - Day Shift]
09/18/2002 07:26	NLOGS01	Wallace, Rob Assumed 4th License Position from Post, Bob, 4th License. [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 07:27	NLOGS01	Lohr, Tim Assumed 3rd License Position from Meaney, Doug, 3rd License. [Lohr, Tim - 3rd License - Station Log - Day Shift]
09/18/2002 07:28	NLOGS01	Purvis, Dale Assumed WtrTreatment(Fire Brigade) Position from Brdlik, Scott, WtrTreatment(Fire Brigade). [Purvis, Dale - WtrTreatment(Fire Brigade) - Station Log - Day Shift]

A/236

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
09/18/2002 07:30	NLOGS01	Alef, Kurt Assumed U1 TurbHall (FireBrigade) Position from LaFountain, Ken, U1 TurbHall (FireBrigade). [Alef, Kurt - U1 TurbHall (FireBrigade) - Station Log - Day Shift]
09/18/2002 07:32	NLOGS01	Fischer, Terry Assumed PAB (FireBrigade) Position from Fischer, Terry, PAB (FireBrigade). [Fischer, Terry - PAB (FireBrigade) - Station Log - Day Shift]
09/18/2002 07:34	1RE-211/212 OOS	Control Room ING (RE-234 & 235) returned to service. TS 3 3 5 CREFS Actuation Instrumentation is met [Schleif, James - MISC - Station Log - Mid Shift]
09/18/2002 07:36	DAV Stack Iso OOS	SPING 21, U-1 Containment Purge Stack OOS for filter change RE-212 is in service [Schleif, James - MISC - Station Log - Mid Shift]
09/18/2002 07:37	WT Backwashed	Cable Tray Covers R84 and DJ09 (1C-167 by 1B03/1B04) removed. Commenced hourly fire rounds in the Cable Spreading Room per OM-3 27. [Schleif, James - MISC - Station Log - Mid Shift]
09/18/2002 07:41	NLOGS01	Scherwinski, Doug Assumed Unit 1 CO Position from Hall, Mark, Unit 1 CO. [Scherwinski, Doug - Unit 1 CO - Station Log - Day Shift]
09/18/2002 07:46	NLOGS02	Log turned over by Schleif, James [Schleif, James - MISC - Station Log - Mid Shift]
09/18/2002 07:46	NLOGS03	Log approved by Schleif, James [Schleif, James - MISC - Station Log - Mid Shift]
09/18/2002 08:49	WT Backwashed	Completed 0-TS-RE-001 Power Level Determination, Sat, on Unit 2. [Lewis, Al - Unit 2 CO - Station Log - Day Shift]
09/18/2002 09:00		Unit 1 Shutdown Safety Assessment Reactivity flow path walkdown completed SAT. [Robbins, Rick - STA - Station Log - Day Shift]
09/18/2002 09:08		Commenced 1RMP 9056-5 1B-03 Safety Related and Technical Specifications Relay Calibration. LCO 3 3.4 is not met for both units due to testing of 1B-03 Loss of voltage relay 1-271/B03 per 1RMP 9056-5. Entering TSAC 3 3 4 A with required action A.1 to place channel in trip within 1 hour. [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 09:12		TSAC 3 3 4.A required action A.1 has been completed for 1B-03 loss of voltage relay 1-271/B03. The relay has been placed in the trip position. [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 09:22	WT Backwashed	Control Room notified of divers entering Unit 1 CW Pumpbay. K. Grasso is PBNP point of contact. [Schleif, James - OS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 09:27		Secured discharge of WG Decay Tank C per OP-9D Volume 3071 cu. ft Discharge Rate 10.4 cu ft. per min. [Fischer, Terry - PAB (FireBrigade) - Station Log - Day Shift]
09/18/2002 09:35		1VNPSE-3213 inside purge exhaust valve went shut causing Unit 1 Purge supply and exhaust to trip. RP informed. [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 10:03		Common: Received a report that an NPS employee working on Main Steam Line slipped and received an abrasion on his cheek. Referred to site medical. Employee's supervisor to follow-up, as appropriate. [Wilson, Jim - DOS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 10:15	EQINSERVIC	Notified by EP that Siren 006 is returned to service. [Schleif, James - OS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 10:18	DSS Midnight Entry	Common - Informed by RP that Radioactive Shipment 02-056 has left Point Beach on route to Unitech Services Group, Morris, IL. [Wilson, Jim - DOS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 10:43		Began processing A HUT to A Monitor Tank per OI-10A [Fischer, Terry - PAB (FireBrigade) - Station Log - Day Shift]
09/18/2002 10:57		Testing of 1B-03 loss of voltage relay 1-271/B03 has commenced in accordance with 1RMP 9056-5 and LCO 3.0 5. [Wallace, Rob - 4th License - Station Log - Day Shift]

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
09/18/2002 11:02	NLOGS01	Wade, Randy Assumed PAB (FireBrigade) Position from Fischer, Terry [Wade, Randy - PAB (FireBrigade) - Station Log - Day Shift]
09/18/2002 11:04		Loss of voltage relay testing is complete for relay 1-271/B03. LCO 3 3 4 is now met for both units Exiting TSAC 3 3 4 A. [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 11:04	OFF-NORMAL	Investigation revealed that the loss of Unit 1 Containment Purge was a result of Maintenance work on 1VNPSE-3213, Inside Containment Purge Exhaust Valve Following trip of 1W-6B, Purge Exhaust Fan and 1W-2B, Purge Supply Fan, no indicating lights were lit for 1W-6B. Bulbs were checked good Continuing efforts to restore Unit 1 Containment Purge [Schleif, James - OS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 11:05		LCO 3 3 4 is not met for both units due to testing of 1B-03 Loss of voltage relay 1-272/B03 per 1RMP 9056-5 Entering TSAC 3 3 4 A with required action A 1 to place channel in trip within 1 hour. [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 11:13		TSAC 3 3 4 A required action A 1 has been completed for 1B-03 loss of voltage relay 1-272/B03 The relay has been placed in the trp position [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 11:41		U-1, 1N-31 Source Range Nuclear instrument RTS per ICP 10 15. [Wilson, Jim - DOS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 11:50	WT Backwashed	WCC and Maintenance notified that Unit 1 Reactor Vessel Head may be detensioned per 1RMP-9096 and RP-1A, Preparation for Refueling. Detensioning the Reactor Vessel Head constitutes transition to Mode 6 Maintenance will inform control when detensioning commences [Schleif, James - OS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 11:55	OFF-NORMAL	Control Room notified that an NDE Contract Employee received a bruise to his left thigh from a scaffold bolt in the Unit 1 66' Fan Room Contract supervision to complete required paperwork. No first aid or medical treatment required [Schleif, James - OS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 12:32	DSS Midnight Entry	Notified by Maintenance that detensioning of the first Unit 1 Reactor Vessel Head closure bolt has commenced. Unit 1 enters Mode 6. RCS boron concentration as of 0926 sample is 2750 ppm. This satisfies the requirements of LCO 3.9.1. [Schleif, James - OS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 12:36		Unit 1- OP-13 B, Secondary System Shutdown, complete. [Raasch, Dean - MISC - Station Log - Day Shift]
09/18/2002 12:50	WT Backwashed	Commenced draining of the lower refueling cavity to the PAB -19ft sump per Operations Work Plan. [Schleif, James - OS (Fire Brigade) - Station Log - Day Shift]
09/18/2002 12:55		Testing of 1B-03 loss of voltage relay 1-272/B03 has commenced in accordance with 1RMP 9056-5 and LCO 3 0 5 [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 12:59		Loss of voltage relay testing is complete for relay 1-272/B03 LCO 3.3 4 is now met for both units Exiting TSAC 3 3 4 A [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 13:00		LCO 3 3 4 is not met for both units due to testing of 1B-03 Loss of voltage relay 1-273/B03 per 1RMP 9056-5. Entering TSAC 3 3 4 A with required action A.1 to place channel in trip within 1 hour. [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 13:03		TSAC 3 3 4.A required action A.1 has been completed for 1B-03 loss of voltage relay 1-273/B03. The relay has been placed in the trp position. [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 13:14		Unit 1- Commencing IT-300A, SG A Main Feed Line Check Valves. [Raasch, Dean - MISC - Station Log - Day Shift]
09/18/2002 13:32		Unit 2 - completed PC-23 part 2, Weekly Periodic Check Charging Pump Vari Drive Exercise - SAT. [Lewis, Al - Unit 2 CO - Station Log - Day Shift]
09/18/2002 13:55		Testing of 1B-03 loss of voltage relay 1-273/B03 has commenced in accordance with 1RMP 9056-5 and LCO 3 0.5 [Wallace, Rob - 4th License - Station Log - Day Shift]

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
09/18/2002 14:00		Loss of voltage relay testing is complete for relay 1-273/B03 LCO 3 3 4 is now met for both units. Exiting TSAC 3 3 4 A. Completed 1RMP 9056-5 1B-03 Safety Related and Technical Specifications Relay Calibration [Wallace, Rob - 4th License - Station Log - Day Shift]
09/18/2002 14:23	NLOGS01	Robbins, Rick Assumed STA Position from Robbins, Rick, STA [Robbins, Rick - STA - Station Log - Swing Shift]
09/18/2002 14:28	NLOGS01	Boeselager, Mike Assumed DOS (Fire Brigade) Position from Wilson, Jim, DOS (Fire Brigade) [Boeselager, Mike - DOS (Fire Brigade) - Station Log - Swing Shift]
09/18/2002 14:46	NLOGS01	Ruesch, Scott Assumed OS (Fire Brigade) Position from Schleif, James, OS (Fire Brigade). [Ruesch, Scott - OS (Fire Brigade) - Station Log - Swing Shift]
09/18/2002 15:18		U-1, Completed draining sump "A" IAW ARB [Lohr, Tim - 3rd License - Station Log - Day Shift]
09/18/2002 15:18	NLOGS01	Kuchera, Brian Assumed WtrTreatment(FireBrigade) Position from Purvis, Dale, WtrTreatment(FireBrigade). [Kuchera, Brian - WtrTreatment(FireBrigade) - Station Log - Swing Shift]
09/18/2002 15:19	NLOGS01	Massey, Steve Assumed U1 TurbHall (FireBrigade) Position from Alef, Kurt, U1 TurbHall (FireBrigade). [Massey, Steve - U1 TurbHall (FireBrigade) - Station Log - Swing Shift]
09/18/2002 15:19	NLOGS01	Heine, Tony Assumed Unit 2 CO Position from Lewis, Al, Unit 2 CO. [Heine, Tony - Unit 2 CO - Station Log - Swing Shift]
09/18/2002 15:20	NLOGS01	Teeter, Cliff Assumed 4th License Position from Wallace, Rob, 4th License. [Teeter, Cliff - 4th License - Station Log - Swing Shift]
09/18/2002 15:20	NLOGS01	Wade, Randy Assumed PAB (FireBrigade) Position from Wade, Randy, PAB (FireBrigade). [Wade, Randy - PAB (FireBrigade) - Station Log - Swing Shift]
09/18/2002 15:21	NLOGS01	Johnson, James M. Assumed U2 TurbHall (FireBrigade) Position. [Johnson, James M. - U2 TurbHall (FireBrigade) - Station Log - Swing Shift]
09/18/2002 15:21	NLOGS01	Bryant, Sky Assumed 3rd License Position from Lohr, Tim, 3rd License. [Bryant, Sky - 3rd License - Station Log - Swing Shift]
09/18/2002 15:21	NLOGS01	Dueno, Dan Assumed Unit 1 CO Position from Scherwinski, Doug, Unit 1 CO [Dueno, Dan - Unit 1 CO - Station Log - Swing Shift]
09/18/2002 15:26		Starting ORT-36, Pressurizer Liquid Sample Line [Raasch, Dean - MISC - Station Log - Day Shift]
09/18/2002 15:32	NLOGS01	Merkes, Rick Assumed DSS Position from Merkes, Rick, DSS. [Merkes, Rick - DSS - Station Log - Swing Shift]
09/18/2002 15:33	NLOGS02	Log turned over by Merkes, Rick [Merkes, Rick - DSS - Station Log - Day Shift]
09/18/2002 15:33	NLOGS03	Log approved by Merkes, Rick [Merkes, Rick - DSS - Station Log - Day Shift]
09/18/2002 16:34	DSS Midnight Entry	Informed by RP that radwaste shipment # 02-056 arrived at Morris, IL. [Ruesch, Scott - OS (Fire Brigade) - Station Log - Swing Shift]
09/18/2002 16:47		Common: Stationed Sky Bryant as level 3 dedicated operator per OI-62A while filling the "A" S/G with P-38A aux feed pump, with duties to realign aux feed as required upon receipt of a valid Aux feed signal to either unit. [Bryant, Sky - 3rd License - Station Log - Swing Shift]
09/18/2002 17:48		Unit 2. Performed 2-TS-CCW-001, CCW flow path verification, sat. [Heine, Tony - Unit 2 CO - Station Log - Swing Shift]
09/18/2002 18:00	NLOGS01	Mohr, Mike Assumed DSS Position from Merkes, Rick [Mohr, Mike - DSS - Station Log - Swing Shift]
09/18/2002 18:19	NLOGS01	Rode, Ryan Assumed STA Position from Robbins, Rick [Rode, Ryan - STA - Station Log - Swing Shift]

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
09/18/2002 18:24	EQINSERVIC	IT-360, Purge Supply & Exhaust Valves (CSD) Unit 1, completed satisfactory for 1VNPSE-3213 1VNPSE-3213 purge exhaust valve returned to service. [Ruesch, Scott - OS (Fire Brigade) - Station Log - Swing Shift]
09/18/2002 19:09	NLOGS01	Wandrie, Tom Assumed PAB (FireBngade) Position from Wade, Randy [Wandrie, Tom - PAB (FireBngade) - Station Log - Swing Shift]
09/18/2002 19:44		Secured processing A-HUT (74%) to B-MT (38%) per OI-10A (purification and transfer of CVCS HUT to A or B monitor tank) [Phillips, Scott - MISC - Station Log - Swing Shift]
09/18/2002 19:47		Unit 2: Commenced 60 min non-parallel H-OH MB run. [Heine, Tony - Unit 2 CO - Station Log - Swing Shift]
09/18/2002 19:48		UNit 1, ORT-36, PZR Liquid Sample Line complete SAT [Harsch, Rob - MISC - Station Log - Swing Shift]
09/18/2002 20:00		Commence pumping down the SFP cavity to A-HUT (74%) per OI-56 (draining and refilling the spent fuel pool and transfer canal). [Phillips, Scott - MISC - Station Log - Swing Shift]
09/18/2002 20:05		T-10A monitor tank on recirc. [Wandrie, Tom - PAB (FireBngade) - Station Log - Swing Shift]
09/18/2002 20:25		Common: Stationed Cliff Teeter as level 3 dedicated operator per OI-62A while filling the "A" S/G with P-38A aux feed pump, with duties to realign aux feed as required upon receipt of a valid Aux feed signal to either unit. [Bryant, Sky - 3rd License - Station Log - Swing Shift]
09/18/2002 20:47		Unit 2: Completed 60 min H-OH MB run [Heine, Tony - Unit 2 CO - Station Log - Swing Shift]
09/18/2002 20:50		Secured pumping SFP canal to A HUT and started pumping to B HUT. [Denneau, Scott - MISC - Station Log - Swing Shift]
09/18/2002 20:50		Common: Stationed Sky Bryant as level 3 dedicated operator per OI-62A while filling the "A" S/G with P-38A aux feed pump, with duties to realign aux feed as required upon receipt of a valid Aux feed signal to either unit. [Bryant, Sky - 3rd License - Station Log - Swing Shift]
09/18/2002 21:04		Secured pumping SFP canal to B HUT and DTO 1Z-24A transfer tube isolation. [Denneau, Scott - MISC - Station Log - Swing Shift]
09/18/2002 21:16		Commenced U-1 Containment Purge per OP-9C, Containment Venting and Purging. [Teeter, Cliff - 4th License - Station Log - Swing Shift]
09/18/2002 21:51		"C" HUT on recirc IAW 0-SOP-BS-03C. [Massey, Steve - U1 TurbHall (FireBngade) - Station Log - Swing Shift]
09/18/2002 22:15		Unit 2: Lube oil conditioner level hi or low alarm came in for about 5 min. Cause is unknown, the U-2 TH watch found everything normal per the ARB. [Heine, Tony - Unit 2 CO - Station Log - Swing Shift]
09/18/2002 22:17	NLOGS01	Larson, Tom Assumed DOS (Fire Brigade) Position from Boeselager, Mike, DOS (Fire Brigade) [Larson, Tom - DOS (Fire Brigade) - Station Log - Mid Shift]
09/18/2002 22:18	NLOGS01	Higgins, Robert E. Assumed OS (Fire Brigade) Position from Ruesch, Scott, OS (Fire Bngade) [Higgins, Robert E. - OS (Fire Brigade) - Station Log - Mid Shift]
09/18/2002 22:18	NLOGS01	Rode, Ryan Assumed STA Position from Rode, Ryan, STA. [Rode, Ryan - STA - Station Log - Mid Shift]
09/18/2002 22:29	NLOGS01	Mohr, Mike Assumed DSS Position from Mohr, Mike, DSS. [Mohr, Mike - DSS - Station Log - Mid Shift]
09/18/2002 22:50		Secured C-HUT recirc per 0-SOP-BS-03C (recirc and sample of "C" HUT). [Phillips, Scott - MISC - Station Log - Swing Shift]
09/18/2002 23:04		Unit 1, Scott Denneau is assigned as a Level 3 Dedicated Operator for the Fuel Transfer Tube gate valve IAW RP-1A [Higgins, Robert E. - MISC - Station Log - Swing Shift]
09/18/2002 23:04		Unit 1, Scott Denneau is assigned as a Level 3 Dedicated Operator for the Fuel Transfer Tube gate valve IAW RP-1A [Higgins, Robert E. - MISC - Station Log - Mid Shift]

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
09/18/2002 23:14		Commence water transfer from A-HUT (87%) to SFP canal per OI-56 (draining and refilling the spent fuel pool and transfer canal) for ORT-15 (fuel manipulator and fuel transfer system checkout unit 1) [Phillips, Scott - MISC - Station Log - Swing Shift]
09/18/2002 23:14		Commence water transfer from A-HUT (87%) to SFP canal per OI-56 (draining and refilling the spent fuel pool and transfer canal) for ORT-15 (fuel manipulator and fuel transfer system checkout unit 1) [Phillips, Scott - MISC - Station Log - Mid Shift]
09/18/2002 23:28	NLOGS01	Kupsch, Loren Assumed 4th License Position from Teeter, Cliff, 4th License. [Kupsch, Loren - 4th License - Station Log - Mid Shift]
09/18/2002 23:28	NLOGS01	Post, Bob Assumed Unit 1 CO Position from Dueno, Dan, Unit 1 CO [Post, Bob - Unit 1 CO - Station Log - Mid Shift]
09/18/2002 23:28	NLOGS01	Meaney, Doug Assumed Unit 2 CO Position from Heine, Tony, Unit 2 CO [Meaney, Doug - Unit 2 CO - Station Log - Mid Shift]
09/18/2002 23:28	NLOGS01	Steuer, Will Assumed U1 TurbHall (FireBrigade) Position from Massey, Steve, U1 TurbHall (FireBrigade) [Steuer, Will - U1 TurbHall (FireBrigade) - Station Log - Mid Shift]
09/18/2002 23:29	NLOGS01	Hall, Mark Assumed 3rd License Position from Bryant, Sky, 3rd License. [Hall, Mark - 3rd License - Station Log - Mid Shift]
09/18/2002 23:29		Common: Stationed Mark Hall as level 3 dedicated operator per OI-62A while filling the "A" S/G with P-38A aux feed pump, with duties to realign aux feed as required upon receipt of a valid Aux feed signal to either unit. [Hall, Mark - MISC - Station Log - Swing Shift]
09/18/2002 23:29		Common: Stationed Mark Hall as level 3 dedicated operator per OI-62A while filling the "A" S/G with P-38A aux feed pump, with duties to realign aux feed as required upon receipt of a valid Aux feed signal to either unit. [Hall, Mark - MISC - Station Log - Mid Shift]
09/18/2002 23:30	NLOGS01	Brdlik, Scott Assumed WtrTreatment(FireBrigade) Position from Kuchera, Brian, WtrTreatment(FireBrigade) [Brdlik, Scott - WtrTreatment(FireBrigade) - Station Log - Mid Shift]
09/18/2002 23:30	NLOGS01	Fischer, Terry Assumed PAB (FireBrigade) Position from Wandrie, Tom, PAB (FireBrigade) [Fischer, Terry - PAB (FireBrigade) - Station Log - Mid Shift]
09/18/2002 23:31	NLOGS01	LaFountain, Ken Assumed U2 TurbHall (FireBrigade) Position from Johnson, James M., U2 TurbHall (FireBrigade). [LaFountain, Ken - U2 TurbHall (FireBrigade) - Station Log - Mid Shift]
09/18/2002 23:35		Secured water transfer from A-HUT (81%) to SFP canal per OI-56 (draining and refilling the spent fuel pool and transfer canal) for ORT-15 (fuel manipulator and fuel transfer system checkout unit 1) [Phillips, Scott - MISC - Station Log - Swing Shift]
09/18/2002 23:35		Secured water transfer from A-HUT (81%) to SFP canal per OI-56 (draining and refilling the spent fuel pool and transfer canal) for ORT-15 (fuel manipulator and fuel transfer system checkout unit 1). [Phillips, Scott - MISC - Station Log - Mid Shift]
09/18/2002 23:40		Scott Denneau assigned as a Level 2 Dedicated Operator IAW ORT-15 for the Fuel Transfer Tube Gate Valve and Fuel Transfer Cart [Harsch, Rob - MISC - Station Log - Mid Shift]
09/18/2002 23:57	NLOGS02	Log turned over by Larson, Tom [Larson, Tom - MISC - Station Log - Swing Shift]
09/18/2002 23:58	NLOGS03	Log approved by Larson, Tom [Larson, Tom - MISC - Station Log - Swing Shift]