



- PORTIONS OF SYSTEM WITHIN LICENSE RENEWAL SCOPE ARE BOUNDED BY LR FLAGS.
 - UNLESS OTHERWISE INDICATED, VENTS, DRAINS AND TEST CONNECTIONS THAT ARE WITHIN LICENSE RENEWAL BOUNDARIES ARE INCLUDED IN LR SCOPE TO THE DISCHARGE OF THE VALVE.
 - ALL INSTRUMENTATION LINES NORMALLY OPEN TO THE PROCESS SYSTEM, THROUGH AND INCLUDING THE INSTRUMENT ARE INCLUDED IN LR SCOPE. IN GENERAL, LR FLAGS ARE NOT SHOWN FOR VENTS, DRAINS, TEST CONNECTIONS OR INSTRUMENT LINES EXCEPT FOR CONTAMINATION PENETRATIONS.
 - THE LICENSE RENEWAL BOUNDARY INCLUDES THE PIPING AND SUPPORTS UP TO THE FIRST SEISMIC SUPPORT PAST THE BLUE BOUNDARY FLAG.

NOTES:
 A. TEMPORARY COOLING WATER SUPPLY.
 B. THE LETTERS W AND E DENOTE THAT VALVE LOCATION IS EITHER AT THE WEST OR EAST SIDE OF THE CONDENSER.

EA-FC-00-063 2/03 1 of 1

FORT CALHOON STATION

FLOW DIAGRAM
CIRCULATING WATER
P & ID

DWG. 11485-M-257, SH. 2	REV. 23
REV. SH. 27268	APPROVED BY: [Signature]
FILE 54891	DATE: 11/2/02