



- PORTIONS OF SYSTEM WITHIN LICENSE RENEWAL SCOPE ARE BOUNDED BY LR FLAGS.
- UNLESS OTHERWISE INDICATED, VENTS, DRAINS AND TEST CONNECTIONS THAT ARE WITHIN LICENSE RENEWAL BOUNDARIES ARE INCLUDED IN LR SCOPE TO THE DISCHARGE OF THE VALVE.
- ALL INSTRUMENTATION LINES NORMALLY OPEN TO THE PROCESS SYSTEM, THROUGH AND INCLUDING THE INSTRUMENT, ARE INCLUDED IN LR SCOPE.
- IN GENERAL, LR FLAGS ARE NOT SHOWN FOR VENTS, DRAINS, TEST CONNECTIONS OR INSTRUMENT LINES EXCEPT FOR CONTAINMENT PENETRATIONS.
- THE LICENSE RENEWAL BOUNDARY INCLUDES THE PIPING AND SUPPORTS UP TO THE FIRST SEISMIC FLAG PAST THE BLUE BOUNDARY FLAG.

EA-FC-00-115 2103 1 of 4

**FORT CALHOUN STATION**  
**CONTAINMENT HEATING, COOLING & VENTILATING FLOW DIAGRAM**  
 P & ID

DWG. 11405-M-1, SH. 2	APP'D	REV
REV. SH. 27947	<i>Chaus</i>	24
FILE 48962	10/21/99	

- NOTES:
1. NOT USED
  2. SAMPLE LINES ARE INSULATED OUTSIDE AND FINISHINGS OF LINES INSIDE ARE INDICATED.
  3. VA ORS SHOWN ALLOWED IN FINISH AIR MAKEUP HERE. VA-088 SHOWN ALLOWED IN CONTAINMENT EVACUATION MAKEUP.
  4. TEMPORARY PARALLEL FITTERS MAY BE ADDED TO PURGE FILTER HEUSINGS AS REQUIRED TO RELIEVE LOADING RELEASES TO THE ENVIRONMENT.

FOR INFORMATION ONLY

140