



-PORTIONS OF SYSTEM WITHIN LICENSE RENEWAL SCOPE ARE BOUNDED BY LR FLAGS.
 -UNLESS OTHERWISE INDICATED, VENTS, DRAINS AND TEST CONNECTIONS THAT ARE WITHIN LICENSE RENEWAL BOUNDARIES ARE INCLUDED IN LR.
 -SCOPE TO THE DISCHARGE OF THE VALVE.
 -ALL INSTRUMENTATION LINES NORMALLY OPEN TO THE PROCESS SYSTEM THROUGH AND INCLUDING THE INSTRUMENT ARE INCLUDED IN LR SCOPE.
 -IN GENERAL LR FLAGS ARE NOT SHOWN FOR VENTS, DRAINS, TEST CONNECTIONS OR INSTRUMENT LINES EXCEPT FOR CONTAMINATION PENETRATIONS.
 -THE LICENSE RENEWAL BOUNDARY INCLUDES THE PIPING AND SUPPORTS UP TO THE FIRST SEISMIC SUPPORT PAST THE BLUE BOUNDARY FLAG.

NOTES:
 A. TEMPORARY COOLING WATER SUPPLY TIE-IN DURING CIRCULATING WATER OUTAGES.
 B. THE LETTERS W AND E DENOTE THAT THE LOCATION IS EITHER AT THE WEST OR EAST SIDE OF THE CONDENSER.

EA-FC-00-100 02/03 8 of 8

FORT CALHOON STATION

FLOW DIAGRAM
 CIRCULATING WATER
 P & ID

DWG. 11405-M-257, SH. 2	APVD	REV
REV. SH. 27268	6/12/02	23
FILE 54891		