	PLANT MODIF	ICATION	FLANT MODIFIC	ATION NU.:	IVIK 99-029*D
INITIATIO	אכ ^ו		<u>, , , , , , , , , , , , , , , , , , , </u>		
Title:	AUX FEI	ED WATER PUMP 2P-29	MINIMUM FLOW	RECIRC LINI	E ORIFICE
⊠ Q	A 🗌 Non-QA	🖾 SR 🔲 Non-SR	Unit 1 🗌	Unit 2	
CHAN	MPS System Code:	AF – Auxiliary Fe	edwater	EWR:	99-031
Priori	ty:	A3D	Cost	Estimate:	
Projec	t Objectives: Elimin	1ate excessive noise and vi	bration attributed to e	erosion in orifi	ice 2RO-4003.
Ргоро	sed Scope:Install	l new orifice in the AFW P	ump 2P-29 minimum	flow recircula	ition line to replace
exist	ing orifice 2RO-4003.				
Initiated By	7:	Alex Foltynowicz		Date:	7/16/1999
FDGH					
Design Con	trols and Project Contro	ols: (Ref. NP 7.2.1, Comme	entary, for completion o	of this section.)	
Check	Applicable Design Cor	ntrols:	Clarifications/B	asis:	
\boxtimes	Design Input Checkl	ist (PBF-1584)			
\boxtimes	DUC (PBF-1606)		·		
\boxtimes	Design Verification I	Notice (PBF-1583)			
\boxtimes	Working Drawings				•
\boxtimes	ECRs				
\boxtimes	Calculations		-		
	Specifications				
	Design Documentat equivalent	tion (PBF-1585), or			
					· :
	• u = tu = t			• =====	
□ Check	Applicable Project Cor Fire Protection/Appe	ntrols:	Clarifications/B	asis:	
Check	Applicable Project Cor Fire Protection/Appe Project Team Require groups to request)	ntrols: endix R Review ed (indicate minimum	Clarifications/B	asis:	
	Applicable Project Cor Fire Protection/Appe Project Team Require groups to request) Conceptual Design P	ntrols: endix R Review ed (indicate minimum 'ackage Required	Clarifications/B	asis:	
	Applicable Project Cor Fire Protection/Appe Project Team Require groups to request) Conceptual Design P Budget Design Project	ntrols: endix R Review red (indicate minimum 'ackage Required ct (Impact) Number	Clarifications/B	asis:	
	Applicable Project Cor Fire Protection/Appe Project Team Requir groups to request) Conceptual Design P Budget Design Project Detailed Project Scho	ntrols: endix R Review red (indicate minimum 'ackage Required ct (Impact) Number edule	Clarifications/B	asis:	
	Applicable Project Cor Fire Protection/Appe Project Team Requir groups to request) Conceptual Design P Budget Design Project Detailed Project School (IWP Required	ntrols: endix R Review red (indicate minimum Package Required ct (Impact) Number edule	Clarifications/B	asis:	
Check	Applicable Project Cor Fire Protection/Appe Project Team Requir groups to request) Conceptual Design P Budget Design Project Detailed Project Schoo (IWP Required oject Manager:	ntrols: endix R Review red (indicate minimum Package Required ct (Impact) Number edule Alex Foltyno	Clarifications/B	asis:	· · ·
Check	Applicable Project Cor Fire Protection/Appe Project Team Requir groups to request) Conceptual Design P Budget Design Project Detailed Project Scho (IWP Required oject Manager:	ntrols: endix R Review red (indicate minimum Package Required ct (Impact) Number edule Alex Foltyno WPHOmeth	Clarifications/B	asis:	· . 12/4/0,

Revision 5 07/14/99

t

.

٠

Reference(s): NP 7.2.1, PBF-1583, PBF-1584 NP 7.2.2, PBF-1585, PBF-1606

NUCLEAR POW	ER BUSINESS UNIT	PLANT MODIF	ICATION NO.: MR 99-029
PROJECT MANAGER - EST	ABLISH PROJECT TEAM		ļ
<u>Group Represented</u> Radiation Protection	Assigned <u>Team Member</u> Carl Onesti	Group Represented	Assigned <u>Team Member</u>
Fire Protection	Bob Ladd		
Mechanical Maintenance	Brian VanderVelde		
Operations	Mike Schug		
System Engineering	John P. Schroeder		
Site QA	Jeff Black		
FDGH Concurrence:	RDJouch		Date: 12/4/01
		-	
PROJECT MANAGER/FDCI Indicate any clarifications or cha (Note: FDGH approval required	I nges to design controls or proj if design controls or project c	ect controls: ontrols relaxed)	
PROJECT MANAGER/FDCI Indicate any clarifications or cha (Note: FDGH approval required	I	ect controls: ontrols relaxed)	
PROJECT MANAGER/FDCI Indicate any clarifications or cha (Note: FDGH approval required	I nges to design controls or proj if design controls or project c	ect controls: ontrols relaxed)	

:

UPDATES TO THIS FORM COVERED BY EXISTING SCR 98-0942

.

Ċ,

ي هه ميدنجو ارد

.

NUCLEAR POWE PLANT MOI	DIFICATION	FLANT MODE		WIK 99-029*D
PROJECT MANAGER - COl Provide a concise description of commentary in NP 7.2.1 for add	NCEPTUAL DESIGN f the conceptual design. List ditional guidance.	[Check here if no all attached documents	ot required: 🔀] which define the cor	nceptual design. See
·				
Conceptual Design Complete:	Pro	oject Manager _		Date
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta	Pro AL DESIGN REVIEW AN ach comments on NPBU Doc	oject Manager D ACCEPTANCE nument Review Comme	[Check here if not r ent Sheet (PBF-1622 of	Date equired: [X] or equivalent)
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u>	Pro AL DESIGN REVIEW AN ach comments on NPBU Doc <u>Acceptance Signatu</u>	oject Manager D ACCEPTANCE nument Review Comme re Dat	[Check here if not r ent Sheet (PBF-1622 o te	Date equired: [X]] or equivalent) <u>Comments</u>
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u> Radiation Protection	Pro AL DESIGN REVIEW AN ach comments on NPBU Doc Acceptance Signaty	oject Manager D ACCEPTANCE nument Review Comme rre Dat	[Check here if not r ent Sheet (PBF-1622 o te	Date equired: [X]] or equivalent) <u>Comments</u> one Attached
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u> <u>Radiation Protection</u> Fire Protection	Provide the Providence of Provide the Providence of Provide the Providence of Provide the	oject Manager D ACCEPTANCE nument Review Comme rre Dat	[Check here if not r ent Sheet (PBF-1622 o te	Date equired: [X]] for equivalent) <u>Comments</u> one Attached one Attached
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u> <u>Radiation Protection</u> <u>Fire Protection</u>	Pro AL DESIGN REVIEW AN ach comments on NPBU Doc Acceptance Signaty	oject Manager D ACCEPTANCE nument Review Comme rre Dat	[Check here if not r ont Sheet (PBF-1622 of te	Date equired: [\]] or equivalent) Comments one Attached one Attached one Attached
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u> <u>Radiation Protection</u> Fire Protection	Pro AL DESIGN REVIEW AN ach comments on NPBU Doc Acceptance Signatu	oject Manager D ACCEPTANCE nument Review Comme rre Dat	[Check here if not r ent Sheet (PBF-1622 o te No No No No	Date equired: [\]] or equivalent) Comments one Attached one Attached one Attached one Attached
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u> <u>Radiation Protection</u> Fire Protection	Pro VAL DESIGN REVIEW AN ach comments on NPBU Doc Acceptance Signatu	oject Manager D ACCEPTANCE nument Review Comme rre	[Check here if not r ent Sheet (PBF-1622 o te	Date equired: []] or equivalent) <u>Comments</u> one Attached one Attached one Attached one Attached one Attached
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u> <u>Radiation Protection</u> Fire Protection	Pro VAL DESIGN REVIEW AN ach comments on NPBU Doc Acceptance Signatu	Dject Manager D ACCEPTANCE nument Review Comme rre Dat	[Check here if not r ent Sheet (PBF-1622 o te	Date equired: [\]] or equivalent) Comments one Attached
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u> <u>Radiation Protection</u> Fire Protection	Provide the second seco	oject Manager DACCEPTANCE Tre Dat	[Check here if not r ent Sheet (PBF-1622 of image: state states	Date equired: [\]] or equivalent) Comments one Attached
Conceptual Design Complete: GROUP HEAD CONCEPTU Review conceptual design. Atta <u>Group</u> <u>Radiation Protection</u> Fire Protection	Provide the second seco	oject Manager DACCEPTANCE Tre Dat	[Check here if not r ent Sheet (PBF-1622 d) te Image: Imag	Date equired: [\]] or equivalent) Comments one Attached

.

UPDATES TO THIS FORM COVERED BY EXISTING SCR 98-0942

5				······································		
	NUCLEAR POWER BU PLANT MODIFIC	SINËSS UNIT CATION	PLAN	T MODIFICATION N	NO.: MR	99-029*D
	FINAL DESIGN REVIEWS					
ž,	Review final design. Attach commen	ts on NPBU Document Re	view Con	nment Sheet (PBF-1622	or equivalent)	
	Group	Acceptance Signat	ure	Date	Con	nments
	Radiation Protection	Cul Auto	5	11/28/01	None	Attached
	Fire Protection	al-lik	2	11-26-2001	None	Attached
	Mechanical Maintenance	Knich Hause Valle		12-4-01	None	Attached
	Operations	Male		12-4-01	None	Attached
	System Engineering	Jul P. Achar	d-	11-26-2001	None	Attached
	St. Qr		ente	12/4/2001	None	Attached
				<u> </u>	None None	Attached
				<u> iz iv</u>	None	Attached
	INDEPENDENT REVIEW OF IN	STALLATION DOCUM	ENTS			
	All design and licensing requirements	s have been incorporated in	the insta	llation and testing docu	ment(s).	
	Reviewer: Ros Char	pman Alte	4	Dat	ie: <u>12-4-</u>	01
	FDGH - RELEASE					
2	All design controls have been proper are approved. This design is released	ly implemented and the pro i for installation. Commen	oject has t ts regardi	been appropriately revie ng release of this desigr	wed. All necess a are noted below	ary documents v:
	FDGH:AAr	nak		- Dat	te: 12/5	<u> q</u>
	PROJECT MANAGER - CLOSEC	DUT				
	Plant modification is complete, include List all Work Order(s) used for instal	ding submittal of all docum	ient upda	tes in the Document Up		/BF-1000).
	9944189		•			
	·			,,		·
	-					<u></u>
	Project Manager: <u>Rob C</u>	hapman Zillt (f-	Da	te: <u>10-11-</u>	
	NUCLEAR INFORMATION MAI	NAGEMENT				
	Microfilm the entire modification particular	ckage.				
					•	
		<u>, , , , , , , , , , , , , , , , , , , </u>				
1						

UPDATES TO THIS FORM COVERED BY EXISTING SCR 98-0942

-

1.4

•

э.

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

Revision 0 December 4, 2001 ļ

PURPOSE

The purpose of the proposed modification is to minimize piping line noise and vibration when operating Auxiliary Feedwater (AF) pump 2P-29 in the recirculation mode. Vibration and excessive noise were attributed to turbulence and cavitation resulting from the flow condition through restrictive orifice 2RO-4003. The reduction of piping line noise and vibration will be accomplished by implementation of the recommendations of root cause evaluation RCE 99-081 and EWR 99-031, which is to replace the existing 2RO-04003.

In addition, as recommended by RCE 99-081 and CR 99-1391, a portion of the AF piping associated with RO will be replaced to facilitate oversized socket welds due to multiple occurrences of pinhole leaks. The purpose for oversized socket welds is to offer a significant high cycle fatigue improvement over standard ASME Code socket weld in vibration-critical application.

<u>SCOPE</u>

The scope of MR 99-029*D is to replace 2RO-4003 with a new pressure reducing orifice. In addition, pipe from the 90° elbow just downstream of 2FE-4049 to the upstream socket-weld on 2AF-53 will be replaced. The replacement piping will be welded with socket welds that are oversized in a 2/1 configuration as described in EPRI technical reports TR-107455 and TR-111188.

This modification is classified as QA, Safety-Related (SR), Seismic Class 1, although all piping downstream of 2RO-4003 is QA, non safety-related (AQ). The RO and modified piping are non-ASME class.

DESIGN INPUTS

- DG-M09, Revision 2, Design Requirements for Piping Stress Analysis, March 20, 2000.
- ASME B31.1 1992, Power Piping
- DG-M03, Revision 9, Bechtel Piping Class Summary, June 8, 2001.
- Wisconsin Electric Power Company, Drawing GLD M-217, Sheet 1, QA Classification Diagram Auxiliary Feedwater System QA Classification Diagram, Point Beach Nuclear Plant – Unit 1 & 2, Revision 11.
- Bechtel Drawing 6118 M-117 Sh. 1, Auxiliary Feedwater System, Revision 68.
- Bechtel Drawing P-159, Aux. F.W. From Heating Boiler Cnds. Return & Pump Recirc. To Cnds Stg. Tank 6" & 3" JG-4 Unit 1.
- Bechtel Pipe Class DB-3, Auxiliary Feedwater Piping
- Flowserve Pressure Reducing Orifice Drawing 94-16249, 2" 600# Globe Control Valve
- FSAR Section 10.2, Auxiliary Feedwater System.
- Design Basis Document DBD-01, Auxiliary Feedwater System.
- EWR 99-031, AF Pump Recirculation Noise In The Control Room

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

Revision 0 December 4, 2001

- CR 99-1391, SCAQ on Potential Common Mode Failure Mechanism Affecting Welds In AFW Pump Recic. Line.
- RCE 99-081, Socket Weld Failures in AF Pump Recirc. Piping
- Wisconsin Electric Power Company, Point Beach Nuclear Plant RCE 99-081, "Socket Weld Failures In Auxiliary Feedwater Pump Recirculation Piping".
- Bechtel Specification No. 6118-M-6, Rev. 3, "Specification For Auxiliary Feedwater Pumps Point Beach Nuclear Plant Units 1 & 2 Wisconsin-Michigan Power Company, dated 10/28/68.
- EPRI TR-111188, "Vibration Fatigue Testing of Socket Welds". Interim Report, December 1998.
- EPRI TR-107455, "Vibration Fatigue of Small Bore Socket-Welded Pipe Joints", Final Report, June 1997.

DESIGN DESCRIPTION AND ANALYSIS

This modification will replace 2RO-4003 installed in the minimum recirculation line for AF pump 2P-29, with a new type of orifice. The presently installed RO was accredited with causing flow induced cavitation, therefore, allowing for excessive noise and vibration in the AF piping system.

The proposed modification meets design, materials, fabrication, construction, and examination and testing standards of the existing installation. The proposed modification will be essentially a direct replacement for the components already installed and operational. The replacement RO will have the same function as the existing orifice, which is to provide pressure reduction and act as a pressure boundary for the AF system piping.

A comparison of the mechanical and flow performance characteristics of existing vs. new RO indicates that replacement RO is equal or better. The replacement RO will provide an improved anti-cavitation characteristics and thus will minimize hydrodynamic noise and vibration under liquid application. The original design requirements for the RO are specified in the Bechtel Specification No. 6118-M-6, Rev. 3, "Specification For Auxiliary Feedwater Pumps Point Beach Nuclear Plant Units 1 & 2 Wisconsin-Michigan Power Company, dated 10/28/68. This specification does not address design/construction specifics for this RO. It specifies that, "Each pump shall be furnished with a pressure reducing orifice to be used in conjunction with the on-off control valve in the pump recirculation piping. The orifice shall be provided with ended weld connections for installation in AF piping. If the flow through the orifice may cause erosion, special materials, such as 316 stainless steel, shall be used."

The currently installed RO, was designed and constructed by the Byron-Jackson Company (BJCO), and installed under MR 88-099. The replacement RO was procured from the Flowserve Company under P.O.# 4500429416, to the requirements of the 10 CFR 50, Appendix B, QA Program. This includes among other QA requirements, a flow calculation to demonstrate that the orifice will perform as specified. A seismic analysis and report, to demonstrate that the orifice will operate during and after a seismic event was determined not to be required for this RO because the component function is passive in nature.

The design of the new RO is different than the presently installed orifice. The existing RO uses inner orifice plates to control the flow and pressure drop across the orifice. The new RO works in a similar manner except that control of flow and pressure drop is accomplished by directing the flow through the series of close-fitting cylindrical stages, each constructed with expansion holes and intersecting circumferential channels that restrict the flow. This flow

MR 99-029*D

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

Revision 0 December 4, 2001

path of multiple restriction and enlargements reduces the pressure gradually across each trim cylinder, avoiding the sharp pressure drop typical to conventional, single-throttling orifice.

In a letter dated 3/2/2001 from Flowserve, the stated minimum recirculation flow for 2P-29 is 75 gpm, but this requires the pump to be inspected after 60 hours of operation at this flow. If the pump is operated at 130 gpm, then up to 1500 hours of service can be accumulated before maintenance is required. Based on calculation N-91-032 and stated in FSAR Section 10.2.3, the current maximum flow through the recirculation line with the control valve failed open is 126 gpm. The new orifice will be set to approximately the same flow rate (between 120 and 130 gpm), even though that this is below the 1500 hour limit. Increasing the flow would require additional analysis since it would reduce the available flow to the steam generators.

The replacement RO is contained in a 2"- 600# cast stainless steel globe valve body (ASME A 351 Type CF8M) and designed to the requirements of ASME B31.1 and ASME B16.34 – 1996 Edition. The working pressure is 1440 psig at 100 °F, meeting the Pipe Class 2"-DB-3 requirements. The flow rate of the RO can be adjusted during operation with the system pressurized. The RO will not be designed to shut-off flow. The adjusting device will be positively secured in its position using a lockwire attached to the stem and bonnet.

A hydrostatic pressure test of the replacement RO shell was performed at the Flowserve facility in accordance with ASME/ANSI B 16.34, except that the test pressure was maintained for at least 30 minutes.

In addition to RO replacement, some of the existing piping associated with RO will also be replaced. The piping to be replaced is shown on Working Drawing SK-MR-99-029*D and includes the two (2) 90° piping elbows upstream of the 2RO-4003 to the upstream socket weld on the isolation valve 2AF-53. This piping replacement is being done to simplify the installation and to allow for the installation oversized socket welds. The replacement piping and RO will be joined by socket welds which are oversized in a 2/1 configuration, as recommended by EPRI technical reports. The oversized socket weld detail is shown on Working Drawing SK-MR-99-029*D. The welds in the recirculation line that are not affected by this modification will be oversized by WO 9914184, which will simply add weld material over the existing welds. All welds in the recirculation line up to valve 2AF-53 will be oversized, with the exception of the buttwelds at the FE-4049 flanges.

The design, materials, construction and, examination and testing requirements for AF piping are summarized in the Wisconsin Electric Design and Installation Guideline DG-M02. The piping to be replaced is classified as Pipe Class 2"-DB-3. This Pipe Class specifies carbon steel materials, however due to wear concerns the existing piping is stainless steel. Thus, replacement piping and piping components will be also stainless steel.

The replacement piping material for the proposed modification is ASTM A-312 Grade TP 316. The replacement piping fittings material is ASTM A-182 Grade F 304. The replacement piping is 2" Schedule 80, and the fittings are 3000# class, which will meet the pressure and temperature ratings for Pipe Class 2"-DB-3 (1440 psig at 100 °F).

The replacement RO is heavier than existing one, and it will add approximately 40 lbs to the existing AF piping system. In addition, the replacement piping assembly will have a slightly different internal length of piping than the existing piping layout. However, face-to-face length of the replacement pipe spool piece will be exactly the same as the existing one. These differences between the existing and proposed piping configurations have been addressed by the Wisconsin Electric Co. (WE) analysis which have demonstrated ASME B31.1 compliance of the modified piping. An addendum to Piping System Qualification Report WE-100070 documents this evaluation.

In addition, the flow characteristic of the replacement RO and its affect on the associated plant calculations was evaluated. This evaluation was documented in Addendum N-91-031-00-A to Calculation No. N-91-031, "1 & 2 P-29 Mini - Recirc Line System Characteristics", Rev.0 and Addendum N-91-032-00-A to Calculation No. N-91-032, "Comparison of Nominal Flow Rates from 2P-29 to 2HX-1A and 2HX-1B with the Recirc Line Open", Rev. 0. The

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

Revision 0 December 4, 2001

results of this evaluation found that the slight differences in the flow characteristic between existing and replacement pressure reducing orifices is acceptable and does not significantly alter the above calculations results.

None of the above changes is introducing a new, unknown equipment to PBNP. Furthermore, replacement components are passive in nature when the system is operational and will be designed, installed and tested in accordance with existing procedures and controls.

To implement this modification, the portion of the AF piping will be cut at the socket weld at valve 2AF-53 and disconnected at the orifice's 2FE-4049 flange. This disassembly is shown on Sketch SK-MR-99-029*D. Piping, and pipe components removed will not be reused for this modification. The only exception is the 2FE-4049 flange and its associated pipe stub up to the first 90° elbow. This assembly will be inspected and then reused. To assure high quality of socket welds, a replacement piping spool piece (containing the new RO) will be fabricated in the shop in accordance with details provided by Working Drawing SK-MR-99-029*D.

Implementation of this modification will reduce the possibility for line noise and vibration when operating this line in the recirculation mode.

Design pressure, operating pressure, design temperature and other pertinent design parameters for RO are specified in the Data Sheet attached to the PO 4500429416.

No procedure changes result from this modification. This is a physical replacement of a RO and associated portion of the AF system. There will be no additional components added or operating modes changes that will require operating procedure changes.

Welding for this modification will be performed in accordance with welding procedure WP-7.

The RO will be tested at a calibrated flow test facility. The RO will be adjusted accordingly during this test to pass a flow of between 120 and 130 gpm at conditions that are identical to those when the 2P-29 AFP is running.

NDE requirements for the Pipe Class affected by the proposed modification are specified in DG-M02 and the original code of construction, USAS B31.1 - 1967. They require the finished socket welds to receive a Visual Examination (VT). The affected existing welds have a history of failure, therefore, in addition to VT of the final socket welds, root welds will receive VT and Liquid Penetrant Examination (PT). Piping socket welds shall be examined utilizing the acceptance criteria of ASME B31.1 - 1992.

As required by ASME B31.1, an initial service leakage test will be performed at normal operating pressure and temperature (with the 2P-29 auxiliary feedwater pump running). Additionally, flow data will be collected during the pump run to verify proper operation of the RO.



AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

Revision 0 December 4, 2001

DESIGN OUTPUT

The Installation Work Plan IWP 99-029*D will be prepared to identify installation requirements including preoperational conditions, installation testing and post installation testing requirements. In addition, a 10 CFR 50.59 Safety Review (SCR 2001-0981) has been prepared to evaluate the proposed change to PBNP.

The following calculations were prepared to address the proposed modification:

- Flowserve Co. pressure reducing device sizing calculation (part of vendor documentation provided with orifice)
- Addendum to WE Piping System Qualification Report WE-100070
- Addendum N-91-031-00-A to WE Calculation No. N-91-031, Rev. 0
- Addendum N-91-032-00-A to WE Calculation No. N-91-032, Rev. 0

The following Installation Work Plan is associated with this modification:

- IWP 99-029*D (WO 9944189), Aux Feed Water Pump 2P-29 Minimum Flow Recirc Line Orifice Unit 2
- WO 9950214, Welding of stub pieces onto orifice for offsite flow testing
- WO 9950215, Prefab work for MR 99-029*D

The following working drawing is associated with this modification:

SK-MR-99-029*D, Auxiliary Feedwater System Orifice 2RO – 4003 Replacement, Unit 2

Other documents:

- 10 CFR 50.59/72.48 Safety Review, SCR 2001-0981
- Document Update Checklist, PBF-1606

٢

Page 5 of 5

NI MOL	JCLEAR POWER B DIFICATION REQU	USINESS UNIT	r IST	MR NUMBER <u>99-029*D</u> (WO#, if non-mod)
OCUMENTA	FION UPDATE SHE	ET AND CLOSE	OUT CHE	CKLIST I
	Require	d For		-
N/A	Acceptance (Completion)	Closeout (Submittal)		
			A. TRA	INING
		X	1.	Lesson Plans
		X	2.	Plant Status Update/Just-in-Time Training
	· · · · · · · · · · · · · · · · · · ·	<u> </u>	3.	Training Handbook
X	• •		4.	Simulator Changes Initiated
			B. FIN	AL DESIGN ORGANIZATION
			1.	Drawings
X				a. Pen & Ink changes and DCNs initiated for Control Room Drawings - Logics, P&IDs, 499 series elementaries.
x				 Pen & Ink changes and DCNs initiated for Work Control Center Drawings - P&IDs
x				c. Pen & Ink changes and DCNs initiated for I&C Drawings Reactor Protection and Safeguards Elementaries.
x				d. Master Data Book - Control Room, Work Control Center, Local Panel - PBF-2093
	<u> </u>	x		e. Drawing Revisions - PBF-1508
		X		f. New Drawings - PBF-1592
X				g. Drawings Voided - PBF-1592
	<u>نى بى بى</u>	X		h. Working Drawings Transferred/Voided - PBF-1592
<u></u>	.,	X	2.	Purchase Orders - (also contract numbers)
X			3.	Specifications
		x	4.	Component Instruction Manuals (for issue, revision, deletion) - PBF-1586
x			5.	Cable and Raceway Data Schedule Revisions - PBF-0091
x			6.	WERLDS Data Base Revision - Design Guideline DG-E08.
x	-		7.	Environmental and Seismic Qualification Documentation Upda Ref. NP 7.7.1, NP 7.7.2.
<u> </u>	• • • • • • •		8.	FPER Revisions - NP 5.2.11
X		•	9.	Update Fire Protection manual.
	X		10.	Calculations added/deleted / revised - PBF-1608
X			11.	FSAR - change; NP 5.2.6
<u> </u>	· · · · · · · · · · · · · · · · · · ·		12.	Technical Specification - change; specify section(s) affected ar
x				change request number, if known.

•

_`

NUCLEAR POWER BUSINESS UNIT MODIFICATION REQUEST CHECKLIST

		Require	ed For		
	N/A	Acceptance (Completion)	Closeout (Submittal)		
	<u>x</u>			13.	Report major changes to radwaste treatment systems with annual FSAR update per PBNP Tech Spec 15.7.8.5.
1_			X	14.	EPIX Update - report MR changes to the EPIX Coordinator.
	<u>x</u>			15.	ALARA Review - specify minutes or review document.
	x	•		16.	Report major changes to the containment aluminum inventory list with FSAR update.
			<u> </u>	17.	DBD Revisions - PBF-1611
-	<u>X</u>			· 18.	PSA Models and Documentation - PBF-1626
		•		C. CH	AMPS DATABASE
_	x		. <u> </u>	1.	Equipment Identification - additions assigned from CHAMPS
			<u> </u>	2.	Permanent Labeling - labels on new equipment; PBF-9900
		<u> </u>		3.	Temporary Labeling - labels on new equipment; PBF-2074
			X	4.	Equipment Record - update to CHAMPS coordinator specify change(s); PBF-9922
	x			5.	Spare parts stocking and scrapping inputs into CHAMPS; PBF-9925, PBF-1023
-			X	6.	Unused material removed from modification bin.
				D. OP	ERATIONS
	x			1.	Abnormal Operating, Normal Operating, and Refueling Procedure PBF-0026a
ĺ.	X	· · · ·	· ·	2.	Operating Instructions and Checklists - PBF-0026a
	x			3.	Alarm Response and RMS Alarm Setpoint and Response Books - PBF-0026a
	x	· .		4.	Testing - TS, IT, ORT, other - PBF-0026a
	x	. <u></u>		5.	EOPs, ECAs, CSPs - PBF-0026a
	x	. <u></u>	•••••	6.	Periodic Callups - PBF-9920
	x		<u></u>	7.	Fire Protection Procedure - PBF-0026a
	x	ι		8.	EOP Setpoints, EOP Instrument Uncertainty Calculations - PBF-8001
	x			9.	Tank Level Book - PBF-0026a
	X			10.	Emergency Plan and EPIPs - PBF-0026a

	NUC MODI	CLEAR POWER B FICATION REQU	USINESS UNIT	r Ist	MR NUMBER <u>99-029*D</u> (WO#, if non-mod)
e R	DOCUMENTATI	ON UPDATE SHE	ET AND CLOSE	EOUT CHE	CKLIST
123	•	Require	d For		
	N/A	Acceptance (Completion)	Closeout (Submittal)		
				E. MAI	NTENANCE/I&C
•	<u> </u>		<u></u>	1.	Maintenance Procedures/Instructions - PBF-0026a
	X	<u> </u>	<u>.</u>	2.	ICPs - PBF-0026a
	X	•		3.	Setpoint Document - PBF-8001
	X		. <u> </u>	4.	Preventative Maintenance - initiate/revise CHAMPS callups; PBF-9921/9920
	<u> </u>	<u>. </u>	·	5.	Ensure station batteries' load profile changes are incorporated into the appropriate discharge test RMPs.
				F. SEC	JRITY
	<u> </u>	<u> </u>		1.	Security Procedures
ľ	X			2.	Security Plan
				G. ENG	INEERING/MISC.
10	<u> </u>			1.	ISI Program
	X		<u> </u>	2.	IST Program
	<u> </u>	·		3.	Miscellaneous HX ECT/Cleaning program
	X			4.	Reactor Engineering Instructions - change; specify section(s) affected.
	<u> </u>		 	5.	Reactor Engineering Refueling Procedures - change; specify section(s) affected.
	X			6.	Software Control - specify system affected and software change request number.
ĺ	X	·		7.	Component maintenance programs.
	<u> </u>			8. (Governing calculations and models (e.g., SW model, DC loading, EDG loading, piping analysis, structural loading, etc.).
			<u> </u>	H. OTH	ER (CHEM, HP, ETC.)
		Ĺ		I. ECRs	
		<u></u>		1.]	ECR Final Resolution completed and approved by FDGH.
				2. 1	ECR Implementation completed.
~		_			

ſ	Section	Specific Updates Required	Prior to <u>Acceptance</u>	Prior to <u>Closeou</u>	<u>By</u>
	A.1	Lesson Plan Updates		\boxtimes	Tusk 00-040 5-10-02 Rec
	A.2	Mod sent to Training for JIT		\boxtimes	Per enal deful 5-14-02 RCC
	A.3	TRHB updated		\boxtimes	Tur 00-046 5-12.02 RCC
	B.1.e	Revise Bechtel Drawing P-103 (if necessary)		\boxtimes	Not weeded 5-7-02 RCC
	B.1.c	Revise Bechtel Drawing P-159 (if necessary)		\boxtimes	DEN 2002-0754 5-10.02 RCC
	B.1.f	Add Flowserve RO Drawing (98-16249) to PDS		\boxtimes	DCN 2002-0450 3-19-02 RCC
	B.1.h	Void working Drawing SK-MR-99-029*D		⊠ -	Travenittal Estimitted 5-7-22 RCC
	B.2	P.O 4500429416 closed		\boxtimes	Emil Sut 5-7-22 RCC
	B.4	Flowserve Component Manual 01708 updated		\boxtimes	Uplated 5-28-02 RCC
	B.10	Stress Analysis Report WE-100070 Addendum			ÁN.] to Ru 3.402 RCC
	B.10	WE Calculation No. N-91-031 Addendum			ANA to RUD 430-02 RCC
	B.10	WE Calculation No. N-91-032 Addendum	⊠		AND A to RWO 4-30-02 RCC
	B.14	Notify EPIX coordinator of mod.		\boxtimes	Emal wat 5-7-02 Bas
	B.17	Update DBD-01, Auxiliary Feedwater		\boxtimes	DBO UPLAR S-Lmithel 9-13-02 RCC
	C.2	Provide Permanent Label for 2RO-4003		\boxtimes	New Jakal andred/recoverd
-32	C.3	Install Temporary Label for 2RO-4003	⊠		Installed 4-19-22 Rec
	C.4	Update 2RO-4003 CHAMPS Record	□-		Volate rub mitted S-7-02 Rec
	C.6	Remove Material From Modification Bin		\boxtimes	Mod Bis Not Veed 5-2-22 REC
	H	TR01.103 reviewed and approved			Around 3-15-02 RCC
Į				- 🗌	
					
	<u> </u>				
	······				
	<u> </u>				
L	······		, — , —		

::~ ۰.

٠

•

. .

		Point	Beach	Nuclear P	lant			
10	CFR	50.59/72.4	48 SC	REENI	NG	(NEW	RUL	E)

~	
PICP.	

Title of Proposed A	Activity: <u>MR 9</u>	9-029*C/*D - A	UX. FEED W.	ATER PUMP 1/2	P-29 MINIMU	M FLOW	RECIRC. LINE
Associated Referen	nce(s) #:MR 9	9-029*C/*D, E	<u>WR 99-031, CI</u>	R 99-1391, ASME	B31.1, RCE 9	9-081, MR	99-029*A/*B
Prepared by:	Rob Chapr Name (Prin	nan nt)	-70	HCf Signature	Dat	e: <u>12</u>	-4-01
Reviewed by:	John P. Schr Name (Prin	oeder nt)	<u>Ja</u>	Z.P.A.L. Signature	Dat	e: <u>12</u>	-4-01

PART I (50.59/72.48) - DESCRIBE THE PROPOSED ACTIVITY AND SEARCH THE PLANT AND ISFSI LICENSING BASIS (Resource Manual 5.3.1)

- NOTE: The "<u>NMC 10 CFR 50.59 Resource Manual</u>" (Resource Manual) and <u>NEI 96-07, Appendix B, Guidelines for</u> <u>10 CFR 72.48 Implementation</u> should be used for guidance to determine the proper responses for 10 CFR 50.59 and 10 CFR 72.48 screenings.
- I.1 Describe the proposed activity and the scope of the activity being covered by this screening. (The 10 CFR 50.59/72.48 review of other portions of the proposed activity may be documented via the applicability and pre-screening process requirements in NP 5.1.8.) Appropriate descriptive material may be attached.

Engineering Work Request (EWR) 99-031 was initiated requesting the evaluation of high noise level and vibration present in the Auxiliary Feedwater (AF) pump recirculation lines during their operation in minimum recirculation mode. This evaluation had determined that the installed flow restricting orifices (ROs), are cavitating and causing excessive noise and vibration in the associated piping. In addition, Condition Report CR 99-1391 was initiated to address the issue of pinhole leaks in the socket welds which have developed at the existing ROs. To improve the socket weld's cycle fatigue response over standard ASME Code socket weld profile in vibration critical application the root cause evaluation RCE 99-081 recommended replacing the orifices to prevent cavitation, and increasing the size of the socket welds. This modification was already performed for the motor driven auxiliary feedwater pumps (P-38A/B) by MR 99-029*A/*B.

The purpose of the proposed modifications is to minimize piping line noise and vibration and preclude socket weld failure when operating the pump on minimum recirculation mode. MR 99-029*C and MR 99-029*D will replace the existing orifices 1RO-4003 and 2RO-4003 in the AF system with improved design orifices. In addition, portion of the AF piping associated with RO will be replaced to simplify the installation and to facilitate increasing the socket weld size. Piping will be replaced upstream of the orifice include some elbows up to and including the upstream weld on the AF pump recirculation line isolation valve 1AF-15 for pump 1P-29 and valve 2AF-53 for pump 2P-29.

The replacement ROs differ from presently installed ROs. The existing ROs have orifice plates to reduce the flow and pressure through the unit. The replacement ROs work in a similar manner except that control of flow and pressure drop is accomplished by directing the flow through the series of close-fitted cylindrical stages, each constructed with expansion holes and intersecting circumferential channels that restrict the flow. These cylinders are placed in a 600# class globe valve body with a valve stem and disk that allows adjustment of the flow setting after installation. This trim will not allow complete shutoff. The flow will be set to a nominal value of between 120 and 130 gpm, which is essentially the same as the existing orifice.

A seismic analysis and report, to determine that the orifice will operate during and after seismic event was determined by WE Seismic Qualification Group not to be required for these ROs. This determination was based on rugged design of the ROs body and pressure reducing component.

PBF-1515c Revision 0 10/24/01 The proposed modifications will meet design, material and construction standards of the existing installation. The implementation of the proposed modifications, will not affect the overall performance of the AF system, operation or function of the AF pumps 1P-29 and 2P-29 and the ability of AF system to perform its intended safety functions.

Post modification testing will include a visual exam (VT) of all replaced piping socket welds. Piping welds will be examined in accordance with ASME B31.1 – 1992. Performance of this exam is required by both the original piping specification, Bechtel M-78, and the original code of construction, USAS B31.1 - 1967. Additional NDE will be performed on the root welds for additional assurance of weld quality. B31.1 also requires that post modification testing include an initial service leak test at normal system operating pressure and temperature, which will be performed with the pump running. In addition, a functional test and verification of the flow through the replacement ROs will also be performed.

The proposed modification MR 99-029*D is scheduled to be installed during U2R25, and MR 99-029*C is scheduled to be installed during U1R27. These modifications will be installed while the unit is in Mode 4, 5 or 6, when the turbine driven AFW pumps 1P-29 and 2P-29 are not be required to be in service per LCO 3.7.5. Upon completion of each modification, the new installed RO will perform the same function as the existing orifices 1RO-4003 and 2RO-4003.

- I.2 Search the PBNP Current Licensing Basis (CLB) as follows: Final Safety Analysis Report (FSAR), FSAR Change Requests (FCRs) with assigned numbers, the Fire Protection Evaluation Report (FPER), the CLB (Regulatory) Commitment Database, the Technical Specifications (both Custom and Improved), the Technical Specifications Bases, and the Technical Requirements Manual. Search the ISFSI licensing basis as follows: VSC-24 Safety Analysis Report, the VSC-24 Certificate of Compliance, the CLB (Regulatory) Commitment Database, and the VSC-24 10 CFR 72.212 Site Evaluation Report. Describe the pertinent design function(s), performance requirements, and methods of evaluation for both the plant and for the cask/ISFSI as appropriate. Identify where the pertinent information is described in the above documents (by document section number and title). (Resource Manual 5.3.1 and NEI 96-07, App. B, B.2)
 - FPER, Auxiliary Feedwater System, Figure 6.6 4a.
 - FSAR Section 1.3, General Design Criteria
 - FSAR Section 10.1, Steam and Power Conversion System
 - FSAR Section 10.2, Auxiliary Feedwater System
 - FSAR Section 14.1.9, Loss of External Electric Load
 - FSAR Section 14.1.10, Loss of Normal Feedwater
 - FSAR Section 14.1.11, Loss of All AC Power to the Auxiliaries
 - FSAR Section 14.2.4, Steam Generator Tube Rupture
 - TS 3.7.5, AFW System

The flow restricting orifices for the turbine driven auxiliary feedwater pumps (1/2RO-4003) have the following design functions, as described in FSAR Section 10.2.

- They serve to restrict the recirculation flow for the pumps to ensure adequate auxiliary feedwater flow to the steam generators in the event that the minimum flow recirculation control valve (1/2AF-4002) fails to close.
- They ensure adequate flow and pressure drop through the auxiliary feedwater pumps when they are operated in retirculation mode, thus preventing low flow instabilities and excessive fluid temperatures.
- They passively maintain the auxiliary feedwater system pressure boundary integrity.
- I.3 Does the proposed activity involve a change to any Custom or Improved Technical Specification (ITS)? Changes to Technical Specifications require a License Amendment Request (Resource Manual Section 5.3.1.2).

Technical Specification Change :

🗌 Yes 🖾 No

Point Beach Nucl 10 CFR 50.59/72.48 SCRE

Point Beach Nuclear Plant 10 CFR 50.59/72.48 SCREENING (NEW RULE)	• SCR 2001-0981 Verify SCR number on all pages Page 3
If a Technical Specification change is required, explain what the change should be and why	it is required.
Does the proposed activity involve a change to the terms, conditions or specifications incor Certificate of Compliance (CoC)? Changes to a VSC-24 cask Certificate of Compliance red	porated in any VSC-24 cask quire a CoC amendment request.
🗌 Yes 🖾 No	
If a storage cask Certificate of Compliance change is required, explain what the change sho	uld be and why it is required.

	****	10 CFR 50.59 SCREENING						
	PART	II (50.59) - DETERMINE IF THE CHANGE INVOLVES A DESIGN FUNCTION (Resource Manual 5.3.2)					
	Compare the proposed activity to the relevant CLB descriptions, and answer the following questions:							
	YES	NO	QUESTION					
	\boxtimes		Does the proposed activity involve Safety Analyses or structures, systems and components (SSCs) credited in the Safety Analyses?					
	\boxtimes		Does the proposed activity involve SSCs that support SSC(s) credited in the Safety Analyses?					
			Does the proposed activity involve SSCs whose failure could initiate a transient (e.g., reactor trip, loss of feedwater, etc.) or accident, <u>OR</u> whose failure could impact SSC(s) credited in the Safety Analyses?					
	\mathbb{Z}		Does the proposed activity involve CLB-described SSCs or procedural controls that perform functions that are required by, or otherwise necessary to comply with, regulations, license conditions, orders or technical specifications?					
		\boxtimes	Does the activity involve a method of evaluation described in the FSAR?					
		\boxtimes	Is the activity a test or experiment? (i.e., a non-passive activity which gathers data)					
		\boxtimes	Does the activity exceed or potentially affect a design basis limit for a fission product barrier (DBLFPB)? (NOTE: If <u>THIS</u> questions is answered <u>YES</u> , a 10 CFR 50.59 Evaluation is required.)					
	·· · · ·	•	د د د هم کاری کاری کاری در چینه بر محمد می معموم و د					

If the answers to ALL of these questions are NO, mark Part III as not applicable, document the 10 CFR 50.59 screening in the conclusion section (Part IV), then proceed directly to Part V - 10 CFR 72.48 Pre-screening Questions.

If any of the above questions are marked <u>YES</u>, identify below the specific design function(s), method of evaluation(s) or DBLFPB(s) involved.

The flow restricting orifices for the turbine driven auxiliary feedwater pumps (1/2RO-4003) have the following design functions that are affected by MR 99-029*C/*D:

- They serve to restrict the recirculation flow for the pumps to ensure adequate auxiliary feedwater flow to the steam generators in the event that the minimum flow recirculation control valve (1/2AF-4002) fails to close.
- They ensure adequate flow and pressure drop through the auxiliary feedwater pumps when they are operated in recirculation mode, thus preventing low flow instabilities and excessive fluid temperatures.
- They passively maintain the auxiliary feedwater system pressure boundary integrity.

I.4

Point Beach Nuclear Plant 10 CFR 50.59/72.48 SCREENING (NEW RULE)

Verify SCR number on all pages Page 4

PART III (50.59) - DETERMINE WHETHER THE ACTIVITY INVOLVES ADVERSE EFFECTS (Resource Manual 5.3.3)

If <u>ALL</u> the questions in Part II are answered <u>NO</u>, then Part III is <u>NOT APPLICABLE</u>.

Answer the following questions to determine if the activity has an *adverse effect* on a design function. Any <u>YES</u> answer means that a 10 CFR 50.59 Evaluation is required; <u>EXCEPT</u> where noted in Part III.3.

III.1 CHANGES TO THE FACILITY OR PROCEDURES

YES NO QUESTIO

- Does the activity adversely affect the *design function* of an SSC credited in safety analyses?
- Does the activity adversely affect the method of performing or controlling the *design function* of an SSC credited in the safety analyses?

If any answer is <u>YES</u>, a 10 CFR 50.59 Evaluation is required. If both answers are <u>NO</u>, describe the basis for the conclusion (attach additional discussion as necessary):

The replacement of flow restricting orifices 1/2RO-4003 by MR 99-029*C/*D will not adversely affect their design functions. Although the new orifices are of a different type, they will perform the same functions to allow flow to maintain TDAFP operability when in recirculation mode and to restrict flow if the recirculation control valve fails open. The method of performing these functions is slightly different, and the capability will be added to adjust the flow, but this will not adversely affect these design functions. The new orifices will provide essentially identical flow through the recirculation line, but with improved flow characteristics that will prevent cavitation. The orifice bodies are designed to ASME standards and have ratings that exceed that of the auxiliary feedwater piping. Non-destructive examination of the new welds and functional testing of the orifice will ensure that all design basis requirements are met.

These orifices are not explicitly required in an accident analysis to be able to pass service water, since the recirculation control valve would be closed when the pump is aligned to the steam generator. However, it is possible that when the pump is aligned to the service water system supply after the condensate storage tanks have been drained, service water could be pumped through the recirculation lines. To preclude the chance of clogging the orifice trim, the flow is directed from the outside of the stages inward. The holes in the outer stage are the smallest, and they get progressively larger in the inner stages. This causes the largest differential pressure to exist at the outer stages at locations with the smallest holes, which will reduce the potential for debris accumulation inside the orifice.

III.2 CHANGES TO A METHOD OF EVALUATION

(If the activity does not involve a method of evaluation, these questions are 🛛 NOT APPLICABLE.)

- YES NO QUESTION
 - Does the activity use a revised or different method of evaluation for performing safety analyses than that described in the CLB?

Does the activity use a revised or different method of evaluation for evaluating SSCs credited in safety analyses than that described in the CLB?

If any answer is <u>YES</u>, a 10 CFR 50.59 Evaluation is required. If both answers are <u>NO</u>, describe the basis for the conclusion (attach additional discussion, as necessary).



Point Beach Nuclear Plant	
10 CFR 50.59/72.48 SCREENING	(NEW RULE)

ŧ

-	
2	

TESTS OR EXPERIMENTS

If the activity is not a test or experiment, the questions in III.3.a and III.3.b are X NOT APPLICABLE.

a. Answer these two questions first:

YES	NO

П

QUESTION

Is the proposed test or experiment bounded by other tests or experiments that are described in the CLB?

Are the SSCs affected by the proposed test or experiment isolated from the facility?

If the answer to <u>BOTH</u> questions in V.3.a is <u>NO</u>, continue to III.3.b. If the answer to <u>EITHER</u> question is <u>YES</u>, then describe the basis.

b. Answer these additional questions <u>ONLY</u> for tests or experiments which do <u>NOT</u> meet the criteria given in III.3.a above. If the answer to either question in III.3.a is <u>YES</u>, then these three questions are **NOT APPLICABLE**.

YES	NO	QUESTION
		Does the activity utilize or control an SSC in a manner that is outside the reference bounds of the design bases as described in the CLB?
		Does the activity utilize or control an SSC in a manner that is inconsistent with the analyses or descriptions in the CLB?
		Does the activity place the facility in a condition not previously evaluated or that could affect the capability of an SSC to perform its intended functions?

If any answer in III.3.b is <u>YES</u>, a 10 CFR 50.59 Evaluation is required. If the answers in III.3.b are <u>ALL NO</u>, describe the basis for the conclusion (attach additional discussion as necessary):

Part IV - 10 CFR 50.59 SCREENING CONCLUSION (Resource Manual 5.3.4).

Check all that apply:

A 10 CFR 50.59 Evaluation is \Box required or \boxtimes NOT required.

A Point Beach FSAR change is required or X NOT required. If an FSAR change is required, then initiate an FSAR Change Request (FCR) per NP 5.2.6.

A Regulatory Commitment (CLB Commitment Database) change is \square required or \boxtimes NOT required. If a Regulatory Commitment Change is required, initiate a commitment change per NP 5.1.7.

A Technical Specification Bases change is required or X NOT required. If a change to the Technical Specification Bases is required, then initiate a Technical Specification Bases change per NP 5.2.15.

A Technical Requirements Manual change is i required or NOT required. If a change to the Technical Requirements Manual is required, then initiate a Technical Requirements Manual change per NP 5.2.15.

(]1.3

TESTS OR EXPERIMENTS

If the activity is not a test or experiment, the questions in III.3.a and III.3.b are X NOT APPLICABLE.

a. Answer these two questions first:

YES	NO	QUESTION
		Is the proposed test or experiment bounded by other tests or experiments that are described in the CLB?

 ······

Are the SSCs affected by the proposed test or experiment isolated from the facility?

If the answer to <u>BOTH</u> questions in V.3.a is <u>NO</u>, continue to III.3.b. If the answer to <u>EITHER</u> question is <u>YES</u>, then describe the basis.

b. Answer these additional questions <u>ONLY</u> for tests or experiments which do <u>NOT</u> meet the criteria given in III.3.a above. If the answer to either question in III.3.a is <u>YES</u>, then these three questions are **NOT APPLICABLE**.

YES	NO	QUESTION
□.		Does the activity utilize or control an SSC in a manner that is outside the reference bounds of the design bases as described in the CLB?
		Does the activity utilize or control an SSC in a manner that is inconsistent with the analyses or descriptions in the CLB?
		Does the activity place the facility in a condition not previously evaluated or that could affect the capability of an SSC to perform its intended functions?

If any answer in III.3.b is <u>YES</u>, a 10 CFR 50.59 Evaluation is required. If the answers in III.3.b are <u>ALL NO</u>, describe the basis for the conclusion (attach additional discussion as necessary):

Part IV - 10 CFR 50.59 SCREENING CONCLUSION (Resource Manual 5.3.4).

Check all that apply:

A 10 CFR 50.59 Evaluation is \Box required or \boxtimes NOT required.

A Point Beach FSAR change is required or 🛛 NOT required. If an FSAR change is required, then initiate an FSAR Change Request (FCR) per NP 5.2.6.

A Regulatory Commitment (CLB Commitment Database) change is \Box required or \boxtimes NOT required. If a Regulatory Commitment Change is required, initiate a commitment change per NP 5.1.7.

A Technical Specification Bases change is required or NOT required. If a change to the Technical Specification Bases is required, then initiate a Technical Specification Bases change per NP 5.2.15.

A Technical Requirements Manual change is irrequired or NOT required. If a change to the Technical Requirements Manual is required, then initiate a Technical Requirements Manual change per NP 5.2.15.

Point Beach Nuclear Plant 10 CFR 50.59/72.48 SCREENING (NEW RULE) · SCR _2001-0981

Verify SCR number on all pages Page 6

•

A A			10 CFR 72.48 SCREENING
	NOTE	• NFI 96.	07 Appendix B. Guidelines for 10 CFR 72 48 Implementation should be used for guidance to determine the
	NOIL	proper 1	responses for 72.48 screenings.
	PART	' V (72.48)	- 10 CFR 72.48 INITIAL SCREENING QUESTIONS
	Part V	determine	s if a full 10 CFR 72.48 screening is required to be completed (Parts VI and VII) for the proposed activity.
	YES	NO .	QUESTION
		⊠.	Does the proposed activity involve <u>IN ANY MANNER</u> the dry fuel storage cask(s), the cask transfer/transport equipment, any ISFSI facility SSC(s), or any ISFSI facility monitoring as follows: Multi-Assembly Sealed Basket (MSB), MSB Transfer Cask (MTC), MTC Lifting Yoke, Ventilated Concrete Cask (VCC), Ventilated Storage Cask (VSC), VSC Transporter (VCST), ISFSI Storage Pad Facility, ISFSI Storage Pad Data/Communication Links, or PPCS/ISFSI Continuous Temperature Monitoring System?
		\boxtimes	Does the proposed activity involve <u>IN ANY MANNER</u> SSC(s) installed in the plant specifically added to support cask loading/unloading activities, as follows: Cask Dewatering System (CDW), Cask Reflood System (CRF), or Hydrogen Monitoring System?
		⊠	Does the proposed activity involve <u>IN ANY MANNER</u> SSC(s) needed for plant operation which are also used to support cask loading/unloading activities, as follows: Spent Fuel Pool (SFP), SFP Cooling and Filtration (SF), Primary Auxiliary Building Ventilation System (VNPAB), Drumming Area Ventilation System (VNDRM), RE-105 (SFP Low Range Monitor), RE-135 (SFP High Range Monitor), RE-221 (Drumming Area Vent Gas Monitor), RE-325 (Drumming Area Exhaust Low-Range Gas Monitor), PAB Crane, SFP Platform Bridge, Truck Access Area, or Decon Area?
		\boxtimes	Does the proposed activity involve a change to <u>Point Beach CLB</u> design criteria for external events such as earthquakes, tornadoes, high winds, flooding, etc.?
		\boxtimes	Does the activity involve plant heavy load requirements or procedures for areas of the plant used to support cask loading/unloading activities?
		\boxtimes	Does the activity involve any potential for fire or explosion where casks are loaded, unloaded, transported or stored?
•	If <u>AN</u> Part V	IY of the P /I and Part	art V questions are answered <u>YES</u> , then a full 10 CFR 72.48 screening is required and answers to the questions in VII are to be provided. If <u>ALL</u> the questions in Part V are answered <u>NO</u> , then check Parts VI and VII as not white Part VIII to document the conclusion that no.10 CFR 72.48 evaluation is required.
	shbu		AND DESERVOIR THE CHANCE INTO MES A SEEL I CENSING BASIS DESIGN FUNCTION
•	PAR	1 11(/24	a) - DETERMINE IF THE CHANGE INVOLVES A ISTSI MCENSING BASIE 2201011 ONOTION
	(If <u>A</u>)	<u>LL</u> the que	stions in Part V are \underline{NO} , then Part VI is $ \times $ NOT APPLICABLE.)
	Com	pare the pro	oposed activity to the relevant portions of the ISFSI licensing basis and answer the following questions:
i	YES	NO	QUESTION
•			Does the proposed activity involve cask/ISFSI Safety Analyses or plant/cask/ISFSI structures, systems and components (SSCs) credited in the Safety Analyses?
			Does the proposed activity involve plant, cask or ISFSI SSCs that support SSC(s) credited in the Safety Analyses?
			Does the proposed activity involve plant, cask or ISFSI SSCs whose function is relied upon for prevention of a radioactive release, <u>OR</u> whose failure could impact SSC(s) credited in the Safety Analyses?
			Does the proposed activity involve cask/ISFSI described SSCs or procedural controls that perform functions that are required by, or otherwise necessary to comply with, regulations, license conditions, CoC conditions, or orders?
Ċ	🔲		Does the activity involve a method of evaluation described in the ISFSI licensing basis?
			Is the activity a test or experiment? (i.e., a non-passive activity which gathers data)

Verify SCR number on all pages Page 7



Does the activity exceed or potentially affect a cask design basis limit for a fission product barrier (DBLFPB)? (NOTE: If <u>THIS</u> questions is answered <u>YES</u>, a 10 CFR 72.48 Evaluation is required.)

If the answers to <u>ALL</u> of these questions are <u>NO</u>, mark Parts VII as not applicable, and document the 10 CFR 72.48 screening in the conclusion section (Part VIII).

If any of the above questions are marked <u>YES</u>, identify below the specific design function(s), method of evaluation(s) or DBLFPB(s) involved.

PART VII (72.48) - DETERMINE WHETHER THE ACTIVITY INVOLVES ADVERSE EFFECTS (NEI 96-07, Appendix B, Section B.4.2.1)

(If <u>ALL</u> the questions in Part V or Part VI are answered <u>NO</u>, then Part VII is NOT APPLICABLE.)

Answer the following questions to determine if the activity has an *adverse effect* on a design function. Any <u>YES</u> answer means that a 10 CFR 72.48 Evaluation is required; <u>EXCEPT</u> where noted in Part VII.3.

VII.1 Changes to the Facility or Procedures

- YES NO QUESTION
 - Does the activity adversely affect the *design function* of a plant, cask, or ISFSI SSC credited in safety analyses?
 - Does the activity adversely affect the method of performing or controlling the *design function* of a plant, cask, or ISFSI SSC credited in the safety analyses?

If any answer is <u>YES</u>, a 10 CFR 72.48 Evaluation is required. If both answers are <u>NO</u>, describe the basis for the conclusion (attach additional discussion, as necessary):

VII.2 Changes to a Method of Evaluation

.. (If the activity does not involve a method of evaluation, these questions are ... NOT APPLICABLE.) ---

YES NO OUESTION	YES	NO	OUESTION
-----------------	-----	----	----------

ι

П

 \Box

- Does the activity use a revised or different method of evaluation for performing safety analyses than that described in a cask SAR?
- Does the activity use a revised or different method of evaluation for evaluating SSCs credited in safety analyses than that described in a cask SAR?

If any answer is <u>YES</u>, a 10 CFR 72.48 Evaluation is required. If both answers are <u>NO</u>, describe the basis for the conclusion (attach additional discussion, as necessary):

		Point	Beach N	luclear Plant		
10	CFR 5	50.59/72	.48 SCI	REENING	(NEW	RULE)

I.3	Tests	٥r	Experiments
-----	-------	----	-------------

i

(If the activity is not a test or experiment, the questions in VII.3.a and VII.3.b are [] NOT APPLICABLE.)

a. Answer these two questions first:

YES	NO.	QUESTION
		Is the propos

Is the proposed test or experiment bounded by other tests or experiments that are described in the cask ISFSI licensing basis?

 Are the SSCs affected by the proposed test or experiment isolated from the cask(s) or ISFSI facility?

If the answer to both questions is <u>NO</u>, continue to VII.3.b. If the answer to <u>EITHER</u> question is <u>YES</u>, then briefly describe the basis.

b. Answer these additional questions <u>ONLY</u> for tests or experiments which do not meet the criteria given in VII.3.a above. If the answer to either question in VII.3.a is <u>YES</u>, then these three questions are **NOT APPLICABLE**:

YES	NO	QUESTION .
		Does the activity utilize or control an SSC in a manner that is outside the reference bounds of the design bases as described in the ISFSI licensing basis?
		Does the activity utilize or control a plant, cask or ISFSI facility SSC in a manner that is inconsistent with the analyses or descriptions in the ISFSI licensing basis?
		Does the activity place the cask or ISFSI facility in a condition not previously evaluated or that could affect the capability of a plant, cask, or ISFSI SSC to perform its intended functions?

If any answer in VII.3.b is <u>YES</u>, a 10 CFR 72.48 Evaluation is required. If the answers are all <u>NO</u>, describe the basis for the conclusion (attach additional discussion as necessary):

PART VIII - DOCUMENT THE CONCLUSION OF THE 10 CFR 72.48 SCREENING

Check all that apply:

A 10 CFR 72.48 Evaluation is required or NOT required. Obtain a screening number and provide the original to Records Management regardless of the conclusion of the 50.59 or 72.48 screening.

A VSC-24 cask Safety Analysis Report change is required or NOT required. If a VSC-24 cask SAR change is required, then contact the Point Beach Dry Fuel Storage group supervisor.

A Regulatory Commitment (CLB Commitment Database) change is required or NOT required. If a Regulatory Commitment Change is required, initiate a commitment change per NP 5.1.7.

A change to the VSC-24 10 CFR 72.212 Site Evaluation Report is required or NOT required. If a VSC-24 10 CFR 72.212 Site Evaluation Report change is required, then contact the Point Beach Dry Fuel Storage group supervisor.

NUCLEAR POWER BUSINESS UNIT

DESIGN VERIFICATION NOTICE

Title of	Document AUX FEED WATER PUMP 2P-2	29 MINIMUM FLOW RECIRC LINE C	DRIFICE		
Docum	nt NoMR 99-029*D	Rev. <u>0</u> Date	12/04/2	001	
Design	Verification Method: Design Review	Alternate Calcs		Qualificatio	on Testing
UPDAT	ES TO THIS FORM COVERED BY EXISTING	3 SCR 97-410	· · · · · · · · · · · · · · · · · · ·		
REVI	WER CHECKLIST CONSIDERATION	IS:			
			<u>Yes</u>	No	<u>N/A</u>
1.	Were the inputs correctly selected and incorpora	ated into design?	\checkmark		
2.	Are assumptions necessary to perform the design reasonable? Where necessary, are the assumption reverifications when the detailed design activities	n activity adequately described and ons identified for subsequent es are completed?	~		
3.	Are the appropriate quality and quality assurance	e requirements specified?	~		
4.	Are the applicable codes, standards, and regulat addends properly identified and are their require	ory requirements including issue and ements for design met?	~		
5.	Have applicable construction and operating exp	erience been considered?	~		
6.	Have the design interface requirements been sat	isfied?	\checkmark		
7.	Was an appropriate design method used?		~		
8.	Is the output reasonable compared to inputs?		<u> </u>	•	
9.	Are the specified parts, equipment and processe	es suitable for the required application?			
10.	Are the specified materials compatible with each conditions to which the material will be exposed	h other and the design environmental d?	~		
) 11.	Have adequate maintenance features and require	ements been specified?			\geq
12.	Are accessibility and other design provisions ad maintenance and repair?	lequate for performance of needed	~		
13.	Has adequate accessibility been provided to per be required during the plant life?	form the in-service inspection expected to	V		
14.	Has the design properly considered radiation ex	posure to the public and plant personnel?	$\overline{}$		
15.	Are the acceptance criteria incorporated in the c verification that design requirements have been	design documents sufficient to allow satisfactorily accomplished?		**************************************	
16.	Have adequate pre-operational (IST, PMT, ISI, and inspection requirements been appropriately	snubber, etc.), subsequent periodic test, specified, including acceptance criteria?	\checkmark		
17.	Are adequate handling, storage, cleaning, and sl	hipping requirements specified?			~
18.	Are adequate identification requirements specifi	ied?	~		<u> </u>
19.	Are requirements for records adequately specifi	ied?	~		
· 20.	Will the change remain within the analyzed or s equipment?	specified capabilities of any affected	·~		
21.	Has a field inspection been done?		~	<u></u>	
22.	Have impacts on other systems been identified?	?	<u> </u>	<u></u>	<u> </u>
COMN	IENTS: X None Attach	hed (Use Form PBF-1633)			
Design	Prepared By: Alex Foltynowicz RCC	for AF per envil D	ate <u>12</u>	-4-01	
Review	red By: Rob Chapman	fr D	ate <u>12</u>	-4-01	
Approv	al By: USThmak	D	ate <u>12</u>	4-01	<u> </u>

~ .

.

Point Beach Nuclear Plant DESIGN INPUT CHECKLIST

dification or Temporary Modification Number: 99-029*D

Title: AUX. FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC. LINE ORIFICE.

INSTRUCTIONS: Consider the basic functions of each structure, system, and component, (SSC), when answering the questions. The designer shall check the appropriate box for each design input or section. All inputs that apply to the design shall be explained. The explanation may be documented on this checklist or in the design summary. The reviewer shall review the checklist, and any differences between the designer and the reviewer should be addressed. This checklist addresses most design concerns, but is not all encompassing. Any additional concerns should be addressed in the design summary.

(Updates to this form covered by SCR 97-411.)

			APPLIES T	O DESIGN
			YES	NO
· A.	Ge	eneral codes, standards, regulatory requirements, and design criteria.		
	1.	Are any of the PBNP FSAR general design criteria applicable? (Reference FSAR, Section 1.3. Identify and address design criteria as appropriate.)		
	2.	Are any design requirements contained in commitments affected? (Reference CLB database and the Safety Evaluation/Screening associated with this change.)	·⊠	
		See 50.59 Screening SCR 2001-0981		
Ì	3.	Meet State of Wisconsin Administrative Code requirements? (Refer to ILHR 41.42, PSC 114, and other sections as appropriate for requirements.)		\boxtimes
	4.	Meet existing DNR permits or require DNR approval? (Contact WE Environmental Department.)		
· •	5.	Consider the effect of design and accident conditions, such as pressure, temperature, fluid chemistry, and radiation on components, including internal elastomers and material coating compatibility. (Changes in design parameters may impact Environmental Qualification.)		
	6.	Incorporate new types/models of equipment not presently used at PBNP?		
	7.	Affect accessibility of any equipment? Consider interim conditions, future maintenance, and in-service inspection. (Reference CIMs and drawings for manufacturer's clearance requirements.)		\boxtimes
	8.	Require breaching a High Energy Line Break (HELB) barrier? (Reference NP 8.4.16) If yes, EQ engineer review required.		\boxtimes
* ~ *	9.	Consider operating experience from PBNP and industry events. (Reference DG-G04 for operating experience reviews and NPRDS, NODIL, CHAMPS, INPO Keywords, or other databases.)		

	DESIGN INDUT CHECKI IST -	APPLIES TO DESIGN		
10. Consider failure effects on structures, systems, and components: (Failure analysis is only required for	YES	NO		
10.	Cons mair	sider failure effects on structures, systems, and components: (Failure analysis is only required for stenance rule systems. Contact the NSA-PSA group for guidance and scope.)		×
	а.	The design discusses those events/accidents which the system/components are to withstand?		
	b.	The failure effect of the system/components: (Reference the NSA-PSA Group, Operating Experience, & IEEE-352-1975.)		
		 How components may fail, and the effect of the failure on the system and related systems? What mechanisms might produce failures? How a failure would be detected? What provisions are included to compensate for the failure? 		
11.	Doe	s the design add or remove components in containment?		\boxtimes
	a.	Change the amount of exposed aluminum in containment? (Reference DG-G07 and FSAR Section 5.6.)		
	b.	Change the amount of exposed zinc in containment? (Reference DG-G07.)		
	c.	Introduce materials into containment that could affect sump performance or lead to equipment degradation? (Reference DG-G07.)		· 🗌 ·
	d.	Decrease free volume of containment?		
	e.	Require addition or modification of a containment penetration boundary? (Consult the containment system engineer.)		
ሙዲሮ ይማርም አማርጅታት በኳኔ ነን።	f.	Require painting in containment? (Reference MI 36.3.)		
12.	Con	sider potential for fuel failure?		
	a.	Affect fuel handling equipment?		
	Ъ.	Present the potential for introducing foreign material/debris into the RCS or connected systems?		
	c.	Affect core barrel flow patterns? ("Baffle jetting" concerns)		

.

.

.

	DESIGN INDUT CHECKI IST		APPLIES TO DESIGN		
	DESIGN INPUT CHECKLIST	YES	NO		
M	echanical requirements. (Contact Mechanical Design Engineering for guidance.)		l		
1.	Have applicable ASME Boiler & Pressure Vessel codes or other standards been identified? (Reference the applicable specification. In addition, safety-related components should be reconciled with DG-M16, and QA components should be reconciled with ANSI N45.2.)				
2.	Affect or add components/systems to ASME Section XI class 1, 2, or 3 equipment? (Reference PBNP CHAMPS, CBD drawings, and IST Coordinator. If YES, follow NP 7.2.5, Repair/Replacement Program.)				
3.	Require State of Wisconsin Administrative Code permits/approvals? (Reference NP 7.4.9, Wisconsin Administrative Code for Boilers and Pressure Vessels or the Authorized Inspector.)				
4.	Consider component performance requirements such as capacity, rating, output?				
5.	Consider hydraulic requirements such as pump net positive suction heads, allowable pressure drops, allowable fluid velocities and pressures, valve trim requirements, packing/seal requirements?				
6.	Provide vents, drains, and sample points to accommodate operational, maintenance and testing needs?		\boxtimes		
<u>ېر</u>	Require service water? (Both essential and nonessential service water loads are modeled, and load changes must be evaluated. Contact the SWAP Coordinator.)				
8.	Require the addition of check valves? (Reference DG-M13 for selection guidance.)				
9. 	Require and evaluate any additional loading on instrument or service air, circ, fire protection, or Themineralized water, or other system?				
10	. Evaluate any additional loading on HVAC systems or affect ventilation flow during or after installation? (This will require an EQ review for potential updates to EQSS, EQML & EQMR.)				
11	. Affect ventilation barriers, including containment, primary auxiliary building, or control room?		\boxtimes		
12	. Require insulation? (Reference WE specification PB-485 for insulation, and NP 1.9.10 for asbestos control.)				
13	. Require lubrication? (Reference Lubrication Manual.)		\boxtimes		

مدرا

٠

		. APPLIES T	O DESIGN
	DESIGN INPUT CHECKLIST	YES	NO
14.	Require an independent means of pressure relief? (Reference B31.1.)		\boxtimes
15.	Affect the assigned system design pressure or temperature?	\boxtimes	
16.	Involve cobalt-laden materials into the RCS or into systems that supply the RCS? (Reference NP 4.2.29, "Source Term Reduction Program.")		
17.	Are new materials and their coatings/plating compatible with system chemistry and disposal systems (NP 8.4.15)?		
18.	Affect embedded or buried piping?		
C. Fl	ectrical requirements (Contact Electrical Design Engineering for guidance.)		
1.	Consider design conditions such as ampacity, voltage drop?		\boxtimes
. 2.	Consider component and system performance requirements, such as current, voltage, or power?		⊠ .
3 .	Consider redundancy, diversity and separation requirements of structures, systems and components? (Reference DG-E07 for separation of electrical circuits.)		
4.	Comply with protective relaying requirements of equipment and systems?		\boxtimes
5.	Selection of overcurrent devices for proper protection and coordination? (Reference DG-E04 for selection of molded case circuit breakers.)		X
6.	Affect available fault current at any bus?		\boxtimes
7.	Assure that all added cables meet fire retardancy requirements? (Reference FPER Section 4.1.8, IEEE 383.)		
8.	Be compatible with existing electrical insulation and wiring?		\boxtimes
9.	Affect ampacity of existing cables?		\boxtimes
. 10.	Maintain UL (or equivalent) listings?		\boxtimes

· ...

•

	 DESIGN INPUT CHECKLIST 11. Alter the voltage harmonic distortion content or change the non-linear loading (i.e., the addition switching power supplies, the alteration of the circuit's power factor, etc.) on a vital or sensitive instrument bus? 12. Add new raceways? (Reference DG-E03 for electrical raceway sizing and DG-E02.) 13. Add cables to existing electrical raceways? 	. APPLIES TO DESIGN		
	DESIGN INPUT CHECKLIST	YES	NO	
J ^{II.}	Alter the voltage harmonic distortion content or change the non-linear loading (i.e., the addition of switching power supplies, the alteration of the circuit's power factor, etc.) on a vital or sensitive instrument bus?			
12.	Add new raceways? (Reference DG-E03 for electrical raceway sizing and DG-E02.)		\boxtimes	
13.	Add cables to existing electrical raceways?		\boxtimes	
14.	Be routed through fire wrapped raceways?		\boxtimes	
15.	Affect the station grounding or lightning protection system?			
16.	Make any vital circuit susceptible to ground?			'
17.	Affect emergency diesel loading? (Reference DG-E06 for diesel load change evaluation.)			
18.	Add more station battery loading?		\boxtimes	
(j).	Add load to a vital bus?			
20.	Add load to a non-vital bus?		\boxtimes	
21.	. Be compatible with service transformer capacity?			
22	. Consider electromagnetic interference between new/existing equipment and electromagnetic coupling interactions between circuits?		· 🔀	-121
23	. Affect embedded conduits or buried cables, including the station grounding system?		\boxtimes	

1 . مترد به

٠

.

٠.

.

.

DESIGN INDUT OFFICIA IST	APPLIES TO DESIGN		
	DESIGN INPUT CHECKLIST		NO
In 1.	strumentation and control requirements. (Contact I&C Design Engineering for guidance.) Consider design conditions such as pressure, temperature, fluid chemistry, amperage, voltage?		
2.	Have the instruments been properly selected for the application?		\boxtimes
3.	Have sufficient instruments for operators to monitor the process?		
4.	Have appropriate instrument scales?		
5.	Have the instruments, control switches, and indicating devices been appropriately located for human factors (both for operations and maintenance)? (Reference DG-G01.)		
6.	Have alarms for off-normal conditions?		
7.	Be capable of or require remote and/or local operation?		
8.	Be capable of or require manual and/or automatic operation?		
9.	Require calibration and maintenance requirements for the instruments to be specified?		
. 10	. Have specified the instruments with proper range and accuracy?		
11 	Address solid state vulnerability to RFI?		₩ *** } ¢ (my2z)ti#Cou 4***
12	. Consider software and programming/programmable settings of digital or electronic equipment?		\boxtimes
13	. Affect logic circuits or associated GL 96-01 review/required testing? Contact I&C System Engineering group.	· 🛛	

L

م الأرا

•

.

.

---- X. .

. • ·

	DESIGN INPUT CHECKI IST	APPLIES TO DESIGN		
	DESIGN INFUT CHECKLIST	YES	NO	
St	ructural requirements. (Contact Civil Design Engineering for guidance.)			
1.	Affect or scope seismically qualified equipment (Class 1 or 2) and therefore require a seismic qualification evaluation? (Reference NP 7.7.2, "Seismic Qualification of Equipment.")			
2.	Affect seismic boundaries?			
3.	Affect stress calculations of pipe? (Reference DG-M09.)	\boxtimes		
4.	Affect the loading or require changes to existing equipment foundations?			
5.	Affect wall stress calculations for pressurized concrete cubicles or structures?			
6.	Require analysis of non-seismic components placed over or adjacent to seismic components?		\boxtimes	
7.	Add items which span between two separate seismic areas/buildings? (The effect of the relative movement must be addressed.)			
8 .	Require clearance review for seismic movement or thermal expansion considerations?			
9.	Require a floor or wall loading analysis? (Reference Bechtel C-dwgs.)		\boxtimes	
10.	Require the addition of new supports, hangers, or foundations or add weight to or between existing supports, hangers, embeds, or foundations during installation or post-installation? (Reference DG-M09 and DG-M10 for pipe support.)			
11.	Add new or add load to seismically qualified raceways? (Reference NP 7.7.2, "Seismic Qualification of Equipment.")			
12.	Modify, attach to, or locate within the proximity of masonry block walls? (Reference IEB 80-11 Block Wall Program.)			
13.	Require core drills, expansion anchors, or re-bar cuts? (Reference DG-C01 for expansion anchor design and installation.)			
14.	Create an external or internal missile hazard?		\boxtimes	
·5.	Consider wind and storm loading on external structures?		\boxtimes	

. *.*.

	DESIGN INDUT CHECKI IST		APPLIES TO DESIGN	
DESIGN INPUT CHECKLIST		YES	NO	
6 .	Requ	ire protection from high energy line break jet? (Refer to FSAR Appendix A.2.)		\boxtimes
17.	Cons	ider dynamic requirements such as live loading, vibration, and shock/impact?		\boxtimes
F. Pr	ngran	19		
1.	ASM	E Section XI and QA considerations:		
	а.	Affect IST acceptance criteria or calculations? (Contact Component Engineering.)		\boxtimes
	ь.	Require classification of new components? (Reference DG-G06 for system, component, and part classification.)		
	c.	Affect QA-scope systems or boundaries? (Contact Site Programs Engineering Support for Q-List.)	⊠	
	đ.	Require special personnel/equipment qualifications not proceduralized at PBNP (i.e., underwater welding)?		
	с.	Require material certification or other certification to ensure quality equal to or better than the affected SSC? (These requirements need to be specified in the specification or purchase requisition.)		
	f.	Have all design requirements, such as pressure or current rating, been reviewed against lot descriptions or been specified on purchase requisitions/specifications?		
2.	Fire	protection considerations:	antes a ser e ser e ser e	3 7-
	a.	Affect access to a fire zone, fire protection equipment or Appendix R safe shutdown equipment, including manual fire fighting activities? (Reference Section 5.2.1 of Design Guide DG-F01)		
	Ъ.	Affect a fire barrier? (Reference NP 8.4.11 and Fire Barrier Drawings WE PBC-218 Sheets 1-20, Section 5.2.2 of Design Guide DG-F01)		
	C.	Affect a fire protection system or its performance? (Reference Section 5.2.3 of Design Guide DG-F01)		
	d.	Increase or decrease permanent combustible loading in a room? (Reference Section 5.2.4 of Design Guide DG-F01)		
~_~				

•

- ; - •

`

a- 34

		DESIGN INPUT CHECKLIST		APPLIES TO DESIGN	
				NO	
Ø	е.	Based on Section 2 and Appendix A of the SSAR, will the change add to, delete from, or affect the performance of safe shutdown systems or equipment? (Reference Section 5.2.5.1 of Design Guide DG-F01)			
	f.	Based on Sections 3, 4, and Appendix C of the SSAR, will the change affect a cable associated with safe shutdown equipment, a safe shutdown power supply, or the physical location of a safe shutdown cable? (Reference Section 5.2.5.2 of Design Guide DG-F01)			
	g.	Based on Table 1-1, Section 5 and Appendix D of the SSAR, will the change affect fire area analysis and compliance with Appendix R separation criteria or the conditions of an approved Appendix R exemption for any PBNP Fire Area? (Reference Section 5.2.5.3 of Design Guide DG-F01, Table 3.2-2 of DBD T-40)			
	h.	Will the change add, remove, or affect the performance of any emergency lighting required for compliance with Section III.J of Appendix R? (Reference Section 5.2.6 of Design Guide DG-F01)			
	i.	Will the change add, remove, or affect the performance of any plant communications system relied upon for fire fighting or safe plant shutdown? (Reference Section 5.2.7 of Design Guide DG-F01)			
S	j.	Will the change affect the Reactor Coolant Pump Oil Collection System? (Reference Section 5.2.8 of Design Guide DG-F01)			
	k.	Will the change affect the Fire Protection Manual?			
×	1.	Will the change affect any of the Supporting Documents listed in the SSAR (Section 6.0) or the FHAR (Section 4.0)?			
If any of the questions a through j are answered "yes", an evaluation must be performed using the applicable sections of the FPCC checklist, PBF-2060 per Section 5 of Design Guide DG-F01.					
3. Flooding protection considerations:					
	A flooding analysis should be performed if any of the following questions are applicable and answered ves. (Reference Section 4.3 of DG-C02.)				
	a.	Modify potential flooding sources or add new potential flooding sources to a flood zone and thereby increase the direct and/or indirect flooding vulnerability of essential equipment?			
	b.	Degrade existing flood barriers or flood mitigation features providing unanalyzed pathway for flooding to propagate? (Reference Section 3.2 of DG-C02.)			

.

- 4

.

	DESIGN INPUT CHECKLIST		APPLIES TO DESIGN		
			YES	NO	
	c.	Involve the opening of potential flood sources anywhere at the station? (Installation procedures need to address inadvertent flooding. Reference DG-C02, Section 4.4.)	\boxtimes		
	d.	Reduce the capacity to isolate or cope with flooding? (Reference Sect. 4.2 of DG-C02.)			
	е.	Change plant drainage/backfill requirements?			
	f.	Locate essential equipment or supporting systems where it would be susceptible to flooding? (Flooding conditions may also impact Environmental Qualification.)		⊠	
4.	Envir	ronmental considerations:			
	a.	Be subject to adverse environmental conditions during storage or construction? (Reference NP 9.5.2.)			
	b.	Require freeze protection or affect existing freeze protection?			
	с.	Locate safety-related or post accident monitoring equipment in a HARSH environment? (Reference NP 7.7.1.)			•
0	d.	Require Environmental Qualification (EQ)? (Reference NP 7.7.1 for EQ qualification.)		\boxtimes	
	e.	Be attached to an EQ system/component? (This will require an EQ review for potential updates to EQSS, EQML & EQMR. Reference EQ master list.)			
1984	f.	Change environmental parameters (e.g., pressure, temperature, radiation, humidity)? (Reference			مريد ک
5.	Radia Guid	ation Protection (RP) and ALARA considerations: (Reference DG-G03, "ALARA Consideration eline for Design & Installation.)			
	The a consi	areas mentioned below are normally within the RCA, but radiological concerns should be dered for SSC outside the RCA also.			
	а.	Affect any SSC in an RWP required area, a contaminated area, or a radiation area, including opening of a system that may be a radiological concern?			
		L Contraction of the second seco			
	b.	Will the change generate excessive radwaste or highly radioactive/contaminated waste?		\boxtimes	
	с.	Remove any plant equipment from a potentially contaminated system (including BOP systems)?		\boxtimes	

21

		DESIGN INPUT CHECKLIST		APPLIES TO DESIGN	
				NO	
Ð	d.	Result in an anticipated increase in operational or maintenance exposures? (Consider equipment rearrangement to reduce plant life dose?)		Ż	
	с.	Result in an expected exposure of greater than 1 Rem for any individual during installation of the change?			
	f.	Result in an anticipated collective exposure of greater than 2 Rem for the installation of the change?		⊠	
	If qu (Ref	estions d, e, or f apply and are answered yes, then an ALARA review shall be performed. erence NP 4.2.3, "ALARA Review Procedure.")			
6.	Cher	nistry considerations:			
	a.	Require or affect established chemistry limits? (Contact system engineer and review chemistry procedures.)			
	b.	Require any routine chemical analyses? (Contact system engineer and review chemistry procedures.)			
<u> </u>	c.	Require chemical additives? (Contact PBNP Chemistry.)			
	d.	Do new fluids/chemicals need to be evaluated for TRI (Toxic Release Inventory), CHES, critical applications, or special disposal requirements? (Contact Chemistry/Chemical Engineering.)			
G. In	stalla	tions			
	Inst		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	- 14- 3 autor	
2.	Con perf mod tests	sider test and inspection requirements, including the conditions under which they will be formed? (Reference NP 7.4.1 for pressure test requirements, NP 7.4.3 for post-maintenance and lification NDE requirements, NP 1.2.5 for special test procedures, and OM 4.2.2 for in-service			
3.	Hav com	e post-installation acceptance criteria been properly specified to test the intended function of the ponent(s)/system?	\boxtimes		
4.	Con Loa	uply with all WE lifting and rigging requirements? (Reference WE Safety Manual, PBNP Safe d Path procedures, and NP 8.4.7.)			
، فر	Con	sider ALARA for installation activities? (i.e., shielding, monitoring water level, etc.)		\boxtimes	

.

	DESIGN INPUT CHECKLIST		APPLIES TO DESIGN	
			NO	
6.	Require special handling, shipping, or environmental conditions for storage or construction? (Reference NP 9.5.2 for material storage.)			
7.	Consider transportability requirements such as size and shipping weight limitations.			
8.	Require spare parts or special non-standard items or tools?		\boxtimes	
9.	Will any added components introduce chemical contaminants to the system? (i.e., preservative coating on valves, coatings on weld rod can also introduce contaminants)			
10.	Consider personnel requirements and limitations, including the qualification and number of personnel available for plant operation, maintenance, testing and inspection, and permissible personnel radiation exposures?	· 🔲		
11.	Operational requirements under various conditions, such as plant startup, normal plant shutdown, plant emergency operation, special or infrequent operation, and system abnormal or emergency operation.			
	a. Require new procedures or procedure changes? (Reference NP 1.2.5.)		\boxtimes	
	b. Potentially impact other systems, components, or structures during installation?			
S	c. Present installation impacts on plant operations (i.e., fire watches, etc.)?	\boxtimes		
12.	Access and administrative requirements for plant security: If any security requirements are applicable, notify Security.			
	a. Create an opening >96 in. ² in any wall, ceiling, or other barrier?		\boxtimes	
an a di ta ta an an an a	b. Require work within 20' of fence?			
	 Affect security equipment and documents, including those containing safeguards information? (Contact Security for design development requirements and design concurrence.) 			
	d. Affect access controls?			
13	Safety requirements:	_	K -3	
	a. Affect safety equipment and thereby create personnel hazards (i.e., removal of handrails)?	L	<u>х</u> .	
• •	b. Introduce hazardous material into the plant? (Reference NP 1.9.1.)		\boxtimes	

٠,

		DESIGN INDUT CHECKT IST	APPLIES TO DESIGN		
		DESIGN INFOT CHECKEIST		NO	
E	с.	Affect evacuation routes or escape provisions from enclosures? i		\boxtimes	
	d.	Meet OSHA regulations? (Reference Wisc. Electric Safety Manual and OSHA 29 CFR 1910.)	\boxtimes		
	с.	Move any energy sources? If yes, verify installation document covers move, including transferring danger tags.			
Designed by: <u>Alex Foltynamicz RCC for AF parenail</u> Date: 12-4-01 Reviewed by: <u>Pob Chapman Milt Coffee</u> Date: 12-4-01					



٤

. ,
IWP N	NUMBER: <u>99-029*D</u>			Page 1 of 2 2
	INSTALLATIO	N WORK PLAN	٧	
	······	······································		
	PBNP MINOR PROCEDURE	~		
		Check As Applicable		•.
	WORK ORDER WORK PLAN			
•				
	FOR MODIFICATION # MR 99-029*D	, WO <u>#</u>	9944189	
	INSTALLATION WORK PLAN TITLE			
	AUX FEED WATER PUMP 2P-29 MINIMUM	I FLOW RECIF	C LINE ORIF	ICE
			· · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·
	•	<u> </u>		
	•			•
		- DA-SCOPE	-	
	Rec AF	- 17-	ຟ <u>≃</u> ກ /	
•	Originator Afex Formula per email	Date <u>12-</u>	<u>1-0</u>	
н н н ц	Poviewor Kob Charman Mart		4-01	درمها اله که که ایک این این و ایک ایک میکی میکی ا
•	Final Design	Date 12	-5-01	
				OC REVIEW:
	Quality Engineer	Date $\underline{/2/}$	4.101	MUMP MARK
	Installation Group Head	Date 2-4	-DÍ	· .
		· · · · · · · · · · · · · · · · · · ·		
	Manager - Operations or DSS ///	Date 12-4	-01	
NOTE	: Changes to this work plan must be trone with the concurre	nce of the		
	responsible or team engineer and the installation surpeviso	r. or as delineated y	within the IWP.	
	responsible of team engineer and the instantation surportso			DG-G02.5

BEST COPY AVAILABLE

.

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

December 4, 2001

1.0 <u>SCOPE</u>

- 1.1 The scope of this installation work plan is to replace a portion of the existing AF line 2"- DB-3, including pressure reducing orifice (2RO-04003). The replaced piping and new RO will be welded back utilizing oversized socket welds.
- 1.2 The purpose of this modification is to reduce piping line noise and vibration when operating Auxiliary Feedwater (AF) pump 2P-29 in the recirculation mode. The presently installed RO is cavitating, causing excessive noise and pipe vibration. The purpose for oversized socket welds is to offer a significant high cycle fatigue improvement over standard ASME Code socket welds.
- 1.3 The approach of this installation is as follows:
 - 1.3.1 Pre-fabricate new section of pipe as shown on sketch SK-MR-99-029*D (prefab work done under WO 9950215).
 - 1.3.2 Isolate and drain the affected piping.
 - 1.3.3 Remove portion of the existing AF line 2"-DB-3.
 - 1.3.4 Install new sections of AF line 2"-DB-3.
 - 1.3.5 Perform VT and PT exams on all new welds.
 - 1.3.6 Functionally test the mini-recirc. line to verify operability.
 - 1.3.7 Perform inservice leak check of new/modified piping and welds.
- 1.4 This installation is scoped as QA, safety-related work.

QA Scope Clarification:

The piping downstream of 2RO-4003 is QA, non safety-related (AQ) scope.

- 1.5 Installation of this IWP will be performed while Unit 2 is in Mode 4, 5, or 6. The 2P-29 auxiliary feedwater pump will be out of service.
- 1.6 This modification will not affect any ASME Section XI pressure boundaries. An R/R/M is not required.

1.7.1

1.7.2

1.7

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW **RECIRC LINE ORIFICE** UNIT 2

IWP 99-029*D

December 4, 2001 Support Requirements Operations: Support to install and remove danger tags, system draining, and post maintenance and operability testing. NDE Group: Perform visual/penetrant (VT/PT) examinations and pipe thickness measurements where specified in this IWP.

- 1.7.3 Security: Performs fire watch duties as directed by Operations.
- 1.7.4 QC: Perform inspections as required.
- 1.7.5 Engineering: Support NDE evaluations and post maintenance testing.
 - RE: Rob Chapman x7636 pager 0114 Home Tel. 920-429-9146
- 1.7.6 Mechanical Maintenance: Perform removal and installation of orifice, piping, and supports.

2.0 PRE-INSTALLATION REQUIREMENTS

2.1 **References:**

- 2.1.1 Working drawing:
 - a. SK-MR-99-029*D, "Auxiliary Feedwater System Orifice 2RO 4003
 - Replacement, Units 1 & 2
- 2.1.2 Vendor/Contractor drawing:
 - a. Flowserve drawing 94-16249
- 2.1.3 Applicable Codes and Standards:
 - a. USAS B31.1 1967
- L b. ASME B31.1 – 1992
- 2.1.4 Supplemental Procedures:
 - Flange and Closure Bolting a. MI 32.1
 - Guidelines for Opening Piping Systems b. MI 32.8

IWP 99-029*D WO 9944189 WORK PLAN

December 4, 2001

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

c.	MI 32.11	Installation and Reuse of Swagelok Fittings
d.	NP 1.9.6	Plant Cleanliness, Storage, and Inspection Program
e.	NP 1.9.9	Transient Combustible Control
f.	NP 1.9.13	Ignition Control Procedure
g.	NP 1.9.15	Danger Tag Procedure
h.	NP 8.4.10	Exclusion of Foreign Material from Plant Components and Systems
i.	NP 8.5.2	CHAMPS Equipment Database Usage and Control
j.	OI 62B	Turbine-Driven Auxiliary Feedwater System (2P-29)
k.	PBF-9142	Bolting-Torque And Loading
1.	WP-7	Welding Procedure for Stainless Steels Group P-8 GTAW- Pipe Diameters Over 1" OD
m.	WP-8	Carbon Steels ASME Group P-1 to Austenitic Stainless Steel ASME Group P-8 GTAW Pipe Diameters Over 1"

Responsible Engineer has assured that all references listed above are approved and the applicable requirements have been incorporated into the JWP. The references are either with the Installation Group, attached, or are readily available to the Installation Group.

4-15-02 RE Date

٢

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

IWP 99-029*D WO 9944189 WORK PLAN

- 2.2 <u>Background References</u> (those references not needed to perform work):
- 2.2.1 Drawings:
 - a. Bechtel Drawing M-217, Sh. 1, P&ID of Auxiliary Feedwater System
 - Bechtel Drawing P-103, Stress Isometric of Emergency Feedwater Pumps to Main Feedwater Lines 4" & 3"-DB-3
- 2.3 Installation Preparation Activities
 - 2.3.1 A Bill of Material (BOM) is attached to this IWP or is included on the Working Drawing.
 - 2.3.2 The Responsible Engineer has assured that all materials on the BOM are on site, available for the modification, and QA released.
 - 2.3.3 The Responsible Engineer has verified that all calculation Addenda specified on PBF-1606 have been approved prior to the start of work.
 - 2.3.4 New CHAMPS label for 2RO-4003 is required and has been requested.

The RE has assured that all of the above Installation Preparation Activities are complete.

_Date 4-15-02

2.4 Pre-Installation Discussions

2.4.1 A pre-installation discussion with the Installation Group representative, the Testing Group representative, and the Acceptance Group representative has been performed.

_Date _04/15 **RE/IS**

A field walkdown has been performed, if necessary, to verify that all aspects of the procedure may be performed as intended.

IS

2.4.3

Support personnel # Seconty BJU 4-15-02 A commitment has been obtained from Security to support fire watch requirements. Record the responsible group below.

Fire Watch Support Group

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2 IWP 99-029*D WO 9944189 WORK PLAN

December 4, 2001

i

2.4.4 Foreign material exclusion (FME) shall be controlled per NP 8.4.10, Exclusion of Foreign Material from Plant Components and Systems, and PBF-9158, FMF Checklist.

_Date <u>04/15/02</u> **RE/IS**

2.5 Personnel Safety Concerns

The following precautionary personnel safety requirements are recommended for this IWP:

- 2.5.1 Caution should be exercised when lifting or rigging components.
- 2.5.2 This installation will take place in an area of increased fire awareness. Installation personnel shall take precautions against fire hazards. Care should be taken no to allow combustibles to extend from the 2P-29 cubicle to the adjacent AFP cubicles.
- 2.5.3 Care should be taken during welding to prevent the halon system in the auxiliary feedwater pump room from actuating. This may be accomplished by removing from service any fire sensors in the 2P-29 cubicle or in the area of the welding.
- 2.5.4 Aux. Feedwater pump 2P-29 minimum recirculation line does not have drain connections. To allow this line to drain, the downstream flange for metering orifice 2FE-4049 will be broken open. The safety cautions of MI 32.8, Guidelines for Opening Piping Systems shall be utilized.

The Installation Supervisor is aware of the above listed safety concerns.

Date_

I

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

IWP 99-029*D WO 9944189 WORK PLAN

December 4, 2001

RE/Date

2.6 Identification of Permits Required

- 2.6.1 Work Order # 9944189 for this IWP has been written and submitted to CHAMPS. The Work Order number has been recorded on the IWP coversheet.
- 2.6.2 Ignition control permit is required for welding and shall be obtained by the Installation Supervisor when needed.

The Installation Supervisor has assured that all necessary permits for this installation will be obtained.

Date 09/15/12

- 2.7 <u>Pre-Installation Work</u>
 - NOTE: The following work will be performed under other work orders.
 - 2.7.1 Orifice has been flow tested, and test data is satisfactory.
 - 2.7.2 Pre-fabricate piping assembly, including replacement orifice 2RO-4003, in accordance with the Working Drawing SK-MR-99-029*D under WO 9950215.
- 2.8 Operational Installation Prerequisites

2.8.1 This installation will be performed during the Unit 2 Reactor being in Hot Shutdown (Mode 4), Cold Shutdown (Mode 5) and/or Refueling (Mode 6) operating condition. If the installation is performed with Unit 2 in any other mode of operation, appropriate action statements per LCO 3.7.5 shall be performed.

- NOTE: The following step indicates a *RECOMMENDED* Danger Tag Series. This may be altered depending on the plant conditions or other work being performed on the auxiliary feedwater system as determined by OPS. Note that WO 9914184 has been initiated to oversize other welds on the mini recirc line for 2P-29.
- 2.8.2 Prepare a Danger Tag Series to isolate the 2P-29 minimum recirculation line from flow element FE-4049 to valve 2AF-53.

IWP 99-029*D WO 9944189 WORK PLAN

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

December 4, 2001

DO NOT HANG the tags until instructed to do so in Section 3.0.

Recommended tag series:

- a. Valve 2AF-00053, Pump 2P-29 Mini Recirc Outlet, CLOSED
- b. Valve 2AF-04002, Pump 2P-29 Mini Recirc Control, CLOSED
- c. Valve 2MS-02019, HX-1B SG Steam Supply to P-29 AFP CLOSED
- d. Valve 2MS-02020, HX-1A SG Steam Supply to P-29 AFP CLOSED

DANGER TAG SERIES: 2 4F P-29 MM NEV 0-1

2.8.3 Release For Installation

All of the above operational installation prerequisites have been met and it is acceptable to proceed with the installation.

DSS M M. Man Date 4/17/2 Time 0615

BEST COPY AVAILABLE

ł

IWP 99-029*D WO 9944189 WORK PLAN

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

December 4, 2001

3.0 INSTALLATION

3.1 · OC Requirements

Hold, inspect, or witness points are included, as needed, in the body of the installation description. QC shall witness final torquing of flange bolts for FE-4049 orifice.

3.2 Installation Description

NOTE: The following is a detailed step-by-step listing of the actions necessary to perform this IWP. The steps are to be performed in a logical work order. Work can be performed in an order other than as written at the discretion of the Responsible Engineer or the Installation Supervisor.

3.2.1 Hang the Danger Tag Series prepared in Step 2.8.4. $1^{-10^{-2}}$

mm 9/17/2 **OPS**/Date

CAUTION

Aux. Feed. pump 2P-29 minimum recirculation line does not have a drain connections. To allow system to drain, downstream flange of metering orifice 2FE- 4049 shall be broken open. Safety caution of MI 32.8, Guidelines for Opening Piping Systems shall be observed.

- 3.2.2 Install temporary supports on recirc piping if necessary.
- 3.2.3 Drain and vent Line 2"-DB-3 by breaking the flange at orifice 2FE-4049: Control drainage as well as possible by using hoses and catch basins.

Note: Coordinate with Operations as necessary.

(m) 4-17-

MT/Date

CAUTION

If leakage past isolation valve 2AF-53 is seen, STOP work and contact the job supervisor or RE immediately.

IWP 99-029*D WO 9944189 WORK PLAN

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

December 4, 2001

CAUTION

Take extreme care to apply all possible fire protection precautions in the AF pump 2P-29 cubicle.

- 3.2.4 Disconnect instrument tubing from 2FE-4049 downstream flange.
- 3.2.5 Remove the piping assembly, including orifice 2RO-4003, as ` required per Working Drawing SK-MR-99-029*D. The U-bolt for the support just downstream of 2FE-4049 will have to be removed.

Note exact orientation of 2FE-4049 orifice plate before removing. Record any orientation information below, and retain the orifice for reinstallation later.

large not remared. pcc 4-17-02

FME HOLD POINT

- 3.2.6 Perform FME cleanliness inspection and install temporary FME covers on all unattended open pipe ends. The guidelines of the FME "Checklist", PBF-9158, shall apply to this IWP.
- 3.2.7 Cut the 2FE-4049 flange and pipe stub from piping assembly removed in Step 3.2.5 at the elbow closest to the flange. Flange and stub piece can be re-used. Save all other pipe for examination by Engineering.

FME HOLD POINT

3.2.8 Prior to installation, perform FME cleanliness inspection of the 2FE-4049 flange with pipe stub, and the upstream piping.

MT/Date

Raw 4.17.01

· NUCLEAR F INSTALLAT	POWER BI	ISINESS UNIT K PLAN	IWP 99-029*D WO 9944189 WORK PLAN	
AUX FEED RECIRC LIN UNIT 2	WATER P IE ORIFIC	JMP 2P-29 MINIMUM FLOW E	December 4, 2001	
	3.2.9	Install the 2FE-4049 orifice and flange in out in Step 3.2.4. Check orientation of or	cluding pipe stub cut rifice before installing.	NIA REF.
	<u>OC HO</u>	DPOINT Not reded becan	re flange not boken RCE 4-	MT/Date
	3.2.10	Torque bolts using a staggered pattern. To Ft-Lbs (+/-) 12 Ft-Lbs in accordance with	orque the bolts to 255 n PBF-9142.	
		QC SHALL witness final torquing of bol	\$1A re	
		M&TE:		
		Cal. Due Date:	·····	
		Final "As Left" torque value:	·	
		99	Date	RCC 4-17- MT/Date
		CAUTION		
	2AF-53 to open valve fi	is an isolation tagout boundary valve. It this valve while welding. Take steps as 1 om getting too hot.	t will not be possible necessary to keep the	
میر میر به این این میر میریند.	FME H	DLD POINT		
· ·	3.2.11	Prior to installation, perform FME cleanl the piping assembly pre-fabricated in Ste	iness inspection of p 2.7.3.	Rev 4.17.0;
	3.2.12	Install the piping assembly pre-fabricated accordance with Working Drawing SK-M weld map (Attachment C). Perform fitup and check that fitup meets ASME B31.1	l in Step 2.7.3 in /R-99-029*D and the only with tack welds, requirements.	MIDale
	ι	Note: Some of the welds below will be f 9950215.	itup under WO	
		Weld #1 By: <u>RAND / WAGJUL</u> Weld #2 By: <u>WOFF 9950214</u> Weld #3 By: <u>WOFF 9950214</u> Weld #4 By: <u>WELF 9950215</u>	Date: <u>4 · 17 · 0 2</u> Date: _ Date: _ Date:	

.

.

Page 11 of 22

IWP 99-029*D WO 9944189 WORK PLAN

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

December 4, 2001

Weld #5	By: <u>₩##9957215</u>	Date:
Weld #6	By: WO#9950215	Date:
Weld #7	By: RANGY WACNUR	Date: <u>4-17.02</u>

3.2.13 Perform <u>root welds</u> in accordance with Working Drawing SK-MR-99-029*D and the weld map (Attachment C).

Note: Some of the welds below will be welded under WO 9950215.

Weld #1	By: RANDY WAGUKE	_ Date: <u>4-17.62</u>
Weld #2	By: wo# 4950214	_•Date:
Weld #3	By: WEH 9950214	_ Date:
Weld #4	By: wo# 9950215	_ Date:
Weld #5	By: 40# 1950215	_ Date:
Weld #6	By: Wo# 1950215	Date:
Weld #7	By: RANDI WAGNER	Date: <u>4-17-02</u>
	· /	

NDE HOLD Point

3.2.14 Perform visual examination (VT) of all field root welds. The acceptance criteria for piping welds are ASME B31.1 – 1992 and Working Drawing SK-MR-99-029*D.

Note: Some of the welds below will be examined under WO 9950215.

W_{ald} #1,	TT Sat	
	i iset	
wela #3:		
Weld #4:		
Weld #5:		
Weld #6:		Unsat
Weld #7:	[归Sat	LJUnsat 42 9-11-0

Note: If an unsat inspection condition is identified, NDE will not sign off this step until the appropriate evaluation and /or rework along with re-inspection has been accomplished.

٢

<u>BJV 418-00</u> NDE/Date

٤

IWP 99-029*D WO 9944189 WORK PLAN

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

December 4, 2001

NDE HOLD Point

3.2.15 Perform penetrant examination (PT) of all field root welds. The acceptance criteria for piping welds are ASME B31.1 – 1992 and Working Drawing SK-MR-99-029*D.

Note: Some of the welds below will be examined under WO 9950215.

		61	4-17-62
Weld #1:	✓Sat	Unsat ω_{2}	/
Weld #2:	□Sat	Unsat	
Weld #3:	[·]	Unsat	
Weld #4:	_]Sat	Unsat	
Weld #5:	□Sat	Unsat	
Weld #6:	□Sat	Unsat	
Weld #7:	⊡ Sat	Unsat Ø7	4-17-02

Note: If an unsat inspection condition is identified, NDE will not sign off this step until the appropriate evaluation and /or rework along with re-inspection has been accomplished.

3.2.16 Perform <u>final welds</u> in accordance with Working Drawing SK-MR-99-029*D and the weld map (Attachment C).

Note: Some of the welds below will be welded under WO 9950215.

Weld #1 By: Karon WAShigh Date: 4-18	<u>`04</u>
Weld #2 By: 60# 9950219 Date:	
Weld #3 By: 40 # 9950214 Date:	
Weld #4 By: 4950215 Date:	
Weld #5 By: 40# 99 50215 Date:	
Weld #6 By: 10# 9750 215 Date:	
Weld #7 By: <u>RANNY</u> MACNER Date: 4-18	·02

.

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2 IWP 99-029*D WO 9944189 WORK PLAN

December 4, 2001

NDE HOLD Point

3.2.17 Perform visual examination (VT) of all field final welds. The acceptance criteria for piping welds are ASME B31.1 – 1992 and Working Drawing SK-MR-99-029*D.

Note: Some of the welds below will be examined under WO 9950215.

		$\nabla f = c \int df = c \int $
Weld #1:	O Sat	Unsat Red 9.10
Weld #2:	□Sat	Unsat
Weld #3:	Sat	Unsat
Weld #4:	□Sat	Unsat
Weld #5:	Sat	Unsat
Weld #6:	_ Sat ∠	Unsat
Weld #7:	28at	Unsat Ech 4.18.02

Note: If an unsat inspection condition is identified, NDE will not sign off this step until the appropriate evaluation and /or rework along with re-inspection has been accomplished.

•	· · · · · · · · · · · · · · · · · · ·	4 18-02
و معه پس محمد		BCA -
3.2.18	Support not disactended. Rec Torque bolts on pipe support next to 2FE-4049 to a nominal 6 ft-lbs. M&TE:	. <u>KWF</u> NDE/Date
•	Cal. Due Date:	
	Final "As Left" torque value:	Ree 4-17 MT/Date
3.2.19	Mark-up Working Drawing SK-MR-99-029*D to indicate new as-installed configuration of this modification.	Rec 4-20

RE/Date

IWP 99-029*D WO 9944189 WORK PLAN

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

December 4, 2001

3.2.20 Restore fire protection for AF system pump room as necessary and notify Construction to release fire watch.

3.3 Clean up

Remove all construction debris, tools, and material from the work area. Ensure all work areas meet PBNP housekeeping expectation.

Onnello L Ran Date 4-19-02 TS

- 3.4' Installation Complete
 - 3.4.1 As-Built Description

This IWP was installed by: <u>Rawny WASSIE</u> Date <u>4-18-02</u>

The installation was performed in accordance with this IWP and drawings (list revisions):

ECR(s) No.	Now	•
CR(s) No.	Non,	
Other consider	rations Nov	

Attach any additional documentation of the as-built description to this IWP.

3.4.2 List all calibrated equipment used during installation of this modification on the work order.

٢

.....

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

IWP 99-029*D WO 9944189 WORK PLAN

December 4, 2001

3.4.3 The installation of this IWP is complete. It has been installed in accordance with this IWP and all associated ECRs.

Date $\frac{4-20-02}{12/02}$ IS Connetty L Rose

4.0 TESTING

4.1 <u>Testing Information</u>

٤

- 4.1.1 The acceptance tests for this modification are:
 - a. Initial Service Leak Test performed at normal operating pressure and temperature (with pump running)
 - b. Functional Test of new orifice 2RO-4003 to verify acceptable recirculation flow.
- 4.1.2 The intent of the testing is to:
 - a. Verify the functional performance of new orifice.
 - b. Verify the integrity of the modified piping.
 - c. Verify that all new welds associated with modified piping are leak tight.
 - d. Satisfy the pressure testing requirements of NP 7.4.1.
- 4.1.3 Acceptance criteria for the testing is as follows:
 - a. Piping and fittings within the modified piping boundary shall not show any evidence of structural distress (bulging or deformation) at normal AF system operating temperature and pressure.
 - b. Piping and fittings within the modified piping boundary shall not show any evidence of through-wall leakage at any new welds at normal AF system operating temperature and pressure.
 - c. New orifice 2RO-4003 flow reading must be between 120 and 130 gpm.

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW **RECIRC LINE ORIFICE** UNIT 2

IWP 99-029*D WO 9944189 WORK PLAN

December 4, 2001

- 4.2 **Pre-Test Requirements**
 - 4.2.1 Remove the Danger Tags that were hung in Step 3.2.1.
 - 4.2.2 Fill and vent auxiliary feedwater system and prepare 2P-29 for operation as described in OI-62B.
- 4.3 **Release for Testing**
 - 4.3.1 The auxiliary feedwater pump 2P-29 is available as required to be started for testing. Testing can start.

_____Date <u>5/11/0 Z</u> Time <u>0/3</u>Z milly

4.4 Testing

٤

Note: Sound and vibration data may be collected as directed by the System Engineer while the pump is running during OI-62B.

4.4.1 Start 2P-29 per OI-62B (or other procedure).

Flow Reading UT # 2

4.4.2 While pump is running, take flow readings below:

> Flow Reading 2FIT-4049 121 ____ gpm. Flow Reading UT # 1 127gpm.

5/11/01 Ra **ENG/Date** 5/ 1 /02 Ra ENG/Date Ra **ENG/Date**

Acceptance criteria: The flow reading must be between 120 and 130 gpm. If 2RO-4003 Performance Test is unacceptable, manually adjust the 2RO-4003 per Attachment B.

gpm.

ortice affrox reading affected by P-30A/15 5#70 * a cuppelle. Rain flow.

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW **RECIRC LINE ORIFICE** UNIT 2

IWP 99-029*D WO 9944189 WORK PLAN

	December 4, 2001	
Acc 5-11-22	•	

.

RCC J-11-02

RCC 5-11-02 **RE**/Date

- When flow is acceptable, red-lock orifice with safety wire 4.4.3 (provided by vendor). RE-OPS/Date
- Mark orifice position using indicating plate. 4.4.4

CAUTION

Use caution when examining piping and welds. The system operating pressure may be in excess of 1300 Psig.

Perform the Initial Service Leak Test of the new piping and 4.4.5 welds while the pump 2P-29 is running in recirculation mode. Examine for leakage all new joints. Record results of the Initial Service Leak Test below and in the attached PBF 0042a&b:

leak fest SAT. 5-11-02 RCC

Acceptance criteria: No visual evidence of weeping or leaking at tested fittings and joints.

- 4.5 Testing Results
 - 4.5.1 Attach any additional testing documentation to this IWP.
 - 4.5.2 List all calibrated equipment used during testing of this modification.
 - UT#/ CEFM-DOZ Cal du 10-11-03 C. de UT#2 CEFM-024 2-17-03
 - 4.5.3 The testing is completed and all Acceptance Criteria have been met.

Date 5-11-0 2 Testing Supervisor ______

IWP 99-029*D WO 9944189 WORK PLAN

l

5.0 <u>RESTORATION</u>

- 5.1 Pre-Acceptance
 - 5.1.1 The following items must be completed prior to acceptance:
 - a. All ECRs have final approvals.
 - b. All update items required prior to acceptance on PBF-1606 have been completed.
 - c. All testing described above has been satisfactorily completed.

All of the above items have been completed.

____ Date _____ Date _____

- 5.2 System Restoration
 - 5.2.1 Close out any remaining tagouts and permits for this IWP.
 - 5.2.2 Aux Feedwater pump 2P-29 is ready for release for operation. DSS Date 5/11/02 Time 0243
- 6.0 <u>ACCEPTANCE</u>
 - 6.1 Verify systems and components affected by this modification are placed in an appropriate condition for present plant configuration.
 - 6.2 If fire rounds in progress, then discontinue fire rounds.
 - 6.3 <u>Final Acceptance</u>

This installation and the associated modification have been installed and tested and are acceptable.

____ Date ____ /11/02. DSS

Return completed IWP and modification to Responsible Engineer

IWP 99-029*D WO 9944189 WORK PLAN

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2

~

December 4, 2001

ATTACHMENT A

BILL OF MATERIAL

ž

1

Š.

ltem	SR	Size	Description	Model Number	Qty	Lot No. / PO	Comments
1	S	2"	Pipe, Sch. 80		5ft	9017551	Seamless Stainless Steel, ASTM A-312, Type TP 316
2	S	2"	Elbow, 90 deg., 3000lb, socket weld		2	9015019	ASTM A-182, Grade F-304
3	S	2"	Pressure Reducing Device	Flowserve 94-16249	1	4500429416	ASTM A-351 Type CF8M body, A-479 Type 316 bonnet, 600# class, Socket Weld ends
4	N	2"	Gasket, Flexitallic		2	9154223	Flexitallic, 1500 Lb., Blue Asbestos and 304 S.S.
				2 5 7			

AUX FEED WATER PUMP 2P-29 MINIMUM_LFLOW RECIRC LINE ORIFICE UNIT 2 IWP 99-029*D WO 9944189 WORK PLAN

December 4, 2001

ATTACHMENT B

2RO-4003 Manual Adjustment Steps (Reference drawing 94-16249)

- B.1. Remove safety wire (Item 260).
- B.2. Loosen jam nut (Item 244).
- B.3. Rotate stem as necessary with the pin nut (Item 235P) to adjust flow *clockwise will reduce flow*.
- B.4. Tighten jam nut (Item 244).
- B.5. Retest per Section 4.4.

٢

B.6. If test is satisfactory, then install safety wire (Item 260).

AUX FEED WATER PUMP 2P-29 MINIMUM FLOW RECIRC LINE ORIFICE UNIT 2 IWP 99-029*D WO 9944189 WORK PLAN

December 4, 2001

ATTACHMENT C



Nuclear Power Business Unit WELD CHECKLIST

wo	9944189	Date	01/15/02	
Describe Valve B	weld, repair, or insp ody SW, A105 CS, 1	ection (identify applicable code to 2" Sch. 80 Pipe ASTM A-	e and edition, B31.1, ASME Section IX 312 TP 316 (Weld #1)	K, AWS D1.1, etc.)
ISE Engi	ineer Notified For Se	ection XI Scope Repairs	YES NOX	<u>(x</u>
Material	to be joined	P-1 to P-8	NDE Requirements:	
Filler me	etal to be used	ER 309/ E309-16	Radiography Test (RT))
Thicknes	ss of weld joint	See SK-MR-99-029*D	Magnetic Particle Test	(MT)
Thicknes	ss of base metal	0.218"	Dye Penetrant Test (PT) <u>XX</u>
Preheat	Required	70° F.	Visual Test (VT)	XX
Postweld	l Heat Treatment	None	Hydrostatic Test	
Weld Provident of the second s	ocedure Specification VT & welders' performanc s. d Welders:	n <u>WP-4</u> PT of Root Weld required. e qualification records and the second secon	Final VT of all welds required. list those welders qualified for th	e base material and
.	H_O MTN Planne	r/Supervisor or MPE Engin	4/17/02 neer // Date	
ob comple ecorded in	ted utilizing the abov Welder's Logbook.	ve information, and the note	ed weld procedure and weld infor	rmation has been <u>4.18-02</u> Date

WO reviewed for documentation of weld rod Lot Numbers and QAR Numbers and successful completion of Indicated NDE.

MIN Supervisor

50-9.102 Date

٠.

Nuclear Power Business Unit WELD CHECKLIST

ι

2" S.S. S Weld nu	ch. 80 Pipe, ASTM A-31 mber 7	2, Type TP 316 to 2"	Elbow, 90 deg., 3000# ASTM A-182, Grade F-304			
ISE Engi	neer Notified For Section	1 XI Scope Repairs	YES NOXX			
Material to be joined		P-8 to P-8	NDE Requirements:			
Filler me	tal to be used	ER-316/E-316	Radiography Test (RT) No			
Thicknes	s of weld joint	* ¼" x ½" 0.218"	Magnetic Particle Test (MT) <u>No</u>			
Thicknes	s of base metal		Dye Penetrant Test (PT) Yes			
Preheat l	Required _	50° F.	Visual Test (VT) Yes			
Postweld	Heat Treatment	None	Hydrostatic Test No			
Weld Procedure Specification		WP-2				
ICCTION 1		~~~ ~	4 -			
Qualified	Welders: <u>Arad</u> AMAU MIN Planner/Su	Eichhorn Wagner pervisor or MPE Eng	$\frac{p \frac{\eta}{\eta}}{Date}$			

4-19-2

يتد ۽

MTNSupervisor

Date

Indicated NDE.

....

81. a

From: Sent: To: Subject: Chapman, Rob Tuesday, May 14, 2002 1:36 PM Siercks, Harold design description for MR 99-029*D

Attached.



Rob Chapman Mechanical Design Engineering Point Beach Nuclear Plant Ph 920-755-7636 Fax 920-755-7410

٢

5.

rs.

From: Sent: To: Subject: Barrows, John Sunday, February 24, 2002 9:45 AM Chapman, Rob RE: TWR no.

reference TWR 00-046 used for the other 2 orifice replacements. No training required per the notes I have.

John

 -----Original Message---

 From:
 Chapman, Rob

 Sent:
 Wednesday, February 20, 2002 11:20 AM

 To:
 Barrows, John

 Subject:
 TWR no.

٢

What is the TWR for MR 99-029*C?

From: Sent: To: Subject: Chapman, Rob Wednesday, May 08, 2002 8:41 AM Glaser, Jill RE: EPIX update

Jill -

- Component ID: 2RO-4003 (1RO-4003 will be replaced during U1R27 this fall too)

- Function: Pressure/flow reduction (use pressure control) on auxiliary feedwater pump minimum flow recirculation line (flow reduction on recirc needed to ensure that AFP will provide adequate flow to the steam generator in accident scenarios)

ŧ

- Size: 2" (NPS)

- Operator: It is a manual operator (the orifice doesn't have a handwheel like a normal valve. It has to be adjusted with a wrench)

- 2RO-4003 was installed during U2R25 (during week of 4-15 to 4-19 - testing has not yet been completed)

- It replaced the existing 2RO-4003 orifice, which was not adjustable, and was not anything like a valve. It was a tube with drilled plates inside.

Thanks.

Rob

Rob Chapman Mechanical Design Engineering Point Beach Nuclear Plant Ph 920-755-7636 Fax 920-755-7410

Origina	I Message
From:	Glaser, Jill
Sent:	Wednesday, May 08, 2002 7:27 AM
To:	Chapman, Rob
Subject:	RE: EPIX update

What is the component ID? What function does this valve serve (i.e., one-way flow, bypass, level control, pressure control, pressure relief, drain, vent, shutoft/isolation/stop), what is the nominal inlet size, what type of operator (balance, ball, electric motor/servo (MOV), hydraulic, manual, mechanical, none, piston, pneumatic, solenoid)?

Also, when was this installed? Did it replace an existing valve?

-----Original Message----From: Chapman, Rob Sent: Tuesday, May 07, 2002 7:35 PM To: Glaser, Jill Cc: Chapman, Rob Subject: EPIX update

MR 99-029*D installed a Valtek Mark I pressure reducing device (orifice). This orifice is essentially a globe valve without a handwheel and some cavitation control trim inside.

Let me know what additional information you need, and I will transmit.

Thanks.

Rob

From: Sent: To: Subject: Chapman, Rob Tuesday, May 07, 2002 7:33 PM Engleman, Christopher; Krause, Diane PO 4500429416 closure

If it has not been done already, could one of you close PO 4500429416, which purchased the 2RO-4003 orifice from Flowserve. This is an item on the closeout checklist for the mod.

Thanks.

Rob

Rob Chapman Mechanical Design Engineering Point Beach Nuclear Plant Ph 920-755-7636 Fax 920-755-7410

L

Chapman.Rob

From: Sent: To: Cc: Subject: Chapman.Rob l Monday, December 03, 2001 4:33 PM 'afoltyno@dukeengineering.com' Chapman.Rob MR 99-029*D

Alex -

I thought it would be a good idea to email my comments / changes to the mod package. Your email response will be attached to the mod as the basis for your signature.

The major changes that were made are below. Please call if you would like to discuss.

Thanks.

Rob

Changes to MR 99-029*D

Design Description

- Added reference to pinhole leaks and RCE 99-081
- Added discussion about flow rates (120-130 gpm)
- Added reference to other weld procedure WP-8 for CS to SS weld at 2AF-53 (valve is carbon steel)

<u>50.59</u>

• Changed from an evaluation to a screening (done under New Rule)

Installation Work Fian"

- Changed CE to MT
- Removed requirement for temporary support (based on walkdown with MT)
- Added step to disconnect flange tubing
- Referenced pre-fab work orders
- Added NDE signoffs for each weld
- Added a weld map
- Added reference to WP-8
- Added step to torque U-bolt for pipe support
- Separated root weld and final weld steps
- Added step to verify calc addenda are done prior to work beginning
- Removed reference to scaffolding
- Added reference to OI-62B for running the pump

Rob Chapman

Chapman.Rob

From: Sent: To: Subject: Alex Foltynowicz [afoltyno@dukeengineering.com] Tuesday, December 04, 2001 8:13 AM Chapman.Rob Re: MR 99-029*D

Rob,

I have reviewed your comments/changes pertaining to the Subject modification package. I agree with all the comments you have made and concur with the changes that you are proposing.

Alex

· . . .

L

WISCONSIN ELECTRIC POWER COMPANY POINT BEACH NUCLEAR PLANT AUX. FEEDWATER SYSTEM PRESSURE REDUCING DEVICE DATA SHEET 1 OF 2

,

l

IDENT								
IDENT.	1	DESCRIPTION: ADJUSTABLE PRESSURE REDUCING DEVICE (APRD)						
	2	QUANTITY REQUIRED: TAG NO.: P & ID NO 1 2RO-04003			O: BECH. 6118 M-217 SH. 1			
	3	CODE CLASS: ASME/ANSI B31.1 – 19 ASME/ANSI B16.34 – 1	67 Edition thro 973 Edition th	ough 1995 Ed rough 1998 E	lition Edition			
	4	SAFETY RELATED: YES (DEVICE BODY 100% RT)	& WELDS-	SEISMIC CLA	ASS: YES-1			
SERVICE	5	FLUID: 1. NORMAL OPERATION: FILTERED & DEMINERALIZED WATER 2. EMERGENCY OPERATION: SERVICE WATER			WATER			
	6,	PUMP DISCHARGE PRESSURE (PSIG):	DESIGN 1440		MINIFLOW			
	7	APRD INLET PRESSURE (PSIG):	1440		1350			
	8	APRD OUTLET PRESSURE (PSIG):	50		15			
	9	TEMPERATURE (°F)	32 - 120		32 - 120			
	10	PREDICTED FLOW RATE: BY VENDOR						
	11	SERVICE CONDITION: FLC	W CONTROL A	ND PRESSUR	EREDUCTION			
	12	PUMP RATED FLOW - APRD ASSOCIATI	ED:	4	00 GPM			
1	13	REQUIRED APRD FLOW (MIN/MAX): 120 / 130 GPM						
	14	PIPING & FITTINGS ΔP UP TO INLET OF APRD: 20 PSIG						
	16	MAX. ALLOWABLE SOUND LEVEL: 75 DBA (THREE FT AWAY FROM THE APRD- UNINSULATED)						
BODY	15	APRD BODY SIZE: 2 INCH						
	16	APRD DESIGN RATING (ANSI PRESSURE CLASS): BY VENDOR						
	17	APRD BODY MATERIAL: BY VENDOR (STAINLESS STEEL)						
	18	18 END CONNECTIONS : SOCKET						
	19	CONNECTING PIPE SIZE/SCHEDULE: 2 IN J SCH. 80						
	20	BODY LENGTH END-TO-END: BY VENDOR WEIGHT: BY VENDOR						
REVISION		PREPARED BY: A. Folle		D	ATE: 07-24-01			
		REVIEWED BY: PLP A.L	nech.	D	ATE: 07/24/01			
		APPROVED BY: Seu Orn	Geong	D	ATE: 1/26/01			
					7 /			

at - -

WISCONSIN ELECTRIC POWER COMPANY POINT BEACH NUCLEAR PLANT AUX. FEEDWATER SYSTEM PRESSURE REDUCING DEVICE DATA SHEET 2 OF 2

ADDITIONAL REQUIREMENTS

1

- 1. Adjustable pressure reducing device (APRD) assembly shall be designed to withstand seismic loading equivalent to 3.0 g in the horizontal direction and 2.0 g in the vertical direction. When exposed to the above loading the APRD shall be capable of performing all its functions. Vendor shall furnish seismic analysis and design report for Purchaser's review.
- 2. Hydrostatic testing of the APRD body shall be conducted in accordance with ASME/ANSI B 16.34 except that the test pressure shall be maintained for at least 30 minutes.
- 3. All materials in contact with the working fluid shall be austenitic stainless steel.
- 4. Castings and wrought materials procured for the manufacture of valve body and trim shall be in accordance with applicable ASTM and ASME specifications and Certified Material Test Reports shall be furnished.
- 5. All welding shall be in accordance with ASME Section IX requirements.
- 6. Examination requirements for pressure retaining parts of the APRD shall be in accordance with ASME/ANSI 16.34, Section 8.0. In addition, radiographic examination shall be performed in accordance with ASME Section V, Article 2.
- 7. Provide calculation certifying that the design flow comply with Data Sheet 1 requirements. This calculation shall be reviewed and accepted by NMC prior to APRD fabrication.
- 8. The APRD flow rate adjusting device shall be equipped with means to secure APRD position using a lockwire attached to the stem and bonnet.
- 9. Fabrication drawing, indicating APRD parts list and their associated ASME/ANSI standards, shall be submitted for NMC approval prior to APRD fabrication.
- 10. Provide Certificate of Compliance attesting that the APRD is designed in accordance with P.O. specified requirements.
- 11. Provide eight (8) copies of Instruction Manuals for APRD including Parts List and Part Numbers.

REVISION	PREPARED BY:	A. Folly	DATE: 01-24-01
	REVIEWED BY:	Joh P. Achrode	DATE: 07/24/01
	APPROVED BY:	April an trong	DATE: 7/26/01

File Q1.3.1 / CEES01 / SS-02-011 supplier code / surveillance no.

QAS SUPPLIER SURVEILLANCE REPORT

Activity Description: Source Surveillance of Flow Testing of a Flowserve Valve

Activity Date: April 2 - 3, 2002 P.O. No.: PO P001901

Supplier Name: Colorado Engineering Experiment Station, Inc.

Location: Nunn, CO

Reference Material: Purchase Order

Deficiency Nos.: None

Copies To: R. Chapman, T. Koeslin, C. Engleman, File Q1.3.1

Summary:

On April 2 - 3, 2002, a source surveillance was conducted at Colorado Engineering Experiment Station, Inc. (CEESI) in Nunn, CO. The source surveillance verified activities associated with the flow testing of pressure reducing device installed in a 2"-600#, socket welded, globe valve body.

Flow testing was performed at the specified inlet pressure. The flow rate was adjusted to the required flow. The resulting outlet pressure was found to be somewhat above the specified pressure. The inlet pressure was increased enough so that the pressure differential between the inlet and outlet pressure was as required and the flow rate was found to be within the required range.

Contacts: Mike Knotts - Flow Measurement Technician, CEESI

1. Was the valve in the original package when received?

The valve was in the box when received. The box had been opened to inspect for damage during transit. The valve was removed from the box after arrival at CEESI.

The QC tag was attached to the valve throughout testing of the valve which provided traceability for the valve. (S/N D440T-1-1, PO 4500429416).

2. Had any damage occurred to the valve during shipping?

No damage was noted to the box or the valve during shipping to CEESI.

8. Was any welding performed on the valve?

Source Surveillance SS-02-011 Colorado Engineering Experiment Station, Inc. April 2 - 3, 2002 Page 2 of 3

No welding was performed directly to the valve body. Welds were made using the GTAW process to join two (2) 600# carbon steel slip on flanges to the pipe stubs.

4. Was machining and welding to attach the weld neck flanges to the pipe stubs controlled?

The pipe was plugged with clean towels to prevent any foreign materials from entering the pipe during the welding operations.

Welding of the flanges to the pipe stubs was made using the GTAW process. The weld was made using 309L filler material. The pipe ends were capped following welding to prevent the introduction of foreign materials.

5. Was the test system cleaned prior to testing to prevent introduction of foreign material?

The line was flushed prior to testing. The in-line Y-Type strainer was installed with .060" screen upstream of the valve.

6. Was testing performed and results recorded the flow rate (required 120 – 130 gpm) at the following service conditions:

P inlet = 1350 - 1360 psig, P outlet - 22 psig

The inlet pressure could be adjusted, the outlet pressure was recorded with the isolation valve fully open. The outlet pressure could not be reduced any more than 22 psig. The inlet pressure was adjusted to 1360 psig so that the resulting differential pressure would be about 1335 psig which was specified in the purchase order (1350 psig inlet – 15 psig outlet). This issue was discussed with the PBNP technical contact and determined to be acceptable. The flow rate at these pressures was adjusted until the flow was between 120 and 130 gpm (actual about 121 gpm).

7. Was the test pressure kept below the 1440 psig maximum?

The maximum test pressure was 1365 psig.

8. Verify the valve was not altered during testing other than any adjustment of the orifice to achieve the desired flow rate.

The valve was not altered during testing other than some adjustments to the orifice to achieve the desired flow rate.

9. Verify the vibration and noise levels were not excessive.

Source Surveillance SS-02-011 Colorado Engineering Experiment Station, Inc. April 2 - 3, 2002 Page 3 of 3

The valve was monitored during testing and did not exhibit any significant vibration or noise.

10. Was flow measurements taken with water at an ambient temperature below 90 degrees F?

Water temperature was below 90 degrees F for all of the testing activities (Maximum water temperature was about 66 degrees F during testing.)

11. Are instruments used to monitor pressure and temperature calibrated to standards traceable to NIST?

Instruments used during testing were verified to have been calibrated using standards traceable to NIST.

12. Is the test media clean tap water?

The test media was clean tap water which was run through a sand filter prior to flowing through the pressure reducing valve. The sand in the filter had been replaced prior to the flushing of the lines for testing.

13. Were the flanges removed from the pipe?

The flanges were sawed off of the pipe about ¹/₄" from the flange weld. The pipe ends were filed down to remove any burrs.

14. Is the valve rinsed clean with demineralized water prior to shipment?

The valve was rinsed with distilled water after testing and allowed to air dry. Tape was placed on both pipe ends to prevent any foreign material from getting inside the valve.

15. Is the valve packaged at the same level of protection as when it was received at CESSI?

The valve was placed back into the original wooden crate. The flanges which CEESI had welded to the pipe stubs were to be put back into the wooden crate with bubble wrap. Actual final packaging was not witnessed during the source surveillance.

16. Are there any nonconformances or other issues which require follow-up?

No nonconformances or other issues were noted during the testing activities that require follow-up.

Steve Forsha

Prepared By:

Date: April 5, 2002

Chapman.Rob

From:	VanderVelde.Brian
Sent:	Wednesday, November 28, 2001 9:55 PM
То:	Chapman.Rob
Cc:	Desroches.Michael
Subject:	MR 99-029*D MM Comments WO 9944189

1. Why replace the piping to build up the welds to meet EPRI guidelines? Can't the welds simply be built up? We did this on other lines in the AFP room during the last two outages.

2. Recommend doing a grammar check on the Final Design Description wording.

3. Under Design Inputs - Has the info been added to the Flowserve Pressure Reducing Orifice Drawing?

4. Are all the parts on site, (i.e., RO, piping, elbows)? If not, has the req been turned into a PO? When will the parts arrive?

5. Please work with Mike Desroches, MM planning, to create a separate work order to perform the pre-fab activities.

6. Has the new RO been pressure tested already?

7. Is the SE done and approved?

8. Unless I missed it, the design description does not mention pinhole leaks in the socket welds as being one of the reasons for building them up, yet the SE mentions it.

9. Will OPS be able to completely drain the associated piping? Are any of the isolation boundary valves work ordered for leakage? If they are, they may cause problems during welding if there is too much water in the lines.

10. Step 1.7.6 of IWP, change ENG information re: Alex.

11. Will you be around during the outage for consultation? If not, who can we work with?

12. Step 2.3.2 of IWP, add a sign off for the RE.

13. Step 3.2.3 should be done by OPS.

14. Step 2.5.3, ensure OPS adds this to their tag series.

15. IWP, change all sign offs from CE to MT.

16. Step 2.7.2, this should be done under a separate WO for scheduling purposes.

17. Do we want a fit-up inspection prior to welding?

318. Work with MM to provide sign-offs for the welders and NDE for each weld and have a weld map with each weld

19. Step 3.2.15 should be an ENG sign-off.

20. Has the IWP been reviewed by OPS to ensure the PMT is acceptable as written?

21. The steps for pre-fab and installation should have a note to allow the steps to be worked in any logical order.

22. Please get working drawings to Mike to include in the work package.

23. If scaffolding is needed, please ensure an activities are in the schedule tied to this mod installation so that the scaffolding can be put up and taken down.

Mike, please update CHAMPS to indicate 30 hours for both 430 and 441. I'd also add a resource for security if they will be required to do fire rounds. If scaffold is needed, then scaffolding will need to be changed to Y.

Brian x7177

Ł
Chapman.Rob

From:VanderVelde.BrianSent:Thursday, November 29, 2001 9:58 PMTo:Chapman.Rob; Castro.RitoCc:Desroches.MichaelSubject:RE: latest IWP 99-029*D

1. Step 3.2.3, breaking the flange - not a problem for MT to break the flange. I just thought that if it was possible for OPS to do it, then the system will have all energy sources completely removed and the system drained for us before we walked the danger tag series down and worked the job. Again, no problem, leave it for MT.

l

2. Rito Castro, one of our lead mechanics, reviewed your package and had many of the same comments that I did. One question Rito had, do you have any details for the temporary pipe support, how it should be done, is there any seismic or structural requirements?

3. I'll wait to here from you regarding your discussion with QC and if fit-up inspections are wanted.

4. I'll wait to here from you after you've had a chance to work with Mike Desroches regarding the weld map and how MTN welding packages are arranged for welder and NDE signoffs.

Rito, please walk this piping down to determine if scaffolding is required, or if a ladder will suffice (and any other support groups needed that are not already identified). If scaffolding is required, let us know so scaffolding activities can be added to the schedule.

Thanks. Brian

----Original Message----From:Chapman.RobSent:Thursday, November 29, 2001 5:27 PMTo:VanderVelde.BrianCc:Desroches.MichaelSubject:latest IWP 99-029*D

I substantially upgraded the IWP. I believe that I have incorporated all of your comments, although I still have MT breaking the flange. I will get this issue resolved. Also, I still need to do the weld map.

Take a look if you get a chance.

Thanks!

Rob

<< File: IWP29D.doc >>

Rob ChapmanPoint Beach Nuclear PlantSite Design Mechanical EngineeringPhone:920-755-7636Fax:920-755-7410Pager:0114

L

Chapman.Rob

From: Sent: To: Subject: VanderVelde.Brian Tuesday, December 04, 2001 5:46 AM Chapman.Rob RE: AF orifice mod work plan

1. Step 3.2.4 - provide a place to record the exact orientation of 2FE-4049.

2. Step 3.2.6 - provide direction to label flange and stub piece for reuse, unless we will be immediately reusing them.

-3. Has QC and NDE reviewed this IWP?

4. Step 3.2.10 and 3.2.11 and any other steps that require welding should have a line that lists the weld #, Signature line, and a Date line for the welder to sign so that each weld can be traced to the welder to ensure each specific weld can be traced to a welder that is qualified to perform that specific weld.

5. See my notes on the marked up IWP.

Original	Message
From:	Chapman.Rob
Sent:	Monday, December 03, 2001 2:58 PM
To:	VanderVelde.Brian
Subject:	AF orifice mod work plan

Brian -

I think the work plan is almost there. I have attached the latest version. I will try to come in early tomorrow to catch you for your signature. Go ahead and email any other comments you may have.

Thanks.

Rob

<< File: IWP29D.doc >>

Rob Chapman Point Beach Nuclear Plant Site Design Mechanical Engineering Phone: 920-755-7636 Fox: -920-755-7410 - - -Pager: 0114

- And stop to expert it receivery - Don't oper Volke i key refer how

CLOSEOUT EXTENSION REQUEST

Normal Program Services

The below listed MODIFICATION will not be closed per the time requirements of NP 7.2.1. Complete the justification for the extension request and obtain the required level of approval. Forward the completed request form the MODIFICATION COORDINATOR prior to the current required closeout date.

MODIFICATION:	99-029*D	AUX FEED WAT RECIRC LINE O	ER PUMP 2P-29 MINI RIFICE.	MUM FLOW	
RESP ENG:	Rob C. Chap	man	CLOSEOUT ASSIGNED TO:	ŀ	shcher
DATE ACCEPTED): 5/11/2002	- 1			810
CURRENT REQU	RED CLOSEC	91/13 OUT DATE 8/9/2002	2		
NEW REQUESTE	D CLOSEOUT	DATE:			
Justification for not	t meeting the c	urrent closeout date): 		,
				<u>-</u>	
· · · · · · · · · · · · · · · · · · ·			-		
		<u></u>		•	
••••••••••••••••••••••••••••••••••••••	• • • ^{• •} • ⁻	· · · · · · · · · · · · · · · · · · ·	e, annu, partere		
<u> </u>		····			
			······································		
Extension requeste	ed by:				
		\sim	1		
Approved by: •	<u> </u>	1Dforck	· · ·	Date:	8/13/ar
	Note FIN/ DES	e: the first extension AL DESIGN GROUP IGN ENGINEERING	i request approval may l HEAD. Subsequent app MANAGER approval.	be approved by rovals require	he

Committed	to Nuclear Excellence		RNAL ONDENCE	EDMS FILE 99 - 029 - D				
	NPM 2001-0545							
To:	M. Schug J. P. Schroeder	D. Faltynski J. Polacek	C. Onesti R. Chapman	J. McCullum C. Olson				
From:	A. Foltynowicz A. Folgen							
Date:	August 2, 2001	0						
Subject:	MR 99-029*D PACKAGE DISTRIBUTION REVIEW TRANSMITTAL							
Сору То:	(W/O Attachment R. Hornak L. Armstrong File: M1.1 MR 99	s) D. Schoon 9-029*D	J. Barrows	W. Wilson				

Attached is the design package for MR 99-029*D, Auxiliary Feedwater Pump 2P-29 Minimum Flow Recirc Line Orifice Replacement, for your review and comments. The supporting documents are:

- Design Description
- Design Input Checklist
- Work Order Work Plan IWP 99-029*D
- Working drawing
- 50.59 Safety Evaluation
- Documentation Update Checklist
- Bill of Materials for IWP 99-029*D

Please review the package applicable to your review and return the package with comments. I am requesting that reviews be completed by Monday, 09/07/01. Contact me at X7411 if you require additional information.

AF/kls

Attachments

٤

RECT AUG 14 2001 _