

March 11, 2003

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNIT 1 - NOTICE OF CONSIDERATION OF
ISSUANCE OF AMENDMENT (TAC NO. MB5371)

Dear Mr. Scalice:

The Commission has forwarded the "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing" to the Office of the Federal Register for publication. A copy is enclosed for your information.

The notice relates to your letter dated March 18, 2002, in which you requested a revision to the Sequoyah Nuclear Plant (SQN) Updated Final Safety Analysis Report. The revision provides an alternative methodology using a Bar-Lock Mechanical Splice in lieu of the Cadweld splice used in the original design and construction of the Unit 1 concrete shield building dome. This proposed Bar-Lock mechanical splice is described in Topical Report No. 24370-TR-C-001, "Alternate Rebar Splice - Bar-Lock Mechanical Splices," and is requested for implementation upon the restoration of the dome as part of the upcoming steam generator replacement project for SQN, Unit 1.

Sincerely,

/RA/

Raj K. Anand, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-327

Enclosure: Notice

cc w/encl: See next page

March 11, 2003

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNIT 1 - NOTICE OF CONSIDERATION OF
ISSUANCE OF AMENDMENT (TAC NO. MB5371)

Dear Mr. Scalice:

The Commission has forwarded the "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for Hearing" to the Office of the Federal Register for publication. A copy is enclosed for your information.

The notice relates to your letter dated March 18, 2002, in which you requested a revision to the Sequoyah Nuclear Plant (SQN) Updated Final Safety Analysis Report. The revision provides an alternative methodology using a Bar-Lock mechanical splice in lieu of the Cadweld splice used in the original design and construction of the Unit 1 concrete shield building dome. This proposed Bar-Lock mechanical splice is described in Topical Report No. 24370-TR-C-001, "Alternate Rebar Splice - Bar-Lock Mechanical Splices," and is requested for implementation upon the restoration of the dome as part of the upcoming steam generator replacement project for SQN, Unit 1.

Sincerely,

/RA/

Raj K. Anand, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-327

Enclosure: Notice

cc w/encl: See next page

Distribution:

Public RAnand AHowe
PDII-2 Reading MDudek BClayton (Hardcopy)
EBrown

ADAMS ACCESSION NO: ML030780015

OFFICE	PDII-2/Intern	PDII-2/PM	PDII-2/PM	PDII-2/LA	PDII-2/SC
NAME	RAnand for MDudek	RAnand	RAnand for EBrown	BClayton	AHowe
DATE	3/11/2003	3/11/2003	3/11/2003	3/11/2003	3/11/2003

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSION

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION, AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (NRC or the Commission) is considering issuance of an amendment to Facility Operating License DPR-77 issued to the Sequoyah Nuclear Plant (SQN) for operation of Unit 1 located in Hamilton County, Tennessee.

The proposed amendment would revise the SQN, Unit 1, Updated Final Safety Analysis Report (UFSAR). The revision provides an alternative methodology using a Bar-Lock Mechanical Splice in lieu of the Cadweld splice used in the original design and construction of the Unit 1 concrete shield building dome. This proposed Bar-Lock mechanical splice is described in Topical Report No. 24370-TR-C-001, "Alternate Rebar Splice - Bar-Lock Mechanical Splices," and is requested for implementation upon the restoration of the dome as part of the upcoming steam generator replacement project for SQN, Unit 1.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in Title 10 of the CODE OF FEDERAL REGULATIONS (10 CFR), Section 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant

increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

No. No changes in event classification, as discussed in UFSAR Chapter 15, will occur due to use of the Bar-Lock couplers.

The restoration of the temporary concrete construction openings in the shield building will utilize Bar-Lock couplers to splice new rebar to the existing rebar. The shield building structure limits the release of radioactivity following an accident and protects the systems, structures, and components inside containment from external events. The accidents of interest are those that rely on the shield building to limit the release of radioactivity to the environment, and those that result from some external events. The design of the shield building is such that it is not postulated to fail and initiate an accident described in the UFSAR.

The Bar-Lock coupler qualification tests detailed in Topical Report 24370-TR-C-001 demonstrate that the Bar-Lock coupler meets the American Society of Mechanical Engineers (ASME) strength requirements and is, therefore, acceptable for use in nuclear safety-related applications. Based on these test results, it is concluded that use of the Bar-Lock couplers in restoring the temporary concrete construction openings will not reduce the structural capability of the repaired structure. The shield building will continue to perform its design function as described in the SQN UFSAR.

Therefore, the proposed use of the Bar-Lock couplers will not significantly increase the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

No. The design of the shield building is such that it is not postulated to fail and initiate an accident described in the UFSAR. The Bar-Lock couplers are passive devices and as such will not initiate or cause an accident.

The restoration of the temporary concrete construction openings in the shield building will utilize Bar-Lock couplers to splice new rebar to the existing rebar. The Bar-Lock coupler qualification tests detailed in Topical Report 24370-TR-C-001 demonstrate that the Bar-Lock coupler meets the ASME

strength requirements and is, therefore, acceptable for use in nuclear safety-related applications. Based on these test results, it is concluded that use of the Bar-Lock couplers in restoring the temporary concrete construction openings will not reduce the structural capability of the shield building. The shield building will, therefore, continue to perform its design functions as described in the SQN UFSAR.

Therefore, the possibility of a new or different accident situation occurring as a result of this condition is not created.

3. Does the proposed change involve a significant reduction in a margin of safety?

No. As indicated in the SQN UFSAR, the structural design of the shield building is in compliance with the American Concrete Institute (ACI) 318-63 building code working stress design requirements. The reinforcing steel conforms to the requirements of ASTM [American Society for Testing and Materials] A 615, Grade 60. The SQN UFSAR states that reinforcing bars were lap spliced in accordance with ACI 318-63 requirements for Strength Design.

The restoration of the temporary concrete construction openings in the shield building will utilize Bar-Lock couplers to splice new rebar to the existing rebar. The restoration of the construction openings, including use of the Bar-Lock couplers, will conform to the requirements of ACI 318. Therefore, following completion of the modification, the shield building will continue to comply with ACI 318 requirements.

In addition to conforming to ACI 318 requirements, the Bar-Lock coupler qualification tests detailed in Topical Report 24370-TR-C-001 demonstrate that the Bar-Lock coupler meets the ASME strength requirements.

Therefore, a significant reduction in the margin to safety is not created by this modification.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the

30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 30-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the FEDERAL REGISTER a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and should cite the publication date and page number of this FEDERAL REGISTER notice. Written comments may also be delivered to Room 6D59, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room, located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By April 16, 2003, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should

consult a current copy of 10 CFR 2.714,¹ which is available at the Commission's Public Document Room, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, or electronically on the Internet at the NRC Web site <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. If there are problems in accessing the document, contact the Public Document Room Reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr@nrc.gov. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

¹ The most recent version of Title 10 of the *Code of Federal Regulations*, published January 1, 2002, inadvertently omitted the last sentence of 10 CFR 2.714(d) and subparagraphs (d)(1) and (2), regarding petitions to intervene and contentions. For the complete, corrected text of 10 CFR 2.714(d), please see 67 FR 20884; April 29, 2002."

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of

the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland, by the above date. Because of the continuing disruptions in delivery of mail to United States Government offices, it is requested that petitions for leave to intervene and requests for hearing be transmitted to the Secretary of the Commission either by means of facsimile transmission to 301-415-1101 or by e-mail to hearingdocket@nrc.gov. A copy of the petition for leave to intervene and request for hearing should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and because of continuing disruptions in delivery of mail to United States Government offices, it is requested that copies be transmitted either by means of facsimile transmission to 301-415-3725 or by e-mail to OGCMailCenter@nrc.gov. A copy of the request for hearing and petition for leave to intervene should also be sent to General Counsel, Tennessee Valley Authority, 400 West Summit Hill Drive, ET 11A, Knoxville, Tennessee 37902, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the

petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated February 14, 2003, which is available for public inspection at the Commission's PDR, located at One White Flint North, File Public Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management System's (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 11th day of March 2003.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Raj K. Anand, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Mr. J. A. Scalice
Tennessee Valley Authority

SEQUOYAH NUCLEAR PLANT

cc:

Mr. Karl W. Singer, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Pedro Salas, Manager
Licensing and Industry Affairs
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. James E. Maddox, Acting Vice President
Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. D. L. Koehl, Plant Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. Richard T. Purcell
Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. Lawrence E. Nanney, Director
Division of Radiological Health
Dept. of Environment & Conservation
Third Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

Mr. Robert J. Adney, General Manager
Nuclear Assurance
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

County Executive
Hamilton County Courthouse
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Ms. Ann P. Harris
341 Swing Loop Road
Rockwood, Tennessee 37854