

James R. Hayes
Manager - Radwaste, Environmental, Chemistry

440-280-7519
Fax: 440-280-5681

March 13, 2003
PY-CEI/LCDU-0069L


Attention: Robert Shelby, Mentor Waste Facility
Lake County Department of Utilities
P.O. Box 490
Painesville, Ohio 44077-0490

Ladies and Gentlemen:

Enclosed are the results of an isotopic analysis performed for industrial wastewater from the Perry Nuclear Power Plant. No radioactive material was detected.

If you have questions or require additional information, please contact Mr. Leo Harte at (440) 280-5514.

Very truly yours,



Enclosures

cc: NRC Region III
NRC Resident Inspector Office
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

JES

Note: [REDACTED]

Test Information by Sample Screen

MPL Number: SEWAGE
Sample ID: 389640
System Name: ENVIRONMEN
Mode Number: 6
Reason/Freq: Q

Sched Sampled Date: 0:00:00 1/01/03
Actual Sampled Date: 9:00:00 2/25/03
Desc: Environmental Sample
Desc: At All Times
Desc: Quarterly

Status: PV

Isotopic by Gamma Spectroscopy

Limit: 0.00 to 0.00

0.00E+00 uCi/ml
uCi/cc for N/G samples
uCi/sec for O/G pre and post samples
uCi/gm for resin samples

MCA: 1002

NOTE: A numeric result of zero indicates 'None Detected'