

March 20, 2003

Mr. William T. Cottle  
President and Chief Executive Officer  
STP Nuclear Operating Company  
South Texas Project Electric  
Generating Station  
P. O. Box 289  
Wadsworth, TX 77483

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2 - SECOND CORRECTION OF  
ADMINISTRATIVE ERRORS RE: AMENDMENTS ON RELOCATION OF  
SHUTDOWN MARGIN LIMITS TO CORE OPERATING LIMITS REPORT  
(TAC NOS. MB5155 AND MB5156)

Dear Mr. Cottle:

On February 4, 2003, the Commission issued Amendment No. 150 to Facility Operating License No. NPF-76 and Amendment No. 138 to Facility Operating License No. NPF-80 for the South Texas Project, Units 1 and 2, respectively. The amendments relocated the shutdown margin limits from the Technical Specifications (TSs) to the Core Operating Limits Report and modified certain boron requirements consistent with NUREG-1431.

Through an administrative error, changes previously made to TS index pages iv and xi in Amendment Nos. 145 and 133 for South Texas Project, Units 1 and 2, respectively, were not captured in Amendments 150 and 138. The revised pages are enclosed.

Sincerely,

***/RA/ DJaffe for***

Mohan C. Thadani, Senior Project Manager, Section 1  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: Corrected TS pages

cc: See next page

March 20, 2003

Mr. William T. Cottle  
President and Chief Executive Officer  
STP Nuclear Operating Company  
South Texas Project Electric  
Generating Station  
P. O. Box 289  
Wadsworth, TX 77483

SUBJECT: SOUTH TEXAS PROJECT, UNITS 1 AND 2 - SECOND CORRECTION OF ADMINISTRATIVE ERRORS RE: AMENDMENTS ON RELOCATION OF SHUTDOWN MARGIN LIMITS TO CORE OPERATING LIMITS REPORT (TAC NOS. MB5155 AND MB5156)

Dear Mr. Cottle:

On February 4, 2003, the Commission issued Amendment No. 150 to Facility Operating License No. NPF-76 and Amendment No. 138 to Facility Operating License No. NPF-80 for the South Texas Project, Units 1 and 2, respectively. The amendments relocated the shutdown margin limits from the Technical Specifications (TSs) to the Core Operating Limits Report and modified certain boration requirements consistent with NUREG-1431.

Through an administrative error, changes previously made to TS index pages iv and xi in Amendment Nos. 145 and 133 for South Texas Project, Units 1 and 2, respectively, were not captured in Amendments 150 and 138. The revised pages are enclosed.

Sincerely,  
**/RA/ DJaffe for**  
Mohan C. Thadani, Senior Project Manager, Section 1  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499  
Enclosure: Corrected TS pages  
cc: See next page

DISTRIBUTION:

PUBLIC  
PDIV-1 r/f  
G. Hill (2)  
RidsNrrDripRorp (R. Dennig)  
RidsAcrsAcnwMailCenter  
RidsNrrDlpmLpdiv (H. Berkow)

RidsNrrLAMMcAllister  
RidsNrrPMMThadani  
RidsNrrPMMHoncharik  
RidsOgcRp  
RidsRgn4MailCenter (B.Johnson)

ACCESSION NO: ML030790167

NRR-106

OFFICE	PDIV-1/PM	PDIV-1/LA	PDIV-1/PM	PDIV-1/SC
NAME	MHoncharik	MMcAllister	DJaffe for MThadani	RGramm
DATE	3/19/2003	3/19/2003	3/19/2003	3/20/2003

OFFICIAL AGENCY RECORD

South Texas, Units 1 & 2

cc:

Mr. Cornelius F. O'Keefe  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, TX 77414

A. Ramirez/C. M. Canady  
City of Austin  
Electric Utility Department  
721 Barton Springs Road  
Austin, TX 78704

Mr. M. T. Hardt  
Mr. W. C. Gunst  
City Public Service Board  
P. O. Box 1771  
San Antonio, TX 78296

Mr. C. A. Johnson/R. P. Powers  
AEP - Central Power and Light Company  
P. O. Box 289  
Mail Code: N5022  
Wadsworth, TX 77483

INPO  
Records Center  
700 Galleria Parkway  
Atlanta, GA 30339-3064

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

D. G. Tees/R. L. Balcom  
Texas Genco, LP  
P. O. Box 1700  
Houston, TX 77251

Judge, Matagorda County  
Matagorda County Courthouse  
1700 Seventh Street  
Bay City, TX 77414

A. H. Gutterman, Esq.  
Morgan, Lewis & Bockius  
1111 Pennsylvania Avenue, NW  
Washington, DC 20004

Mr. T. J. Jordan, Vice President  
Engineering & Technical Services  
STP Nuclear Operating Company  
P. O. Box 289  
Wadsworth, TX 77483

S. M. Head, Manager, Licensing  
Nuclear Quality & Licensing Department  
STP Nuclear Operating Company  
P. O. Box 289, Mail Code: N5014  
Wadsworth, TX 77483

Environmental and Natural Resources  
Policy Director  
P. O. Box 12428  
Austin, TX 78711-3189

Jon C. Wood  
Matthews & Branscomb  
112 East Pecan, Suite 1100  
San Antonio, TX 78205

Arthur C. Tate, Director  
Division of Compliance & Inspection  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756

Brian Almon  
Public Utility Commission  
William B. Travis Building  
P. O. Box 13326  
1701 North Congress Avenue  
Austin, TX 78701-3326

South Texas, Units 1 & 2

-2-

Susan M. Jablonski  
Office of Permitting, Remediation  
and Registration  
Texas Commission on  
Environmental Quality  
MC-122  
P.O. Box 13087  
Austin, TX 78711-3087

G. R. Bynog, Program Manager/  
Chief Inspector  
Texas Department of Licensing  
and Regulation  
Boiler Division  
P. O. Box 12157, Capitol Station  
Austin, TX 78711

Mr. Ted Enos  
4200 South Hulen  
Suite 630  
Ft. Worth, Texas 76109

## INDEX

### LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

---

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.0 APPLICABILITY</u>	3/4 0-1
<u>3/4.1 REACTIVITY CONTROLS SYSTEMS</u>	
3/4.1.1 BORATION CONTROL	
Shutdown Margin	3/4 1-1
Moderator Temperature Coefficient	3/4 1-6
FIGURE 3.1-2a BOL MTC VERSUS POWER	3/4 1-7a
Minimum Temperature for Criticality	3/4 1-8
3/4.1.2 (This specification not used)	
3/4.1.3 MOVEABLE CONTROL ASSEMBLIES	
Group Height	3/4 1-16
TABLE 3.1-1 ACCIDENT ANALYSIS REQUIRING REEVALUATION IN THE EVENT OF AN INOPERABLE FULL-LENGTH ROD	3/4 1-18
Position Indication Systems - Operating	3/4 1-19
Rod Drop Time	3/4 1-21
Shutdown Rod Insertion Limit	3/4 1-22
Control Rod Insertion Limits	3/4 1-23

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

---

<u>SECTION</u>	<u>PAGE</u>	
3/4.9.11	WATER LEVEL - STORAGE POOLS	
	Spent Fuel Pool	3/4 9-12
	In-Containment Storage Pool	3/4 9-13
3/4.9.12	FUEL HANDLING BUILDING EXHAUST AIR SYSTEM	3/4 9-14
3/4.9.13	SPENT FUEL POOL MINIMUM BORON CONCENTRATION	3/4 9-17
<u>3/4.10 SPECIAL TEST EXCEPTIONS</u>		
3/4.10.1	SHUTDOWN MARGIN	3/4 10-1
3/4.10.2	GROUP HEIGHT, INSERTION, AND POWER DISTRIBUTION LIMITS	3/4 10-2
3/4.10.3	PHYSICS TESTS	3/4 10-3
3/4.10.4	REACTOR COOLANT LOOPS	3/4 10-4
3/4 10.5	(This specification not used)	
3/4-10.6	(This specification not used)	
3/4.10.7	(This specification not used)	
<u>3/4.11 RADIOACTIVE EFFLUENTS</u>		
3/4.11.1	LIQUID EFFLUENTS	
	Liquid Holdup Tanks	3/4 11-1
3/4.11.2	GASEOUS EFFLUENTS	
	Gas Storage Tanks	3/4 11-3
3/4.11.3	(This specification not used)	
3/4.11.4	(This specification not used)	