

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
11/06/2002 12:25		Started discharge of "B" MT [Shaw, Mike - PAB (FireBngade) - Station Log - Swing Shift]
11/06/2002 12:45		Placed U1 and U2 traveling screens in automatic [Scheppman, Darrell - U2 TurbHall (FireBngade) - Station Log - Day Shift]
11/06/2002 13:19		Common - IT-15 Chill Water Pumps and Valves (Quarterly) completed satisfactorily (WO 9947659) [Jessessky, Tom - OS (Fire Brigade) - Station Log - Day Shift]
11/06/2002 14:10		Common - P-38B Motor Driven Auxiliary Feed Pump has been returned to service. Reference OPR 000031 (CAP 029952). Administrative and procedural controls are in place and thus, operability of the pump is not relying on the recirculation path. [Jessessky, Tom - OS (Fire Bngade) - Station Log - Day Shift]
11/06/2002 14:10	1RE-211/212 OOS	Common P-38B returned to service. LCO 3 7.5 is now met. [Stalzer, Charles - OS (Fire Bngade) - Station Log - Swing Shift]
11/06/2002 14:21		Placed U1 traveling screens in hand to supply pressure for filling sodium hypochlorite tank. [Scheppman, Darrell - U2 TurbHall (FireBrigade) - Station Log - Day Shift]
11/06/2002 14:35	NLOGS01	Schleif, James Assumed DOS (Fire Brigade) Position from Hansen, Mark, DOS (Fire Bngade) [Schleif, James - DOS (Fire Bngade) - Station Log - Swing Shift]
11/06/2002 14:36	NLOGS01	Mohr, Mike Assumed DSS Position from Mohr, Mike, DSS. [Mohr, Mike - DSS - Station Log - Swing Shift]
11/06/2002 14:36	NLOGS01	Jessessky, Tom Assumed OS (Fire Brigade) Position from Jessessky, Tom, OS (Fire Bngade) [Jessessky, Tom - OS (Fire Bngade) - Station Log - Swing Shift]
11/06/2002 14:37	NLOGS01	Wilson, Jim Assumed STA Position from Raasch, Dean, STA. [Wilson, Jim - STA - Station Log - Swing Shift]
11/06/2002 14:40		Secured discharge of "B" MT due to radiography affecting 2RE-229 [Shaw, Mike - PAB (FireBrigade) - Station Log - Swing Shift]
11/06/2002 14:52	NLOGS01	Green, Jim Assumed 4th License Position from Pond, Dan, 4th License. [Green, Jim - 4th License - Station Log - Swing Shift]
11/06/2002 14:55	NLOGS01	Pond, Dan Assumed Unit 2 CO Position from Herman, Bill [Pond, Dan - Unit 2 CO - Station Log - Day Shift]
11/06/2002 15:08		Placed U1 traveling screens in auto [Scheppman, Darrell - U2 TurbHall (FireBrigade) - Station Log - Day Shift]
11/06/2002 15:26	NLOGS01	Lohr, Tim Assumed 3rd License Position from Hammill, Pete, 3rd License. [Lohr, Tim - 3rd License - Station Log - Swing Shift]
11/06/2002 15:26	NLOGS01	Wallace, Rob Assumed Unit 1 CO Position from Inman, Rick, Unit 1 CO [Wallace, Rob - Unit 1 CO - Station Log - Swing Shift]
11/06/2002 15:27	NLOGS01	Becker, Joe Assumed U2 TurbHall (FireBrigade) Position. [Becker, Joe - U2 TurbHall (FireBrigade) - Station Log - Swing Shift]
11/06/2002 15:27	NLOGS01	Purvis, Dale Assumed WtrTreatment(FireBrigade) Position from Thilmony, Steve, WtrTreatment(FireBrigade). [Purvis, Dale - WtrTreatment(FireBrigade) - Station Log - Swing Shift]
11/06/2002 15:27	NLOGS01	Baugniet, Jeff Assumed U1 TurbHall (FireBrigade) Position from Becker, Joe, U1 TurbHall (FireBrigade) [Baugniet, Jeff - U1 TurbHall (FireBngade) - Station Log - Swing Shift]
11/06/2002 15:29	NLOGS01	Shaw, Mike Assumed PAB (FireBngade) Position from Shaw, Mike, PAB (FireBrigade). [Shaw, Mike - PAB (FireBrigade) - Station Log - Swing Shift]
11/06/2002 15:34	NLOGS02	Log turned over by Schleif, James [Schleif, James - MISC - Station Log - Day Shift]
11/06/2002 15:35	NLOGS03	Log approved by Schlerf, James [Schleif, James - MISC - Station Log - Day Shift]

A/319

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
11/06/2002 16:19		Doug VanDyke is a level 3 dedicated operator IAW OI-62A while P-38B motor driven aux feed pump is running [Lohr, Tim - 3rd License - Station Log - Swing Shift]
11/06/2002 16:20		Secured purification of U1 RWST [Shaw, Mike - PAB (FireBngade) - Station Log - Swing Shift]
11/06/2002 16:21		Started P-38B, electric aux feed pump, IAW OI-62A to facilitate radiography [Lohr, Tim - 3rd License - Station Log - Swing Shift]
11/06/2002 16:34		Secured P-38B electric AFP IAW OI-62A. [Lohr, Tim - 3rd License - Station Log - Swing Shift]
11/06/2002 16:35		Doug VanDyke is released as a level 3 dedicated operator IAW OI-62A [Lohr, Tim - 3rd License - Station Log - Swing Shift]
11/06/2002 16:50		Data from the P38B Aux Feed Pump run. From C01 Discharge flow = 0, Suction Pressure 15.5 psig, Discharge Pressure= 1310 psig At Pump: Recirc Flow = 69gpm, Suction Pressure = 16 psig, Discharge Pressure = 1315 psig [Jessesky, Tom - OS (Fire Brigade) - Station Log - Swing Shift]
11/06/2002 17:00	DSS Midnight Entry	Performed limited restoration of PAB Ventilation to support Chemistry sampling activities. Started W-21B, PAB Stack Fan, W-27B, HP Exhaust Fan, and W-30B, PAB Exhaust Filter Fan. Notified Chemistry. [Schleif, James - DOS (Fire Brigade) - Station Log - Swing Shift]
11/06/2002 17:00	ANNOTATION	Common. LCO 3 7.5 is not met for both units. Entering TSAC 3.7.5 C required action C 1 to restore pump to operable status in 7 days and within 10 days of failure to meet LCO. [Stalzer, Charles - OS (Fire Brigade) - Station Log - Swing Shift]
11/06/2002 17:00		P38B Motor Driven Aux Feed Pump OOS for recirc line inspection. Fire rounds initiated in accordance with OM 3 27. [Jessesky, Tom - OS (Fire Brigade) - Station Log - Swing Shift]
11/06/2002 17:20	NLOGS01	Stalzer, Charles Assumed OS (Fire Brigade) Position from Jessesky, Tom [Stalzer, Charles - OS (Fire Brigade) - Station Log - Swing Shift]
11/06/2002 17:25	PC 23 part 1	Completed review of PC 75 Part 3, Monthly Smoke and Heat Ventilation Systems Surveillance Test - SAT. [Schleif, James - DOS (Fire Brigade) - Station Log - Swing Shift]
11/06/2002 17:37	PC 23 part 1	Completed Attachment A of WP #2002-088, Unit 2 Main Electrical Generator Liquid In-Leakage Draining. Amount of leakage drained is 1250 ml. [Schleif, James - DOS (Fire Brigade) - Station Log - Swing Shift]
11/06/2002 17:39		Drained Unit 1 Sump 'A' IAW the ARB. [Wallace, Rob - Unit 1 CO - Station Log - Swing Shift]
11/06/2002 18:15	WT Backwashed	Unit 2, 2RE-109 flow is secured for Chemistry sampling. [Lewis, Al - Unit 2 CO - Station Log - Swing Shift]
11/06/2002 18:22	WT Backwashed	(Late Entry 1155) Unit 1 completed 60 minute mixed bed run per OP 5D Part 7 CVCS Demineralizer Operation. [Stalzer, Charles - OS (Fire Brigade) - Station Log - Swing Shift]
11/06/2002 18:51	NLOGS01	Boris, Randy Assumed U2 TurbHall (FireBrigade) Position from Becker, Joe [Boris, Randy - U2 TurbHall (FireBrigade) - Station Log - Swing Shift]
11/06/2002 18:52	NLOGS01	Johnson, James M. Assumed PAB (FireBrigade) Position from Shaw, Mike [Johnson, James M. - PAB (FireBrigade) - Station Log - Swing Shift]
11/06/2002 19:00	Facade Sump	Stop discharge of T-10B Monitor Tank, final level 11%. [Johnson, James M. - PAB (FireBrigade) - Station Log - Swing Shift]
11/06/2002 19:12	NLOGS01	Weber, Dan Assumed DSS Position from Mohr, Mike [Weber, Dan - DSS - Station Log - Swing Shift]
11/06/2002 19:16	EQINSERVIC	Started and paralleled Unit 1 Rod Drive MG Set G-06 per OI-31. PMT-SAT. 1G-06 Rod Drive MG Set returned to service. [Schleif, James - DOS (Fire Brigade) - Station Log - Swing Shift]

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
11/06/2002 19:23	WT Backwashed	Unit 2, 2RE-109 flow is restored Chemistry RCS sampling is completed [Lewis, Al - Unit 2 CO - Station Log - Swing Shift]
11/06/2002 19:53	DSS Midnight Entry	Common - Shifted PAB ventilation filters from F-29, HEPA, to F-23, Charcoal, for RP testing. [Green, Jim - 4th License - Station Log - Swing Shift]
11/06/2002 20:05		started release of neut tank level at 90% [Purvis, Dale - WtrTreatment(FireBngade) - Station Log - Swing Shift]
11/06/2002 20:30	EQOUTOFSRV	Notified by EP that Siren P-006 is OOS. Population coverage is 10 47% This is not reportable per DCS 2.1.1. [Schleif, James - DOS (Fire Bngade) - Station Log - Swing Shift]
11/06/2002 20:50		Unit 1 Completed IT-380, Purge Valve Air System Check Valve Test. [Johnson, James M. - PAB (FireBngade) - Station Log - Swing Shift]
11/06/2002 20:56	DSS Midnight Entry	Unit 1 - Added nitrogen to 1T-34A, SI Accumulator, IAW OI-100 Pressure increased from 720 psig to 730 psig Final levels: 1LI-938 = 20%, 1LI-939A = 22%. [Green, Jim - 4th License - Station Log - Swing Shift]
11/06/2002 22:10		completed release of neut tank level at 0% [Purvis, Dale - WtrTreatment(FireBngade) - Station Log - Swing Shift]
11/06/2002 22:10	NLOGS01	Hastings, Randy Assumed STA Position from Wilson, Jim, STA. [Hastings, Randy - STA - Station Log - Mid Shift]
11/06/2002 22:39		Notified by chemistry that at 2120 Unit 1 enters ACTION LEVEL 1 for Lithium being low. [Boeselager, Mike - MISC - Station Log - Swing Shift]
11/06/2002 22:41	NLOGS01	Boeselager, Mike Assumed OS (Fire Brigade) Position from Stalzer, Charles, OS (Fire Brigade). [Boeselager, Mike - OS (Fire Brigade) - Station Log - Mid Shift]
11/06/2002 22:42	NLOGS01	Milner, Dave Assumed DOS (Fire Brigade) Position from Schleif, James, DOS (Fire Brigade). [Milner, Dave - DOS (Fire Brigade) - Station Log - Mid Shift]
11/06/2002 22:43	NLOGS01	Weber, Dan Assumed DSS Position from Weber, Dan, DSS. [Weber, Dan - DSS - Station Log - Mid Shift]
11/06/2002 22:50	NLOGS01	Boris, Randy Assumed U2 TurbHall (FireBrigade) Position from Boris, Randy, U2 TurbHall (FireBrigade). [Boris, Randy - U2 TurbHall (FireBrigade) - Station Log - Mid Shift]
11/06/2002 23:04		Common - Shifted PAB ventilation filters from F-23 (Charcoal filter) to F-29 (HEPA filter) following RP testing [Wallace, Rob - Unit 1 CO - Station Log - Swing Shift]
11/06/2002 23:22	NLOGS01	Hopka, Neil Assumed Unit 1 CO Position from Wallace, Rob, Unit 1 CO. [Hopka, Neil - Unit 1 CO - Station Log - Mid Shift]
11/06/2002 23:22	NLOGS01	Bryant, Sky Assumed Unit 2 CO Position from Lewis, Al, Unit 2 CO. [Bryant, Sky - Unit 2 CO - Station Log - Mid Shift]
11/06/2002 23:22	NLOGS01	Wallace, Rob Assumed 3rd License Position from Lohr, Tim, 3rd License. [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/06/2002 23:23	NLOGS01	O'Connor, Dennis Assumed 4th License Position from Green, Jim, 4th License. [O'Connor, Dennis - 4th License - Station Log - Mid Shift]
11/06/2002 23:23	NLOGS01	Johnson, James M. Assumed PAB (FireBrigade) Position from Johnson, James M, PAB (FireBrigade). [Johnson, James M. - PAB (FireBrigade) - Station Log - Mid Shift]
11/06/2002 23:23	NLOGS01	Beale, Ray Assumed WtrTreatment(FireBrigade) Position from Purvis, Dale, WtrTreatment(FireBrigade). [Beale, Ray - WtrTreatment(FireBrigade) - Station Log - Mid Shift]
11/06/2002 23:24	NLOGS01	Jemigan, Dave Assumed U1 TurbHall (FireBrigade) Position from Baugniet, Jeff, U1 TurbHall (FireBrigade). [Jemigan, Dave - U1 TurbHall (FireBrigade) - Station Log - Mid Shift]

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
11/07/2002 00:00		Both units in MODE 1 at full power TS LCO 3.7.5 not met for Units 1 and 2 due to P-38B Motor Driven Aux Feed Pump being inoperable for onfice inspection TSAC 3 7.5 C 7 days and 10 days from discovery to complete Required Action C.1. 2RC-508 is OOS, Unit 2 TSAC 3 6 3.A 2 to verify isolation once per 31 days 2TI-450C A loop T cold wide range is OOS, TSAC 3 3 3.A and B met, restore within 30 days or submit a report to NRC (14 day PAM Report per TS 5.6 6 was submitted 9/26/02) Equipment OOS and Fire Rounds are per the OOS doc [Weber, Dan - DSS - Station Log - Mid Shift]
11/07/2002 00:00	NLOGS02	Log turned over by Milner, Dave [Milner, Dave - MISC - Station Log - Swing Shift]
11/07/2002 00:01	NLOGS03	Log approved by Milner, Dave [Milner, Dave - MISC - Station Log - Swing Shift]
11/07/2002 00:14		Jim Johnson stationed as a Level 2 Dedicated Operator for 2WL-1409B while obtaining a Unit 2 Sump 'A' sample IAW OI-95 [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/07/2002 00:20		Completed obtaining a Unit 2 Sump 'A' sample Jim Johnson is released as the Level 2 Dedicated Operator for 2WL-1409B. [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/07/2002 00:25		Drained Unit 2 Sump 'A' IAW the ARB. [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/07/2002 00:25		LCO 3.4.15, RCS Leakage Detection instrumentation is not met due to filter change out on 1RE-211/212 by RP. Enter TSAC 3 4.15.B for 1RE-211/212. RA B 1.1, Analyze grab samples of the containment atmosphere with a completion time of once per 24 hours or B.1.2, Perform SR 3.4.13.1 with a completion time of once per 24 hours, and B.2., Restore required containment atmosphere radioactivity monitor to OPERABLE status with a completion time of 30 days. [Hopka, Neil - Unit 1 CO - Station Log - Mid Shift]
11/07/2002 00:29		1RE-211/212 filter change out complete. Exit TSAC 3.4.15 Condition B. LCO 3.4 15 met. [Hopka, Neil - Unit 1 CO - Station Log - Mid Shift]
11/07/2002 00:32		LCO 3.4.15, RCS Leakage Detection Instrumentation is not met due to filter change out on 2RE-211/212 by RP. Enter TSAC 3.4.15 B for 2RE-211/212. RA are B.1.1, Analyze grab samples of the containment atmosphere with a completion time of once per 24 hours or B.1.2, Perform SR 3 4.13.1 with a completion time of once per 24 hours, and B.2., Restore required containment atmosphere radioactivity monitor to OPERABLE status with a completion time of 30 days. [Hopka, Neil - Unit 1 CO - Station Log - Mid Shift]
11/07/2002 00:34		2RE-211/212 filter change out complete. Exit TSAC 3.4.15 Condition B. LCO 3.4.15 met. [Hopka, Neil - Unit 1 CO - Station Log - Mid Shift]
11/07/2002 01:28		Ray Beale stationed as a Level 3 Dedicated Operator to monitor P-38B AFW pump recirc flow IAW OI-62A [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/07/2002 01:30		Started P-38B AFW pump IAW OI-62A, for a 5 minute PMT run. [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/07/2002 01:36		Secured P-38B AFW pump. [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/07/2002 01:37		Released Ray Beale as the Level 3 Dedicated Operator IAW OI-62A. [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/07/2002 01:43		P-38B AFW pump PMT run completed SAT IAW OI-62A. P-38B returned to service Both Units exit TSAC 3.7.5.C (entered on 11-06-02 @ 1700) and LCO 3.7.5 is now met for both Units. [Wallace, Rob - 3rd License - Station Log - Mid Shift]
11/07/2002 02:45		Secured PAB ventilation for W21A fan work. [Hopka, Neil - Unit 1 CO - Station Log - Mid Shift]
11/07/2002 02:50	NLOGS01	Stock, Lee Assumed 3rd License Position from Wallace, Rob [Stock, Lee - 3rd License - Station Log - Mid Shift]
11/07/2002 03:00		Received Revision 1 of OPR 000031 for CAP 029952 concerning potential for insufficient minimum pump flow for the AFW pumps The AF System remains Operable but Non Conforming [Weber, Dan - DSS - Station Log - Mid Shift]

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
11/07/2002 04:15	ICP-2.001xx Start	0-TS-EP-001 Weekly Power Availability Verification completed SAT. [Hastings, Randy - STA - Station Log - Mid Shift]
Entry Date/Time	Entry Type	Entry Text
11/07/2002 05:00		Unit 2 LCO 3 7.5 not met. Enter TSAC 3.7.5 A 1 and B 1 for MS-2019 and MS-2020 OOS and 2P-29 OOS IAW PC 43 Part 5 [Boeselager, Mike - OS (Fire Brigade) - Station Log - Mid Shift]