



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
801 Warrenton Road, Suite 266
Lisle, Illinois 60532-5351

TELEFAX TRANSMITTAL

DATE: 11/20/02 NUMBER OF PAGES: 2
(including this page)

SEND TO: Mike Kunowick

LOCATION: R III / DRP / Branch 5

FAX NUMBER: - - - VERIFY BY CALLING SENDER

FROM: Paul Krohn
(SENDER)

TELEPHONE NUMBER: 630 - - - FAX NUMBER: 630 - - -

If you do not receive the complete fax transmittal, please contact the sender as soon as possible at the telephone number provided above.

MESSAGE

Mike,
Got this from Ken Peveler, 11/20 @ 1300.
AFW receive Issue timeline.

Paul

NOTICE

This message is intended only for the use of the individual or entity to which it is addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If the reader of this message is not the intended recipient or the employee responsible for delivering the message to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please notify the sender immediately by telephone and return the original to the above address, by U.S. Mail. Thank you.

OPEN ISSUES	WHO	WHEN	COMMENTS
Incident Investigation	S. Thomas	11/21/2002	
On-Line Work Risk Management NP 10.3.7, Unplanned Yellow Actions	J. Anderson R. Wood	Ongoing Ongoing	Ref CA27023 and CAP30052/Mod required for green
Interim Corrective Actions			
CA026908/Charter Tracking Item	D. Schoon	11/27/2002	
Training Needs Analysis and Related Actions	P. Smith	2/2/2003	Ref CAP029999/CA026986- Trng Needs Analysis is completed
Condition Evaluation/further enhancements	M. Schug	12/6/2002	Ref CAP029999/CE10848
Independent Evaluation of Procedure changes	D. Schoon	11/27/2002	Ref CA026909 - review complete/complete CA
Independent Evaluation of briefings & training	D. Schoon	11/27/2002	Ref CA026910 - review complete/complete CA
Engineering Resolution Team and RCE			
Conduct Root Cause Evaluation - Draft Report	R. Flessner	11/18/2002	Ref RCE0000191 - first draft issued
Conduct Root Cause Evaluation - Final Report	R. Flessner	11/26/2002	
PRA/risk significance evaluation	J. Masterark	1/29/2003	Ref CA026900/Also requires PII inputs
Hydraulic system response	T. Kendall	12/15/2002	CA026911- PII final report expected 12/20/02
Develop a test plan	T. Kendall	TBD	CA026912 - PII/PSA/Engr - remains under consideration
Analyze corrosion products	B. Zipp	1/20/2003	CA026913- PII final report expected 12/20/02
AFW sources and quantity of corrosion products	B. Zipp	1/20/2003	CA026914 - PII final report expected 12/20/02
Modifications to onice design	J. McNamara	12/13/2002	Ref CA026918
Fabrication	J. McNamara	12/17/2002	5 weeks from 11/12 is December 17
Testing	J. McNamara	TBD	Coordination
Installation	J. McNamara	TBD	Planning for
Coordination of work schedule with station	J. McNamara	TBD	13 week schedule process - Input
OPR000031 Part II/Schedule for correction due	J. McNamara	11/27/2002	Complete Part II of OD 31
NEW - Electrical design modifications	M. Rosseau	TBD	Scope, schedule, etc (Clint Drescher as designer)