

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.9 Pressurizer

LCO 3.4.9 The pressurizer shall be OPERABLE with:

- a. Actual pressurizer water level \leq 58.3% in MODES 1 and 2 or \leq 90% in MODE 3; and
- b. Two groups of pressurizer heaters OPERABLE with the capacity of each group \geq 150 kW and capable of being powered from an emergency power supply.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Pressurizer water level not within limit.	A.1 Be in MODE 3 with reactor trip breakers open.	6 hours
	<u>AND</u> A.2 Be in MODE 4.	12 hours
B. One required group of pressurizer heaters inoperable.	B.1 Restore required group of pressurizer heaters to OPERABLE status.	72 hours
C. Required Action and associated Completion Time of Condition B not met.	C.1 Be in MODE 3.	6 hours
	<u>AND</u> C.2 Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.9.1	Verify actual pressurizer water level is $\leq 58.3\%$ in MODES 1 and 2 <u>OR</u> $\leq 90\%$ in MODE 3.	12 hours
SR 3.4.9.2	Verify capacity of each required group of pressurizer heaters is ≥ 150 kW.	24 months

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources - Operating

LCO 3.8.4 The following four DC electrical power subsystems shall be OPERABLE:

Battery 31 and associated Battery Charger;
Battery 32 and associated Battery Charger;
Battery 33 and associated Battery Charger; and
Battery 34.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. DC electrical power subsystem 34 inoperable.	A.1 Declare Inverter 34 inoperable and take Required Actions specified in LCO 3.8.7, Inverters-Operating.	2 hours
B. One DC electrical power subsystem (31 or 32 or 33) inoperable.	B.1 Restore DC electrical power subsystem to OPERABLE status.	2 hours
C. Required Action and Associated Completion Time not met.	C.1 Be in MODE 3.	6 hours
	<u>AND</u> C.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.1 Verify battery terminal voltage on float charge is within the following limits:</p> <p> a. ≥ 125.7 V for battery 31;</p> <p> b. ≥ 123.5 V for battery 32; and</p> <p> c. ≥ 127.8 V for batteries 33 and 34.</p>	<p>31 days</p>
<p>SR 3.8.4.2 -----NOTE----- This Surveillance shall not be performed in MODE 1, 2, 3, or 4. -----</p> <p>Verify each battery charger supplies its associated battery at the voltage and current adequate to demonstrate battery charger capability requirements are met.</p>	<p>24 months</p>
<p>SR 3.8.4.3 -----NOTES----- This Surveillance shall not be performed in MODE 1, 2, 3, or 4. -----</p> <p>Verify battery capacity is adequate to supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test or a modified performance discharge test.</p>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p>SR 3.8.4.4 -----NOTE----- This Surveillance shall not be performed in MODE 1, 2, 3, or 4. ----- Verify battery capacity is $\geq 80\%$ of the manufacturer's rating when subjected to a performance discharge test or a modified performance discharge test.</p>	<p>60 months <u>AND</u> 12 months when battery shows degradation or has reached 85% of expected life with capacity < 100% of manufacturer's rating <u>AND</u> 24 months when battery has reached 85% of the expected life with capacity $\geq 100\%$ of manufacturer's rating</p>
<p>SR 3.8.4.5 Verify battery cells, cell plates, and racks show no visual indication of physical damage or abnormal deterioration.</p>	<p>24 months</p>