

**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

AGENDA

- Purpose of Meeting
- Background
- SL2-14 Inspection Scope
- Projected Tube Plugging
- Inspection Criteria Changes
- Contingency Planning
- Contingency License Amendment Request
- Summary & Closing

1



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

Purpose of Meeting

- Review SL2 S/G Condition
- Review SL2-14 Inspection Plans
- Address Staff Request to NEI on Tubesheet Inspections
- Identify & Address Any Staff Concerns

2




STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Background

S/G Design

- ▶ CE Model 3410
- ▶ 8411 Tubes / SG
- ▶ ~16.8 EFPY @ SL2-14
- ▶ A-600 HTMA Tubing
- ▶ CS Lattice Support System
- ▶ Tubesheet Joint - Explosive
- ▶ Total Tubes Plugged
 - SG A - 474 (5.6%)
 - SG B - 539 (6.4%)
- ▶ T-Hot ~600°F



3



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Background

FPL Steam Generator Program

- Committed to Safe Operation
- Full Implementation of NEI 97-06, S/G Program Guidelines
 - ▶ Inspection
 - ▶ Chemistry
 - ▶ Leak Monitoring
- Incorporate Industry Experience
- Extensive Examination History at Unit 2
- Conservative Approach
 - ▶ In Situ Pressure Test at Last 4 Inspections

4



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

Background

- Last Inspection - SL2-13 in December 2001
- Operational Assessment Presented May 2, 2002
 - Most Damage Mechanisms as Expected
 - Increase in Axial ODSCC at Eggcrate Supports
 - On-set of Axial ODSCC at Dings
 - Degradation Trend Typical for Unit with A-600 MA Tubing



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

Background

Indication Count at SL2-13 (11/01)

Mechanism	S/G A	S/G B	Total
Axial ODSCC at Eggcrates	97	201	298
Axial ODSCC at Dings	5	1	6
Axial ODSCC at Tubesheet (Hot)	8	16	24
Axial IDSCC below Tubesheet (Hot)	2	0	2
Circumferential ODSCC at Tubesheet (Hot)	4	9	13
OD Volumetric	0	2	2
Wear at Tubesheet (Cold)	0	5	5
Wear at Tube Diagonal and Vertical Supports	581	397	978
Tubes Plugged at SL2-13	129	232	361



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

Background

In Situ Pressure Testing at SL2-13

<u>Mechanism</u>	<u>Tested</u>	<u>Pressure</u>
Axial ODSCC at Eggcrates	9	4950 psi
Axial ODSCC at Dents	5	4950 psi
Axial ODSCC at TTS	6	4950 psi
Axial IDSCC below TTS	2	4950 psi
Circ ODSCC at TTS	4	5550 psi
<u>OD Volumetric TTS</u>	<u>1</u>	<u>4950 psi</u>
Total Tested	27	

No Leakage or Burst

7



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

SL2-14 Inspection Scope

- Visual Examination of All Tube Plugs
- Bobbin Probe All Active Tubes
 - Full Length Row 3-140
 - Straight Length Row 1-2
 - Screening of Dings <5 Volts
- Plus Point Probe
 - 100% Hot Leg Top of Tubesheet (+3"/-5")
 - 20% Cold Leg Top of Tubesheet (+3"/-5")*
 - 25% Row 1-2 U-bends
 - 20% Wear Scars in U-bends*

*Added for SL2-14

8



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

SL2-14 Inspection Scope (Con't)

■ Plus Point Probe for Dings

- All Dings Hot Leg Tubesheet to 1st Support (A=45, B=36)
- All Dings >5 volts 1st Support to Hot Leg Bend (A=73, B=90)
- All Dings in HL & CL Square Bends Row 19-140 (A=8, B=5)
- All Dings >5 volts in Horizontal Run Row 19-140 (A=76, B=117)
- All Dings in U-Bend Region Rows 1-18 (A=107, B=114)
- 20% of Dings >5 volts TSC to CL Bend (A=17, B=25)*

*SL2-13 Included All Dings >10 volts TSC to CL Bend

9



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

Projected Tube Plugging

<u>Mechanism/Location</u>	<u>Predicted Number</u> <u>EOC 13</u>
Axial ODSCC at Eggcrate Supports	150 – 200
Axial ODSCC at Top of Tubesheet	40 – 60
Circumferential ODSCC at Expansion Transitions	15 – 25
Axial ODSCC at Dings	5 – 20
Axial IDSCC Below Secondary Face of Tubesheet	5 – 10
TOTAL PROJECTED	215 - 315

10



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Inspection Criteria Changes to Address Operating Experience

- Look Backs & Reporting Issues
 - Look Backs Over Longer Period
 - Apply Low Frequency Screen to U-bends & Square Bends
 - Modify Reporting Criteria to Include Flaw-like Indications <1%
- High Residual Stress - Manufacturing
 - Existing Issue for MA Tubing Plants
 - Screening Addressed by Existing Data Analysis Guidelines

11



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Contingency Planning

- Cold Leg Top of Tubesheet - Complete 100%
- Row 1&2 U-bends - Complete 100% and 20% Row 3
 - Continue Until No Defective U-bends
- U-bend Wear Scars - 100% Hot Leg & 20% Cold Leg
- Cold Leg Dings >5Volts - Complete 100%
- Freespan Cracking - See Next Pages

12



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

Contingency Planning (Con't)

- Overview Of Freespan Contingency Plan
 - Discussed with NRC prior to Last 4 Inspections
 - Sampling Methodology to Optimize Use of Resources
 - Statistical Basis for Operational Assessment
 - Reduces Risk of not Inspecting Affected Areas
 - Modified for SL2-14 Based on Industry Experience

13



**STEAM GENERATOR INSPECTION PLANNING
SL2-14 APRIL 2003 - NRR, WHITE FLINT**

Contingency Planning (Con't)

Free Span Cracking Plan

- Complete 100% Bobbin Coil Screening
- Plus Point Inspect Indications that are New or Show Change
- If Cracking is Confirmed:
 - Inspect Entire Straight Length On Side With Crack
 - Inspect 6 Neighbor Tubes at Same Span
- Validate Bobbin Probe POD
 - If Acceptable - End Free Span Program
 - If Not Acceptable - Proceed to Sampling Schemes

14



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Contingency Planning (Con't)

- Evaluate Locations of All Confirmed Free Span Cracks
- Determine Applicable Inspection Scenario
- Select Appropriate Sample Scheme
 - Maximize Use of Resources
 - Maximize Potential to Demonstrate Full Cycle Tube Integrity

SCENARIO	DEGREE	CLUSTERED	# CRACKS	SAMPLE SCHEME
CASE 1	NONE	N/A	0	NONE
CASE 2	MINIMAL	YES	<15	LHS
CASE 3	MINIMAL	NO	<15	LHS
CASE 4	MODERATE	YES	15-50	IMPORTANCE
CASE 5	MODERATE	NO	15-50	REDUCED LHS
CASE 6	SEVERE	YES	>50	IMPORTANCE
CASE 7	SEVERE	NO	>50	SYSTEMATIC*

LHS - Latin Hypercube Sampling
*Optimized to support bobbin POD

15



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Contingency Planning (Con't)

Case 2 or 3 Most Likely Scenario for Free Span Cracking

- Latin Hypercube Sampling Scheme
 - Proven Efficiency vs. Random Sampling
 - Provides Optimal Coverage
 - Widely Used Strategy in Monte-Carlo Simulation
 - Good Approach for Uncertainty in Extent of Condition
 - Robust Approach


16



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Contingency Planning (Con't)

LHS Example: Generate 11 X 11 Tube Box Around Tubes w/Crack
Sample Affected Region to Cover All Possibilities



17



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Contingency License Amendment Request

Change Definition of a Tube Inspection

- Contingency for Cycle 14 Only if Circumferential Cracks Detected in Tubesheet
- Limit Inspection Within the Tubesheet to 5"
- Similar to Recent Requests Approved for 1 Cycle
- Based on CEOG Work & Site Specific Topical
- NEI Letter of February 3, 2003 Responded to Staff Request for Information (15 Plants)

18



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Contingency License Amendment Request

Recent Inspections & Results for Indications Below the
Hot Leg Top-of-Tubesheet (TTS)

- No Circumferential Indications To Date Below TTS

Outage	HL-TTS Scope	Test Extent	Axials	Location	Depth	Length
SL2-10	100%	-2"	1	1.10"	93% ⁽¹⁾	0.22" ⁽¹⁾
SL2-12	100%	-2"	1	0.17"	90% ⁽²⁾	0.12" ⁽²⁾
SL2-13	100%	-5"	2*	2.10"	75% ⁽²⁾	0.23" ⁽²⁾

* 2 Indications in 1 Tube - Passed In Situ Pressure Test
(1) Max Depth/Length (2) Structural Depth/Length

19



STEAM GENERATOR INSPECTION PLANNING SL2-14 APRIL 2003 - NRR, WHITE FLINT

Summary & Closing

- FPL Program Meets Industry Guidance
- Reasonable Assurance of Tube Integrity
- Basis for Limiting Inspections Tubesheet
 - Contingency for Cycle 14 Only
 - Continue Effort Through NEI for Long-Term Resolution
- Identify & Address Staff Concerns

20