

From: Steven Long
To: Timothy Steingass *> NRR*
Date: 5/21/02 11:46AM
Subject: Re: Significance Review

Time,

- ✓ There are templates for performing "phase 2" of the "significance determination process" that assigns a "color" to inspection findings. However, those are not applicable to all findings and circumstances. When there is a finding (e.g., a hole in the D-B head) that doesn't fit any existing "phase 2" template, the process goes to "phase 3" which is completely free-form.

Steve

- ✓ >>> Timothy Steingass 05/21/02 10:58AM >>>
Steve:

Is there a template out there that the Residents and Senior Residents use to perform a safety significance review?

Tim Steingass
NRR/DE/EMCB
301-415-3312
09 G5

B/160