

Log Entries Report

Entry Date/Time	Entry Type	Entry Text
11/18/2002 02:01	DSS Midnight Entry	Unit 2 - Exited AOP-21, PPCS Malfunction Power maintained at 99.5% per DTP. [Green, Jim - Unit 2 CO - Station Log - Mid Shift]
11/18/2002 02:04	WT Backwashed	Common. Completed PC 6 part 2 with the number of Reverse Osmosis filter cartridges being UNSAT due to only 12 available (24 required). All other parts completed SAT. [Stalzer, Charles - DOS (Fire Brigade) - Station Log - Mid Shift]
11/18/2002 03:10	WT Backwashed	NRC plant status and phone check completed SAT. [Stalzer, Charles - DOS (Fire Brigade) - Station Log - Mid Shift]
11/18/2002 04:03	1RE-211/212 OOS	Unit 2, LCO 3.5.2, ECCS Operating is not met due to maintenance activities on 2P-15A Safety Injection Pump Entering TSAC 3.5.2.A for ECCS Train A (2P-15A) OOS RA A.1, Restore train to Operable within 72 hours [Schleif, James - OS (Fire Brigade) - Station Log - Mid Shift]
11/18/2002 06:00	DSS Midnight Entry	Unit 2 - Commenced 2% load swing IAW OP-2A Attachment A, for PPCS maintenance. [Green, Jim - Unit 2 CO - Station Log - Mid Shift]
11/18/2002 06:25	DSS Midnight Entry	Unit 2 - Holding power at 98% (1deg < full Delta T) IAW OP-2A. [Green, Jim - Unit 2 CO - Station Log - Mid Shift]
11/18/2002 06:25	WT Backwashed	U2. Notified Power Supply Supervisor that U2 is holding at 98% DTP. [Rittich, Dave - MISC - Station Log - Mid Shift]
11/18/2002 06:27	NLOGS01	Robbins, Rick Assumed STA Position from Wilson, Jim, STA. [Robbins, Rick - STA - Station Log - Day Shift]
11/18/2002 06:30	NLOGS01	Millen, Mike Assumed DOS (Fire Brigade) Position from Stalzer, Charles, DOS (Fire Brigade). [Millen, Mike - DOS (Fire Brigade) - Station Log - Day Shift]
11/18/2002 06:33	NLOGS01	Rittich, Dave Assumed OS (Fire Brigade) Position from Schleif, James, OS (Fire Brigade). [Rittich, Dave - OS (Fire Brigade) - Station Log - Day Shift]
11/18/2002 06:36	NLOGS01	Schug, Mike Assumed DSS Position from Merkes, Rick, DSS. [Schug, Mike - DSS - Station Log - Day Shift]

A1341