

FOR INCLUSION ON TECHNICAL SPECIFICATION WEB PAGE

THE FOLLOWING EXAMPLE OF AN APPLICATION WAS PREPARED BY THE NRC STAFF TO FACILITATE THE USE OF THE CONSOLIDATED LINE ITEM IMPROVEMENT PROCESS (CLIIP). THE MODEL PROVIDES THE EXPECTED LEVEL OF DETAIL AND CONTENT FOR AN APPLICATION TO ADOPT TSTF-404 USING CLIIP. LICENSEES REMAIN RESPONSIBLE FOR ENSURING THAT THEIR ACTUAL APPLICATION FULFILLS THEIR ADMINISTRATIVE REQUIREMENTS AS WELL AS NRC REGULATIONS.

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

SUBJECT: PLANT NAME
DOCKET NO. 50-
APPLICATION FOR TECHNICAL SPECIFICATION IMPROVEMENT TO
REVISE TECHNICAL SPECIFICATION [3.1.8], "SCRAM DISCHARGE VOLUME
(SDV) VENT AND DRAIN VALVES ," USING THE CONSOLIDATED LINE ITEM
IMPROVEMENT PROCESS

Gentlemen:

In accordance with the provisions of Section 10 CFR 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), [LICENSEE] is submitting a request for an amendment to the technical specifications (TSs) for [PLANT NAME, UNIT NOS.].

The proposed changes would revise the required action within TS [3.1.8, "Scram Discharge Volume (SDV) Vent and Drain Valves"] for the condition of having one or more SDV vent or drain lines with one valve inoperable. These changes are based on Technical Specifications Task Force (TSTF) change traveler TSTF-404 (Revision 0) that has been approved generically for the BWR [boiling water reactor]/4[6] Standard Technical Specifications (STS), NUREG-1433 [1434], Revision 2. The availability of this TS improvement was announced in the *Federal Register* on [DATE OF NOTICE OF AVAILABILITY] as part of the consolidated line item improvement process (CLIIP).

Enclosure 1 provides a description of the proposed change and confirmation of applicability. Enclosure 2 provides the existing TS pages marked-up to show the proposed change. *[IF APPLICABLE: Enclosure 3 provides the existing TS Bases pages marked-up to reflect the proposed change (for information only). Changes to the TS Bases will be provided in a future update in accordance with the Bases Control Program.]* There are no new regulatory commitments associated with this proposed change.

[LICENSEE] requests approval of the proposed license amendment by [DATE], with the amendment being implemented [BY DATE OR WITHIN X DAYS].

In accordance with 10 CFR 50.91, a copy of this application, with enclosures, is being provided to the designated [STATE] Official.

I declare under penalty of perjury under the laws of the United States of America that I am authorized by [LICENSEE] to make this request and that the foregoing is true and correct. [Note that request may be notarized in lieu of using this oath or affirmation statement].

If you should have any questions regarding this submittal, please contact [].

Sincerely,

Name, Title

Enclosures: 1. Description and Assessment
2. Proposed Technical Specification Changes
3. Proposed Technical Specification Bases Changes (if applicable)

cc: NRR Project Manager
Regional Office
Resident Inspector
State Contact

Description and Assessment

1.0 DESCRIPTION

The proposed changes would revise the required action within TS [3.1.8, "Scram Discharge Volume (SDV) Vent and Drain Valves"] for the condition of having one or more SDV vent or drain lines with one valve inoperable. These changes are based on Technical Specifications Task Force (TSTF) change traveler TSTF-404 (Revision 0) that has been approved generically for the BWR [boiling water reactor]/4[6] Standard Technical Specifications (STS), NUREG-1433 [1434], Revision 2. The availability of this technical specification improvement was announced in the *Federal Register* on [DATE OF NOTICE OF AVAILABILITY] as part of the consolidated line item improvement process (CLIIP).

2.0 ASSESSMENT

2.1 Applicability of Published Safety Evaluation

[LICENSEE] has reviewed the safety evaluation published on [DATE OF NOTICE OF AVAILABILITY] (68 FR) as part of the CLIIP. This verification included a review of the NRC staff's evaluation as well as the supporting information provided to support TSTF-404. [LICENSEE] has concluded that the justifications presented in the TSTF proposal and the safety evaluation prepared by the NRC staff are applicable to [PLANT, UNIT NOS.] and justify this amendment for the incorporation of the changes to the [PLANT] Technical Specifications.

2.2 Optional Changes and Variations

[LICENSEE] is not proposing any variations or deviations from the technical specification changes described in TSTF-404 or the NRC staff's model safety evaluation published on [DATE OF NOTICE OF AVAILABILITY].

3.0 REGULATORY ANALYSIS

3.1 No Significant Hazards Determination

[LICENSEE] has reviewed the proposed no significant hazards consideration determination published on [DATE OF NOTICE OF AVAILABILITY] as part of the CLIIP. [LICENSEE] has concluded that the proposed determination presented in the notice is applicable to [PLANT] and the determination is hereby incorporated by reference to satisfy the requirements of 10 CFR 50.91(a).

3.2 Verification and Commitments

There are no new regulatory commitments associated with this proposed change.

4.0 **ENVIRONMENTAL EVALUATION**

[LICENSEE] has reviewed the environmental evaluation included in the model safety evaluation published on [DATE OF NOTICE OF AVAILABILITY] as part of the CLIIP. [LICENSEE] has concluded that the NRC staff's findings presented in that evaluation are applicable to [PLANT] and the evaluation is hereby incorporated by reference for this application.

PROPOSED TECHNICAL SPECIFICATION CHANGES (MARK-UP)

POSSIBLE CHANGES TO TS BASES PAGES
(Optional - Bases to be updated per TS Bases Control Program)

In accordance with 10 CFR 50.91, a copy of this application, with enclosures, is being provided to the designated [STATE] Official.

I declare under penalty of perjury under the laws of the United States of America that I am authorized by [LICENSEE] to make this request and that the foregoing is true and correct. [Note that request may be notarized in lieu of using this oath or affirmation statement].

If you should have any questions regarding this submittal, please contact [].

Sincerely,

Name, Title

- Enclosures: 1. Description and Assessment
2. Proposed Technical Specification Changes
3. Proposed Technical Specification Bases Changes (if applicable)

cc: NRR Project Manager
Regional Office
Resident Inspector
State Contact

Distribution:

PUBLIC
PDIV-1 Reading File
RDennig
GHill

Accession Number: ML030980665
ADAMS Template: N/A

File:C:\ORPCheckout\FileNET\ML030980665.wpd

OFC	NRR/DLPM/PM	NRR/DLPM/LA
NAME	W Reckley	M McAllister
DATE	4/08/2003	4/08/2003

OFFICIAL AGENCY RECORD