

3.7 PLANT SYSTEMS

3.7.11 Spent Fuel Pool Exhaust Ventilation System (SFPEVS)

LCO 3.7.11 The SFPEVS shall be OPERABLE and in operation.

APPLICABILITY: During movement of recently irradiated fuel assemblies in the Auxiliary Building.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One SFPEVS charcoal adsorber bank inoperable.</p> <p><u>OR</u></p> <p>One SFPEVS exhaust fan inoperable.</p> <p><u>OR</u></p> <p>One SFPEVS charcoal adsorber bank and one SFPEVS exhaust fan inoperable.</p>	<p>A.1 Verify OPERABLE SFPEVS train is in operation.</p> <p><u>OR</u></p> <p>A.2 Suspend movement of recently irradiated fuel assemblies in the Auxiliary Building.</p>	<p>Immediately</p> <p>Immediately</p>
<p>B. No OPERABLE SFPEVS train.</p> <p><u>OR</u></p> <p>No OPERABLE SFPEVS train in operation.</p>	<p>B.1 Suspend movement of recently irradiated fuel assemblies in the Auxiliary Building.</p>	<p>Immediately</p>