

Jim McKnight
05/22

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REACTOR REGULATION
WASHINGTON, D.C. 20555-0001

September 22, 1995

**NRC INFORMATION NOTICE 95-42: COMMISSION DECISION ON THE RESOLUTION OF
GENERIC ISSUE 23, "REACTOR COOLANT PUMP SEAL
FAILURE"**

Addressees

All holders of operating licenses or construction permits for nuclear power reactors.

Purpose

The U.S. Nuclear Regulatory Commission (NRC) is issuing this information notice to notify addressees of the Commission's decision on Generic Issue (GI) 23, "Reactor Coolant Pump Seal Failure." This decision was documented in a staff requirements memorandum (SRM) from John C. Hoyle to James M. Taylor, dated March 31, 1995 (Accession Number 9504140300), written in response to SECY-94-225, "Issuance of Proposed Rulemaking Package on GI-23, 'Reactor Coolant Pump Seal Failure'." No specific action or written response is required as a result of this information notice.

Background

On April 19, 1991, the NRC published a *Federal Register* notice (56 FR 16130) requesting comments on the then-current understandings, findings, and potential recommendations regarding GI-23, together with a draft Regulatory Guide, DG-1008, "Reactor Coolant Pump Seals." On May 2, 1991, NRC issued Generic Letter (GL) 91-07, "GI-23, 'Reactor Coolant Pump Seal Failures' and Its Possible Effect on Station Blackout," which stated that preliminary results of NRC studies suggested that reactor coolant pump (RCP) seal leak rates could be substantially higher than those assumed in the coping analyses for implementation of the station blackout (SBO) issue. The generic letter reminded licensees that higher seal leak rates could affect licensee analyses and actions addressing conformance to the SBO rule.

Staff studies and analyses concerning RCP seal leakage are documented in Appendices A and B to NUREG/CR-5167, "Cost/Benefit Analysis for Generic Issue 23: Reactor Coolant Pump Seal Failure," April 1991, which contains the NRC model for RCP seal failure. The report identifies several modes of RCP seal leakage which may be in excess of that assumed in licensee coping analyses for implementing the requirements of 10 CFR 50.63, the SBO rule. GI-23 is related to a number of other generic issues: GI-65, "Component Cooling Water System Failure"; GI-130, "Essential Service Water (ESW) System Failure at Multiplant Sites"; GI-153, "Loss of Essential Service Water in LWRs"; GI-106, "Piping and the Use of Highly Combustible Gases in Vital Areas"; and Three Mile Island (TMI) Actions II.K.2.16 and II.K.3.25. In addition, the Individual Plant Evaluation (IPE) Program, as described in

9509200232

updated on 9/29/95

PDR IPE Notice 95-042

95092

Dfor


GL 88-20, requests evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The Commission considered the proposed rulemaking as a method to resolve GI-23. In SECY-94-225, dated August 26, 1994, a draft rule was proposed for public comment that would resolve GI-23.

On March 31, 1995, the Commission voted against the publication of the proposed rule on the resolution of GI-23, "Reactor Coolant Pump Seal Failure." The Commission concluded that the proposed rule did not provide sufficient gain in safety to justify its issuance. The Commission was also concerned that inaccuracies in the NRC seal leakage evaluation model may exist. Further, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits; also some licensees are addressing the issue by using the IPE program and accident management strategies. Therefore, the NRC will not proceed with the rulemaking effort described in SECY-94-225. The staff is currently exploring options to determine what, if any, further action will be taken regarding the final disposition of GI-23.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.


Dennis M. Crutchfield, Director
Division of Reactor Program Management
Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR
(301) 415-2878

Syed K. Shaukat, RES
(301) 415-6592

Christopher Jackson, NRR
(301) 415-2947

Lead project manager: Linh N. Tran, NRR
(301) 415-1361

*Attachment filed
in Jacket*

LIST OF RECENTLY ISSUED
NRC INFORMATION NOTICES

Information Notice No.	Subject	Date of Issuance	Issued to
95-41	Degradation of Ventilation System Charcoal Resulting from Chemical Cleaning of Steam Generators	09/22/95	All holders of OLs or CPs for nuclear power reactors.
95-40	Supplemental Information to Generic Letter 95-03, "Circumferential Cracking of Steam Generator Tubes"	09/20/95	All holders of OLs or CPs for nuclear power reactors.
95-39	Brachytherapy Incidents Involving Treatment Planning Errors	09/19/95	All U.S. Nuclear Regulatory Commission Medical Licensees.
95-38	Degradation of Boraflex Neutron Absorber in Spent Fuel Storage Racks	09/08/95	All holders of OLs or CPs for nuclear power reactors.
95-37	Inadequate Offsite Power System Voltages during Design-Basis Events	09/07/95	All holders of OLs or CPs for nuclear power reactors.
95-36	Potential Problems with Post-Fire Emergency Lighting	08/29/95	All holders of OLs or CPs for nuclear power reactors.
95-35	Degraded Ability of Steam Generators to Remove Decay Heat by Natural Circulation	08/28/95	All holders of OLs or CPs for pressurized water reactors (PWRs).
95-34	Air Actuator and Supply Air Regulator Problems in Copes-Vulcan Pressurizer Power-Operated Relief Valves	08/25/95	All holders of OLs or CPs for nuclear power reactors.
93-83, Supp. 1	Potential Loss of Spent Fuel Pool Cooling After a Loss-of-Coolant Accident or a Loss of Offsite Power	08/24/95	All holders of OLs or CPs for nuclear power reactors.

OL = Operating License
CP = Construction Permit

GL 88-20, requests evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The Commission considered the proposed rulemaking as a method to resolve GI-23. In SECY-94-225, dated August 26, 1994, a draft rule was proposed for public comment that would resolve GI-23.

On March 31, 1995, the Commission voted against the publication of the proposed rule on the resolution of GI-23, "Reactor Coolant Pump Seal Failure." The Commission concluded that the proposed rule did not provide sufficient gain in safety to justify its issuance. The Commission was also concerned that inaccuracies in the NRC seal leakage evaluation model may exist. Further, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits; also some licensees are addressing the issue by using the IPE program and accident management strategies. Therefore, the NRC will not proceed with the rulemaking effort described in SECY-94-225. The staff is currently exploring options to determine what, if any, further action will be taken regarding the final disposition of GI-23.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

orig /s/'d by DMCrutchfield
 Dennis M. Crutchfield, Director
 Division of Reactor Program Management
 Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR
 (301) 415-2878

Syed K. Shaukat, RES
 (301) 415-6592

Christopher Jackson, NRR
 (301) 415-2947

Lead project manager: Linh N. Tran, NRR
 (301) 415-1361

*See previous concurrence page DOCUMENT NAME: 95-42.IN

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	SRXB:DSSA*	ADM:PUB*	SRXB:DSSA*	RES:DET*	D:DSSA*
NAME	EWEISS	TECH EDITOR	RJONES	LSHAO	GHOLAHAN
DATE	9/05/95	8/25/95	9/06/95	09/08/95	09/19/95
OFFICE	PECB:DRPM	PECB:DRPM	PECB:DRPM	C:PECB:DRPM	D:DRPM
NAME	TKoshy*	EFGoodwin*	RJKiesel*	AEChaffee*	DMCrutchfield
DATE	09/19/95	09/15/95	09/19/95	09/19/95	09/21/95

OFFICIAL RECORD COPY

requests evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The Commission considered the proposed rulemaking as a method to resolve GI-23. In SECY-94-225, dated August 26, 1994, a draft rule was proposed for public comment that would resolve GI-23.

On March 31, 1995, the Commission voted against the publication of the proposed rule on the resolution of GI-23, "Reactor Coolant Pump Seal Failure". The Commission concluded that the proposed rule did not provide sufficient gain in safety to justify its issuance. The Commission was also concerned that inaccuracies in the NRC seal leakage evaluation model may exist. Further, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits; also some licensees are addressing the issue by using the IPE program and accident management strategies. Therefore, the NRC will not proceed with the rulemaking effort described in SECY-94-225. The staff is currently exploring options to determine what, if any, further action will be taken regarding the final disposition of GI-23.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate Office of Nuclear Reactor Regulation (NRR) project manager.

Dennis M. Crutchfield, Director
 Division of Reactor Program Management
 Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR
 (301) 415-2878

Syed K. Shaukat, RES
 (301) 415-6592

Christopher Jackson, NRR
 (301) 415-2947

should send no problem with change 9/15/95 aside

Lead project manager: Linh N. Tran, NRR
 (301) 415-1361

*See previous concurrence page DOCUMENT NAME: G:\IN\INGE23.TK

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	SRXB:DSSA*		ADM:PUB*		SRXB:DSSA*		RES:DET*		D:DSSA*	
NAME	EWEISS		TECH EDITOR		RJONES		LSHAO		GHOLAHAN	
DATE	9/05/95		8/25/95		9/06/95		09/08/95		09/19/95	
OFFICE	PECB:DRPM		PECB:DRPM		PECB:DRPM		C:PECB:DRPM		D:DRPM	
NAME	TKoshy*		EFGoodwin*		RJKiessel*		AECaffee		DMCrutchfield	
DATE	09/19/95		09/15/95		09/19/95		09/19/95		09/ /95	

OFFICIAL RECORD COPY

9/20/95

requests evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The Commission considered the proposed rulemaking as a method to resolve GI-23. In SECY-94-225, dated August 26, 1994, a draft rule was proposed for public comment that would resolve GI-23.

On March 31, 1995, the Commission voted against the publication of the proposed rule on the resolution of GI-23, "Reactor Coolant Pump Seal Failure". The Commission concluded that the proposed rule did not provide sufficient gain in safety to justify its issuance. The Commission was also concerned that inaccuracies in the NRC seal leakage evaluation model may exist. Further, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits; also some licensees are addressing the issue by using the IPE program and accident management strategies. Therefore, the NRC will not proceed with the rulemaking effort described in SECY-94-225. The staff is currently exploring options to determine what, if any, further action will be taken regarding the final disposition of GI-23.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate NRC project manager.

Dennis M. Crutchfield, Director
 Division of Reactor Program Management
 Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR
 (301) 415-2878

Syed K. Shaukat, RES
 (301) 415-6592

Christopher Jackson, NRR
 (301) 415-2947

Lead project manager: Linh N. Tran, NRR
 (301) 415-1361

*9/19/95 taken w/3H/CONNOR
 - he is aware of IN
 and has no objections
 to issuance. R3/11/95*

*See previous concurrence page

DOCUMENT NAME: G:\IN\INGE23.TK

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	SRXB:DSSA*	ADM:PUB*	SRXB:DSSA*	RES:DET*	D:DSSA*
NAME	EWEISS	TECH EDITOR	RJONES	LSHAO	GHOLAHAN
DATE	9/05/95	8/25/95	9/06/95	09/08/95	09/19/95
OFFICE	PECB:DRPM	PECB:DRPM	PECB:DRPM	C:PECB:DRPM	D:DRPM
NAME	TKoshy <i>AK</i>	EFGoodwin*	RJKiesel <i>AK</i>	AEChaffee	DMCrutchfield
DATE	09/19/95	09/15/95	09/19/95	09/ /95	09/ /95

requests evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The Commission considered the proposed rulemaking as a method to resolve GI-23. In SECY-94-225, dated August 26, 1994, a draft rule was proposed for public comment that would resolve GI-23.

On March 31, 1995, the Commission ^{voted against} ~~did not approve~~ the publication of the proposed rule on the resolution of GI-23, "Reactor Coolant Pump Seal Failure". The Commission concluded that the proposed rule did not provide sufficient gain in safety to justify its issuance. The Commission was also concerned that inaccuracies in the NRC seal leakage evaluation model may exist. Further, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits; also some licensees are addressing the issue by using the IPE program and accident management strategies. Therefore, the NRC will not proceed with the rulemaking effort described in SECY-94-225. The staff is currently exploring options to determine what, if any, further action will be taken regarding the final disposition of GI-23. This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate NRC project manager.

Dennis M. Crutchfield, Director
Division of Reactor Program Management
Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR
(301) 415-2878

Syed K. Shaukat, RES
(301) 415-6592

Christopher Jackson, NRR
(301) 415-2947

Lead project manager: Linh N. Tran, NRR
(301) 415-1361

requests evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The Commission considered the proposed rulemaking as a method to resolve GI-23. In SECY-94-225, dated August 26, 1994, a draft rule was proposed for public comment that would resolve GI-23.

On March 31, 1995, the Commission did not approve the publication of the proposed rule on the resolution of GI-23, "Reactor Coolant Pump Seal Failure". The Commission concluded that the proposed rule did not provide sufficient gain in safety to justify its issuance. The Commission was also concerned that inaccuracies in the NRC seal leakage evaluation model may exist. Further, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits; also some licensees are addressing the issue by using the IPE program and accident management strategies. Therefore, the NRC will not proceed with the rulemaking effort described in SECY-94-225. The staff is currently exploring options to determine what, if any, further action will be taken regarding the final disposition of GI-23. This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate NRC project manager.

Dennis M. Crutchfield, Director
 Division of Reactor Program Management
 Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR (301) 415-2878
 Syed K. Shaukat, RES (301) 415-6592

Christopher Jackson, NRR
 (301) 415-2947

Lead project manager: Linh N. Tran, NRR
 (301) 415-1361

*See previous concurrence page

DOCUMENT NAME: G:\IN\INGE23.TK

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	SRXB:DSSA*		ADM:PUB*		SRXB:DSSA*		RES:DET*		D:DSSA*	
NAME	EWEISS		TECH EDITOR		RJONES		LSHAO		GHOLOHAN	
DATE	9/05/95		8/25/95		9/06/95		09/08/95		09/13/95	
OFFICE	PECB:DRPM	E	PECB:DRPM		PECB:DRPM		C:PECB:DRPM		D:DRPM	
NAME	TKoshy <i>AK</i>		EFGoodwin <i>frdk</i>		RJKiesel		AECChaffee		DMCrutchfield	
DATE	09/15/95		09/15/95		09/ /95		09/ /95		09/ /95	

OFFICIAL RECORD COPY

GI-130, "Essential Service Water (ESW) System Failure at Multiplant Sites"; GI-153, "Loss of Essential Service Water in LWRs"; GI-106, "Piping and the Use of Highly Combustible Gases in Vital Areas"; and Three Mile Island (TMI) Actions II.K.2.16 and II.K.3.25. In addition, the Individual Plant Evaluation (IPE) Program, as described in GL 88-20, requests the evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The staff proposed rulemaking to resolve GI-23. In SECY-94-225, dated August 26, 1994, the staff requested approval from the Commission to issue a draft rule for public comment that would resolve GI-23. In response to SECY-94-225, the Commission transmitted an SRM on March 31, 1995.

In this SRM, the Commission declined to approve publication of a proposed rule for comment on the resolution of GI-23, "Reactor Coolant Pump Seal Failure." The Commission believes that the proposed rule provides an insufficient basis for gains in safety and that concerns with the NRC seal leakage evaluation model may exist. Also, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits. The Commission also stated in the SRM that some licensees appear to be addressing the issue by using the IPE program and accident management strategies. The staff will therefore not proceed with the rulemaking effort described in SECY-94-225. The staff is currently exploring options to determine what, if any, further action will be taken regarding the final disposition of GI-23. This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate NRC project manager.

Alfred E. Chaffee, Chief
Events Assessment and Generic
Communications Branch
Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR
(301) 415-2878

Syed K. Shaukat, RES
(301) 415-6592

Christopher Jackson, NRR
(301) 415-2947

Lead project manager: Linh N. Tran, NRR
(301) 415-1361

EDITED BY: B. Calure
DATED: 8/25/95

Distribution: see next page
*see previous concurrence page

SRXB:DSSA*
EWEISS
9/05/95

SRXB:DSSA*
RJONES
9/06/95

RES:DET*
LSHAO
9/08/95

D:DSSA
GHOLAHAN
9/15/95

G:\IN-GE23.TYP

GI-130, "Essential Service Water (ESW) System Failure at Multiplant Sites"; GI-153, "Loss of Essential Service Water in LWRs"; GI-106, "Piping and the Use of Highly Combustible Gases in Vital Areas"; and Three Mile Island (TMI) Actions II.K.2.16 and II.K.3.25. In addition, the Individual Plant Evaluation (IPE) Program, as described in GL 88-20, requests the evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The staff proposed rulemaking to resolve GI-23. In SECY-94-225, dated August 26, 1994, the staff requested approval from the Commission to issue a draft rule for public comment that would resolve GI-23. In response to SECY-94-225, the Commission transmitted an SRM on March 31, 1995.

In this SRM, the Commission declined to approve publication of a proposed rule for comment on the resolution of GI-23, "Reactor Coolant Pump Seal Failure." The Commission believes that the proposed rule provides an insufficient basis for gains in safety and that concerns with the NRC seal leakage evaluation model may exist. Also, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits. The Commission also stated in the SRM that some licensees appear to be addressing the issue by using the IPE program and accident management strategies. The staff will therefore not proceed with the rulemaking effort described in SECY-94-225. ~~Considering the past NRC effort, the staff is currently exploring options for the final disposition of GI-23. The appropriate NRC action on the issue is being investigated.~~ This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate NRC project manager.

to determine what, if any, further action will be taken regarding

Alfred E. Chaffee, Chief
Events Assessment and Generic
Communications Branch
Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR
(301) 415-2878

Syed K. Shaukat, RES
(301) 415-6592

Christopher Jackson, NRR
(301) 415-2947

Lead project manager: Linh N. Tran, NRR
(301) 415-1361

EDITED BY: B. Calure
DATED: 8/25/95

Distribution: see next page

with comments

*see previous concurrence page

SRXB:DSSA*
EWEISS
9/05/95

SRXB:DSSA*
RJONES
9/06/95

RES:DET
LSHAO
9/8/95

D:DSSA
GHOLAHAN
9/ /95

G:\IN-GE23.TYP

GI-130, "Essential Service Water (ESW) System Failure at Multiplant Sites"; GI-153, "Loss of Essential Service Water in LWRs"; GI-106, "Piping and the Use of Highly Combustible Gases in Vital Areas"; and Three Mile Island (TMI) Actions II.K.2.16 and II.K.3.25. In addition, the Individual Plant Evaluation (IPE) Program, as described in GL 88-20, requests the evaluation of plant vulnerabilities with respect to certain generic issues, including GI-23.

Discussion

The staff proposed rulemaking to resolve GI-23. In SECY-94-225, dated August 26, 1994, the staff requested approval from the Commission to issue a draft rule for public comment that would resolve GI-23. In response to SECY-94-225, the Commission transmitted an SRM on March 31, 1995.

In this SRM, the Commission declined to approve publication of a proposed rule for comment on the resolution of GI-23, "Reactor Coolant Pump Seal Failure." The Commission believes that the proposed rule provides an insufficient basis for gains in safety and that concerns with the NRC seal leakage evaluation model may exist. Also, the wide range of plant-specific considerations with regard to pressurized-water reactor (PWR) RCP seals would result in the spending of excessive resources by some licensees without commensurate safety benefits. The Commission also stated in the SRM that some licensees appear to be addressing the issue by using the IPE program and accident management strategies. The staff will therefore not proceed with the rulemaking effort described in SECY-94-225. Considering the past NRC effort, the staff is currently exploring options for the final disposition of GI-23. The appropriate NRC action on the issue is being investigated. This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact one of the technical contacts listed below or the appropriate NRC project manager.

Alfred E. Chaffee, Chief
Events Assessment and Generic
Communications Branch
Office of Nuclear Reactor Regulation

Technical contacts: Chu-yu Liang, NRR
(301) 415-2878

Syed K. Shaukat, RES
(301) 415-6593

Christopher Jackson, NRR
(301) 415-2947

Lead project manager: Linh N. Tran, NRR
(301) 415-1361

EDITED BY: B. Calure
DATED: 8/25/95

Distribution: see next page

SRXB:DSSA
EWEISS
9/5/95

SRXP:DSSA
RJONES
9/6/95

RES:DET
LSHAO
9/ /95

D:DSSA
GHOLAHAN
9/ /95

G:\IN-GE23.TYP

NRC INFORMATION NOTICE 95-XX

DISTRIBUTION

Central File

PDR

SRXB R/F (Wits 9200243)

FMiraglia

RZimmerman

BGrimes

AThadani

GHolahan

LTran

LShao

JShapaker

RJones

OGC

CLiang

CLiang R/F

SShaukat

PMagnanelli (Wits 9200243)

KBohrer

NRR Mailroom (Wits 9200243)

DCrutchfield